



SACRAMENTO MUNICIPAL UTILITY DISTRICT □ 6201 S Street, P.O. Box 15830, Sacramento, CA 95852-1830, (916) 452-3211
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

RECEIVED
NRC
REGION V

1990 AUG 16 AM 10:31

AGM/NUC 90-220

August 13, 1990

U. S. Nuclear Regulatory Commission
Attn: J. B. Martin, Regional Administrator
Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596

Docket No. 50-312
Rancho Seco Nuclear Generating Station
License No. DPR-54
Special Report 90-12: Fire Barrier Breached More Than 7 Days

Dear Mr. Martin:

In accordance with Technical Specification 3.14.6.2, the District hereby submits Special Report 90-12. This special report discusses fire barriers in the Auxiliary Building which became inoperable but were not returned to service within 7 days as required by Technical Specification 3.14.6.2.

Members of your staff with questions requiring additional information or clarification may contact Dennis Tipton at (209) 333-2935, extension 4548.

Sincerely,

Dan R. Keuter
Assistant General Manager
Nuclear

Attachment

cc w/atch: C. Myers, NRC, Rancho Seco
Document Control Desk, Washington DC

9008270161 900813
PDR ADOCK 05000312
S PDC

SPECIAL REPORT NUMBER 90-12
Fire Barriers Breached More Than 7 Days

Date of Occurrence

July 18, 1990

Plant Conditions at the Time of Occurrence

The plant has been shutdown since June 7, 1989, and is in a defueled condition.

Identification of the Occurrence

The fire barrier penetration (door) AV117, Fire Area 31 to 32 breached and not returned to operable status within 7 days as required by Rancho Seco Technical Specification 3.14.6.2. In addition

Description of the Occurrence

The door AV117 was blocked open for work.

Corrective Actions Taken

Operability of fire detectors have been verified on at least one side of the breached barriers and hourly fire watches have been established in accordance with Technical Specification 3.14.6.2.