

September 10, 1990

Mr. George Papanic, Jr.
Senior Project Engineer - Licensing
Yankee Atomic Electric Company
580 Main Street
Bolton, Massachusetts 01740-1398

Dear Mr. Papanic:

SUBJECT: ISSUANCE OF AMENDMENT NO. 136 TO FACILITY OPERATING LICENSE
NO. DPR-3 - YANKEE NUCLEAR POWER STATION (ROWE) (TAC NO. 77085)

The Commission has issued the enclosed Amendment No. 136 to Facility Operating License No. DPR-3 for the Yankee Nuclear Power Station (Rowe). This amendment is in response to your application dated June 25, 1990.

This amendment simplifies the Technical Specifications by specifying only the tank level and deleting the redundant gallons values for the Safety Injection Tank (SIT). Also, the "Bases" for Section 3/4.5.4 will be revised to show that the SIT reserve is increased from 40,000 gallons to 52,000 gallons.

A copy of our Safety Evaluation is also enclosed. Notice of issuance will be included in the Commission's biweekly Federal Register Notice.

Sincerely,

PS

Patrick M. Sears, Project Manager
Project Directorate I-3
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 136 to License No. DPR-3
- 2. Safety Evaluation

cc w/enclosures:
See next page

OFC	: PDI-3/LA(A)	: <i>PM</i>	: SRXB <i>PS</i>	: OGC <i>Qib</i>	: PDI-3D(A)	:
NAME	: BCT <i>pyton</i>	: PMSears:mw	: RJones	: <i>E HOLLER</i>	: <i>W</i> <i>Sears</i>	:
DATE	: <i>1/2</i> 5/90	: <i>1/2</i> 7/90	: 7/30/90	: 8/6/90	: 8/13/90	:

OFFICIAL RECORD COPY
Document Name: YR 77085

9009140106 900910
PDR ADOCK 05000029
P PDC

QF01
11

Mr. George Papanic, Jr.

Yankee Rowe

cc:

Dr. Andrew C. Kadak, President
and Chief Executive Officer
Yankee Atomic Electric Company
580 Main Street
Bolton, Massachusetts 01740-1398

Mr. Jay K. Thayer
Vice President And Manager
of Operations
Yankee Atomic Electric Company
580 Main Street
Bolton, Massachusetts 01740-1398

Thomas Dignan, Esquire
Ropes and Gray
225 Franklin Street
Boston, Massachusetts 02110

Mr. T. K. Henderson
Acting Plant Superintendent
Yankee Atomic Electric Company
Star Route
Rowe, Massachusetts 01367

Resident Inspector
Yankee Nuclear Power Station
U.S. Nuclear Regulatory Commission
Post Office Box 28
Monroe Bridge, Massachusetts 01350

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Robert M. Hallisey, Director
Radiation Control Program
Massachusetts Department of Public Health
150 Tremont Street, 7th Floor
Boston, Massachusetts 02111

Mr. George Sterzinger
Commissioner
Vermont Department of Public Service
120 State Street, 3rd Floor
Montpelier, Vermont 05602

Ms. Jane M. Grant
Senior Engineer - License Renewal
Yankee Atomic Electric Company
580 Main Street
Bolton, Massachusetts 01740-1398

AMENDMENT NO. 136 TO DPR-3 YANKEE NUCLEAR POWER STATION (ROWE) DATED September 10, 1990

DISTRIBUTION:

Docket File 50-029

NRC PDR

Local PDR

PDI-3 Reading

S. Varga

R. H. Wessman

V. Nerses

P. Sears

M. Rushbrook

OGC

Dennis Hagan

E. Jordan

G. Hill (4)

Wanda Jones - 7103 MNBB

J. Calvo

R. Jones

ACRS (10)

GPA/PA - 2G5 OWFN

ARM/LFMB

J. Johnson, Region I