



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION V

1450 MARIA LANE, SUITE 210
WALNUT CREEK, CALIFORNIA 94596

AUG 30 1990

PROCESSED ORIGINAL

Certified By J. Garcia

Docket No. 50-344

Portland General Electric Company
121 S. W. Salmon Street
Portland, Oregon 97204

Attention: Mr. James E. Cross
Vice President, Nuclear

Subject: NRC Inspection of the Trojan Nuclear Power Plant

Gentlemen:

This refers to the special unannounced inspection conducted by M. Miller, F. Gee, and D. Corporandy of this office, and T. Scarbrough of NKR during June 25 through July 20, 1990. This inspection examined your activities as authorized by NRC License No. NPF-1. Discussions of our findings were held with you and other members of your staff, at the conclusion of the inspection.

Areas examined during this inspection are described in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

Violations of NRC requirements were identified within the scope of this inspection in the area of administrative controls. A violation is included which identifies that important vendor documentation for motor operated valves was not being incorporated in your records and training programs. Also, three non-cited violations are included. The three non-cited violations include a failure to provide specific operability requirements for safe shutdown equipment, improper posting of an unapproved operating instruction on the wall of the control room, and an improperly performed evaluation of the operability of the positive displacement charging pump.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC Public Document Room.

The responses directed by this letter and the attached Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

Should you have any questions concerning this inspection, we will be glad to discuss them with you.

Sincerely,

Dennis Kirsch, Chief
Reactor Safety Branch

00041

9009140168 900830
PDR ADDCK 05000344
PIC

11
IEO1

Enclosures:

1. Appendix A (Notice of Violation)
2. Inspection Report No. 50-344/90-20

cc w/enclosures:

Mr. Scott Bauer, Branch Manager
B. Robinson, General Manager
L. A. Girard, Vice President and General Counsel

bcc w/enclosures:
docket file
Project Inspector
Resident Inspector
G. Cook
B. Faulkenberry
J. Martin
State of Oregon
Project Manager
D. Notley, NRR

bcc w/o enclosure 2:
M. Smith
J. Zollicoffer
N. Western

REGION V
M Miller *MM*
8/23/90

[Signature]
FGee *for*
8/30/90

[Signature]
DCornorandy
8/30/90

[Signature]
TSeabrough
8/27/90

[Signature] *for FRH*
FRHuey
8/30/90

REQUEST COPY	REQUEST COPY	REQUEST COPY	REQUEST COPY	REQUEST COPY
YES / NO	YES / NO	YES / NO	YES / NO	YES / NO

[Signature]
AJohnson
8/17/90

[Signature]
DKirsch
8/13/90

REQUEST COPY	REQUEST COPY
YES / NO	YES / NO

SEND TO PCR
YES / NO