

APPENDIX A

NOTICE OF VIOLATION

Northeast Nuclear Energy Company
Millstone Nuclear Power Station Unit 1

Docket No. 50-245
License No. DPR-21

During a routine resident inspection from June 25 through August 6, 1990, the following violation was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (Enforcement Policy-1990), the violation is listed below.

Plant technical specification 4.12.E.2, Fire Detection Instrumentation, requires that the non-supervised circuits between the control room and the detection circuits listed in Table 3.12.2, including those in the gas turbine enclosure, shall be demonstrated to be operable once every 31 days per approved procedures. However, surveillance procedure SP-418H, Gas Turbine Fire Detection Functional Test, revision 9, which provides the specific functional test procedure for this non-supervised circuit, is performed semiannually.

Contrary to the above, on April 24, 1990, the licensee determined that the above test had not been performed at the required 31-day interval pursuant to technical specification 4.12.E.2.

This is a Severity Level V Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Northeast Nuclear Energy Company is hereby required to submit to this office, within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and, (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.