

OCT 03 1990

Docket/Licensee: 50-334/DPR-66
50-412/NPF-73

Duquesne Light Company
ATTN: Mr. J. D. Sieber
Vice President, Nuclear Group
Post Office Box 4
Shippingport, Pennsylvania 15077

Gentlemen:

Subject: Inspection Report Nos. 50-334/90-18 and 50-412/90-18

This letter transmits our report of the routine resident safety inspection by Mr. J. Beall at the Beaver Valley Power Station in Shippingport, Pennsylvania. The reporting period covers from July 28, 1990 - September 7, 1990. The inspection consisted of document reviews, interviews and observation of activities. The findings were summarized and discussed with you and members of your staff at the conclusion of the inspection.

Based on the results of this inspection, it appears that in two instances activities were not conducted in compliance with NRC requirements. In the first instance, a Unit 2 Engineered Safety Feature actuation resulted from the failure to follow a surveillance procedure. Secondly, the Onsite Safety Committee failed to review a Unit 1 modification prior to installation as required.

Please respond to this matter in accordance with enclosure 1.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By

Edward C. Wenzinger, Chief
Projects Branch No. 4
Division of Reactor Projects

Enclosures:

1. Appendix A, Notice of Violation
2. Executive Summary
3. NRC Region I Combined Inspection Report Nos. 50-334/90-18 and 50-412/90-18

00209

OFFICIAL RECORD COPY

CIR BV 90-18 - 0001.0.0
11/29/80

9010180077 901003
PDR ADOCK 05000334
Q PDC

IE-01 11

cc w/encls:

J. J. Carey, Executive Vice President, Operations
W. S. Lacey, General Manager, Corporate Nuclear Services
T. P. Noonan, General Manager, Nuclear Operations
D. E. Spoerry, General Manager, Nuclear Operations Services
K. D. Grada, Technical Assistant to Vice President, Nuclear Group
K. E. Halliday, Manager, Nuclear Engineering
S. C. Fenner, Manager, Quality Services
N. R. Tonet, Manager, Nuclear Safety
H. R. Caldwell, General Superintendent, Nuclear Operations
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc: w/encls:

Region I Docket Room (with concurrences)
W. Ruland, DRP
J. Stewart, DRP
A. DeAgazio, NRR
R. Bores, DRSS
E. Collins, DRP
F. Young, DRP

bcc w/Executive Summary Only:

C. W. Hehl, DRP
J. Wiggins, DRP
W. Hodges, DRS
J. Durr, DRS
R. Gallo, DRS
M. Knapp, DRSS
R. Bellamy, DRSS
J. Stolz, NRR

DRP:RI
WR
W. Ruland
10/02/90

WR
10/3/90

OFFICIAL RECORD COPY

CIR BV 90-18 - 0002.0.0
09/27/90