



EDISON DRIVE  
AUGUSTA, MAINE 04336  
(207) 623-3521

December 30, 1982  
MN-82-255

JHG-82-250

United States Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Office of Nuclear Reactor Regulation  
Division of Licensing  
Operating Reactor Branch No. 3  
Mr. Robert A. Clark, Chief

References: (a) License No. DPR-36 (Docket No. 50-309)  
(b) USNRC Letter dated September 29, 1981, Generic Letter 81-36  
(c) MYAPCo Letter to NSNRC, MN-82-65, dated March 30, 1982  
(d) MYAPCo Letter to USNRC, MN-82-124, dated June 30, 1982  
(e) MYAPCo Letter to USNRC, MN-82-155, dated August 5, 1982  
(f) Letter from R. Wells, C. E. Owners Group to H. R. Denton,  
NRC, dated October 18, 1982  
(g) MYAPCo Letter to USNRC, MN-82-241, dated November 30, 1982

Subject: Evaluation of Safety and Relief Valve Operation

Dear Sir:

This letter transmits additional information which supplements References (c), (d), and (e) regarding the pressurizer safety valves installed at Maine Yankee.

Safety Valve Operability

Item II.D.1.A of NUREG 0737 required that utilities operating and/or constructing Pressurized Water Reactor (PWR) power plants, provide evidence supported by tests of safety and relief valve functionality.

Reference (d) addressed the on-site testing experience of the pressurizer safety valves and associated discharge piping at Maine Yankee and in summary, reported the successful results of as-installed tests. However, Maine Yankee also committed, in Reference (d), to further improve the assurance of smooth safety valve operation, consistent with the EPRI Test Program results which demonstrated that stable valve operation can best be assured with low-pressure drop inlet lines.

A046  
s  
1/11  
limited  
Dist

8301040179 821230  
PDR ADDCK 05000309  
P PDR

0330L - AJC

United States Nuclear Regulatory Commission  
 Attention: Mr. Robert A. Clark, Chief

December 30, 1982  
 Page two  
 MN-82-255

Redesign of the inlet piping for each of the three safety valves and portions of the outlet piping has been ongoing since the submittal of Reference (d). Various piping layouts have been evaluated. It is anticipated that the new design will result in inlet line lengths of less than 6 feet. Reference (d), as corrected by Reference (e), scheduled a final report to be submitted on December 31, 1982. The difficulty of laying out the piping and performing the necessary Safety Class 1 piping analysis, and the dynamic analysis, has caused delay in the final layout determination. Therefore, Maine Yankee's final safety valve operability and piping evaluations will be submitted, as indicated in Reference (g), on or before April 1, 1983. However, as discussed above and in Reference (d), the as-installed safety valves and piping were successfully tested during the original plant Hot Functional Testing Program.

Maine Yankee participated in the CE Owners Group efforts as mentioned in Reference (d). However, portions of their program to demonstrate valve operability could not be directly applied to Maine Yankee because of inlet piping geometry differences. In addition, Maine Yankee has a slightly smaller Dresser safety valve than the two Dresser valves tested in the EPRI Test Program. The Dresser valve tested by EPRI was a model 31739A which has a #3 orifice with an area of 2.545 in<sup>2</sup>, while the Maine Yankee valves are model 31709KA which has a K orifice with an area of 1.841 in<sup>2</sup>. The justification for enveloping the Maine Yankee valve by the EPRI test valve was addressed in detail in EPRI Report EPRI-NP-2292-LD, PWR Safety and Relief Valve Test Program, Valve Selection/Justification Report, submitted by Dave Hoffman of Consumers Power for the EPRI Test Program participants. Reference (c) docketed this submittal for Maine Yankee.

#### Maine Yankee Response to Reference (f)

In response to concerns by Dresser (Reference f), Maine Yankee, on a recent shutdown, determined the actual ring settings on each of the three safety valves. After consultation with Dresser Engineering, Maine Yankee readjusted the rings to settings which were recommended based upon the successful results in the EPRI Test Program. The new rings settings are as follows:

Upper Ring = -48 notches  
 Middle Ring = -40 notches  
 Lower Ring = 0 notches (flush)

These new settings will increase valve stability and provide greater assurance of full-rated lift.

United States Nuclear Regulatory Commission  
Attention: Mr. Robert A. Clark, Chief

December 30, 1982  
Page three  
MN-82-255

Extended Safety Valve Blowdown


Maine Yankee, as a participant in the CE Owners Group, had an analysis performed by CE to determine the effect of pressurizer safety valve extended blowdown upon pressurizer liquid level and primary loop subcooling. A copy of the evaluation is attached at Appendix A. Basically, that evaluation demonstrates that blowdown to 20% below setpoint will result in acceptable safety valve and primary coolant conditions for Maine Yankee.

Schedule

As stated in Reference (g) and discussed above, Maine Yankee will provide its final Discharge Piping Analysis and Safety Valve Operability Reports on or before April 1, 1983.

Very truly yours,

MAINE YANKEE ATOMIC POWER COMPANY

  
for J. H. Garrity, Senior Director  
Nuclear Engineering & Licensing

JHG/WGJ/kac

cc: Mr. Ronald C. Haynes  
Mr. Paul A. Swetland

Attachment -\*Effect of Pressurizer Safety Valve Extended Blowdown Upon  
Pressurizer Liquid Level and Primary Loop Subcooling for  
CE Plants (49 Pages)

APPENDIX "A"

EFFECT OF PRESSURIZER SAFETY VALVE EXTENDED BLOWDOWN  
UPON PRESSURIZER LIQUID LEVEL AND  
PRIMARY LOOP SUBCOOLING FOR C-E PLANTS

## TABLE OF CONTENTS

		Page
1.0	PURPOSE	1
2.0	BACKGROUND	1
3.0	SCOPE	2
4.0	APPROACH	2
5.0	METHOD OF ANALYSIS	3
	5.1 Introduction	3
	5.2 Description of the LTC Code	3
	5.3 Adjustment of the LTC Results	4
6.0	ANALYSIS DATA	4
	6.1 Introduction	4
	6.2 Assumptions	5
	6.3 Initial Conditions	6
7.0	RESULTS	7
	7.1 Pressurizer Liquid Level	7
	7.2 Reactor Coolant Subcooling	9
8.0	CONCLUSIONS	10
9.0	REFERENCES	10

## TABLES

1. PALISADES PARAMETERS
2. FORT CALHOUN PARAMETERS
3. MILLSTONE 2 PARAMETERS
4. ST. LUCIE 1 AND 2 PARAMETERS
5. 3410 MWt CLASS PARAMETERS
6. 3817 MWt CLASS PARAMETERS
7. MAINE YANKEE PARAMETERS
8. CALVERT CLIFFS 1 AND 2 PARAMETERS
9. ARKANSAS NUCLEAR ONE 2 PARAMETERS
10. PRESSURIZER SAFETY VALVE DATA FOR CE PLANTS
11. MAXIMUM PRESSURIZER LEVELS AND SAFETY VALVE NOZZLE ELEVATIONS

## LIST OF FIGURES

1. Palisades Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
2. Palisades Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
3. Millstone 2 Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
4. Millstone 2 Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
5. St. Lucie 1 and 2 Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
6. St. Lucie 1 and 2 Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
7. 3410 MWt Class Plants Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
8. 3410 MWt Class Plants Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
9. 3817 MWt Class Plants Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
10. 3817 MWt Class Plants Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
11. Fort Calhoun Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.

12. Fort Calhoun Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
13. Fort Calhoun Pressurizer Pressure Response Following a Loss of Load Transient With 20% Blowdown and 4.0 Second Delay in Relieving Steam Through Primary Safety Valves.
14. Fort Calhoun Pressurizer Level Response Following a Loss of Load Transient With 20% Blowdown and 4.0 Second Delay in Relieving Steam Through Primary Safety Valves.
15. Maine Yankee Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
16. Maine Yankee Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
17. Calvert Cliffs 1 and 2 Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
18. Calvert Cliffs 1 and 2 Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
19. ANO-2 Pressurizer Pressure Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
20. ANO-2 Pressurizer Level Response Following a Loss of Load Transient With 20% Primary Safety Valve Blowdown.
21. Maximum Upper Head Temperatures and Minimum Saturation Temperatures.



Effect of Pressurizer Safety Valve Extended Blowdown  
Upon Pressurizer Liquid Level and Primary Loop Subcooling for CE Plants

1.0 PURPOSE

The purpose of this effort is to determine for CE NSSSs the effect of extended blowdown of pressurizer safety valves upon pressurizer two-phase level. This information is required for the justification of the acceptability of pressurizer safety valve ring adjustments that result in blowdowns greater than the maximum of five percent below setpressure specified by the ASME Code. The objective is to demonstrate that steam conditions are maintained at the safety valve inlets during the blowdown. Another objective of this effort is to verify that flashing of the reactor coolant does not occur in the primary loop or the reactor vessel as a result of the extended safety valve blowdown.

2.0 BACKGROUND

The full scale performance testing of nuclear primary safety valves conducted by EPRI in 1981 demonstrated that safety valve operating stability is dependent upon valve inlet piping configuration, valve ring adjustment, and valve inlet fluid conditions. Further, it was found that changes in safety valve ring adjustments to promote stability tended to increase valve blowdown. Blowdown to a sufficiently low pressure could cause flashing in the pressurizer liquid and expansion of the liquid level to the elevation of the pressurizer safety valve nozzles. Flow of water through the safety valves would then result. Since water flow conditions and the resulting hydraulic loads were not considered in the design of the safety valves, it is desirable to limit valve inlet fluid conditions to steam only. Therefore, an effort was undertaken to determine an acceptable extended safety valve blowdown which would not result in passing liquid through the valve. Also, an investigation of the effect of safety valve blowdown to relatively low pressures upon primary loop or reactor vessel subcooling was required to verify that no steam bubbles

formed in the primary loop or the reactor vessel. Avoidance of steam formation in the primary loop or the reactor vessel is good operational practice.

### 3.0 SCOPE

The evaluation of the extended safety valve blowdown was performed for all CE plants. Due to the differences in the design features of various CE plants, such as rated power, size of pressurizer, operating parameters, and safety valve type, number, capacity and setpoint, it was necessary to perform the evaluation on a plant-specific basis in most cases. However, some plants belonging to certain CE plant classes were similar enough in design so that a single enveloping evaluation could be done. The following plants were analyzed: Palisades, Fort Calhoun, St. Lucie-1 (also applicable to St. Lucie-2), Millstone-2, Calvert Cliffs-1 (also applicable to Calvert Cliffs-2), Arkansas Nuclear One-2 (ANO-2), the 3410 Mwt Class Plant (applicable to Waterford-3), and the 3817 Mwt Class Plant (applicable to Palo Verde-1, -2, and -3 and to Washington Nuclear Power-3).

### 4.0 APPROACH

Since the Loss of Load event was the sizing design basis for the pressurizer safety valves, this event was also used as the basis for evaluating the acceptability of extended safety valve blowdown for the CE plants. Analyses were performed for CE plants to determine the maximum pressurizer level attained during an assumed 20% blowdown (down to 2000 psia) of pressurizer safety valves subsequent to their actuation. Conservative assumptions were made with respect to initial plant conditions and steam accumulation in the pressurizer liquid during the transient in order to maximize pressurizer liquid level. The results of the analyses were evaluated to determine a range of values of safety valve blowdown which would ensure that the safety valves would be exposed to steam flow only. Also, the calculated primary loop and upper reactor head temperatures were reviewed to determine whether subcooled conditions were maintained during the transient.

## 5.0 METHOD OF ANALYSIS

### 5.1 Introduction

The effect of extended blowdown of the pressurizer safety valves during the Loss of Load transient upon the pressurizer liquid level was calculated using CE's LTC computer Code (Reference 1). Input data was biased in a manner to provide increased pressurizer liquid levels. The calculated pressurizer liquid levels were then adjusted to provide additional conservatism. The LTC code and the adjustments of its results are described in the following sections.

### 5.2 Description of the LTC Computer Code

LTC is a versatile code which can be used either for best estimate analysis or, with conservative biases, for conservative predictions. Events may be analyzed from the initial transient through plant cooldown until the plant is in a cold shutdown condition. The code has been verified against plant data such as startup tests and post incident data including plant cooldown on natural circulation.

The LTC computer code models the major plant systems and components, as well as plant control and protection systems. Plant systems and components modeled include the reactor core, reactor coolant system (including pumps and steam generators), pressurizer, chemical and volume control system, shutdown cooling system, safety injection system, main steam lines, main and auxiliary feedwater lines, condenser, and the containment. Control and plant protection systems modeled include the following systems: reactor regulating, pressurizer pressure control, pressurizer level control, main feedwater control, steam dump and bypass control, turbine control, reactor protection, and engineered safety features actuation. With respect to the reactor coolant system and its associated components, the code accurately models nuclear, thermal, and hydraulic performance. The computer simulation includes consideration of reactor kinetics, steam generator thermal-hydraulic performance, reactor coolant pump performance, elevation heads, inertia of surge line water, friction drop in the surge line, and a pressurizer model involving heat and mass transfer between liquid and vapor.

### 5.3 Adjustment of the LTC Results

The LTC Code uses a non-equilibrium pressurizer model considering the mass and heat transfer across the liquid/vapor interface. Liquid insurge from the RCS during a transient is assumed to mix homogeneously with the pressurizer liquid. This mixing tends to reduce the pressurizer liquid temperature and the tendency of the liquid to flash to steam as a result of the pressure decrease due to an extended safety valve blowdown. Since the results of LTC analyses have been found to be in excellent agreement with plant performance data obtained for a wide range of events, the pressurizer model is considered to be a best estimate type of simulation.

For the LTC calculations, as discussed in Sections 5.1 and 5.3, some key input data were biased to produce conservative results. To introduce an additional conservatism, an adjustment was made to the pressurizer level determined from LTC to more conservatively account for flashing in the pressurizer liquid. The correction was made by adding to the pressurizer level as calculated by LTC (which also considers flashing) an additional expansion of the initial saturated pressurizer liquid. The additional expansion was calculated by assuming that the initial pressurizer liquid does not mix with the cooler insurge liquid, that the initial liquid remains in equilibrium with the pressurizer steam space, and that steam formed in this liquid volume when flashing occurs at reduced pressures does not escape into the steam space. As an additional conservatism, another additive correction was made to the pressurizer liquid level by assuming that steam calculated by the LTC Code to escape into the vapor space actually remains in the liquid.

## 6.0 ANALYSIS DATA

### 6.1 Introduction

Overpressure protection of CE reactor coolant systems is provided by primary (pressurizer) and secondary (main steam) safety valves and the Reactor Protection System. The Loss of Load transient, in conjunction with a delayed reactor trip, is the design basis for the sizing of the primary safety valves. The analysis of blowdown discussed herein assumes the Loss

of Load transient as the cause of the safety valve actuation preceding the extended blowdown. Generally, except for certain initial conditions, which were biased so as to tend to maximize pressurizer levels, the assumptions and input to this analysis were basically the same as for a typical Loss of Load analysis used to size the safety valves.

## 6.2 Assumptions

Important assumptions made in the typical Loss of Load analyses are noted below:

- a. Moderator temperature coefficient is zero. Since this coefficient is generally negative, this choice of coefficient tends to increase the severity of the transient.
- b. A zero Doppler temperature coefficient is used so that the reduction in reactivity with increasing fuel temperature is minimized, thereby maximizing the rate of power rise.
- c. No credit is taken for letdown, pressurizer spray, power operated relief valves, turbine bypass, or feedwater addition after turbine trip in the Loss of Load analysis. Letdown and pressurizer spray both act to reduce primary pressure. By not taking credit for these systems, the rate of pressurization is increased and the reactor trip on high pressure is hastened, but only by less than a second. Peak primary pressure is not significantly affected. By not taking credit for the addition of feedwater, the steam generator secondary inventory is depleted at a faster rate. This in turn reduces the capability of the steam generator to remove heat from the primary loop and results in increased pressurizer liquid levels.
- d. The pressurizer safety valve blowdown assumed in typical analyses is generally with the limits (<5%) specified by the ASME Code. In this particular study, the effect of extended safety valve blowdown is of prime interest, and a blowdown of 20% is assumed. The 20% blowdown is large enough to bound the maximum blowdown observed in the EPRI test program for those valve adjustments which resulted in stable valve operation under steam discharge conditions.

### 6.3 Initial Conditions

In performing the LTC Loss of Load analysis for the various CE plants, it was necessary to select initial values for key parameters. Certain key parameter selections were conservatively biased in a direction which tended to increase transient pressurizer liquid levels. These selections are discussed below. Nominal values were used for other input parameters.

#### a. Power

A higher initial plant power level produces a greater mismatch between heat generated and heat dissipated during the transient, resulting in a greater volume of insurge and a higher level in the pressurizer. An initial value of approximately 102% of rated power was used in the LTC analysis.

#### b. Pressurizer Pressure

A higher initial pressurizer pressure, though it hastens reactor trip and thus reduces heat generation - heat dissipation mismatch as well as volume of insurge, results in a greater volume of flashed steam and an increased pressurizer level as the pressure decreases during the extended blowdown. The initial pressure selected for the LTC analysis was about 50 psi above the normal operating pressure. This increase above the normal value was to account for the normal operating band and instrument error.

#### c. Pressurizer Volume

A higher initial pressurizer liquid inventory, though it hastens reactor trip, provides a greater amount of liquid, of which a fixed fraction is flashed at a given pressure during blowdown. This tends to maximize pressurizer level. The initial pressurizer liquid volume selected for the LTC analysis was the value associated with the highest pressurizer high level alarm for the plant.

d. High Pressurizer Pressure Reactor Trip

An increased high pressurizer pressure reactor trip setpoint produces a delay in reactor trip, which increases the heat generation-heat dissipation mismatch, thus increasing the transient severity and pressurizer level. The high pressurizer pressure reactor trip setpoints were therefore increased by 22 psi to account for instrument error.

A listing of the nominal values of some key parameters as well as initial values used in the analyses of the Loss of Load event with extended safety valve blowdown are provided in Tables 1 through 9 for comparison purposes. In these tables the location of pressurizer levels and level alarms are expressed as the percentage of the distance from the lower level nozzle to the upper level nozzle. The lower and upper level nozzles are located in the lower and upper heads, respectively, of the pressurizer. Table 10 presents data for pressurizer safety valves in C-E plants.

## 7.0 RESULTS

### 7.1 Pressurizer Liquid Level

The results of the analyses of the Loss of Load event with extended safety valve blowdown are presented as pressurizer pressure and level curves versus time (Figures 1 through 20) for the various CE plants and plant classes.

For Fort Calhoun an additional set of pressure and level curves was calculated for the case of a four second delay in the release of steam subsequent to safety valve actuation. The purpose for considering this additional case was to simulate the time for discharging the water from the loop seal at the safety valve inlet on Fort Calhoun. The assumed four second delay was conservative, since loop seal tests in the EPRI test program had indicated steam release delays of the order of one second. Thus, the zero and four second delay analyses for Fort Calhoun bounded the

actual delay time in steam release for this plant. Besides Fort Calhoun, the only other C-E plant having a loop seal at the safety valve is Millstone-2. However, since this loop seal is to be eliminated, no analysis of its impact was done.

Two pressurizer level curves are presented for each plant. The lower curve represents the pressurizer level as calculated by the LTC code. This curve is considered to be conservative since it was obtained by assuming conservatively biased initial conditions to maximize pressurizer level. The upper curve was generated from the lower curve by adding additional conservatisms in the pressurizer model, i.e. no mixing of initial pressurizer liquid inventory with insurge, and no disengagement of flashed steam from the liquid phase, as described in Section 5.3. Consequently, the upper curve has a high degree of conservatism with respect to high pressurizer level. The elevation of the pressurizer safety valve nozzles is also shown on these graphs to indicate the magnitude of the elevation margin between the maximum liquid level and the safety valve nozzles. A review of the pressurizer level curves shows that in no case, for the Loss of Load event, does pressurizer liquid level reach the elevation of the pressurizer safety valve nozzles. The results are summarized in Table 11, which shows, for all the plants evaluated, the maximum pressurizer liquid level attained during the transient as well as the relative elevation of the pressurizer safety valve nozzles.

For Fort Calhoun, a comparison of the curves for a zero and four second delay in the release of steam after safety valve actuation (Figures 11-14) indicates that the delay has no significant effect on maximum pressurizer level. Maximum pressurizer pressure increases significantly, but not to an unacceptable level. Based on the loop seal tests of a Fort Calhoun-type safety valve in the EPRI safety valve test program, the delay in the release of steam due to the discharge of water from the Fort Calhoun loop seal is expected to be of the order of one second, so that Figures 11-14 represent bounding pressurizer pressures and levels.

Additional LTC runs were made for Palisades, the 3410 Mwt Class, and the 3817 Mwt class in which credit was taken for the pressurizer spray.



Compared to the runs for which the pressurizer spray was assumed to be inoperative, reactor trip was delayed by less than one second, and maximum pressurizer level increased by less than 1.5%. It is concluded that taking credit for the pressurizer spray in the LTC analyses does not significantly affect maximum pressurizer level.

A feature of the pressurizer pressure vs time curves should be noted. For those plants in which all the safety valves have a common setpoint, the pressure begins to drop immediately when the safety valves open. For those plants in which the safety valve setpoints are staggered, the pressure continues to increase after the safety valve with the lowest setpoint opens.

## 7.2 Reactor Coolant Subcooling

An extended blowdown of the primary system, if great enough, can reduce the pressure below the saturation pressure of the coolant in the reactor vessel or primary loop, causing formation of a steam bubble. A likely place for steam bubble formation is in the reactor vessel upper head, since the highest coolant temperatures, and hence the highest coolant saturation pressure, exist at the core outlet. During the blowdown of the safety valves the reactor is in a post-trip condition. Therefore, loop and reactor temperatures are generally decreasing along with the pressure, tending to maintain reactor coolant temperatures below saturation. Figure 21 presents a pair of limiting temperature curves vs time which demonstrate that flashing will not occur in the primary loop or reactor vessel during the extended safety valve blowdowns (20%) considered here. The upper curve in Figure 21 represents the plant (Palisades) with the lowest reactor vessel upper head fluid pressures, and hence, the lowest saturation temperatures during blowdown. The lower curve represents the plant (3817 Mwt Class) which has the highest reactor vessel upper head fluid temperatures during the blowdown. Figure 21 shows that the upper reactor vessel head fluid temperatures for the 3817 Mwt Class plant remain lower (by at least 9°F) than the reactor vessel upper head fluid saturation temperatures for the Palisades plant at all times during the transient. Since the 3817 Mwt Class and the Palisades curves represent bounding

conditions with respect to the highest reactor vessel upper head fluid temperatures and lowest fluid saturation temperatures, respectively, they envelop all the plants under consideration. It is concluded that, for all C-E plants considered, reactor vessel and primary coolant loop fluid will always be in a subcooled condition during the transient, so that steam bubble formation will not occur at these locations.

## 8.0 CONCLUSIONS

- (a) The results of the analyses described herein have demonstrated that, for CE plants, the pressurizer liquid level does not reach the elevation of the pressurizer safety valve nozzles during safety valve actuation in a Loss of Load event with a 20% safety valve blowdown down to 2000 psia.
- (b) It has also been demonstrated that, for CE plants, steam bubble formation will not occur in the reactor vessel or the reactor coolant loops during Loss of Load events associated with a pressurizer safety valve blowdown to 2000 psia.

## 9.0 REFERENCES

- 9.1 CEN-128, "Response of Combustion Engineering Nuclear Steam Supply System to Transients and Accidents," April, 1980, page 4, Nuclear Power Systems Division of CE Power Systems, C-E, Inc.

TABLES

TABLE 1

## PALISADES PARAMETERS

	<u>Nominal</u>	<u>Analysis</u> <u>Initial Conditions</u>
Power, Mwt	2541	2593
Cold leg temperature, °F	536	536
Pressurizer pressure, psia	2010	2100
Steam generator pressure, psia	680	690
High pressurizer pressure trip, psia	2255	2277
Pressurizer level, %	49	75
Pressurizer high level alarm, %	75	N/A
Pressurizer total volume, ft <sup>3</sup>	1500	N/A

TABLE 2

## FORT CALHOUN PARAMETERS

	<u>Nominal</u>	<u>Analysis</u> <u>Initial Conditions</u>
Power, Mwt	1506	1536
Cold leg temperature, °F	540	540
Pressurizer pressure, psia	2100	2150
Steam generator pressure, psia	820	820
High pressurizer pressure trip, psia	2400	2422
Pressurizer level, %	65	73
Pressurizer high level alarm, %	73	N/A
Pressurizer total volume, ft <sup>3</sup>	900	N/A

TABLE 3

## MILLSTONE 2 PARAMETERS

	<u>Nominal</u>	<u>Analysis</u> <u>Initial Conditions</u>
Power, Mwt	2710	2764
Cold leg temperature, °F	548	548
Pressurizer pressure, psia	2250	2300
Steam generator pressure, psia	890	890
High pressurizer pressure trip, psia	2400	2422
Pressurizer level, %	65	75.5
Pressurizer high level alarm, %	75.5	N/A
Pressurizer total volume, ft <sup>3</sup>	1500	N/A

TABLE 4

## ST. LUCIE 1 AND 2 PARAMETERS

	<u>Nominal</u>		<u>Analysis</u>
	St. Lucie 1	St. Lucie 2	<u>Initial Conditions</u>
Power, Mwt	2710	2570	2764
Cold leg temperature, °F	549	550	549
Pressurizer pressure, psia	2250	2250	2300
Steam generator pressure, psia	875	815	810
High pressurizer pressure trip, psia	2400	2400	2422
Pressurizer level, %	55.6	55.6	66.3
Pressurizer high level alarm, %	65.6	66.2	N/A
Pressurizer total volume, ft <sup>3</sup>	1500	1500	N/A

TABLE 5

## 3410 Mwt CLASS PARAMETERS

	<u>nominal</u>	<u>Analysis</u> <u>Initial Conditions</u>
Power, Mwt	3410	3478
Cold leg temperature, °F	553	553
Pressurizer pressure, psia	2250	2300
Steam generator pressure, psia	900	900
High pressurizer pressure trip, psia	2400	2422
Pressurizer level, %	55.7	66.2
Pressurizer high level alarm, %	66.1	N/A
Pressurizer total volume, ft <sup>3</sup>	1500	N/A



TABLE 6

## 3817 Mwt CLASS PARAMETERS

	<u>Nominal</u>	<u>Analysis</u> <u>Initial Conditions</u>
Power, Mwt	3817	3893
Cold leg temperature, °F	564.5	564.5
Pressurizer pressure, psia	2250	2300
Steam generator pressure, psia	1067	1070
High pressurizer pressure trip, psia	2400	2425
Pressurizer level, %	52.6	61.5
Pressurizer high level alarm, %	61.5	N/A
Pressurizer total volume, ft <sup>3</sup>	1800	N/A

TABLE 7

## MAINE YANKEE PARAMETERS

	<u>Nominal</u>	<u>Analysis</u> <u>Initial Conditions</u>
Power, Mwt	2640	2693
Cold leg temperature, °F	550	550
Pressurizer pressure, psia	2250	2300
Steam generator pressure, psia	390	890
High pressurizer pressure trip, psia	2400	2422
Pressurizer level, %	57	68
Pressurizer high level alarm, %	68	N/A
Pressurizer total volume, ft <sup>3</sup>	1500	N/A

TABLE 8

## CALVERT CLIFFS 1 AND 2 PARAMETERS

	<u>Nominal</u>	<u>Analysis Initial Conditions</u>
Power, Mwt	2710	2764
Cold leg temperature, °F	548	548
Pressurizer pressure, psia	2250	2300
Steam generator pressure, psia	850	850
High pressurizer pressure trip, psia	2400	2422
Pressurizer level, %	59.7	70.6
Pressurizer high level alarm, %	70.6	N/A
Pressurizer total volume, ft <sup>3</sup>	1500	N/A

TABLE 9

## ARKANSAS NUCLEAR ONE 2 PARAMETERS

	<u>Nominal</u>	<u>Analysis</u> <u>Initial Conditions</u>
Power, MWt	2815	2881
Cold leg temperature, °F	553.5	553.5
Pressurizer pressure, psia	2250	2300
Steam generator pressure, psia	900	900
High pressurizer pressure trip, psia	2400	2422
Pressurizer level, %	55.6	68.8
Pressurizer high level alarm, %	68.8	N/A
Pressurizer total volume, ft <sup>3</sup>	1200	N/A

TABLE 10

PRESSURIZER SAFETY VALVE DATA  
FOR C-E PLANTS

<u>Plant</u>	<u>Vendor</u>	<u>Model</u>	<u>Number</u>	<u>Setpoint</u> <u>psia</u>	<u>ASME</u> <u>Rated Min.</u> <u>Capacity</u> <u>lb/hr</u>
Palisades	Dresser	31739A	3	2500	230,000
				2540	
				2580	
Fort Calhoun	Crosby	HB-BP-86	2	2500	216,002
				2545	212,182
St. Lucie 1 & 2	Crosby	HB-BP-86	3	2500	212,182
Millstone 2	Dresser	31739A	2	2500	296,069
Waterford 3 (3410 Mwt Class)	Dresser	31709NA	2	2500	504,874
Palo Verde 1,2 &3 (3817 Mwt Class)	Dresser	31709NA	4	2500	504,874
WNP 3 (3817 Mwt Class)	Crosby	HB-BP-86	4	2500	504,953
Maine Yankee	Dresser	31709KA	3	2500	214,159
				2525	216,301
				2550	218,442
Calvert Cliffs 1 and 2	Dresser	31739A	2	2500	296,065
				2565	303,765
ANO-2	Crosby	HB-BP-86	2	2500	420,006

TABLE 11

MAXIMUM PRESSURIZER LEVELS  
AND  
SAFETY VALVE NOZZLE ELEVATIONS

	Pressurizer Level, %		Safety Valve Nozzle Elev., %
	<u>LTC</u>	<u>Adjusted</u>	
Palisades	89.2	106.1	110.5
Fort Calhoun	82.3	91.1	110.0
Millstone 2	88.0	100.5	107.0
St. Lucie 1 and 2	83.2	95.5	107.0
3410 Mwt Class (Waterford 3)	86.0	98.6	100.0
3817 Mwt Class (Palo Verde 1, 2 and 3, WNP 3)	89.0	97.8	100.0
Maine Yankee	75.8	84.0	100.0
Calvert Cliffs 1 and 2	83.2	94.5	100.0
Arkansas Nuclear One 2	89.4	102.4	110.0

FIGURES

FIGURE 1  
PALISADES  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN






FIGURE 2  
PALISADES  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 3  
MILLSTONE 2  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 4  
MILLSTONE 2  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 5  
ST. LUCIE 1 & 2  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 6  
ST. LUCIE 1 & 2  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 7  
3410 CLASS PLANTS  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 8  
3410 CLASS PLANTS  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 9  
3817 MWT CLASS PLANT  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN






FIGURE 10  
3817 MWT CLASS PLANT  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 11  
FORT CALHOUN  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 12  
FORT CALHOUN  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 13  
FORT CALHOUN  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20% BLOWDOWN  
AND 4.0 SECOND DELAY IN RELIEVING STEAM  
THROUGH PRIMARY SAFETY VALVES




FIGURE 14  
FORT CALHOUN  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20% BLOWDOWN  
AND 4.0 SECOND DELAY IN RELIEVING STEAM  
THROUGH PRIMARY SAFETY VALVES




FIGURE 15  
MAINE YANKEE  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE SLOWDOWN




FIGURE 16  
MAINE YANKEE  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 17  
CALVERT CLIFFS 1 & 2  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN






FIGURE 18  
CALVERT CLIFFS 1 & 2  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 19  
ARKANSAS NUCLEAR ONE - 2  
PRESSURIZER PRESSURE RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 20  
ARKANSAS NUCLEAR ONE - 2  
PRESSURIZER LEVEL RESPONSE FOLLOWING A  
LOSS OF LOAD TRANSIENT WITH 20%  
PRIMARY SAFETY VALVE BLOWDOWN




FIGURE 21  
UPPER HEAD MAXIMUM TEMPERATURES AND  
MINIMUM SATURATION TEMPERATURES

