NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

Attachment to AECM-82/638
Page 1 of 1

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	LICENSEE CODE (2)	MSGGS1
01	LICENSE NUMBER (3)	00-00000-00
01	LICENSE TYPE (4)	41111
01	CAT (5)	
01 CON'T	REPORT SOURCE (6)	L
01	DOCKET NUMBER (7)	0500416
01	EVENT DATE (8)	112282
01	REPORT DATE (9)	122882

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On November 22, 1982, an LCO was entered in accordance with T.S.3.7.7 when five fire-
03 rated floor penetrations in the Auxiliary Building were opened. The penetrations were
04 opened to route cable as required by Design Change Package (DCP) 82-4145. The event
05 had no effect on the public health and safety and did not constitute a threat to plant
06 safety. This report is submitted as a Special Report pursuant to T.S.3.7.7 and is
07 considered an interim report.
08

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
AB	X	Z	XXXXXX	Z	Z

LER/RO REPORT NUMBER (17)	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	82	—	150	/	99	X	—	0

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER (26)
X	X		Z	0000	N	N	Z	Z999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 DCP 82-4145 was issued to complete the heat tracing portion of the Drywell Monitoring
11 System and required cable routing through the penetrations. A fire watch was
12 established on November 22, 1982. Work is continuing on the heat tracing. A follow-up
13 report will be submitted by February 28, 1983.
14

Line	Field	Value
15	FACILITY STATUS (28)	B
15	% POWER (29)	000
15	OTHER STATUS (30)	NA
15	METHOD OF DISCOVERY (31)	A
15	DISCOVERY DESCRIPTION (32)	Planned Activity
16	ACTIVITY RELEASED (33)	Z
16	CONTENT OF RELEASE (34)	Z
16	AMOUNT OF ACTIVITY (35)	NA
16	LOCATION OF RELEASE (36)	NA
17	PERSONNEL EXPOSURES NUMBER (37)	000
17	TYPE (38)	Z
17	DESCRIPTION (39)	NA
18	PERSONNEL INJURIES NUMBER (40)	000
18	DESCRIPTION (41)	NA
19	LOSS OF OR DAMAGE TO FACILITY TYPE (42)	Z
19	DESCRIPTION (43)	
20	PUBLICITY ISSUED (44)	N
20	DESCRIPTION (45)	NA

NRC USE ONLY

8301040188 821228
PDR ADOCK 05000416
S PDR

NAME OF PREPARER Original signed by Ron Byrd PHONE

GPO 917-326