

APPENDIX A

NOTICE OF VIOLATION

Mississippi Power and Light Co.
Grand Gulf

Docket No. 50-416
License No. NPF-13

As a result of the inspection conducted on October 4-8, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

10 CFR 50, Appendix B Criterion XVII and the accepted QA Program (MPL-TOP-1A) require that records shall be maintained consistent with applicable regulatory requirements. The accepted QA Program endorses ANSI N45.2.9-1974. Paragraph 5.4.2 of this standard requires that records shall not be stored loosely. Additionally, paragraph 5.4.3 requires special processed records (such as radiographs, photographs, negatives and microfilm) which are light-sensitive, pressure sensitive or temperature sensitive shall be packaged and stored as recommended by the manufacturer of these materials.

Contrary to the above, several packets of radiographs were being stored loosely on a file cabinet. This was identified during an inspection of the vault on October 7, 1982.

This is a Severity Level V Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: October 27, 1982