

FEB 24 1994

DCS

Docket Nos. 50-317
50-318

License Nos. DPR-53
DPR-69

Mr. Robert E. Denton
Vice President-Nuclear Energy
Baltimore Gas and Electric Company (BG&E)
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, Maryland 20657-4702

Dear Mr. Denton:

Subject: NRC Region I Resident Inspection Report Nos. 50-317/93-32 and
50-318/93-32 (December 26, 1993 - February 5, 1994)

This report transmits the findings of the safety inspection conducted by the resident inspectors at the Calvert Cliffs Nuclear Power Plant. At the conclusion of the inspection, these findings were discussed with Mr. Cruse of your staff.

Areas examined during this inspection are described in the NRC Region I Inspection Report which is enclosed with this letter and were selected in order to ensure that your facility is operated with due regard for the public health and safety. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors. Overall, the NRC has concluded that your facility was operated in a safe manner.

The NRC completed review of an issue involving electrical technicians placing an erroneous equalizing charge on one of the station batteries. There were no safety consequences as a result of the error and BG&E took appropriate corrective action. However, the failure to properly implement the maintenance order was a violation of NRC requirements. The violation was not cited because the criteria for discretion specified in the NRC Enforcement Policy, Section VII.B., was met.

08-045

9403090035 940224
PDR ADDCK 05000317
0 PDR

OFFICIAL RECORD COPY

JE01

FEB 24 1994

Mr. Robert E. Denton

2

Your cooperation is appreciated.

Sincerely,

ORIGINAL SIGNED BY:
CURTIS J. COWGILL

Curtis J. Cowgill, Chief
Reactor Projects Branch No. 1
Division of Reactor Projects

Enclosure: NRC Region I Resident Inspection Report Nos. 50-317/93-32 and 50-318/93-32

cc w/encl:

G. Detter, Director, Nuclear Regulatory Matters (CCNPP)
R. McLean, Administrator, Nuclear Evaluations
J. Walter, Engineering Division, Public Service Commission of Maryland
K. Burger, Esquire, Maryland People's Counsel
R. Ochs, Maryland Safe Energy Coalition
K. Abraham, PAO (2)
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of Maryland (2)

OFFICIAL RECORD COPY

FEB 24 1994

Mr. Robert E. Denton

3

bcc w/encl:

Region I Docket Room (with concurrences)

C. Cowgill, DRP

L. Nicholson, DRP

R. Fuhrmeister, DRP

P. Wilson - Calvert Cliffs

V. McCree, OEDO

R. Capra, NRR

D. McDonald, NRR

RI:DRP
PWilson

2/24/94

RI:DRP
LNicholson

2/21/94

RI:DRP
CCowgill

1/194

OFFICIAL RECORD COPY

a:IR9332