

December 27, 1982

Docket No. 50-254
Docket No. 50-265

Commonwealth Edison Company
ATTN: Cordell Reed
Vice President
P.O. Box 767
Chicago, IL 60690


Gentlemen:

Attached is an addendum to Inspection Report 50-254/82-13 and 50-265/82-15, transmitted by our August 17, 1982, letter. Table II lists (1) the comparative beta analyses results of the liquid sample split during the July 19-23, 1982, inspection and (2) the comparative gamma analyses of a spiked charcoal adsorber forwarded to the Quad-Cities Station following recalibration of their analytical system. All comparisons meet criteria for agreement or possible agreement.

This addendum closes Open Items 50-254/82-13-01; 50-265/82-15-01 and 50-254/82-13-02; 50-265/82-15-02.

We will gladly discuss any questions you have concerning this addendum.

Sincerely,



C. J. Paperiello, Chief
Emergency Preparedness and Program
Support Branch

Enclosure: Table II

cc w/encl:

Louis O. DelGeorge, Director
of Nuclear Licensing
N. Kalivianakis, Plant
Superintendent
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Karen Borgstadt, Office of
Assistant Attorney General

RIII

nan
Nicholson/jp
12/17/82

RIII

SR
Rozak

RIII

SW
Schumacher

RIII

CJP
Paperiello
12/22/82

RIII

R. Walker
Walker
12/22/82