JUN 0 3 1982

Tennessee Valley Authority ATTN: Mr. H. G. Parris Manager of Power 500A Chestnut Street Tower II Chattanooga, TN 37401

Gentlemen:

Subject; Report No. 50-438/82-08

This refers to the investigation conducted by Mr. J. Y. Vorse of this office on March 16-18, 1982, of activities authorized by NRC Construction Permit No. CPPR-122 for the Bellefonte Unit 1 facility and to the discussion of our findings held with Mr. W. R. Dahnke, Project Manager at the conclusion of the investigation.

Within these areas, the investigation consisted of selective examinations of procedures and representatives records, interviews with personnel, and observations by the investigator.

Within the scope of this investigation, one violation regarding reheating welds without following approved procedures was identified. This violation was previously cited in the Notice of Violation accompanying our letter to you dated April 22, 1982.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosed Summary of Investigation will be placed in the NRC's Public Document Room unless you notify this office by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 10 CFR 2.790(b)(1).

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

K1

James P. O'Reilly Regional Administrator

Enclosure: Summary of Investigation

cc w/encl: (See Page 2)

an infattation family in	3	
8301040217 820603 PDR ADDCK 05000438		TEOI
G PDR		
* * * * * * * * * * * * * * * * * * *		
INAME	a naderal contraction for the statement of	
DATE 🕨		
IC FORM 318 (10-80) NRCM 0240	OFFICIAL RECORD COPY	

Tennessee Valley Authority

cc w/encl: H. J. Green, Director of Nuclear Power A. M. Qualls, Plant Superintendent W. R. Dahnke, Project Manager D. L. Terrill, Project Engineer J. F. Cox, Supervisor, Nuclear Licensing Section H. N. Culver, Chief, Nuclear Safety Review Staff

bcc w/encl: R. Fortuna, IE:IS M. Resner, OIA

bcc w/o encl: Resident Inspector Document Management Branch State of Tennessee

NRC FORM 318 (10-80) NRCM 0240 RII:EIS ARIE RII:PRP/JC/ RII:ETP RCLewis ARHerdt 5/32 /82 OFFICIAL RECORD COPY