

February 18, 1994

Docket/License: 50-219/DPR-16

Mr. John J. Barton
Vice President and Director
GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station
P.O. Box 388
Forked River, New Jersey 08731

Dear Mr. Barton:

Subject: **Safeguards Inspection 50-219/94-02 (01/18-21/94)**

This letter refers to the above subject physical security inspection of the Oyster Creek Nuclear Generating Station by Messrs. E. B. King and A. Della Ratta of this office. The preliminary inspection findings were discussed with Mr. S. Levin and other members of your staff by Mr. King at the conclusion of the inspection.

Areas examined during this inspection are described in the enclosed NRC Region I Inspection Report. Within those areas, the inspection consisted of observations of security activities, interviews with personnel, and selective examinations of security procedures and representative records.

Overall, we found that your physical security program was generally effective and directed toward assuring public health and safety. However, based on the results of this inspection, two of your activities appeared to be in violation of NRC requirements, as specified in the enclosed Notice of Violation (Notice). These violations involved: (1) two areas that did not satisfy the applicable protected area minimum lighting requirement, with no compensatory measures implemented; and (2) failure to satisfy the physical and training requalification requirements specified in the NRC-approved Training and Qualification Plan. In preparing the required response to these apparent violations, you should follow the instructions in the enclosed Notice. In particular, you should document in the response the specific actions taken and any additional actions you plan to prevent recurrence. After reviewing your response to the enclosed Notice, the NRC will determine whether further NRC enforcement action is necessary to ensure compliance with regulatory requirements.

08-013

OFFICIAL RECORD COPY

9403090118 940218
PDR ADOCK 05000219
Q PCR

11
RE-04

Thank you for your cooperation.

Sincerely,

Original Signed By;
James H. Joyner

James H. Joyner, Chief
Facilities Radiological Safety
and Safeguards Branch
Division of Radiation Safety
and Safeguards

Enclosures:

1. Notice of Violation
2. Inspection Report 50-219/94-02

cc w/encls:

M. Laggart, Manager, Corporate Licensing
G. Busch, Manager, Site Licensing, Oyster Creek
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
K. Abraham, PAO (2)
NRC Resident Inspector
State of New Jersey

GPU Nuclear Corporation

3

bcc w/encls:

Region I Docket Room (with concurrences)

J. Rogge, DRP

bcc w/encls (VIA E-MAIL):


V. McCree, OEDO

J. Stolz, NRR/PD 1-4

A. Dromerick, NRR/PD 1-4

M. Shannon, NRR/ILPB


RI:DRSS


King
02/16/94


RI:DRSS


Della Ratta
02/17/94

RI:DRSS


McCabe
02/17/94

RI:DRSS


Joyner
02/16/94

OFFICIAL RECORD COPY