## PALISADES

NRC FORM 366 (7-77)

LPDR

U. S. NUCLEAR REGULATORY COMMISSION

## LICENSEE EVENT REPORT

| 011                                   | CONTROL BLOCK:   |
|---------------------------------------|--|
| CONT                                  | 3 LICENSEE CODE 14 15 LICENSE NUMBER 25 28 LICENSE TYPE 30 57 CAT 54 SOURCE 50 51 DOCKET NUMBER 25 39 EVENT DATE 74 15 REPORT DATE 80  |
| 012                                   | EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) During Routine Plant operations, it was discovered that CRDM-39 could not   |
| 03                                    | be withdrawn. In order to prevent rod misalignment, rod insertion was  |
| 04                                    | blocked by removing the CRDM's control fuses. This rendered the rod in-  |
| 0 5                                   | operable as defined by T.S. 3.10.4. Event reportable under Special Tech-   |
| 015                                   | nical Specification S-5.1. Because the rod was able to be tripped (as  |
| 0 7                                   | demonstrated during the following reactor shutdown) shutdown margin  |
| 018                                   | requirements were not affected.  |
| 0 9                                   | CODE SUBCODE S |
|                                       | TO LERING EVENT YEAR REPORT NO. SEQUENTIAL REPORT NO. CODE TYPE SUBMITTED TORM SUBMITTED TORM SUBMITTED TORM SUPPLIER COMPONENT MANUFACTURER COMPONENT MANUFACTU |
| 110                                   | The inability to withdraw CFDM-39 was caused by shorting of the motor  |
|                                       | windings from water which apparently had entered the drive package as a  |
|                                       | result of seal leakage. The drive package was replaced and the CRDM was  |
|                                       | restored to normal operation.  |
| TH,                                   | So ACILITY SPOWER OTHER STATUS (10) METHOD OF DISCOVERY DESCRIPTION (12) P (13) Operator Observation (13)  |
| 7 9                                   | STIVITY CONTENT 12 13 M 45 46  |
| <u>∏6</u>                             | LEASED OF RELEASE N/A AMOUNT OF ACTIVITY 35  |
|                                       | PERSONNEL EXPOSURES  NUMBER DESCRIPTION (39) N/A   |
|                                       | PERSONNEL NJURIES NUMBER DESCRIPTION (4) N/A   |
| · · · · · · · · · · · · · · · · · · · | SSS OF DR DAMAGE TO FACILITY 43) THOSE DESCRIPTION N/A   |
| PDR TO                                | SSLED DESCRIPTION 45 N/A NAC USE ONLY  |
| -21                                   | 38 69 50   |
| 781416                                | PDR ADOCK \$50-2555 781\$\$2   |