

CONTROL BLOCK: [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	4	8	7	0	9	1	7	7	8	8	1	0	1	6	7	8	9		
60	61	DOCKET NUMBER										68	69	EVENT DATE					74	75	REPORT DATE					80

02 During the performance of Surveillance Test Procedure FNP-1-STP-40.3, Safety Injection
03 with Loss of Off-Site Power Test, D/G 1B auto-started, but frequency could not be
04 increased above 58.5Hz (frequency could be decreased). T/S 3.8.1.1 requires two
05 separate independent diesel generator sets be operable. D/G 1B was declared inoperable
06 at 0830. T/S 3.8.1.1 action statement requirements were met. The other diesel
07 generator set (D/G's 1-2A and 1C) was operable. D/G 1B was returned to an operable
08 status at 1300 on 9/17/78. Health/safety of general public were not affected.

SYSTEM CODE [E][E] (11)		CAUSE CODE [E] (12)		CAUSE SUBCODE [B] (13)		COMPONENT CODE [M][E][C][F][U][N] (14)				COMP. SUBCODE [Z] (15)		VALVE SUBCODE [Z] (16)	
EVENT YEAR [7][8] (17)		SEQUENTIAL REPORT NO. [0][6][8] (18)		OCCURRENCE CODE [0][3] (19)		REPORT TYPE [L] (20)		REVISION NO. [0] (21)		ACTION TAKEN [E] (22)		FUTURE ACTION [Z] (23)	
EFFECT ON PLANT [Z] (24)		SHUTDOWN METHOD [Z] (25)		HOURS [0][0][0][0] (26)		ATTACHMENT SUBMITTED [N] (27)		NPRD-4 FORM SUB. [N] (28)		PRIME COMP. SUPPLIER [A] (29)		COMPONENT MANUFACTURER [W][2][9][0] (30)	

1 0 Coupling between D, C, motor and the potentiometer which positions the governor was

1 1 loose allowing the potentiometer to be driven in only one direction. The potentiometer

1 2 was positioned manually to increase the frequency. The coupling was then tightened and

1 3 the operation of the potentiometer/governor verified. Diesel generator 1E was tested

1 4 to verify operability.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z 33 Z 34 NA NA

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
000040	NA

9 8 9 10 NA 80
PUBLICATION
ISSUED DESCRIPTION 45 NRC USE ONLY

7810200089

7810200089

NAME OF PREPARER W. G. Hairston, III

PHONE (205) 899-5156