

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | 0 | R | T | N | P | 1 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | 4 | 5  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

CONT  
0 1 | REPORT SOURCE | L | 0 | 5 | 0 | - | 1 | 0 | 3 | 4 | 4 | 0 | 6 | 2 | 2 | 7 | 8 | 1 | 0 | 1 | 6 | 7 | 8 | 9  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

0 2 | DURING LATE 1977 AND EARLY 1978, WHILE INVESTIGATING INDEPENDENT PLANT  
0 3 | PROBLEMS, QUESTIONS AROSE CONCERNING A SOLIDLY GROUTED PENETRATION. DESIGN  
0 4 | STRESS CALCULATIONS ASSUMED AN UNRESTRICTED PENETRATION. DURING SUB-  
0 5 | SEQUENT PLANT REVIEW OF PIPE PENETRATIONS, OTHER INCORRECTLY GROUTED PEN-  
0 6 | ETRATIONS WERE LOCATED. A THOROUGH DESIGN REVIEW OF PIPING STRESS ON  
0 7 | LINES WITH GROUTED PENETRATIONS WAS PERFORMED. ON THIRTEEN ISOMETRICS  
0 8 | PIPING STRESSES EXCEEDED CODE ALLOWABLE OR SUPPORT STRESS WAS EXCESSIVE.

0 9 | SYSTEM CODE | Z | Z | CAUSE CODE | B | CAUSE SUBCODE | C | COMPONENT CODE | Z | Z | Z | Z | Z | Z | COMP. SUBCODE | Z | VALVE SUBCODE | Z |  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 | LER/RO REPORT NUMBER | 7 | 8 | EVENT YEAR | 7 | 8 | SEQUENTIAL REPORT NO. | 0 | 2 | 0 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | X | REVISION NO. | 2 |  
21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN | F | FUTURE ACTION | K | EFFECT ON PLANT | Z | SHUTDOWN METHOD | Z | HOURS | 0 | 0 | 0 | 0 | ATTACHMENT SUBMITTED | Y | NPRD-4 FOR SUB. | N | PRIME COMP. SUPPLIER | Z | COMPONENT MANUFACTURER | Z | 9 | 9 | 9 |  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

1 0 | AS THE CAUSE, WE DETERMINED THAT THE SELECTION AND INSTALLATION OF PENE-  
1 1 | TRATION DETAILS DURING CONSTRUCTION WAS NOT PART OF A CONTROLLED PROCESS.  
1 2 | CORRECTIVE ACTION CONSISTS OF PIPE SUPPORT MODIFICATIONS OR GROUT REMOVAL,  
1 3 | AS APPROPRIATE.  
1 4 |

1 5 | FACILITY STATUS | G | % POWER | 0 | 0 | 0 | OTHER STATUS | NA | METHOD OF DISCOVERY | D | DISCOVERY DESCRIPTION | PIPING PENETRATION REVIEW  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 6 | ACTIVITY RELEASED | Z | CONTENT OF RELEASE | Z | AMOUNT OF ACTIVITY | NA | LOCATION OF RELEASE | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 7 | PERSONNEL EXPOSURES | 0 | 0 | 0 | TYPE | Z | DESCRIPTION | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 8 | PERSONNEL INJURIES | 0 | 0 | 0 | DESCRIPTION | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

1 9 | LOSS OF OR DAMAGE TO FACILITY | Z | TYPE | Z | DESCRIPTION | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

2 0 | PUBLICITY ISSUED | Z | DESCRIPTION | NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER M. A. Bell

PHONE: 503-556-3713 EXT. 227

7810200108 S