

# NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
HOLYOKE WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270  
HARTFORD, CONNECTICUT 06141-0270  
(203) 666-6911

December 15, 1982

Docket No. 50-245  
50-336  
A02567

IE HQ FILE COPY

George H. Smith, Director  
Division of Emergency Preparedness  
and Operations Support  
Region 1  
Regional Office  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

- References: (1) G. H. Smith letter to W. G. Council, dated June 11, 1982.
- (2) W. G. Council letter to G. H. Smith, dated July 30, 1982.
- (3) W. G. Council letter to G. H. Smith, dated October 29, 1982.

Gentlemen:


Millstone Nuclear Power Station, Unit Nos. 1 and 2  
Emergency Preparedness Appraisal

As a result of the NRC Staff's appraisal of the state of emergency preparedness at the Millstone Nuclear Power Station (MNPS), which was conducted during the period of January 4-14, 1982, several items which warranted further action were identified. These items were documented by the NRC Staff in Reference (1). For your convenience, the specific references in which we responded to each item in Appendix A to Reference (1) were identified in Attachment No. 1 to Reference (2). Our responses to those items listed in Appendix B to Reference (1) were provided in Attachment 2 to Reference (2). Reference (3) provided additional information regarding Item Nos. 2, 34, and 37 in Appendix B to Reference (1).

The purpose of this submittal is to report Northeast Nuclear Energy Company's completion of commitments regarding Item Nos. 2 and 37 in Appendix B of Reference (1).

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



W. G. Council  
Senior Vice President

Docket No. 50-245  
50-336

ATTACHMENT NO. 1  
MILLSTONE NUCLEAR POWER STATION UNIT NOS. 1 AND 2  
EMERGENCY PREPAREDNESS APPRAISAL

DECEMBER, 1982

Responses to Items Identified  
in Appendix B to Reference (1)

Item No. 2:

Revise the Emergency Plan to fully reflect the assignment of responsibilities for maintaining emergency preparedness of Corporate and Station personnel including the Emergency Planning Coordinator.

Response

The Millstone Nuclear Power Station Emergency Plan (MNPSEP) has been revised (Revision 10) to fully incorporate the Item No. 2 concerns noted above. Station procedures have been revised to implement the changes in the MNPSEP. The revised MNPSEP became effective on December 15, 1982.

Item No. 37:

Develop a procedure to implement the transition from an emergency classification to a recovery mode, including specific criteria upon which the emergency classes will be downgraded and provisions for notifying Federal, State and local officials prior to entering a recovery mode.

Response

A corporate procedure has been developed which covers the transition from an emergency classification mode to a recovery mode. Millstone procedures have been revised to include the requirements of the corporate procedure; the Millstone and corporate procedures became effective on December 15, 1982.