

UNITED STATES NUCLEAR REGULATORY COMMISSION

DOCKET NO. 50-368

ARKANSAS POWER AND LIGHT COMPANY

ARKANSAS NUCLEAR ONE, UNIT 2

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

The U. S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 3 to Facility Operating License No. NPF-6 to Arkansas Power and Light Company for operation of Arkansas Nuclear One, Unit 2 (the facility) located at the licensee's site in Pope County, Arkansas. The amendment is effective as of the date of its issuance.

This amendment revises Technical Specification 4.6.4.3.b to specify that the flow rate for each of the containment recirculation fans will be at least equal to 4500 cubic feet per minute.

The amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations. The Commission has made appropriate findings as required by the Act and the Commission's regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant


7810230301 P

to 10 CFR §51.5(d)(4) an environmental impact statement, or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action see (1) the licensee's application for amendment dated September 7, 1978 (2) Amendment No. 3 to License No. NPF-6, and (3) the Commission's related Safety Evaluation supporting Amendment No. 3 to License No. NPF-6. All of these items are available for public inspection at the Commission's Public Document Room at 1717 H Street, N. W., Washington, D. C. 20555 and the Arkansas Polytechnic College, Russellville, Arkansas 72801.

Dated at Bethesda, Maryland, this *4th* day of October 1978.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management