

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20545

PDR

OCT 17 1979

Docket No. 50-341 A


MEMORANDUM FOR: J. Stolz, Chief, Light Water Reactors Branch #1,
Division of Project Management

FROM: Paul F. Collins, Chief, Operator Licensing
Branch, Division of Project Management

SUBJECT: REVIEW OF CONDUCT OF OPERATIONS (SECTIONS 13.2
AND 13.5)

Plant Name: Enrico Fermi 2
Licensing Stage: OL
Branch and Project Manager Requesting Assistance: LWR 1, L. Kintner
Review Branch Involved: OLB:DPM
Description of Review: Review of Conduct of Operations, Sections 13.2
and 13.5.
Review Status: Safety Evaluation

We have reviewed Sections 13.2 and 13.5 and have determined that the additional information indicated in Attachment A is necessary for us to complete our review. We will be able to discuss these items, should the applicant so desire.


Paul F. Collins, Chief
Operator Licensing Branch
Division of Project Management

Enclosure:
Attachment A

7810230384 A

J. Stolz

- 2 -

cc: w/enclosure
D. Shovholt
W. Haas
D. Vassallo
L. Kintner
R. Hartfield

Attachment A
Fermi Unit No. 2
Docket No. 50-341

440.0 Operator Licensing Branch

441.1 Amend FSAR Section 13.2 to include fire protection
(13.2) training as required by Revision No. 1 of Standard
Review Plan 13.2. The applicable sections of SRP 13.2
that pertain to fire protection training are I.5, II.2,
II.6, III and IV.

442.1 Amend the list of plant procedures in Section 13.5.1
(13.5) to add Fire Protection Procedures.