



**GPU Nuclear Corporation**  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:

December 30, 1982  
4410-82-L-0080

TMI Program Office  
Attn: Mr. L. H. Barrett, Deputy Program Director  
US Nuclear Regulatory Commission  
c/o Three Mile Island Nuclear Station  
Middletown, PA 17057-0191

Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)  
Operating License No. DPR-73  
Docket No. 50-320  
SDS Staffing

Previously (GPU letters LL2-81-0101 dated April 24, 1981, and LL2-81-0128 dated May 11, 1981 from G. K. Hovey to L. H. Barrett), the following commitments were made with regard to SDS staffing levels during operational periods:

- Two (2) System Operators
- One (1) Chemistry Technician
- One (1) Health Physics Technician

Additionally, direct supervision would be provided by either a Certified Control Room Operator or a Radwaste Foreman during initial operations.

Based on the experience that has been gained since initial SDS startup in September, 1981, the above requirements are no longer necessary. The operation of SDS has proven to be efficient and smooth and, therefore, some reduction in staffing is warranted. GPUNC proposes that these staffing levels be reduced to:

- One (1) System Operator
- One (1) Chemistry Technician
- One (1) Health Physics Technician

Coverage by the Chemistry Technician and the Health Physics Technician will be on an as-required basis. This staffing reduction will allow more efficient use of existing personnel.

Additionally, since the initial phase of SDS operation is complete with the removal of the highly radioactive water in the Reactor Building Sump and the first two batches of Reactor Coolant System processing, the requirement for direct supervision by a

955 JAN 3 AM 11 03  
U.S. NUCLEAR  
REGULATORY COMMISSION

D009


GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation

8301040515 821230  
PDR ADOCK 05000320  
P PDR

Certified Control Room Operator and a Radwaste Foreman is being eliminated. As indicated in GPU letter LL2-81-0101, systems operation supervision will continue to emanate from the Operations Shift Foreman.

Your prompt consideration of this staffing modification is requested.

Sincerely,



B. K. Kanga  
Director, TMI-2

BKK/SDC/jep

CC: Dr. B. J. Snyder, Program Director - TMI Program Office