

Appendix A

NOTICE OF VIOLATION

Dairyland Power Cooperative

Docket No. 50-409

As a result of the inspection conducted on September 1 through October 31, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified:

Technical Specification 5.2.10.1.1.2.c.3.b states in part, "Each diesel generator shall be demonstrated OPERABLE: At least once per 18 months during shutdown by: Simulating a loss of offsite power in conjunction with an emergency core cooling system test signal, and: Verify the diesel starts from ambient condition on the autostart signal, energizes the essential buses with permanently connected loads, energizes the auto connected loads and operates while its generator is loaded with the emergency loads".

Contrary to the above, the diesel generators were not tested in accordance with the Technical Specification requirements in that they were not loaded with all the emergency loads as the core spray pumps were not started.


A review of the 18 month tests that were performed for the No. 1A and 1B diesel generators on June 3, 1982; December 30, 1980; and May 10, 1979, indicated that the tests were performed in accordance with the licensee procedure in lieu of the procedure specified in the Technical Specifications.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

DEC 2 1982

Dated



R. L. Spessard, Director
Division of Project and
Resident Programs