



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555
October 6, 1978

NR-364
E

Docket No. 50-261

Carolina Power and Light Company
ATTN: Mr. J. A. Jones
Senior Vice President
336 Fayetteville Street
Raleigh, North Carolina 27602

Gentlemen:

The Commission has issued the enclosed Amendment No. 34 to Facility Operating License No. DPR-23 for the H. B. Robinson Steam Electric Plant, Unit No. 2. This amendment is in response to your application dated December 2, 1977.

The amendment revises Technical Specifications 4.5.2.4 and 4.5.2.6 concerning testing requirements of the containment spray additive valves and the refueling water storage tank outlet valves. These changes are consistent with NRC guidance for meeting the requirements of 10 CFR 50.55a(g)

The NRC Safety Evaluation and Notice of Issuance for this amendment are also enclosed.

Sincerely,

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosures:

1. Amendment No. 34 to DPR-23
2. Safety Evaluation
3. Notice of Issuance

cc: w/enclosures
See next page

7810310233

E