

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | | | | | ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

① ② ③ ④ ⑤
C T M N S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 4 | | | | | ⑤
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
① ② ③ ④ ⑤ ⑥ ⑦ ⑧ ⑨
REPORT SOURCE ⑥ 0 5 0 0 0 2 4 5 ⑦ 1 1 1 2 9 8 2 ⑧ 1 2 2 2 8 2 ⑨
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩
① ② | On November 29, 1982, at 1430 hours, while performing a fire protection surveillance, |
① ③ | a missing fire barrier was discovered in the cable vault area where plumbing and storm |
① ④ | drains pass through. A continuous fire watch was immediately established. Technical |
① ⑤ | Specification 3.12.F.1 requires all penetration fire barriers to be functional when |
① ⑥ | safety-related equipment in the area is operable. There were no consequences. See |
① ⑦ | attached sheet. |

① ② ③ ④ ⑤ ⑥ ⑦ ⑧ ⑨
SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
A B ⑪ X ⑫ X ⑬ Z Z Z Z Z Z Z Z ⑭ X ⑮ Z ⑯
EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
8 2 ⑰ 0 2 8 ⑰ / ⑰ 0 3 ⑰ L ⑰ 0 ⑰
ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
X ⑱ Z ⑲ Z ⑳ Z ㉑ 0 0 0 0 ㉒ Y ㉓ N ㉔ Z ㉕ Z 9 9 9 ㉖

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉗
① ② | During the initial fire protection survey the above mentioned penetration, pipe chase, |
① ③ | was evaluated and dispositioned as not requiring a fire barrier. During a recent |
① ④ | fire inspection, however, the pipe chase was re-evaluated with additional facts and |
① ⑤ | dispositioned as needing a fire barrier. The opening was sealed with 9 inches of |
① ⑥ | silicone RTV. |

① ② ③ ④ ⑤ ⑥ ⑦ ⑧ ⑨
FACILITY STATUS | % POWER | OTHER STATUS ⑳ | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION ㉓
E ㉔ 1 0 0 ㉕ NA ㉒ C ㉓ Fire Protection Surveillance
ACTIVITY RELEASED | CONTENT | AMOUNT OF ACTIVITY ㉔ | LOCATION OF RELEASE ㉕
Z ㉖ Z ㉗ NA ㉒ NA ㉓
PERSONNEL EXPOSURES | NUMBER | TYPE | DESCRIPTION ㉔
0 0 0 ㉕ Z ㉖ NA
PERSONNEL INJURIES | NUMBER | DESCRIPTION ㉔
0 0 0 ㉕ NA
LOSS OF OR DAMAGE TO FACILITY | TYPE | DESCRIPTION ㉔
Z ㉕ NA
ISSUED | PUBLICITY | DESCRIPTION ㉔
N ㉕ 8301040691 821222
PDR ADOCK 05000245
S PDR
NRC USE ONLY
7 8 9 10 68 69 80

NAME OF PREPARER: Trudy Schweikert Thull PHONE: (203) 447-1791