



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

CONSUMERS POWER COMPANY

DOCKET NO. 50-155

BIG ROCK POINT NUCLEAR PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 21
License No. DPR-6

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Consumers Power Company (the licensee) dated May 17, 1978, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

7811090 ~~339~~ 071 P

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C(2) of Facility Operating License No. DPR-6 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 21, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: October 20, 1978

ATTACHMENT TO LICENSE AMENDMENT NO. 21

FACILITY OPERATING LICENSE NO. DPR-6

DOCKET NO. 50-155

Revise Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page includes the captioned amendment number and contain vertical lines indicating the area of change.

REMOVE

3-8

INSERT

3-8

- (f) If two consecutive integrated leak rate tests fail to meet the specifications contained in this section, then an ILRT shall be performed at each plant shutdown for refueling or approximately 18 months, whichever occurs first, until two consecutive ILRTs meet the acceptance criteria. After the above special retest requirement is satisfied, then the testing schedule outlined in 3.7.E may be resumed from the date of the last special test (i.e., 3-1/3 years after completion of the second consecutive satisfactory special test).
- (g) All leakage rates determined by a test pressure less than the applicable design pressure (containment design or design basis accident) shall be corrected using the following formula:

$$L_t = L_e (P_t/P_e)^{1/2}$$

L_t = % maximum allowable leakage rate, at test pressure.

L_e = % leakage rate, at extrapolated pressure.

P_t = Test pressure (PSIG).

P_e = Extrapolated pressure (PSIG).

Acceptance criteria on allowable leakage for the ILRT is .75 L_t .