

APPENDIX A

NOTICE OF VIOLATION

Mississippi Power & Light Company  
Grand Gulf

Docket No. 50-416  
License No. NPF-13

As a result of the inspection conducted on September 20 - October 18, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

10 CFR 50.72(a)(7) requires one hour notification of the NRC for any event resulting in a manual or automatic actuation of Engineered Safety Features, including the Reactor Protection System.

Contrary to the above, the requirement for one hour notification was not met in that:

- (1) On 9/22/82 an Engineered Safety Feature system challenge was not reported within one hour.
- (2) On 9/29/82 a manual scram initiated to control the reactor was not reported within one hour.

This is a Severity Level V Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date:           OCT 29 1982