

Big Rock Point

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIBR P 1 2 00-10 000000-1000 3 4 1 1 1 1 4 5

CON'T 01 REPORT SOURCE L 6 0 5 0 - 0 1 5 5 7 0 9 0 4 7 8 8 1 0 2 6 7 8 9

02 During routine testing of the containment ventilation isolation valves, the
03 supply valve CV/4097 leaked in excess of T/S criteria 3.7(a). Reactor
04 shutdown was established in approximately 12 hours and containment inte-
05 grity established by installation of a blank flange in the supply line in
06 21 hours. The redundant valve was later proven operable. Reportable under
07 T/S 6.9.2a(3). Previous reportable occurrences include letters of 2/1/78,
08 5/3/76 and 7/21/76.

09 SYSTEM CODE S A 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE VALVE EX 14 COMP. SUBCODE B 15 VALVE SUBCODE D 16
17 LER NO REPORT NUMBER 7 8 EVENT YEAR 7 8 SEQUENTIAL REPORT NO. 0 3 5 OCCURRENCE CODE 0 1 REPORT TYPE T REVISION NO. 1
ACTION TAKEN E 18 X 19 EFFECT ON PLANT A 20 SHUTDOWN METHOD A 21 HOURS 0 0 3 0 ATTACHMENT SUBMITTED Y 23 NPR-4 FORM SUB. N 24 PRIME COMP. SUPPLIER L 25 COMPONENT MANUFACTURER A 1 8 0 26

10 The 24" butterfly valve disc seal was readjusted and the valve tested
11 satisfactorily on 9/6/78 and on 9/11/78. Adjustment procedures and valve
12 design will be reviewed with the vendor to determine if other long-term
13 improvements can be made.

15 FACILITY STATUS E 28 % POWER 0 8 0 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Routine Test 32

16 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45 NRC USE ONLY

7811090229