



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 2, 1978

NRC PAR

P

MEMORANDUM FOR: Thomas Ippolito, Chief, Operating Reactors Branch #3, DOR
FROM: G. Lainas, Chief, Plant Systems Branch, DOR
SUBJECT: SAFETY EVALUATION OF PROPOSED CHANGES TO TECHNICAL
SPECIFICATION RE: BATTERY SURVEILLANCE TESTING FOR
JAMES A. FITZPATRICK (TAC10390)

Plant Name: James A. FitzPatrick Nuclear Power Plant
Docket No.: 50-333
Responsible Branch: P. Polk
Reviewing Branch: Plant Systems Branch
Review Status: Complete

The Power Authority of the State of New York, by its letter dated September 1, 1978, submitted a request for the changes to the Technical Specification for the surveillance requirements of discharge test on the Station Batteries and LPCI system MOV's power supplies.

Based on our evaluation of the licensee's proposal, we find the changes to Technical Specifications acceptable.

G. Lainas, Chief
Plant Systems Branch
Division of Operating Reactors

Contact:
S. Rhow
X-28077

Enclosure:
As stated

cc w/enclosure:
See next page

7811130299

P

cc w/enclosure:

D. Eiserhut

B. Grimes

W. Russell

T. Ippolito

P. Polk

F. Rosa

G. Lainas

D. Tondi

S. Rhow