

QUAD CITIES
DPR-29

e. With the measured leakage rate exceeding 11.5 scf per hour for any one main steam isolation valve, restore the leakage rate to \leq 11.5 scf per hour for any one main steam isolation valve prior to increasing the reactor coolant temperature above 212°F.

2) Main steam isolation valves, which shall be leak tested at least once per 18 months at a pressure of 25 psig.

3) Bolted double-gasketed seals which shall be tested at a pressure of 48 psig whenever the seal is closed after being opened and each operating cycle.

e. All test leakage rates shall be calculated using observed data converted to absolute values. Error analyses shall be performed to select a balanced integrated leakage measurements system.

3. Pressure Suppression Chamber-
Reactor Building Vacuum Breakers

a. The pressure suppression chamber-reactor building vacuum

3. Pressure Suppression Chamber-
Reactor Building Vacuum Breakers

a. Except as specified in Specification 3.7.A.3.b below, two pressure sup-

QUAD CITIES
DPR-30

e. With the measured leakage rate exceeding 11.5 scf per hour for any one main steam isolation valve, restore the leakage rate to \leq 11.5 scf per hour for any one main steam isolation valve prior to increasing the reactor coolant temperature above 212°F.

2) Main steam isolation valves, which shall be leak tested at least once per 18 months at a pressure of 25 psig.

3) Bolted, double-gasketed seals which shall be tested at a pressure of 48 psig whenever the seal is closed after being opened and each operating cycle.

e. All test leakage rates shall be calculated using observed data converted to absolute values. Error analyses shall be performed to select a balanced integrated leakage measurements system.

3. Pressure Suppression Chamber-
Reactor Building Vacuum Breakers

a. The pressure suppression chamber-reactor building vacuum

3. Pressure Suppression Chamber-
Reactor Building Vacuum Breakers

a. Except as specified in Specification 3.7.A.3.b below, two pressure sup-