

Virginia Electric and Power Company
North Anna Power Station, Unit No. 1
Docket No. 50-338
Report No. LER 78-026/99X-1

Attachment: Page 1 of 2

Positive Moderator Coefficient

On 4/13/78, analysis of startup physics testing data revealed that a positive moderator temperature coefficient (MTC) was present at the all rods withdrawn, beginning of core life, hot zero thermal power condition. The finalized data indicated an isothermal temperature coefficient of $-0.979 \text{ pcm}/^{\circ}\text{F}$, which converts to an MTC of $+1.126 \text{ pcm}/^{\circ}\text{F}$ when corrected for the Doppler Contribution ($-2.105 \text{ pcm}/^{\circ}\text{F}$), was present with an RCS boron concentration of 1322 ppm. The rod withdrawal limits illustrated by the attached figure have been instituted. It is estimated that a core burnup of 3000 MWD/MTU will be required to restore the MTC within its limits.

The withdrawal limits will apply throughout the entire first cycle of the unit or until a negative MTC for the ARO configuration is verified by measurement.

Virginia Elec & Power Co.
North Anna Power Station, Unit #1
Docket No. 50-338
Report No. LER 78-026/99X-1

K+E 16 X 16 TO 16 INCHES
KEUFFEL & ESSER CO. MADE IN U.S.A.

Update Report - Previous Report Date 4-21-78
471320 Attachment: Page 2 of 2

NORTH ANNA UNIT 1 CYCLE 1
MODERATOR COEFFICIENT ROD WITHDRAWAL RESTRICTIONS

