

APPENDIX ANOTICE OF VIOLATION

Virginia Electric and Power Company

License No. NPF-4

Based on the results of the NRC inspection conducted on September 11-15, 1978, it appears that certain of your activities were not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in our correspondence to you dated December 31, 1974.

Facility Operating License No. NPF-4, Section 2.D.(3)e, states that if VEPCO plans to remove or to make significant changes in the normal operation of equipment that controls the amount of radioactivity in effluents from the North Anna Station, the Commission shall be notified in writing regardless of whether the change affects the amount of radioactivity in the effluents.

Contrary to the above, the Commission was not notified in writing of a July, 1978, modification to the liquid waste disposal system involving the installation and use of a demineralization system.

This is a deficiency.

781124005h