

APPENDIX A

NOTICE OF VIOLATION

Virginia Electric and Power
Company

License No. NPF-4

Based on the results of the NRC inspection conducted July 31 - September 1, 1978, it appears that certain of your activities were not conducted in full compliance with NRC requirements as indicated below. This item has been categorized as described in our correspondence to you dated December 31, 1974.

Technical Specification 6.9.1.9.b requires that a written report be submitted to NRC within thirty days whenever conditions lead to operation in a degraded mode as permitted by a limiting condition for operation, or plant shutdown is required by a limiting condition for operation.

Contrary to the above, a written report was not submitted to NRC concerning a reactor coolant system unidentified leakage rate of greater than one (1) gallon per minute on May 15, 1978. One gallon per minute is the operational limit specified by Technical Specification 3.4.6.2.b.

This is a deficiency.

7811270012 Q