

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NOS. 50-317 AND 50-318BALTIMORE GAS AND ELECTRIC COMPANYNOTICE OF GRANTING OF RELIEF FROM ASME SECTION XIINSERVICE INSPECTION REQUIREMENTS

The U. S. Nuclear Regulatory Commission (the Commission) has granted relief from certain requirements of the ASME Code, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components" to Baltimore Gas and Electric Company (the licensee), which revised the inservice inspection program for Calvert Cliffs Nuclear Power Plant, Units No. 1 and No. 2. The ASME Code requirements are incorporated by reference into the Commission's rules and regulations in 10 CFR Part 50. The relief is effective as of its date of issuance.

The NRC has provided a relief from the ASME Boiler and Pressure Vessel Code, Section XI, regarding the requirements for:

- Inspection of Seal Weld in Closure Head,
- Inspection of Primary Nozzle-to-Vessel Welds and Nozzle Inside Radiused Section,
- Inspection of Reactor Vessel Cladding,
- Repair of an Arc Strike, Class 2 Pipe,
- Pressure Test Hold Time,
- Class 3 System Pressure Tests,
- Inservice Leak Test (Hydrostatic Testing) for the Salt Water Cooling System and Service Water Main Headers,
- Ultrasonic Examination Techniques,
- Repair and Hydrostatic Testing for Small Steam and Feedwater Piping, Class 2.


- 2 -

The Commission has determined that the granting of this relief will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with this action.

For further details with respect to this action, see (1) the licensee's request for relief from code requirements dated December 5, 1978, March 29, 1980, November 19, 1980 and May 29, 1981 and additional information submitted by the licensee's letters dated July 22, 1982, August 30, 1982, October 29, 1982 and (2) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H. Street, N.W. Washington, D.C. 20555, and at the Calvert County Library, Prince Frederick, Maryland. A copy of item (2) may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Director, Division of Licensing.

Dated at Bethesda, Maryland this 13th day of December, 1982.

FOR THE NUCLEAR REGULATORY COMMISSION


Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing