


Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 323-5341

F. L. CLAYTON, JR.
Senior Vice President



November 17, 1978

Docket Nos. 50-348
50-364 A

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

JOSEPH M. FARLEY NUCLEAR PLANT-UNITS 1 AND 2
REACTOR COOLANT SYSTEM OVERPRESSURIZATION MITIGATING SYSTEM

Gentlemen:

The following is provided in response to NRC questions discussed by telephone on November 9, 1978 with Alabama Power Company concerning the proposed overpressurization mitigating system for the Farley Nuclear Plant. Two (2) marked-up drawings showing preliminary design of part of the subject system are attached as requested.

Alabama Power Company investigated the feasibility of increasing the frequency of RHR relief valve testing. In place verification of relief valve set point will be conducted on alternate refueling outages.

Should you have any questions, please advise.

Very truly yours,

F. L. Clayton, Jr.
F. L. Clayton, Jr.

FLCJr/HRF/mmb

Attachments

cc: Mr. R. A. Thomas
Mr. G. F. Trowbridge

7811280283

A010
S/O
1/0
1 set Drawings
TO
REG FILES

Docket Nos. 50-348
50-364

November 17, 1978

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Page 2

bc: Mr. W. G. Hairston
Mr. J. T. Young
Mr. H. O. Thrash
Mr. T. N. Epps
Mr. H. R. Fair
Mr. Ken McCracken
Mr. Dan Poole
Mr. O. D. Kingsley
Mr. Don Crowe
Mr. Ozen Batum
Mr. Ed Reeves