


# YANKEE ATOMIC ELECTRIC COMPANY



Rowe, Massachusetts 01367

November 20, 1978

Mr. B. H. Grier, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Subject: Reportable Occurrence 50-29<sup>S</sup>/78-27/03L  
Secondary Water Chloride Ion Concentration  
Greater than 0.5 ppm

Dear Mr. Grier:

In accordance with Technical Specifications, Section 6.9.4.b, the attached Licensee Event Report is hereby submitted.

Very truly yours,

Herbert A. Autio  
Plant Superintendent

RLB/mid

Enclosure:

cc: [30] Director, Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

[3] Director, Office of Management Information & Program Control  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

RT: 17-R-04-013  
IMS: D-06-01-01  
W-02-04-08  
G-01-08-01

7811280284

A002  
5/11