LICENSEE EVENT REPORT CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 00000001-101 134 MAYKR (2) LICENSEE CODE CON'T (8) 1 0 1 | L (6) 0 | 5 | 0 | 0 | 0 | 0 | 2 | 9 | (7) 1 | 10 | 2 | 1 SOURCE EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) [0 2] | During a scheduled shutdown, the steam generator's chloride concentration exceeded [0]3] [0.5 ppm. Technical Specification, section 3.7.1.6, limits the chloride ion concentra-[0 [4] | tion to ≤0.5 ppm during Modes 1-3. Similar occurrences of this nature were reported jas LER 78-24, 78-20, 77,22, 77-18, 77-17 & 77-13. Secondary water chemistry remained optimum for inhibition of chloride induced stress corrosion cracking. Thus, there were no adverse effects on the health and safety of the public. SYSTEM COMP CAUSE CAUSE VALVE CODE CODE SUBCODE COMPONE', T CODE SUBCODE REVISION OCCURRENCE SEQUENTIAL REPORT EVENT YEAR REPORT NO. CODE LER/RO TYPE NO REPORT 0 | 2 | 0 NUMBER NPRD-4 PRIME COMP COMPONENT ACTION FUTURE TAKEN ACTION SHUTDOWN ATTACHMENT SUBMITTED HOURS (22) FORM SUB. SUPPLIER MANUFACTURER Z (21) X (18) Z (19) W 1 1 2 1 0 0 0 0 0 0 N (23) N (25) Z (20) N (24) 0 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The root cause of this event is steam generator's chemical hideout 1 0 The plant continued shutting down and entered Mode 5 as required by Technical Specification. The plant will remain shutdown for the scheduled Core XIII-XIV refueling. 1 3 1 4 FACILITY METHOD OF (30) DISCOVERY DESCRIPTION (32) % POWER OTHER STATUS DISCOVERY B (31) Chemistry Analysis 0101 9 10 ACTIVITY CONTENT LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35) RELEASED OF RELEASE Z 33 Z 34) N/A N/A PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER 0 0 0 (37) N/A PERSONNEL INJURIES DESCRIPTION (41) NUMBER 0 0 0 (40) N/A LOSS OF OR DAMAGE TO FACILITY (43) DESCRIPTION N/A 10 PUBLICITY NRC USE ONLY DESCRIPTION (45) (44) 2 0 IN N/A 7811280290 PREPAREN. PHONE: 1-413-625-6140

Boutwel]