



SAFEGUARDS INFORMATION

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA STREET, N.W., SUITE 2900
ATLANTA, GEORGIA 30323-0199

Report Nos. 50-424/94-03 and 50-425/94-03

Licensee: Georgia Power Company
P. O. Box 1295
Birmingham, AL 35201

Docket Nos. 50-424 and 50-425

License Nos. NPF-68 and NPF-81

Facility Name: Vogtle 1 and 2

Inspection Conducted: January 31 - February 4, 1994

Inspector: G. A. Todd
G. A. Todd, Safeguards Specialist

02-03-94
Date Signed

Approved by: D. R. McGuire
D. R. McGuire, Chief
Safeguards Section
Nuclear Materials Safety and Safeguards Branch
Division of Radiation Safety

3/3/94
Date Signed

SUMMARY

Scope:

This routine, announced inspection was conducted in the areas of the Physical Security Program for Power Reactors. Specifically, the areas evaluated were: Management Support; Protected and Vital Area Barriers; Protected Area Access Control; Alarm Stations; Power Supply; and Security Training.

Results:

In the areas inspected, violations or deviations were not identified. Violation 93-12-01 (Inadequate illumination of laydown yard within Protected Area) was closed. The licensee's corrective action and continued assessment was deemed adequate. (See Paragraph 2, Report Details).

The licensee's security program was determined to be effective in providing an acceptable level of protection for the nuclear station's resources and the design basis threat of radiological sabotage. The performance of the security force was reflected in their professionalism in carrying out their operational duties. Of noteworthy mention is the proficiency displayed by the security force during their implementation of their contingency response following an early morning reactor trip on February 2, 1994.

9403150241 940303
PDR ADOCK 05000424
Q PDR

SAFEGUARDS INFORMATION

Document transmitted herewith
contains sensitive unclassified
information. When separated from
enclosures, this document is decontrolled.