

DEC 21 1982

Docket No. 99900401/82-04

Combustion Engineering, Incorporated
Power Systems Group
ATTN: Mr. M. R. Etheridge, Vice President
General Services
1000 Prospect Hill Road
Windsor, Connecticut 06095

Gentlemen:

This refers to the inspection conducted by Mr. W. M. McNeill of this office on October 25-29, 1982, of your facility at Windsor, Connecticut, and to the discussions of our findings with you and members of your staff at the conclusion of the inspection.

This inspection was made as a result of the identification at the Arkansas Nuclear One, Unit 2 facility of insufficient clearance between fuel rods and the upper flow plate in Batch C fuel assemblies.

Areas examined during this inspection and our findings are discussed in the enclosed report. Within these areas, the inspection consisted of an examination of procedures and representative records, interviews with personnel, and observations by the inspector.

During this inspection it was found that you failed to meet certain commitments in your Topical Report No. CENPD-210-A. The specific findings and references to the pertinent requirements are identified in the enclosures to this letter.

Please provide us within 30 days from the date of this letter a written statement containing: (1) a description of steps that have been or will be taken to correct this item; (2) a description of steps that have been or will be taken to prevent recurrence; and (3) the dates your corrective actions and preventive measures were or will be completed. Consideration may be given to extending your response time for good shown.

The response requested by this letter is not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be exempt from disclosure under 10 CFR 9.5(a)(4), it is necessary that you (a) notify this office by telephone within 10 days from the date of this letter of your intention to file a request for withholding; and (b) submit within 25 days from the date of this letter a written application to this

8301060298 B21221
PDR 0A999 EMVC-E
99900401 PDR

TE:09

RIV

OFFICE	CI:R&CPS <i>WMC</i>	SC:R&CPS <i>IB</i>	BC:VPB <i>CP</i>	AD:DV&TP <i>RLB</i>	D:ES <i>WJS</i>	RA:RIV
SURNAME	WMMcNeill:ms	IBarnes	UPotapovs	RLBargart	EHJohnson	JCollins
DATE	12/8/82	12/8/82	12/16/82	12/10/82	12/20/82	12/1/82

office to withhold such information. If your receipt of this letter has been delayed such that less than 7 days are available for your review, please notify this office promptly so that a new due date may be established. Consistent with Section 2.790(b)(1), any such application must be accompanied by an affidavit executed by the owner of the information which identifies the document or part sought to be withheld, and which contains a full statement of the reasons on the basis which it is claimed that the information should be withheld from public disclosure. This section further requires the statement to address with specificity the considerations listed in 10 CFR 2.790(b)(4). The information sought to be withheld shall be incorporated as far as possible into a separate part of the affidavit. If we do not hear from you in this regard within the specified periods noted above, the report will be placed in the Public Document Room.

Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Uldis Potapovs, Chief
Vendor Program Branch

Enclosures:

1. Appendix A - Notice of Nonconformance
2. Appendix B - Inspection Report No. 99900401/82-04
3. Appendix C - Inspection Data Sheets (4 pages)

bcc:

- IE Files
- AEOD
- QAB
- NRC:PDR
- Reg. Administrators, I, II, III, IV, V
- EHJohnson, RIV
- RLBangart, RIV
- C. Berlinger, NRR

OFFICE							
SURNAME							
DATE							