

JAN 3 1983

Docket No. 50-387

Pennsylvania Power & Light Company
ATTN: Mr. Bruce D. Kenyon
Vice President, Nuclear Operations
2 North Ninth Street
Allentown, Pennsylvania 18101

Gentlemen:

Subject: Inspection 50-387/82-36

This refers to your letter dated December 10, 1982, in response to our letter dated November 12, 1982.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

With respect to the dispositioning and recording of acceptable indications on radiographic review forms, the ASME III Code Interpretation, III-1-78-07 addresses this subject. It requires that acceptable linear indications be recorded and dispositioned. Further, NRC Inspection Report 50-387/76-04 identified a similar violation dealing with the reactor vessel safe end weld radiographs.

Your cooperation with us is appreciated.

Sincerely,

ORIGINAL SIGNED BY *Lee 21. Betteshausen*
for Thomas T. Martin, Director
Division of Engineering and Technical Programs

cc:
Norman W. Curtis, Vice President, Engineering and Construction - Nuclear
A. R. Sabol, Manager, Nuclear Quality Assurance
W. E. Barberich, Licensing Engineer
H. W. Keiser, Superintendent of Plant
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc:
Region I Docket Room (with concurrences)
Jessica H. Laverty, ELD
DPRP Section Chief

8301060335 830103
PDR ADOCK 05000387
G PDR

1601

OFFICE	DETP <i>JD</i>	DETP <i>TD</i>	DETP <i>MA</i>			
SURNAME	McBrearty	Durr	Ebnetter			
DATE	12/16/82	12/16/82	12/30/82			