

ENCLOSURE 1

NOTICE OF VIOLATION

Entergy Operations, Inc.
Grand Gulf Unit 1

Docket No. 50-416
License No. NPF-29

During a Nuclear Regulatory Commission (NRC) inspection conducted on January 24-28, 1994, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation with two examples is listed below:

10 CFR 50, Appendix B, Criterion V, requires, in part, that "Activities affecting quality shall be prescribed by documented instructions, procedures, and drawings of a type appropriate to the circumstances and shall be accomplished in accordance with these instructions...."

Technical Specification (TS) 6.8.1.f. requires that written procedures be established, implemented and maintained covering the Fire Protection Program implementation. License Condition 2.C.(41) requires that Entergy Operations, Inc. implement and maintain in effect all provisions of the approved Fire Protection Program.

1. Administrative Procedure No. 01-S-16-1, Plant Design Change Implementation, Section 6.3, requires the review of design changes by specific interfacing plant organizations. The review requires the identification and documentation of those procedures, programs, material requirements, and operator training which must be revised as a result of the design change.

Contrary to the above, on February 18, 1989 and January 11, 1991, Administrative Procedure 01-S-16-1 was not adequately implemented in that the Operations Section reviews, of procedures, programs, training, or material requirements affected by Design Change Packages (DCPs) 85-0050, Snubber Test Facility, and 88-0050, Expanded Protected Area, did not identify that fire brigade Fire Preplans needed to be updated, the transient combustible control program required revisions for Fire Area 59 in accordance with the Fire Hazards Analysis description, and fire brigade re-training was required for areas affected by the modifications.

2. Operations Section Procedure 02-S-01-18, Control of Fire Preplans, established for implementing controls of Fire Preplans as an element of the plant Fire Protection Program, requires, in part, that the Fire Preplans be reviewed on an annual basis and revised when changes or modifications are made to plant structures, systems, or components.

Entergy Operations, Inc.
Grand Gulf Unit 1

2

Docket No. 50-416
License No. NPF-29

Contrary to the above, as of January 28, 1994, Operations Section Procedure 02-S-01-18, effective November 8, 1991, was not adequately implemented in that the plant Fire Preplans, Revision 0, used for fighting fires in safety-related plant areas had not been reviewed and revised on an annual basis since their original issuance.

This is a Severity Level IV Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Entergy Operations, Inc. is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or Demand for Information may be issued as to why the license should not be modified, suspended, or revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Atlanta, Georgia
this 25th day of February 1994