NRC FORM 366 (12-81)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011 EXPIRES 4-30-82

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S C V C S 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 0 0 0 (4) | (5)

LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 9 5 (7) | 1 2 0 2 8 2 (8) | 1 2 3 0 8 2 (9)

DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On December 2, 1982, with the Plant in Mode 2, the Main Control Board Indicator
03 | for Reactor Building Pressure (PI-950) failed low and was subsequently declared
04 | inoperable. The failure cleared prior to identification of component. The
05 | channel was tested and returned to service. Similar failures occurred on
06 | October 3, 19, and 28. There were no adverse consequences during any of the
07 | events as three (3) channels of Reactor Building Pressure Indication remained
08 | operable.

09 | SYSTEM CODE: I B (11) | CAUSE CODE: X (12) | CAUSE SUBCODE: Z (13) | COMPONENT CODE: I N S T R U (14) | COMP. SUBCODE: I (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 2 — SEQUENTIAL REPORT NO. 0 1 6 / OCCURRENCE CODE 0 3 — REPORT TYPE L — REVISION NO. 1

ACTION TAKEN X (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0 0 0 0 (22) | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER W 1 2 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The cause of this occurrence is still under investigation. The corrective
11 | action will be dependent on the cause determination.
12 |
13 |
14 |

15 | FACILITY STATUS B (28) | % POWER 0 0 4 (29) | OTHER STATUS N/A (30) | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY N/A (35) | LOCATION OF RELEASE (36) N/A

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) N/A

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) N/A

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) N/A

8301060374 821230
PDR ADOCK 05000395
S PDR

NRC USE ONLY

NAME OF PREPARER C. J. McKinney PHONE: (803) 345-5209

C. J. McKinney