

## ATTACHMENT 3

### Core Operating Limits Report

(COLR)

#### 1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report (COLR) for Zion Unit 1 Cycle 14 has been prepared in accordance with the requirements of Zion Technical Specification 6.6.1.F.

The Technical Specifications affected by this report are:

LCO	3.2.1.C.3 3.2.1.D.1	Shutdown Bank Insertion Limit
LCO	3.2.1.C.3 3.2.1.D.1	Control Bank Insertion Limit
LCO	3.2.2.A.1.1	Heat Flux Hot Channel Factor - $F_Q(Z)$
LCO	3.2.2.A.1.1	Nuclear Enthalpy Rise Hot Channel Factor - $F_{\Delta H}^N$
LCO	3.2.2.A.2.2.c(2) 3.2.2.A.4 3.2.2.A.6.1	Axial Flux Difference ( $\Delta I$ Target Band)

9403150393 940307  
PDR ADJCK 05000295  
P PDR

## 2.0 OPERATING LIMITS

The cycle specific parameter limits for the LCOs specified in Section 1.0 are presented in the subsections which follow. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 6.6.1.F.

### 2.1 Shutdown Bank Insertion Limits (LCO 3.2.1.C.3 and 3.2.1.D.1)

The Shutdown Banks shall be fully withdrawn when the reactor is approaching criticality or is critical.

### 2.2 Control Bank Insertion Limits (LCO 3.2.1.C.3 and 3.2.1.D.1)

The Control Bank Insertion Limits are specified by Figure 2.2-1.

The sequence for Control Bank Withdrawal shall be Control Bank A, Control Bank B, Control Bank C, and Control Bank D.

Successive Control Banks shall overlap by 50 steps.

# Zion Unit 1 Cycle 14

Banks A and B Fully Withdrawn




Figure 2.2-1 Control Bank Insertion Limits vs. rated Thermal Power

2.3B Heat Flux Hot Channel Factor -  $F_Q(Z)$  ( $F_Q$  Methodology)

(LCO 3.2.2 A.1.1)

2.3B.1

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{P} * K(Z) \quad \text{for } P > 0.5$$

$$F_Q(Z) \leq \frac{F_Q^{RTP}}{0.5} * K(Z) \quad \text{for } P \leq 0.5$$

where:

$$F_Q^{RTP} = 2.40$$

$$P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$$

$K(Z)$  is provided in Figure 2.3B - 1

### Zion Unit 1 Cycle 14 K(Z)




Figure 2.3B-1 K(Z) - Normalized  $F_Q(Z)$  as a Function of Core Height

2.4 Nuclear Enthalpy Rise Hot Channel Factor -  $F_{\Delta H}^N$

(LCO 3 2.2.A.1.1)

2.4.1

$$F_{\Delta H}^N \leq F_{\Delta H}^{RTP} * (1 + PF_{\Delta H} * (1 - P))$$

where:  $F_{\Delta H}^{RTP} = 1.65$

$$PF_{\Delta H} = 0.3$$

$$P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$$

for  $0.02 \leq P \leq 1.00$

2.5 Axial Flux Difference (CAOC Methodology)

(LCO 3.2.2.A.2.2 c(2), 3.2.2.A.4, and 3.2.2.A.6.1)

2.5A.1 The AXIAL FLUX DIFFERENCE (AFD) target band is +6%, -7% of the target flux difference.

2.5A.2 The AFD acceptance operation limits are an envelope bounded by  $+\gamma$  percent and  $-\gamma$  percent at a power of 90% of  $P_T$  and increasing by +1 percent and -1 percent for each 2 percent of rated power below  $P_T$ .  $\gamma = 10.8\%$  of  $P_T$  rounded to the nearest percent.