



Consumers
Power
Company

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 768-0550

November 30, 1978

Director, Nuclear Reactor Regulation
Att: Mr Dennis L Ziemann, Chief
Operating Reactors Branch No 2
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 -
BIG ROCK POINT PLANT - RESPONSE
TO LETTER DATED SEPTEMBER 6, 1978:
ENVIRONMENTAL QUALIFICATION
(SEP TOPIC III-12)

Your letter of September 6, 1978 transmitted a tabulation of information regarding safety-related electrical equipment qualification using an NRC standard format. Consumers Power Company was requested to complete as much of the table as possible, identify appropriate references and confirm the accuracy and completeness of the table. Attachment I to this letter provides Consumers Power Company's response to your request.

As stated in our previous submittal of February 24, 1978, the equipment addressed is: (1) That equipment which must operate to ensure safe shutdown of the plant during a loss of coolant accident (inside of containment) and a main steam line break (outside of containment) and (2) that equipment that is subject to a potentially hostile environment due to the above events. You will note that the table, as submitted to Consumers Power Company on September 6, 1978, has been broken down using four criteria: (1) By equipment manufacturer, (2) by equipment location (ie, inside or outside containment), (3) by time needed, and (4) whether or not the equipment was submerged. It is Consumers Power Company's conclusion that this breakdown is necessary to ensure that future users of this tabulated data will be able to draw realistic conclusions regarding this equipment.

The electrical equipment was reviewed to determine the length of time required to remain operational. This was based on time span from the initiation of the event until the component is required to start to operate and the time span over which it must continue to operate. The time needed identified for each item is conservative and, in some cases, is considerably longer than the equipment will actually be required to function.

7812050224

P

It is Consumers Power Company's conclusion that this list provides an adequate basis to support operation of the plant.

Included as Attachment II to this letter is an updated copy of the electrical equipment qualification tables in the format as previously submitted by Consumers Power Company (February 24, 1978). This attachment is being submitted in order to ensure that previously submitted information is current. Some revision was required to accommodate newly acquired information and to correct errors found during this review. Other unrevised pages of the previous submittal have not been resubmitted.

David A Bixel (Signed)

David A Bixel
Nuclear Licensing Administrator

CC: JGKepler, USNRC

ATTACHMENT 1

Electrical Equipment-Environmental
Qualification and Requirements

Reactor: Big Rock Point Plant		Systematic Evaluation Program						See note 2 for Time Needed determination	
Equipment Type	SEP Submittal Reference	Loc	Time Needed	Environment Parameter	Environment Spec.	Qual.	Qual. Method		Reference
1	Solenoid Valve ASCO/HY830061RF	I	10m	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	235 42 100% No 1.4X10 ⁶ Yes	415 42 100% -- 6X10 ⁶ Yes	Eval ↓	2 1,19 1,19 1 -- 19 Note 1	See note 6
2	Solenoid Valve ASCO/830060RF SV-4869 SV-4891	I	10m	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	235 42 100 No 1.4X10 ⁶ Yes	340 42 100 -- 4X10 ⁶ Yes	Eval ↓	2 1 1 1 -- 19 Note 1	
3	Solenoid Valve ASCO/831620 HVA 90-441-1A SV-4879	I	10m	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	235 42 100 No 1.4X10 ⁵ No	240 42 100 -- 3X10 ⁶ --	Eval ↓	2 1,52 1,52 1,52 -- 19 --	

Reactor: Big Rock Point Plant			Systematic Evaluation Program					
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment			Qual. Method	Reference
				Parameter	Spec.	Qual.		
Solenoid Valve	50 ASCO/ HT831677 pg 9 Items 1-4	I	30d	Temp. (F)	235	240	V. Data	20
				Pr. (Psia)	42	42	↓	20
				RH (%)	100	100		20
				Chem. Rad. (R)	No 1.3X10 ⁶	-- 2X10 ⁸		-- 20, 63, 64
				Sub.	N	--		
SV-498Q thru SV-4983								
Solenoid Valve Target Rock/ 73V001	50 pg 9 Items 55-8	I	30d	Temp. (F)	235	300	Test	8
				Pr. (Psia)	42	85	↓	8
				RH (%)	100	100		8
				Chem. Rad. (R)	No 1.3X10 ⁶	-- 3.3X10 ⁷		-- 8
				Sub.	Nc	--		--
SV-498H through SV-4987								
Motor Operated Valve Starter	52 pg. 4 Items 11, 12	0	30d	(see Note 4)			Eval	2
				Temp. (F)	100	140	↓	Note 13, 4 Note 4 See Note 5, 13, 4
				Pr. (Psia)	15	15		
				RH (%)	100	100		
				Chem. Rad. (R)	No	--		--
				Sub.	No	--		--
GE CR-106-CO TEC 36015								
NO-1 52-2045								

Reactor: Big Rock Point Plant			Systematic Eval				On Program	
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment Parameter	Spec.	Qual.	Qual. Method	Reference
Motor Operated Valve Rotork/14A	49 Pg. 4 Items 9,10	I	30d	Temp. (F) Pr. (Psia) RH (%)	235 42 100	235 42 100	Test ↓	2 12 12 12
Limitorque/SMA-00	Pg. 5 Items 1-5			Chem. Rad. (R) Sub.	No 1.3X10 ⁶ No	-- 3X10 ⁶ --	-- Eval --	-- 15 --
MO-7064								
MO-7068								
MO-7054								
MO-7061								
MO-7071								
MO-7069								
Penetration, Elec. Amphenol-Borg/Co-axial	50 Pg. 11 Items 3	I	30d	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	235 42 100 No 6X10 ⁴ No	235 42 100 -- 6X10 ⁴ --	V. Data ↓ -- Eval --	67,68 ↓ -- 69 --
Penetration Conax B4205	50 Pg. 9 Items 9-12	I	30d	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	235 42 100 No 1.3X10 ⁶ No	280 60 100 -- 2.3X10 ⁷ --	Test, Eval Test, Eval Test, Eval -- Test, Eval --	22,27 ↓ -- 22,27 --
H40								See note 9
H65								
H81								
H83								

Reactor: Big Rock Point Plant			Systematic Evaluation Program					
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment Parameter	Environment Spec.	Qual.	Qual. Method	Reference
10 Penetration Rundel Manufacturer;	50	I	30d	Temp. (F)	235	274	Eval	5, 65
Bechtel Specification 3159E-19	Page 11 Item 2			Pr. (Psia)	42	45	↓	↓
				RH (%)	100	100	--	--
				Chem. Rad. (R) Sub.	No	--	Eval	5, 65, 66
					1.3X10 ⁶	Sat	--	--
					No	--	--	--
11 Terminal Connections (RDS Syst.)	50	I	30d	Temp. (F)	235	235	V. Data	6
AMP Special Products	page 11 Item 6			Pr. (Psia)	42	42	↓	↓
				RH (%)	100	100	--	--
				Chem. Rad. (R) Sub.	No	--	V. Data	6
					1.3X10 ⁶	7X10 ⁸	--	--
					No	--	--	--
12 Terminal Block (RDS System)	50	I	30d	Temp. (F)	235	235	Eval	33, 14
States Block/NT	page 11 Item 7			Pr. (Psia)	42	42	↓	↓
				RH (%)	100	100	--	--
				Chem. Rad. (R) Sub.	No	--	Eval	33, 14
					1.3X10 ⁶	1X10 ⁸	--	--
					No	--	--	--

Reactor: Big Rock Point Plant			Systematic Evaluation Program					
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment		Qual.	Qual. Method	Reference
				Parameter	Spec.			
SplICE								
Amp	49	I	30d	Temp. (F)	235	392	Test	55,61
CertiSeal 324549	page 7			Pr. (Psia)	42	42	Eval	Note 14
324990	Item 2			RH (%)	100	100	Eval	Note 14
(see item 50 for other splices)				Chem. Rad. (R)	No	--	--	--
				Sub.	1.3X10 ⁶	1.3X10 ⁶	Eval	36,59,61
					No	--	--	Note 17
Junction Box	52	I	30d	Temp. (F)	235	235	Eval	33
Rumsey Electrical Gasketed	page 10			Pr. (Psia)	42	42	↓	↓
TR240-TB 243	Item 1			RH (%)	100	100	↓	↓
				Chem. Rad. (R)	No	--	--	--
				Sub.	1.3X10 ⁶	1X10 ⁸	Eval	33
					No	--	--	--
Junction Box	52	I	30d	Temp. (F)	235	235	Eval	4,2,26
JB 160	page 6			Pr. (Psia)	42	42	↓	↓
JB 161	Item 12			RH (%)	100	100	↓	↓
JB 164				Chem. Rad. (R)	No	--	--	--
JB 166				Sub.	1.3X10 ⁶	Sat	Eval	4,2,26
JB 167					No	--	--	--

Reactor: Big Rock Point Plant		Systematic Evaluation Program										
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment			Qual.	Qual. Method	Reference			
				Parameter	Spec.	Spec.						
Cable Kerite/FR	50 page 6 Item 11	I	30d	Temp. (F)	235		325	Test	9			
				Pr. (Psia)	42		97	↓	↓			
				RH (%)	100		100	--	--			
				Chem. Rad. (R)	No 6 7X10 ⁶		1.2X10 ⁸	Test	9	Note 1		
				Sub.	Yes		Sat	Eval				
Cable Raychem	50 page 9 Item 13	I	30d	Temp. (F)	235		270	Test	11			
				Pr. (Psia)	42		85	↓	↓			
				RH (%)	100		100	--	--			
				Chem. Rad. (R)	No 6 7X10 ⁶		1.0X10 ⁸	Test	11	Note 1		
				Sub.	Yes		Sat	Eval				
Cable Cerro Wire and Cable/FR	50 page 10 Item 2	I	30d	Temp. (F)	235		280	Test	10			
				Pr. (Psia)	42		85	↓	↓			
				RH (%)	100		100	--	--			
				Chem. Rad. (R)	No 6 7X10 ⁶		2X10 ⁸	Test	10	Note 1		
				Sub.	Yes		Sat	Eval				

Systematic Evaluation Program

Reactor: Big Rock Point Plant

Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment		Qual. Method	Reference
				Parameter	Spec.		
Cable Various Vendors	50	I	30d	Temp. (F)	235	Test	3,7
	page 10			Pr. (Psia)	42	↓	↓
	Item 3			RH (%)	100	--	--
				Chem. Rad. (R)	7x10 ⁶	Eval	Note 17
				Sub.	Yes	--	--
Transmitter Flow Barton/386 (224)	49	I	30d	Temp. (F)	235	CofC	2,13
	page 1			Pr. (Psia)	42	↓	↓
	Item 2, 4			RH (%)	100	--	--
				Chem. Rad. (R)	1.3x10 ⁶	Test	13
				Sub.	No.	CofC	13
Pressure Transmitter Foxboro E11GM-HSAE 1	52	I	30d	Temp. (F)	235	CofC	28
	page 5			Pr. (Psia)	42	↓	↓
	Item 8			RH (%)	100	--	--
				Chem. Rad. (R)	1.3x10 ⁶	Test	28
				Sub.	No.	CofC	13
PT-186							

Reactor: Big Rock Point Plant		Systematic Evaluation Program									
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment			Qual.	Reference	Qual. Method	Reference	Qual. Method
				Parameter	Spec.	Qual.					
Pressure Transmitter	52	I	30d	Temp. (F)	235	316	CofC	29	CofC	29	CofC
Rosemount 1152GP	Pg. 10 Item 4			Pr. (Psia)	42	85	↓	↓	↓	↓	↓
				RH (%)	100	100	--	--	--	--	--
PT-1A-079				Chem. (R)	No	--	--	--	--	--	--
				Rad. (R)	1.3X10 ⁶	5X10 ⁶	CofC	29	CofC	29	CofC
				Sub.	No	--	--	--	--	--	--
Level Transmitter Westinghouse 590P4C997050	49 Pg. 8 All	I	30d	Temp. (F)	235	286	Test	31	Test	31	Test
IT-3180 through IT-3187				Pr. (Psia)	42	75	↓	↓	↓	↓	↓
				RH (%)	100	100	--	--	--	--	--
				Chem.	No	--	--	--	--	--	--
				Rad. (R)	1.3X10 ⁶	2X10 ⁸	Test	31	Test	31	Test
				Sub.	No	--	--	--	--	--	--
Switch Jo-Bell Products R232A-2XP(R)	49 Pg. 2 Items 5-8	I	1d	Temp. (F)	235	250	Spec.	2	Spec.	2	Spec.
LS-3562 through LS-3565				Pr. (Psia)	42	45	↓	↓	↓	↓	↓
				RH (%)	100	100	--	--	--	--	--
				Chem. (R)	No	--	--	--	--	--	--
				Rad. (R)	5.9X10 ⁶	Sat	Eval	2	Eval	2	Eval
				Sub.	Yes	Sat	Eval	2	Eval	2	Eval

Reactor: Big Rock Point Plant			Systematic Evaluation Program					
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment Parameter	Environment Spec.	Qual.	Qual. Method	Reference
Switch Rochester Instr.	49 Pg.1 Items 9-12	0	30d	Temp. (F)	90	120	Eval	40 Note 12
FT-215 (T-2)				Pr. (Psia)	15	15	↓	40
FS-2520 through FS-2523				RH (%)	80	80		42 Note 12, 15
				Chem. (R)	No	No	--	--
				Rad. (R)	No	No	--	--
				Sub.	No	No	--	--
							1	
Switch Static-O-Ring 9TA-S411SSX12	52 Pg.3 Items 4-11	I	90m	Temp. (F)	235	250	CofC	23,25,62
				Pr. (Psia)	42	42	Eval	23,62
				RII (%)	100	100	Eval	23,62
				Chem.	No	--		
				Rad. (R)	3.6X10 ⁻⁴	3.6X10 ⁻⁴	Eval	24
				Sub.	No	--	--	--
Switch Static-O-Ring 4MN-E-411-VXSST 12L-AA5-FSS	50 Pg.6 Items 7-10	0	30d	Temp. (F)	100	200	Eval	44 Note 13
				Pr. (Psia)	15	15	↓	↓
				RII (%)	100	100		--
				Chem. (R)	No	--	--	--
				Rad. (R)	No	--	--	--
				Sub.	No	--	--	--
PS-636 PS-637 PS-7064A PS-7064B								

Reactor: Big Rock Point Plant		Systematic Evaluation Program						
Equipment Type	SEP Submittal Reference	Loc	Time Needed	Environment Parameter	Environment Spec.	Qual.	Qual. Method	Reference
Switch	52	I	20m	Temp. (F) Pr. (Psia) RH (%)	235 42 100	270 42 100	↓ ↓	2,16,14,1
IS-RE09A through IS-RE09H				Chem. (R) Rad. Sub.	No 3.6X10 ⁴ No	-- 3.6X10 ⁴ --	Eval -- --	-- -- -- See footnote 7
Indicator Analogic Meas. PI2445/6/2	50 Pg.10 Item 6	0	30d	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	90 15 80 No No No	140 15 95 -- -- --	Cofc ↓ -- -- --	30 ↓ -- -- --
PI-IA05								
Indicator Bailey Meter ROOB (IM) LI-3400	49 Pg.3 Item 2	0	24h	Temp. (F) Pr. (Psia) RH (%) Chem. (R) Rad. Sub.	90 15 80 No No No	140 15 80 -- -- --	Eval ↓ -- -- --	40,41 ↓ -- -- --

Reactor: Big Rock Point Plant		Systematic Evaluation Program									
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment			Qual. Method	Reference	Qual. Method	Reference	Qual. Method
Indicator				Parameter	Spec.	Qual.					
Indicator	49	0	30d	Temp. (F)	90	110	Eval	2	Eval	2	Note 12
Balliey Meter/ S3-F2	Pg. 1 Items 5-8			Pr. (Psia)	15	15	↓	↓	↓	↓	Note 12, 15
				RII (%)	No	80	--	--	--	--	
				Chem. (R)	No	--	--	--	--	--	
FI-2333 through FI-2336				Rad. (R)	No	--	--	--	--	--	
				Sub.	No	--	--	--	--	--	
Indicator	49	6	30d	Temp. (F)	90	122	Eval	54	Eval	54	Note 12
Foxboro/651V0GH	Pg. 6 Item 1			Pr. (Psia)	15	15	↓	↓	↓	↓	Note 12
				RII (%)	80	80	--	--	--	--	
				Chem.	No	--	--	--	--	--	
				Rad. (R)	No	--	--	--	--	--	
PI-412				Sub.	No	--	--	--	--	--	
Indicator	52	0	30d	Temp. (F)	90	132	Eval	48	Eval	48	Note 12
Sigma 9270-22	Pg. 6			Pr. (Psia)	15	15	↓	↓	↓	↓	Note 12
	Items 4, 6			RII (%)	80	80	--	--	--	--	
	Pg. 11			Chem. (R)	No	--	--	--	--	--	
9270-01	Item 5			Rad. (R)	No	--	--	--	--	--	
PIS-173				Sub.	No	--	--	--	--	--	
PIS-187											
PIS-367											

Reactor: Big Rock Point Plant		Systematic Evaluation Program									
Equipment Type	SEP Submittal Reference	Loc	Time Needed	Environment			Qual.	Qual. Method	Reference		
				Parameter	Spec.	Qual.					
Power Supply Barton/291	49	0	30d	Temp. (F)	100	100	Eval	2,38	↓	Note 13	
	Pg.2		Pr. (Psia)	15	15						
	ES-2160 through ES-2163	Items 1-4 Pg.3 Item 3			RH (%)	100	100				Note 13,16
				Chem. (R)	No	--					
				Rad. (R)	No	--					
				Sub.	No	--					
Power Supply Foxboro 610A	49	0	30d	Temp. (F)	90	122	Eval	43		Note 12	
	Pg.6		Pr. (Psia)	15	15						
	ES-2165	Item 2			RH (%)	80	100				Note 12
				Chem.	No	--					
				Rad. (R)	No	--					
				Sub.	No	--					
Power Supply 1 Rosemount SPS-2101P	50	0	30d	Temp. (F)	90	140	CofC	47	47	Note 12	
	Pg.10		Pr. (Psia)	15	15						
	ES-1A80	Item 5			RH (%)	80	80	↓			Note 12,15
				Chem. (R)	No	--					
				Rad. (R)	No	--					
				Sub.	No	--					

Reactor: Big Rock Point Plant			Systematic Eval on Program					
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment			Qual. Method	Reference
				Parameter	Spec.	Qual.		
Power Panel	49	0	30d	Temp. (F)	100	140	Eval	2, 37
TYPE/PL15	Pg. 7 Item 1			Pr. (Psia)	15	15		↓
				RH (%)	100	100	--	--
Panel 3Y				Chem. (R)	No	--	--	Note 13
				Rad. (R)	No	--	--	Note 13
				Sub.	No	--	--	
Differential Pressure Switch	49	0	30d	Temp. (F)	100	200	Eval	39
ITF Barton/289A	Pg. 2 Item 9-11			Pr. (Psia)	15	15	↓	↓
				RH (%)	100	100		Note 13, 16
PDIS-7814 through PDIS-7816				Chem.	No	--		
				Rad. (R)	No	--		
				Sub.	No	--		
Motor Operated Valve	50	0	30d	Temp. (F)	90	235	Test	12, 46
Rotork/14A	Pg. 5 Items 6, 7			Pr. (Psia)	15	42	↓	12, 46
				RH (%)	80	100		12, 46
Limitorque SMA-00				Chem. (R)	No	--	--	--
				Rad. (R)	1.3X10 ⁵	3X10 ⁶	Eval	15
MO-7072				Sub.	No	--	--	--
MO-7066								

Reactor: Big Rock Point Plant		Systematic Evaluation Program					
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment		Qual. Method	Reference
				Parameter	Spec.	Qual.	
Transmitter							
Pressure	52 Pg.6	0	30d	Temp. (F) Pr. (Psia) RH (%)	100 15 100	200 15 100	32 ↓ Note 13
Rosemount 1151GP	Items 3,5 Pg.11 Item 4			Chem. Rad. (R) Sub.	No No No	-- -- --	-- -- --
PI-173 PI-187 PI-174							
Terminal Blocks	52 Pg.10 Item 11	I	30d	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	235 42 100 No 1.3X10 ⁶ No	235 42 100 -- Sat --	14,33 ↓ -- 14,33 --
Crouse Winds FID-222							
Solenoid Valves ASCO/831622 with HVIA 90-441-1A conversion	50 Pg.11 Item 1	I	2m	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	235 42 100 No 1.1X10 ⁵ Yes	240 42 100 -- 2X10 ⁸ Sat	20 20 20 -- 20,63,64 Note.1
SV-NC27 A2A through SV-NC27 F5B							

Reactor: Big Rock Point Plant			Systematic Evaluation Program					
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment		Qual.	Qual. Method	Reference
				Parameter	Spec.			
43 Transmitter Flow	49 Pg 1 Item 3	I	30d	Temp. (F)	235	235	CofC	2,13
Barton/366				Pr. (Psia)	42	42	↓	↓
				RII (%)	100	100	--	--
FT-2162				Chem. Rad. (R)	No	--	Test CofC	13
				Sub.	7X10 ⁶ Yes	Sat		13
44 Solenoid Valve ASCO	52 Pg.11 Items 8-10	I	2m	Temp. (F)	235	235	SIMILARITY	20
B31622 with				Pr. (Psia)	42	42	↓	↓
IWA-90-441-1A Conversion or				RII (%)	100	100	--	--
IWA-90-405-2A conversion				Chem. Rad. (R)	No	No	V.Data	20
BV-NC-22A, B				Sub.	5X10 ⁵ * Yes	Sat	V.Data	20
BV-NC-22F through J								
BV-NC-22C, D								
45 Solenoid Valve ASCO/B30060RF	52 Pg 7 Item 6	I	10m	Temp. (F)	235	340	V.Data	1
BV-4892				Pr. (Psia)	42	42	↓	↓
				RII (%)	100	100	--	--
				Chem. Rad. (R)	No	No	V.Data	1,19
				Sub.	1.5X10 ⁵ No	4X10 ⁶ No	--	--

Reactor: Big Rock Point Plant			Systematic Evaluation Program				
Equipment Type	Submittal Reference	Loc.	Time Needed	Environment Parameter	Environment Spec.	Qual. Method	Reference
46 Switch		I	2m	Temp. (F) Pr. (Psia) RH (%) Chem. (R) Rad. (R) Sub.	235 42 100 No 1.5X10 ⁴ No	270 42 100 -- 3.6X10 ⁴ --	2,16,14,18 ↓ -- 2,16,14,18 --
47 Power Supply	49 Pg. 3 Item 3	0	24hr	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	100 15 100 No No No	100 15 100 -- -- --	2,38 ↓ -- -- --
48 Motor Operated Valve		I	10min	Temp. (F) Pr. (Psia) RH (%) Chem. Rad. (R) Sub.	235 42 100 -- 1.5X10 ⁵ No	235 42 100 -- 3X10 ⁶ --	2,12 ↓ -- 2 --
Limitorque SMA-2-60							
MO-7050							

Reactor: Big Rock Point Plant		Systematic Evaluation Program										
Equipment Type	SEP Submittal Reference	Loc.	Time Needed	Environment			Qual.	Qual. Method	Reference			
				Parameter	Spec.	Qual.						
Transmitter Level Barlon 1386	52	1	304	Temp. (F)	235	235	Cofc	↓	2,13	↓		
	pg 3			Pr. (Psia)	42	42						
LF 3171	Item 1			RII (%)	100	100						
				Chem. (R)	--	--	Test		--			
				Rad. Sub.	4.1X10 ⁶	2X10 ⁸			13			
					--	--			--			

* Radiation dose linearly extrapolated for data in Attachment 1.

Notes

1. If the evaluation or test shows that the cable or splice can withstand 100% relative humidity, and chemical spray, it is assumed that it can withstand submergence as the conditions (wetting of the outside) are similar. It is not likely that the solenoid valves SV-4876, SV-4869 and SV-4891 will become submerged before performing their safety function, however if they do become submerged and fail the system will go to a fail safe condition.
2. The values in the "time needed" column are based on the 0.008ft² break in the primary coolant piping or steam line. For environmental conditions see Reference 34, figure 1. For justification of the actuation times see Reference 24.
3. Values for the specified radiation dose were obtained by combining the data in Reference 35, 36, and 53 with that of Note 2 above.
4. The specified environmental data for equipment outside of containment was derived from References 45, 46, and 53.
5. Reference 49 stated that if the radiation levels were less than 10⁵Rads documentation is not applicable. Reference 53 shows that the radiation levels in the outside containment locations is much less than 10⁵Rads over a 30 day period following a LOCA.
6. The definition of "Qualified by Evaluation" was provided in a May 15, 1975 letter (RESewell to Division of Reactor Licensing) in response to staff questions concerning Special Report No 21, "Investigation of and Correction of Discrepancies Associated With Equipment Required to Operate During a Postulated Loss of Coolant Accident." This definition specified the following:

"The term 'Qualified by Evaluation' says that certain equipment which must function in the LOCA environment was investigated and a judgment made with respect to its ability to withstand the LOCA environment and perform its required function with reasonable assurance.

The equipment so qualified was reviewed to determine:

1. Its location;
2. Its operating principles;
3. Which materials used in its construction are essential to reasonably assure operability;
4. If the essential materials remain functional under postulated LOCA conditions. This was established through one or a combination of the following:
 - a. Standard engineering handbooks,
 - b. Telephone contacts with vendors regarding unusual materials,
 - c. Vendor catalogs and design application data, and
 - d. Where possible, comparison of Big Rock Point equipment to qualified models of current manufacture, and
 - e. Experience.

(No 6 Contd)

Based upon the above information and consistent with the FHSR and the applicable design and equipment specifications at the time of procurement, a judgment was made regarding the ability of the equipment to perform its safety function with reasonable assurance in the LOCA environment."

7. Core spray level and pressure actuation switches are evaluated to withstand radiation levels of at least 3.6×10^4 rad. Attachment 1, Table 1, of Reference 49 lists the integrated absorbed dose after LOCA. Inherent in this table is the concept that release begins (ie, core melt starts) at time $t = 0$. Since the core spray system is obviously designed to operate (the pertinent control functions being accomplished) prior to the beginning of core melt, it is conservative to assume that the need for the level and pressure actuation switches is over well within the first minute of the postulated core melt. Thus, since the radiation dose for submerged components one minute after inception of core release is 3.4×10^4 , it is concluded that the radiation qualification of the core spray level and pressure switches is satisfactory.
8. The existence of cable splices within containment for safety-related systems at Big Rock Point was initially identified and addressed in the Big Rock Point Fire Safety Analysis dated March 29, 1977. At that time, Consumers Power Company committed to modify these splices to ensure their environmental qualification initially for waterproofing and later extended to include LOCA conditions. These splices have been wrapped with waterproof tape (see Reference 60). An evaluation was made (see Reference 61) which demonstrates their ability to remain functional during and after a LOCA.
9. Although the specific type test referenced for the RDS penetration qualification stipulated a maximum temperature of 223°F, an alternate test conducted successfully on similar penetrations provided additional data. The test parameters were: 280°F for 30 minutes, then 220°F for 30 minutes and finally 150°-170°F over the next 1.75 hours with an approximate 24-hour hold period. These test parameters are not fully consistent with the conditions specified in the qualification envelope of Attachment 1; however, in all cases, the test parameters cited above meet or exceed the containment temperature transient predictions for the various coolant pipe break sizes that were considered in constructing the qualification envelope. Thus, it is concluded that the environmental qualification documentation that exists for the RDS penetrations is adequate to ensure their capability to perform as designed.
10. There is approximately 250,000 feet of cabling supplied by Anaconda, Okonite, Plastic Wire and Cable Corp, Rome Cable and General Electric that was part of the initial construction package at Big Rock Point. This wiring is used for both safety-related and nonsafety-related equipment; no wiring segregation or detailed identification has been accomplished or is contemplated. The cables have been tested and shown capable of withstanding LOCA temperatures, although no other type testing has been done. Because of the age of the cabling, it is anticipated that no further documentation will be retrievable.

11. This instrument is located in a room where the normal dose is 10r/hr at power and 350mr/hr at shutdown. The plant is down a minimum of 6 weeks per year so that the average dose is 8.9r/hr which equals 3.1×10^6 r over 40 years. This instrument will also be submerged during a LOCA. The LOCA dose is 7×10^6 . The combination of the LOCA dose and normal dose is less than the dose for which the instrument is qualified.
12. Environmental conditions within the main control room at any time are not expected to exceed 90°F and/or 80% RH. Information found in Reference 46 substantiates this claim.
13. Environmental conditions within the Cable Penetration Room, lay down area and shop during postulated Main Steam piping breaks will result in relative humidity of 100% but no greater than ambient temperatures. It is not expected that these temperatures will exceed 100°F. References 46, 57, and 58 substantiate this claim.
14. The effect of pressure in this case is to force moisture into the cracks possibly resulting in a short. However since it is temperature and radiation qualified the damage will be so minor that a short would not develop.
15. References state that the piece of equipment is rated for 75% relative humidity. It is not expected that the relative humidity in the control room will exceed 75% for any significant length of time, if indeed it ever reaches that value. It is considered that the probability of this occurring at the same time as a LOCA is insignificant. In addition general industrial use of the equipment would indicate that it will function at higher than 75% humidity since such levels are common in unheated or un-air-conditioned areas.
16. This piece of equipment is rated at 80% relative humidity. It is not expected that the relative humidity in these areas will exceed 80% for any significant length of time, if indeed it ever reaches that value. It is considered that the probability of this occurring at the same time as a LOCA is insignificant. In addition, general industrial use of the equipment would indicate that it will function at higher than 80% humidity since such levels are common in unheated or un-air-conditioned areas. The only time when it is known that the humidity will exceed 80% is when there is a steam line break outside of containment. This equipment is not required for outside containment breaks.
17. The cable was rated at 5×10^6 Rads and the splice at 1.0×10^6 Rads because of the materials used in its construction. Reference 37 points out that using FSHR assumptions may reduce the dose by a factor of 2-4. We therefore believe that the uncertainties in the specified radiation envelopes the dose to which these are qualified.

References:

1. DEMoeggenberg, "Containment Isolation Solenoid Valves," BRP-TF-131, April 8, 1975.
2. RESewell, "Responses to Additional Information Requested Regarding the Big Rock Point Plant, Special Report No. 21," BRP-TF-217, May 15, 1975.
3. RBCherba, "Radiation Resistance of Big Rock Control Cable," BRP-TF-204, May 22, 1975.
4. JDWestbrook, "Big Rock Point Task Force Junction Box Qualification," BRP-TF-222, May 29, 1975.
5. MRWade, "Environmental Qualification of Big Rock Point Original Containment Penetrations," February 16, 1978.
6. AMP Engineering Test Report, GPR-575-98, May 14, 1974.
7. Consumers Power Company Research and Testing Laboratory Report I-3-A-75, May 6, 1975.
8. East-West Technology Corp., "Environmental Test Report on TRC Model 72V Type 1, "Y Pattern Solenoid Motor Valve," 798-4, October 22, 1974.
9. Franklin Institute Research Laboratories, Report F-C2737.
10. Franklin Institute Research Laboratories, Report F-C3798.
11. Franklin Institute Research Laboratories, Report F-C4033-1.
12. Franklin Institute Research Laboratories, Report F-C4124.
13. ITT Barton Report, RI-386-2.
14. NUS Test Report, TM-ED-116.
15. RBCherba, "Radiation Evaluation/Qualification of Limitorque and Rotork Motor Operators," BRP-TF-220, May 29, 1975.
16. RO-BRP-78-10.
17. Sandia Laboratories, "Preliminary Data Report-Testing to Evaluate Synergistic Effects from LOCA Environments," Test IX, Frank V. Thome, SAND 78-0718.
18. RBCherba, "Yarway Level Switch Modification" May 20, 1975.
19. Big Rock Point Containment Isolation System, BRP-TF-172.
20. AJDeGrasse, "Reactor Depressurization System Qualification of Isolation Valve Solenoids," C-36690-6, February 17, 1978.
21. WJBeckius/DJVandewalle, "Comment on Big Rock Point Electrical Equipment List for Environmental Qualification - SEP," February 8, 1978.

22. AOBarry, "Qualification Report for Electrical Equipment" June 22, 1976.
23. BRP-TF-251, File page 515321.
24. EJPalmer, "Static "O" Ring Pressure Switches Radiation Qualification," May 23, 1975, BRP-TF-199.
25. JDay, "S Switch Operation versus Temperature," May 14, 1975, BRP-TF-178, 178A.
26. RBCherba, "Big Rock Point Junction Box Recommendations," May 30, 1975, BRP-TF-223.
27. Conax Corp., IPS-73.4, February 15, 1978.
28. Foxboro Company, "Statement of Compliance with Specification I-1," April 28, 1975, BRP-TF-158E, File #516574.
29. Rosemount, Inc., "Quality Certification of Compliance," November 12, 1976.
30. Analogic Corporation, "Certificate of Compliance on Purchase Order 85480," February 9, 1977.
31. Franklin Institute Research Laboratories, Test Report F-C3715, October 1973.
32. Rosemount Product Data Sheet 2260.
33. AOBarry, "Qualification Report for Electrical Equipment," June 22, 1976.
34. DABixel to DKDavis, February 24, 1976.
35. RAEnglish, "Audit of Dose Analysis for Big Rock Point Containment Following Loss of Coolant Accident," May 20, 1975.
36. RWSinderman/WRStrodl, "Big Rock Point Plant - Radiation Dose in Containment Loss of Coolant Accident with Fuel Clad Perforation," February 10, 1975.
37. BRP-TF File 21.1, Post Incident Equipment Review.
38. IIT Barton Drawing D4R-160697, BRP-TF File K2.6, Post Incident Equipment Review.
39. IIT Barton Bulletin 288A/289A-2 and Drawing D4R-162697.
40. WCCooper, "Big Rock Point Plant Instrument Investigation," March 17, 1975, BRP-TF File A.34.
41. Bailey Meter Company General Catalog.
42. BRP-TF File K4.2, Post Incident Equipment Review.
43. BRP-TF File K15.1, Post Incident Equipment Review.

44. BRP-TF File K7.2, Post Incident Equipment Review.
45. Specification for Instrumentation and Supervisory Control Equipment I-1.
46. DEMoeggenberg, "Environmental Conditions Before, During and After LOCA - Big Rock Point Plant," May 23, 1975, BRP-TF File A.30.
47. Rosemount Inc., Certificate of Compliance for P.O. 84333-Q, October 19, 1976.
48. Instruction Manual for Model 9270-20/21/22, Indicating Dual Alarm Instrument.
49. DABixel to Don Davis, "Response to Letter dated December 23, 1977: Environmental Qualification," February 24, 1978.
50. WSSkibitsky to DLZiemann, March 23, 1978.
51. DEMoeggenberg, "Big Rock Point EEO Summary Sheet," September 5, 1978.
52. CJHartman, "Big Rock Point Plant - Update of SEP Tables for Equipment Qualification," October 2, 1978.
53. RWSinderman, "Big Rock Point-Dose Assessment for Post LOCA Direct Shine," January 25, 1978.
54. RBCherba/EJPalmer, "Qualification of Pressure Transmitter Loop PT186," May 21, 1975.
55. Research and Testing Laboratory Report I-8-A-75, Project No. 752008.05 March 27, 1975.
56. Ramsey Electric, Certificate of Compliance on Purchase Order 34490-1601-50.
57. Bechtel Corporation, "Report I-Effect of Compartment Pressurization Due to Pipe System Break Outside Containment," April, 1973.
58. Bechtel Corporation, "Report II - Effect on Safety Related Equipment Due to Pipe System Break Outside Containment " April 25, 1973.
59. Telephone call to AMP Special Industries, Mr. Bister, October 19, 1978 who referenced Report 46 Battelle Memorial Institute, "Effect of Radiation on Electrical Insulation Materials."
60. David A Bixel to D K Davis, "Fire Safety Analyses and Proposed Technical Specifications Change Request," March 29, 1977.
61. RMMarusich, "Qualification of Cable Splices which Were Covered with Waterproofing Tape," October 31, 1978.
62. F Conroy Mechanical Contractors, "Environmental Test for Pressure Switches - Dresden Nuclear Power Plant," November 10, 1972.

- 63. W M Brown, "ASCO Valve Catalog HT831677 - Operational Capabilities at High Ambient Temperatures," June 11, 1976.
- 64. C J Hartman/ D E DeMoor, "Big Rock Point Plant - Comments on SEP Draft, Attached to MARU 2-78," November 3, 1978.
- 65. "Sphere Electrical Penetration Assembly Unit Report E 1 Covering Testing of Typical Sphere Penetrations," Bechtel Corp, July 7, 1978.
- 66. M S Turbak to E G Case (NRC), December 9, 1977.
- 67. R O Aumiller, Amphenol Connector Division to E Barlow, Bechtel Corporation, September 21, 1961.
- 68. Burr Randolph, Bechtel Corporation to W C Cooper, Consumers Power Co., "Coaxial Cable Penetration Units," March 1, 1962.
- 69. R M Marusich, "Radiation Qualification of Amphenol - Borg Coaxial Cable Penetrations Units".

ATTACHMENT 2

Electrical Equipment-Environmental
Qualification and
Requirements

(CPCo updated original submittal)

Tag No.	System	Function	Location			Manufacturer/Model (Type)	Limiting Environmental Qualification Criteria	Environmental Design Qualification					Big Rock Point Sheet 4 of 11 Method of Qualification
			Area	Sub	Room			Pressure Psls	Temperature °F	Humidity %	Radiation	Chemicals	
11-8029A	PIB	Actuate MO-7061 Level Switch Reactor Vessel	C	Yes	418	Yarway/4420C	Environment 1	41.7	270	100	1.5x 10 ⁴ R	NA	<p>Manufacturer's certificate of compliance stating model's ability to comply with CP Co Specification 1-1, specification for instrument and supervisory control equipment, Rev A, 2/11/75.</p> <p>A Model 4416C was tested by MUEB for temperature, pressure and relative humidity. The environmental specifications for Models 4416C and 4420C are identical. There is a minor difference in the operating parameters. Refer to Footnote 2.</p> <p>Ref: 2,16,14,18 See Footnote 7</p>
12-8029B		Actuate MO-7051											
12-8029C		Actuate MO-7061											
12-8029D		Actuate MO-7051											
13-8029E		Actuate MO-7070											
12-8029F		Actuate MO-7071											
13-8029H		Actuate MO-7070											
12-8029H		Actuate MO-7071											
80-7064	PIB	Enclosure Spray Valve Rotork 1/4 Hp	C	No	446	Rotork/14 A Synchronet (125 V D-C)	Environment 1	41.7	235	100	5x10 ⁶ R	NA	<p>Type tested for pressure, temperature, relative humidity and water spray by Franklin Institute. Documented in F-Check report. Radiation qualified by evaluation as documented in internal memo, H B Cherba to file, dated 5/29/75.</p> <p>Ref: 2,12,15</p>
80-7068		Enclosure Backup Spray Valve Limitorque 1/4 Hp				Limitorque/SMA-00 (480 - 3 Ø)							
80-1	PIB	Enclosure Backup Spray Valve GE Reversing Starter	0	No	105	General Electric/CR-106-C0	Normal Environment	14.7	140	100	NA	NA	<p>located in station power room and will experience normal operating ambient conditions. Ref: 2, Note 13,4,5</p>
82-2895	PIB	Enclosure Backup Spray Valve ACB	0	No	105	General Electric TEC 3015	Normal Environment	14.7	50-140	100	NA	NA	<p>located in station power room and will experience normal operating ambient conditions. Ref: 2, Note 13,4,5</p>

Tag No.	System	Function	Location		Manufacturer/Model (Type)	Limiting Environmental Qualification Criteria	Environmental Design Qualification				Chemicals	Method of Qualification
			Area	Sub			Pressure P _{21a}	Temperature T _{21b}	Humidity H _{21c}	Radiation		
80-7051	PIB	Core Spray Valve LimitTorque 1/2 Hp	C	Ro 400	LimitTorque/ SRA-00 (125 V D-C)	Environment 1	41.7	235	100	3x10 ⁶	NA	Refer to 80-7064 for method of qualification. Ref: 2,12,15
80-7061		Core Spray Valve LimitTorque 1/2 Hp	C	Ro 451	Rotork/1/4 A Synchronous (400 V - 3 φ)							
80-7070		Core Backup Spray Valve Rotork 2 Hp	C	Ro 400	Rotork/1/4 A Synchronous (400 V - 3 φ)							
80-7071		Core Backup Spray Valve Rotork 2 Hp	C	Ro 400	Rotork/1/4 A Synchronous (400 V - 3 φ)							
80-7072		Spray Group- Connect Valve Rotork 2 Hp	C	Ro 400	Rotork/1/4 A Synchronous (400 V - 3 φ)	Normal Environment	42	235	100	3x10 ⁶	NA	De-energized and disabled open. Ref: 2,12,15
80-7086		Core Spray Hx Cooling Water Inlet Valve LimitTorque	C	Ro 436	LimitTorque/ SRA-00 (400 V - 3 φ)							Located outside containment and will experience normal ambient operating conditions. Ref: 12,46,45
80-7090	PIB	Core Spray Pressure Transmitter	C	Yes 436	Foshoro EUGR-ROKER	Environment 1	41.7	235	100	1x10 ⁷	NA	Manufacturer's certificate of compliance stating model's ability to comply with CP Co Specification 1-1, specification for Instrument and supervisory control equipment, Rev A, 2/11/75. Ref: 2B
80-7065	CI3	Main Steam Isolation Valve	C	Ro	LimitTorque SRA-2-60	Environment 1	41.7	235	100	3x10 ⁶	NA	Refer to 80-7064 for method of qualification
80-7065	CI3	Main Steam Prin Valve	C	Ro	LimitTorque SRA-0005	Environment-1						Valve disabled in closed position
80-7065	CI3	Main Steam Prin Valve	C	Ro		Environment 1	235	42	100	1x10 ⁶	NA	Ref: 61

Tag No	System	Function	Location			Manufacturer/Model (Type)	Limiting Environmental Qualification Criteria	Environmental Design Qualification					Big Rock Point Sheet 7 of 11 Method of Qualification
			Area	Sub	Room			Pressure Psia	Temperature °F	Humidity %	Radiation	Chemicals	
Panel 3V	PIS	Sphere Instrument and Control Power Panel	0	No	105	IPE/P115	Normal Environment	14.7	50-140	100	NA	NA	Not required. Located in station power room and will experience normal ambient operating conditions. Ref: 2, 37 Note 13
	PIS CIB	Cable Splices for Control Cables	C	No	436	Amp/Certified Wire Connectors #324990 and #324549	Environment 1	42	392	100	1.3x10 ⁶	NA	Qualified by type test for temperature, conducted by GE Co Research and Testing Laboratory. Ref: 55, 61, 30, 59 Note 14 Report No I-B-A75 dated 1/21/75. See Note 8 & 17. Qualified by evaluation for remainder
SV-4079	CIB	Air to CV-4091, CV-4092, CV-4093	C	No	Out- side 426	ASCO/B31620 (3-Way 115 VAC)	Environment 1	41.7	240	100	1x10 ⁶	NA	Same method as used to qualify SV-4091 and memo from plant personnel documenting change Ref: 1, 2, 19, 52
SV-4069		Air to CV-4031	C	Yes	424	ASCO/B30060RF (3-Way 115 VAC) with RVA-90-441-1A	Environment 1	41.7	340	100	4x10 ⁶	NA	Qualified by evaluation as documented in letter D E Hoeggenburg to H B Cherba dated 4/8/75 in response to telephone conversation with manufacturer, and indicated type test results. Ref: 1, 2, 19 Note 1
SV-4094		Air to CV-4025											
SV-4092	ROSI	Air to CV-4049	C	No	Cable Penetration								Ref: 1, 19
SV-4076	CIB	Air to CV-4027	C	Yes	424	ASCO/HTXB300 CG1RF (3-Way 115 VAC)	Environment 1	41.7	415	100	6x10 ⁶	NA	Ref: 1, 2, 19 Note 1 See Note 6

Tag No.	Function	Location		Manufacturer/ Model (TYPE)	Environmental Qualification Criteria	Environmental Design Qualification				Big Back Point Sheet 9 of 11	Method of Qualification
		Area	Room			Pressure Puls	Temperature Y	Humidity	Redu- ction		
1W- 4/230	Reactor Depressure Isolation Valve	C	452	ACECO/11031677 (BETHA K)	Environment 1	41.7	240° Inter- mittent; 220° Continuous	100	2X10 ⁻⁸	NA	Qualified by vendor documentation for pressure, temperature, relative humidity, and radiation. Intermittent defined as up to one hour service at maximum temperature. Ref: 20,61,64, 240 to 1 hour 220° continuous
1W- 4/231	Reactor Depressure Isolation Valve	C	452	TARGET Rock/	Environment 1	41.7	300	100	3.3X10 ⁻⁷	NA	Qualified by Type Test conducted by East-Test Technology Corp as documented in Report #79B-4. Ref: B
1W- 4/232	Reactor Depressure Isolation Valve	C	452	Gamma/104,205	Environment 1	41.7	280	100	2.3X10 ⁻⁷	NA	Qualified by evaluation similar penetration tested to conditions stated Ref: 22,27 See Note 9
1W- 4/233	Reactor Depressure Isolation Valve	C	452	Baychem	Environment 1	41.7	270	100	4x10 ⁻⁸	NA	Qualified by Type Test conducted by Franklin Institute as docu- Note:1 mented in Test Report F-C 4034-1. Ref: 11

Tab. No.	Sketch	Function	Location		Manufacturer/Model (Type)	Limiting Environmental Qualification Efficiencies	Environmental Design Qualification				BIG Back Print Sheet 10 of 11	Method of Qualification
			Area	Room			Pressure	Temperature	Humidity	Vibration		
106	Blue Junction Box		C	You	Metallac-More With Coated Cover Rummy Electrical	Environment 1	63.7	235	100	1K10 ⁰	NA	Qualified by evaluation, based on HEE-TR-ED-116 test report. Radiation qualification strictly by evaluation. Ref: 33
107	Cache for Core Spray Valve Reconnection Box PC-100		C	You	Corro Wire & Cable Co. (YH)	Environment 1	64.7	280	100	3x10 ⁶	NA	Qualified by type test conducted by Franklin Institute Report F-4 379B, March 1974. Ref: 10
108	Cache (Built Feb 1968-1969)		C	You	From Various Sources	Environment 1	62	250	100	7.10 ⁶	NA	Qualified by type test, for temperature only, conducted by CP Co Research and Testing Laboratory. Qualified by evaluation for radiation as documented by letter R B Choebo dated 5/22/75. Refer to Footnote 5-ref: 3,7,36. See Note 10 & 17
109	Reactor Pressure Transmitter		C	You	Boehmann/13538P	Environment 1	64.7	316	100	6x10 ⁶	NA	Qualified by manufacturer's certificate of compliance. Ref: 29
110	Power Source for Reactor Pressure Transmitter Loop		0	No	Boehmann/8P3-2101P	Normal Environment	64.7	140	95		NA	Not required. Located in control room and with experience normal ambient operating conditions. Ref: 47
111	Reactor Pressure Indicator		0	No	Analogic Beam Indicator/PEBk5/0/2							Refer to Footnote 5-ref: 3,7,36. See Note 10 & 17
112	Heat Steam Drum 107" Level Indicator		C	No	Yarsany/4320PE	Environment 1	63.7	270	100	6.6x10 ⁶	NA	Refer to Qualification Methodology for BEP (Page 4). Methodology as described in the HRI test words. Refer to HRP-00P-7B-10 of 2/17/78. Ref: 2,16,14,18
113	Heat Steam Drum 107" Level Indicator											
114	Steam Drum Low Motor Level 20											
115	Steam Drum Low Motor Level 20											
116	HEC Junction Boxes				Grainger Model/490-222 Terminal Box M/GF Terminal Block/38151B6			235	100	5AT	NA	Qualified by evaluation, based on HEE-TR-ED-116 test report. Reference Catalytic Memo from AOBerry to Bibasso, dated 6/22/76. "Qualification Report for Electrical Equipment". Ref: 14,33

Tab's
marked
with
29-3-78
there
BY 4061

Fuel ID	Function	Location		Manufacturer/ Model (Type)	Identifying Qualification Criteria	Environmental Design Qualification				Method of Qualification	
		Area	Room			Pressure Pala	Temperature of Intermittent Continuous	Humidity %	Radia- tion R/h		Chemicals
3W-01 A, B, C, D, E, F, G, H, J	Steam Filter Valves	C	401	ASCO/B31632 With HVA 90- 441-1A Conversion	Environment 1	41.7	240° Intermittent 220° Continuous	100	2x10 ⁶	NA	Refer to Qualification Methodology for 3W-4980 (Page 9). Refer to Footnote 6. Ref: 20, 63, 64 Note 1
4W-01	Continuous Electrical Function	C	436	Bunker/Polled	Environment 1	41.7	274	100	6x10 ⁶	NA	Qualified by evaluation as documented by letter H H Made to M B Bhattaraj dated 1/16/78 (Mada 01-11). Ref: 5, 65, 66 Ref: 67, 68, 69
4W-02	Electrical Function	C	110	Amphenol Bort Electronics Corp/Constant	Environment 1	41.7	-20 to 200	100	1.2 10 ⁷ R	NA	Located outside of containment and with experience normal ambient operating cond. Ref: 32 440000 Ref: 40 Note 12
4W-03	Water Treatment Connections	C	307	Boonmont/ 115, 2015 115, 1 Dipco/9270	Environment 1	41.7	132	80	NA	NA	Qualified by vendor supplied documentation based on engineering test report "Asp 4111-5, 7, 9, 11" conducted by AEP and Franklin Institute Ref: 6
4W-04	Terminal Blocks	C	-	Bluten Block/ BT	Environment 1	41.7	235	100	1x10 ⁶	NA	Qualified by evaluations based on RUS-TH-ED-116 test report. Reference Catalytic Memo from AOSarry to REBasso dated 6/22/76, "Qualification Report for Electrical Equipment". Ref: 14, 33
4W-05	Steam Header Filter Valves	C	401	ASCO/B31632 With HVA 90-441-1A Conversion	Environment 1	41.7	240° Intermittent 220° Continuous	100	1x10 ⁶	NA	Refer to qualification methodology for 3W-4980 (Page 9). Ref: 20
4W-06	Dump Tank Vent Valves	C	401	ASCO HVA 90- 405-2A	Environment 1	41.7	240° Intermittent 220° Continuous	100	1x10 ⁶	NA	Refer to qualification methodology for 3W-4980 (Page 9). Ref: 20
4W-07	Dump Tank Isolation Valves	C	401	ASCO B31632 With HVA 90-441-1A Conversion	Environment 1	41.7	240° Intermittent 220° Continuous	100	1x10 ⁶	NA	Refer to qualification methodology for 3W-4980 (Page 9). Ref: 20

Notes

1. If the evaluation or test shows that the cable or splice can withstand 100% relative humidity, and chemical spray, it is assumed that it can withstand submergence as the conditions (wetting of the outside) are similar. It is not likely that the solenoid valves SV-4876, SV-4869 and SV-4891 will become submerged before performing their safety function, however if they do become submerged and fail the system will go to a fail safe condition.
2. The values in the "time needed" column are based on the 0.008ft² break in the primary coolant piping or steam line. For environmental conditions see Reference 34, figure 1. For justification of the actuation times see Reference 24.
3. Values for the specified radiation dose were obtained by combining the data in Reference 35, 36, and 53 with that of Note 2 above.
4. The specified environmental data for equipment outside of containment was derived from References 45, 46, and 53.
5. Reference 49 stated that if the radiation levels were less than 10⁵Rads documentation is not applicable. Reference 53 shows that the radiation levels in the outside containment locations is much less than 10⁵Rads over a 30 day period following a LOCA.
6. The definition of "Qualified by Evaluation" was provided in a May 15, 1975 letter (RESewell to Division of Reactor Licensing) in response to staff questions concerning Special Report No 21, "Investigation of and Correction of Discrepancies Associated With Equipment Required to Operate During a Postulated Loss of Coolant Accident." This definition specified the following:

"The term 'Qualified by Evaluation' says that certain equipment which must function in the LOCA environment was investigated and a judgment made with respect to its ability to withstand the LOCA environment and perform its required function with reasonable assurance.

The equipment so qualified was reviewed to determine:

1. Its location;
2. Its operating principles;
3. Which materials used in its construction are essential to reasonably assure operability;
4. If the essential materials remain functional under postulated LOCA conditions. This was established through one or a combination of the following:
 - a. Standard engineering handbooks,
 - b. Telephone contacts with vendors regarding unusual materials,
 - c. Vendor catalogs and design application data, and
 - d. Where possible, comparison of Big Rock Point equipment to qualified models of current manufacture, and
 - e. Experience.

(No 6 Contd)

Based upon the above information and consistent with the FHSR and the applicable design and equipment specifications at the time of procurement, a judgment was made regarding the ability of the equipment to perform its safety function with reasonable assurance in the LOCA environment.

7. Core spray level and pressure actuation switches are evaluated to withstand radiation levels of at least 3.6×10^4 rad. Attachment 1, Table 1, of Reference 49 lists the integrated absorbed dose after LOCA. Inherent in this table is the concept that release begins (i.e., core melt started) at time $t = 0$. Since the core spray system is obviously designed to operate (the pertinent control functions being accomplished) prior to the beginning of core melt, it is conservative to assume that the need for the level and pressure actuation switches is over well within the first minute of the postulated core melt. Thus, since the radiation dose for submerged components one minute after inception of core melt is 3.4×10^4 rad, it is concluded that the radiation qualification of the core spray level and pressure switches is satisfactory.
8. The existence of cable splices within containment for safety-related systems at Big Rock Point was initially identified and addressed in the Big Rock Point Fire Safety Analysis dated March 29, 1977. At that time, Consumers Power Company committed to modify these splices to ensure their environmental qualification initially for waterproofing and later extended to include LOCA conditions. These splices have been wrapped with waterproof tape (see Reference 60). An evaluation was made (see Reference 61) which demonstrates their ability to remain functional during and after a LOCA.
9. Although the specific type test referenced for the RDS penetration qualification stipulated a maximum temperature of 223°F , an alternate test conducted successfully on similar penetrations provided additional data. The test parameters were: 280°F for 30 minutes, then 220°F for 30 minutes and finally $150^{\circ}\text{--}170^{\circ}\text{F}$ over the next 1.75 hours with an approximate 24-hour hold period. These test parameters are not fully consistent with the conditions specified in the qualification envelope of Attachment 1; however, in all cases, the test parameters cited above meet or exceed the containment temperature transient predictions for the various coolant pipe break sizes that were considered in constructing the qualification envelope. Thus, it is concluded that the environmental qualification documentation that exists for the RDS penetrations is adequate to ensure their capability to perform as designed.
10. There is approximately 250,000 feet of cabling supplied by Anaconda, Okonite, Plastic Wire and Cable Corp, Rome Cable and General Electric that was part of the initial construction package at Big Rock Point. This wiring is used for both safety-related and nonsafety-related equipment; no wiring segregation or detailed identification has been accomplished or is contemplated. The cables have been tested and shown capable of withstanding LOCA temperatures, although no other type testing has been done. Because of the age of the cabling, it is anticipated that no further documentation will be retrievable.

11. This instrument is located in a room where the normal dose is 10r/hr at power and 350mr/hr at shutdown. The plant is down a minimum of 6 weeks per year so that the average dose is 8.9r/hr which equals 3.1×10^6 r over 40 years. This instrument will also be submerged during a LOCA. The LOCA dose is 7×10^6 . The combination of the LOCA dose and normal dose is less than the dose for which the instrument is qualified.
12. Environmental conditions within the main control room at any time are not expected to exceed 90°F and/or 80% RH. Information found in Reference 46 substantiates this claim.
13. Environmental conditions within the Cable Penetration Room, lay down area and shop during postulated Main Steam piping breaks will result in relative humidity of 100% but no greater than ambient temperatures. It is not expected that these temperatures will exceed 100°F. References 46, 57, and 58 substantiate this claim.
14. The effect of pressure in this case is to force moisture into the cracks possibly resulting in a short. However since it is temperature and radiation qualified the damage will be so minor that a short would not develop.
15. References state that the piece of equipment is rated for 75% relative humidity. It is not expected that the relative humidity in the control room will exceed 75% for any significant length of time, if indeed it ever reaches that value. It is considered that the probability of this occurring at the same time as a LOCA is insignificant. In addition general industrial use of the equipment would indicate that it will function at higher than 75% humidity since such levels are common in unheated or un-air-conditioned areas.
16. This piece of equipment is rated at 80% relative humidity. It is not expected that the relative humidity in these areas will exceed 80% for any significant length of time, if indeed it ever reaches that value. It is considered that the probability of this occurring at the same time as a LOCA is insignificant. In addition, general industrial use of the equipment would indicate that it will function at higher than 80% humidity since such levels are common in unheated or un-air-conditioned areas. The only time when it is known that the humidity will exceed 80% is when there is a steam line break outside of containment. This equipment is not required for outside containment breaks.
17. The cable was rated at 5×10^6 Rads and the splice at 1.0×10^6 Rads because of the materials used in its construction. Reference 37 points out that using FSHR assumptions may reduce the dose by a factor of 2-4. We therefore believe that the uncertainties in the specified radiation envelopes the dose to which these are qualified.

References:

1. DEMoeggenberg, "Containment Isolation Solenoid Valves," BRP-TF-131, April 8, 1975.
2. RESewell, "Responses to Additional Information Requested Regarding the Big Rock Point Plant, Special Report No. 21," BRP-TF-217, May 15, 1975.
3. RECherba, "Radiation Resistance of Big Rock Control Cable," BRP-TF-204, May 22, 1975.
4. JDWestbrook, "Big Rock Point Task Force Junction Box Qualification," BRP-TF-222, May 29, 1975.
5. MEWade, "Environmental Qualification of Big Rock Point Original Containment Penetrations," February 16, 1978.
6. AMP Engineering Test Report, GPR-575-98, May 14, 1974.
7. Consumers Power Company Research and Testing Laboratory Report I-8-A-75, May 6, 1975.
8. East-West Technology Corp., "Environmental Test Report on TRC Model 72V Type 1, "Y Pattern Solenoid Motor Valve," 798-4, October 22, 1974.
9. Franklin Institute Research Laboratories, Report F-C2737.
10. Franklin Institute Research Laboratories, Report F-C3798.
11. Franklin Institute Research Laboratories, Report F-C4033-1.
12. Franklin Institute Research Laboratories, Report F-C4124.
13. IIT Barton Report, RI-386-2.
14. NUS Test Report, TM-ED-116.
15. RECherba, "Radiation Evaluation/Qualification of Limitorque and Rotork Motor Operators," BRP-TF-220, May 29, 1975.
16. RO-BRP-78-10.
17. Sandia Laboratories, "Preliminary Data Report-Testing to Evaluate Synergistic Effects from LOCA Environments," Test IX, Frank V. Thome, SAND 78-0718.
18. RECherba, "Yarway Level Switch Modification" May 20, 1975.
19. Big Rock Point Containment Isolation System, BRP-TF-172.
20. AJDeGrasse, "Reactor Depressurization System Qualification of Isolation Valve Solenoids," C-36690-6, February 17, 1978.
21. WJBeckius/DJVandewalle, "Comment on Big Rock Point Electrical Equipment List for Environmental Qualification - SEP," February 8, 1978.

22. AOBarry, "Qualification Report for Electrical Equipment" June 22, 1976.
23. BRP-TF-251, File page 513321.
24. HJPalmer, "Static "O" Ring Pressure Switches Radiation Qualification," May 23, 1975, BRP-TF-199.
25. JDay, "S Switch Operation versus Temperature," May 14, 1975, BRP-TF-178, 178A.
26. RECherba, "Big Rock Point Junction Box Recommendations," May 30, 1975, BRP-TF-223.
27. Conax Corp., IPS-73.4, February 15, 1978.
28. Foxboro Company, "Statement of Compliance with Specification I-1," April 28, 1975, BRP-TF-158E, File #516574.
29. Rosemount, Inc., "Quality Certification of Compliance," November 12, 1976.
30. Analogic Corporation, "Certificate of Compliance on Purchase Order 85480," February 9, 1977.
31. Franklin Institute Research Laboratories, Test Report F-C3715, October 1973.
32. Rosemount Product Data Sheet 2260.
33. AOBarry, "Qualification Report for Electrical Equipment," June 22, 1976.
34. DABixal to DKDavis, February 24, 1976.
35. RAEnglish, "Audit of Dose Analysis for Big Rock Point Containment Following Loss of Coolant Accident," May 20, 1975.
36. RWSinderman/WFStrodl, "Big Rock Point Plant - Radiation Dose in Containment Loss of Coolant Accident with Fuel Clad Perforation," February 10, 1975.
37. BRP-TF File 21.1, Post Incident Equipment Review.
38. ITT Barton Drawing D4R-160697, BRP-TF File K2.6, Post Incident Equipment Review.
39. ITT Barton Bulletin 288A/289A-2 and Drawing D4R-162697.
40. WCCooper, "Big Rock Point Plant Instrument Investigation," March 17, 1975, BRP-TF File A.34.
41. Bailey Meter Company General Catalog.
42. BRP-TF File K4.2, Post Incident Equipment Review.
43. BRP-TF File K15.1, Post Incident Equipment Review.

44. BRP-TF File K7.2, Post Incident Equipment Review.
45. Specification for Instrumentation and Supervisory Control Equipment I-1.
46. DEWeggenberg, "Environmental Conditions Before, During and After LOCA - Big Rock Point Plant," May 23, 1975, BRP-TF File A.30.
47. Rosemount Inc., Certificate of Compliance for P.O. 84333-Q, October 19, 1976.
48. Instruction Manual for Model 9270-20/21/22, Indicating Dual Alarm Instrument.
49. DABixel to Don Davis, "Response to Letter dated December 23, 1977: Environmental Qualification," February 24, 1978.
50. WSSkibitsky to DLZiemann, March 23, 1978.
51. DEWeggenberg, "Big Rock Point EEQ Summary Sheet," September 5, 1978.
52. CJHartman, "Big Rock Point Plant - Update of SEP Tables for Equipment Qualification," October 2, 1978.
53. RWSinderman, "Big Rock Point-Dose Assessment for Post LOCA Direct Shine," January 25, 1978.
54. RBCherba/HJPalmer, "Qualification of Pressure Transmitter Loop PT186," May 21, 1975.
55. Research and Testing Laboratory Report I-8-A-75, Project No. 752008.05 March 27, 1975.
56. Rumsey Electric, Certificate of Compliance on Purchase Order 34490-1601-50.
57. Bechtel Corporation, "Report I-Effect of Compartment Pressurization Due to Pipe System Break Outside Containment," April, 1973.
58. Bechtel Corporation, "Report II - Effect on Safety Related Equipment Due to Pipe System Break Outside Containment," April 25, 1973.
59. Telephone call to AMP Special Industries, Mr. Eister, October 19, 1978 who referenced Report 46 Battelle Memorial Institute, "Effect of Radiation on Electrical Insulation Materials."
60. David A Bixel to D K Davis, "Fire Safety Analyses and Proposed Technical Specifications Change Request," March 29, 1977.
61. RMMarusich, "Qualification of Cable Splices which Were Covered with Waterproofing Tape," October 31, 1978.
62. F Conroy Mechanical Contractors, "Environmental Test for Pressure Switches - Dresden Nuclear Power Plant," November 10, 1972.

63. W M Brown, "ASCO Valve Catalog HT831677 - Operational Capabilities at High Ambient Temperatures," June 11, 1976.
64. C J Hartman/ D E DeMoor, "Big Rock Point Plant - Comments on SEP Draft, Attached to MARU 2-78," November 3, 1978.
65. "Sphere Electrical Penetration Assembly Unit Report E 1 Covering Testing of Typical Sphere Penetrations," Bechtel Corp, July 7, 1978.
66. M S Turbak to E G Case (NRC), December 9, 1977.
67. R O Aumiller, Amphenol Connector Division to E Barlow, Bechtel Corporation, September 21, 1961.
68. Burr Randolph, Bechtel Corporation to W C Cooper, Consumers Power Co., "Coaxial Cable Penetration Units," March 1, 1962.
69. R M Marusich, "Radiation Qualification of Amphenol - Borg Coaxial Cable Penetrations Units".