

ACRST-1999

ORIGINAL

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards

Title: Subcommittee Meeting on ABB CE Standard
Plant Designs

Docket No.

LOCATION: Bethesda, Maryland

DATE: Tuesday, March 8, 1994

PAGES: 1 - 298

ACRS Office Copy - Retain
for the Life of the Committee

9403150492 940308
PDR ACRS
T-1999 PDR

ANN RILEY & ASSOCIATES, LTD.
1612 K St., N.W., Suite 300
Washington, D.C. 20005
(202) 293-3950

ACRST-1799

ORIGINAL

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards

Title: Subcommittee Meeting on ABB CE Standard
Plant Designs

Docket No.

LOCATION: Bethesda, Maryland

DATE: Tuesday, March 8, 1994

PAGES: 1 - 298

ACRS Office Copy - Retain
for the Life of the Committee

ANN RILEY & ASSOCIATES, LTD.
1612 K St., N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

9403150492 940308
PDR ACRS
T-1999 PDR

0/1

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DATE: March 8, 1994

The contents of this transcript of the proceedings of the United States Nuclear Regulatory Commission's Advisory Committee on Reactor Safeguards, (date) March 8, 1994, as Reported herein, are a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected or edited, and it may contain inaccuracies.

150081

ANN RILEY & ASSOCIATES, Ltd.
Court Reporters
1612 K. Street, N.W., Suite 300
Washington, D. C. 20006
(202) 293-3950

1 NUCLEAR REGULATORY COMMISSION

2 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

3
4 SUBCOMMITTEE MEETING ON ABB CE STANDARD PLANT DESIGNS5
6
7 Nuclear Regulatory Commission

8 7920 Norfolk Avenue

9 Room P-110

10 Bethesda, Maryland

11
12 Tuesday, March 8, 199413
14 8:30 a.m.15
16 ACRS MEMBERS PRESENT:

17 J. CARROLL, CHAIRMAN

18 P. DAVIS

19 C. MICHELSON

20 I. CATTON

21 T. KRESS

22 W. LINDBLAD

23 R. SEALE

24 C. WYLIE

25 D. COE, COGNIZANT ACRS STAFF MEMBER

ANN RILEY & ASSOCIATES, LTD.

Court Reporters

1612 K Street, N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

P R O C E E D I N G S

[8:30 a.m.]

1
2
3 MR. CARROLL: The meeting will now come to order.
4 This is a meeting of the Advisory Subcommittee on the ABB-
5 CE standard plant designs system 80+. I'm Jay Carroll,
6 subcommittee chair. The ACRS members in attendance are Pete
7 Davis, Carlyle Michelson, Ivan Catton, Tom Kress, Bill
8 Lindblad, Bob Seale, and Charile Wylie.

9 MR. COE: Charlie came to the meeting this time.
10 You sure know how to pick meetings to be sick from.

11 MR. WYLIE: That is strategic planning.

12 MR. CARROLL: The purpose of this meeting is for
13 the subcommittee to continue its review of the System 80+
14 standard plant design. Mr. Doug Coe is the cognizant ACRS
15 staff member for the meeting. The rules for participation
16 in today's meeting have been announced as part of the notice
17 of this meeting, previously published in the Federal
18 Register on February 23, 1994, and as modified March 1,
19 1994.

20 MR. FRANOVICH: That means we extended the meeting
21 by one day from the earlier notice. What does that mean?

22 MR. CARROLL: A transcript of the meeting is being
23 kept and will be made available as stated in the Federal
24 Register notice. It is requested that each speaker first
25 identify himself or herself and speak with sufficient

1 clarity and volume so that he or she can be readily heard.
2 We have received no written comments or requests to make
3 oral statements.

4 A couple of items. Doug is progressing with
5 making arrangements for our subcommittee to make a fact-
6 finding visit to Palo Verde on St. Patrick's Day, right?

7 MR. COE: Right.

8 MR. CARROLL: Okay, everybody wear their green. I
9 wanted to -- during today's meeting, we're going to try to -
10 - or today and tomorrow's meeting, we're going to try and
11 cover factors 2, 3 and 19. Originally, we were only going
12 to concern ourselves with the seismic structural aspects of
13 Chapter 2 and 3, but since tomorrow became available to us,
14 the intent is to cover the entirety of those two chapters.
15 I'd like to ask the staff what progress has been made in the
16 finalizing of the chapters that we have looked at at our
17 past meetings so that we can take a look at them in final
18 forms.

19 MR. FRANOVICH: This is Mike Franovich from NRR
20 projects. The FSER was issued by the Commission on the
21 third. The FSER contains no open items and eight
22 confirmatory items. We will need to make arrangements as to
23 how we want to deliver a copy of the FSER to each of the
24 members. I did bring down a courtesy copy for today for
25 references should anyone need to look at a bound copy. I

1 did send an extra copy to Doug Coe yesterday. So, you can
2 assess that later how we want to handle sending each of the
3 members a copy.

4 MR. CARROLL: Why don't we just sent it?

5 MR. FRANOVICH: Well, it's currently in
6 reproduction.

7 MR. CARROLL: Oh, I see. When do you think it
8 will be ready?

9 MR. FRANOVICH: Later this week.

10 MR. ARCHISAL: This is Ralph Archisal from the
11 staff. Just one comment on your question. When things have
12 been through the tech editor and get them to you, the
13 Chapters 8, 9, 11, and 16 that you will get with this
14 version have been through the technical editor and have
15 basically final form content. The rest of the chapters we
16 will have, like you know, we will give you the other
17 chapters, but those chapters will basically be finished.

18 MR. CARROLL: Okay, now, with respect to the
19 chapters you identified as being complete, were there any
20 substantial changes made to them? One of the commitments we
21 have from you is that --

22 MR. ARCHISAL: When there were technical editor
23 comments, they were strictly editorial, no technical content
24 was changed.

25 MR. CARROLL: Okay. We'll do an audit of that and

1 see if we agree with it.

2 MR. ARCHISAL: I should note that the sections for
3 today, Chapters 2, 3, and 19, there were portions that were
4 technically changed, namely 19, in the shutdown risk area.
5 For chapters 3, I believe, and 2, to the best of my
6 knowledge, I don't believe there's been anything technically
7 changed.

8 MR. CARROLL: Well, in 19 there were also some
9 missing pieces.

10 MR. ARCHISAL: Yes.

11 MR. CARROLL: And I assume those have been --

12 MR. ARCHISAL: We tried to fill those holes in the
13 report, draft version.

14 MR. CARROLL: Bill?

15 MR. LINDBLAD: Mr. Chairman, we in the last few
16 weeks have been working with some individual pages dated
17 February '94. Is that what we're talking about? Those were
18 the most recent ones that have been now technically edited
19 and ready to go?

20 MR. CROM: What you've been reading, we still had
21 additional changes and the chapters you've been reading for
22 this meeting have not received technical editor comments
23 yet, so they will be changed again in the future for
24 technical editor comments. Also, the OGC review has not
25 been done yet, and we may get additional changes out of

1 that. I guess our previous arrangement was after the
2 technical area comments were incorporated, we would give you
3 those chapters and noting significant changes. We will
4 still have to do that even for these chapters you're going
5 to hear about today.

6 MR. LINDBLAD: So, to help me in my communications
7 with CE-ABB today, have they seen your drafts?

8 MR. CROM: No, they have not seen a copy of the
9 report.

10 MR. LINDBLAD: Okay, thank you.

11 MR. DAVIS: Mr. Chairman, a quick question. This
12 may come later, but on page 235 of Chapter 19, there's
13 reference made to a new amendment that will be coming out
14 that will update the analysis of the steam generator tube
15 rupture, and will show an increase in risk of about a factor
16 of two. I got a little confused because it looks like
17 that's already been submitted as part of the document that
18 we got at PRA. Do you know what I'm talking about.

19 MR. FRANOVICH: This is Mike Franovich again. I
20 believe you're talking about the design alternatives
21 evaluation which is 19.4. That section, the draft was
22 written with the idea that Amendment U would have contained
23 those changes to the release classes for two ruptures. That
24 was premature and that did not come in Amendment U but will
25 come in Amendment V, but the numbers reflected in the report

1 in the following report are accurate.

2 MR. DAVIS: So, you have another amendment coming?

3 MR. FRANOVICH: That is correct. Amendment B
4 should be coming sometime in the April time frame.

5 MR. CARROLL: Is that expected to be the last
6 amendment?

7 MR. FRANOVICH: I suspect that -- well, ABB is in
8 a better position to answer that, but there will probably
9 have to be an amendment after that to incorporate ACRS
10 comments sometime in June.

11 MR. CARROLL: Does anyone else have any general
12 sort of questions before we move into the chapters?

13 MR. LINDBLAD: Mr. Chairman, as I look over the
14 proposed agenda for today, they appear to be mostly
15 presentations by the applicant. Is the staff going to have
16 a presentation of their review at some point?

17 MR. CARROLL: No, the way we've been doing this,
18 Bill, is Combustion has been making presentations on these
19 topics, and it turns into sort of a free-for-all where we
20 ask questions in combustion or questions of the staff about
21 their FSER during the course of the discussion on the
22 particular chapter. It's not that structured. Somehow it
23 didn't get there.

24 Okay, if nobody else has anything, let's turn it
25 over to Charlie to lead off. Charlie Brinkman?

1 MR. BRINKMAN: Good morning. I'm Charlie
2 Brinkman, director of nuclear systems licensing at ABB
3 Combustion Engineering. I just want to say a couple of
4 words before we get into the technical presentation. I
5 wanted to announce what you already heard, that we did --
6 Dr. Murley signed out the FSER. He signed it out on his
7 last day in office, as a matter of fact, on February 28,
8 which was right on the schedule that the staff had set about
9 a year ago. I want to express publicly our appreciation for
10 the staff's effort, along with the effort by the ABB-CE team
11 which culminated in that. I think it was just a super
12 accomplishment.

13 I want to also express our appreciation for the
14 fact the ACRS is giving us such a focused review to meet the
15 schedule that we're on which the next major milestone after
16 the advance copy of the FSER, is to achieve the final issue
17 of the FSER in June, which means that we need an ACRS letter
18 in June. We are very much appreciative of your effort, and
19 we've attempted to be responsive. We have responded in
20 writing to the questions that were left over from the
21 December meeting and before the February meeting, and we
22 covered many of those, and I understand on today's agenda
23 time is set aside to cover those for Mr. Wylie.

24 Then we've also responded in writing to the
25 questions that were left over from the February meeting

1 prior to this meeting, and I believe there's time on the
2 agenda tomorrow to discuss those.

3 MR. CARROLL: Those responses are in your
4 packages, and as you get time today, you might want to
5 glance through them so that when you get to that on the
6 agenda, you're ready to say whether you agree or disagree
7 and if you have any questions on the responses.

8 [Slide.]

9 MR. BRINKMAN: Despite your remarks about the
10 structure of the meeting, you can see that the staff is here
11 in force to stand by their FSER, and I wanted to let you
12 know that the ABB-CE team is as well. I won't read all
13 these names, but you can see that behind you here, we have a
14 staff of our experts. We hope to be responsive to all of
15 your inquiries today.

16 MR. CARROLL: Now, if it comes down to a vote on
17 some issue, you can't count on those guys.

18 MR. BRINKMAN: Finally here is today's agenda as
19 we see it, and if there's no further questions about that,
20 I'd like to introduce Lyle Gerdes of ABB-CE who has been
21 heading up the structural design of System 80+.

22 MR. GERDES: Thank you. I'm Lyle Gerdes, senior
23 consultant at ABB Combustion Engineering in the mechanical
24 engineering group. I've been with Combustion Engineering
25 for over 20 years, primarily in the area of seismic and

1 structural design. Today I would like to briefly cover some
2 of the site parameters that we've considered, the seismic
3 design, and highlight the structural design efforts.

4 First, some of the site parameters. For external
5 floods, the grade elevation, finish grade elevation for
6 reference is 90 foot, 9 inches. Our maximum ground water
7 level is two feet below grade, and the probable maximum
8 flood level is one foot below grade. Some of the design
9 features that are incorporated in the structural design are
10 concrete construction joints are sealed with water stops,
11 external penetrations below grade are sealed, doors and
12 accesses are at least one foot off grade level.

13 MR. CARROLL: What does that second bullet mean in
14 terms of the pressure rating of the seals? What is assumed
15 in terms of hydrostatic rate?

16 MR. GERDES: The pressure rating of the seals,
17 Todd, do you have an answer on that?

18 MR. OSWALD: This is Todd Oswald with engineering
19 services. The pressure rating of the seals will be for the
20 static head of the water when the penetration enters the
21 structure.

22 MR. CARROLL: So it assumes a flood, an external
23 flood, for example?

24 MR. GERDES: External flood design level is one
25 foot below grade.

1 MR. OSWALD: It's Todd Oswald again. Yes, that
2 does assume that external flood level.

3 MR. MICHELSON: Is that actually said in the word
4 somewhere I can read? Later on if you could tell me where I
5 can read the pressure rating on this.

6 MR. OSWALD: That is not specifically stated.

7 MR. MICHELSON: Doesn't it have to be specifically
8 stated if it's going to be a reality? You can tell us
9 whatever you think, but what it is it really going to be
10 when the COL starts the design?

11 MR. OSWALD: I'll have to review exactly how it is
12 stated.

13 MR. MICHELSON: Did the staff ever check into that
14 to see if they were satisfied with what the SSAR says? We
15 pursued this a long time on APWR, so I thought this would be
16 an immediately available answer.

17 MR. BAGCHI: A slight perimeter is a
18 discriminating factor.

19 MR. MICHELSON: The flood will always be one foot
20 below grade maximum. I don't care what the site is. This
21 is what you are designing for. That sets the hydrostatic
22 pressure of the seal. The only question is there somewhere
23 in the SSAR that says that the seals will be rated for that
24 hydrostatic pressure?

25 MR. BAGCHI: It is not specifically addressed in

1 the SSAR.

2 MR. MICHELSON: Do you think it should be, and if
3 not, why not?

4 MR. BAGCHI: I will take your recommendation and
5 we will look at that.

6 MR. LINDBLAD: Mr. Gertes, your next line you were
7 going to say doors are at least one foot above grade. So
8 certainly you have no tracks leading in and out of the
9 building, is that right? How do you accomplish rails that
10 might be there? Is there a slope that matches?

11 MR. GERDES: Yes, there are slopes. There are no
12 rails leading in below one foot above grade.

13 MR. LINDBLAD: So, what kind of slope is it over
14 the one foot rise?

15 MR. GERDES: I don't have --

16 MR. LINDBLAD: Local, or is grade a general
17 backrow description, or is there a micro-dimension of grade
18 immediately outside the doors and access?

19 MR. OSWALD: This is Todd Oswald of Duke
20 Engineering and Services. It will be a local grade in that
21 area because in general all the way around the plant, we
22 want to keep that one foot elevation as much as possible.
23 It will be a local grade.

24 MR. LINDBLAD: And so there will not be a step at
25 doors and accesses, but there will be a local grade sloping

1 up to the door threshold, is that right?

2 MR. OSWALD: There may be a step at doors and
3 access. Normally you have about a seven inch rise in a
4 step, so there would probably be a step, yes.

5 MR. LINDBLAD: But where do have wheeled vehicles
6 going in and out?

7 MR. OSWALD: There would be a local ramp.

8 MR. LINDBLAD: Thank you.

9 MR. CARROLL: I'm not sure this is the right place
10 to ask this question, but I came across numerous references
11 to a magic plus 70 feet in the context of the divisional
12 separation is solid up to plus 70 feet. I never could quite
13 figure out what was magic about plus 70 feet. I got the
14 sense that that was as high as you could --

15 MR. CROM: This is Tom Crom from Duke Engineering.
16 I've got a presentation later that will address that.

17 MR. CARROLL: All right, thank you. We'll wait
18 for that. Okay.

19 MR. LINDBLAD: I have a question later on
20 precipitation. Is this the right place?

21 MR. GERDES: I believe this would be the right
22 place.

23 MR. LINDBLAD: In your CDM site envelope, you
24 identified that there's a certain maximum precip, but you
25 limit it to roof design. Is there some reason that it's

1 limited to roof design? Are there other places that are
2 designed for less or more maximum precip rates?

3 MR. GERDES: Any area where precipitation would
4 influence the design, it will be designed for this maximum
5 precipitation. The roofs, I believe, are identified
6 specifically because this is where you may have a water
7 buildup.

8 MR. LINDBLAD: So, it's the roof structure as well
9 as drainage from the roof?

10 MR. GERDES: The drainage, yes, is designed for
11 this maximum precipitation.

12 MR. LINDBLAD: And how about the local ground
13 level drainage, storm water drainage? I'm trying to
14 understand why was there a limitation in the site envelope
15 description for roof design.

16 MR. OSWALD: This is Todd Oswald, Duke Engineering
17 Services. That was not intentional just to limit it to just
18 the roof design. Any of your hydrologic issues would have
19 to be addressed with the site drainage system. That's
20 somewhat of a site specific thing, the elevations, et cetera
21 at the site. It was intended to -- I guess that was just
22 addressing the structural issues at that point where you
23 were reading that.

24 MR. LINDBLAD: It was supposed to explain what the
25 relevance was in that particular page rather than to be a

1 limit, is that what you are saying?

2 MR. OSWALD: That is correct.

3 MR. LINDBLAD: Thank you.

4 MR. CARROLL: If you could explain where that
5 probable maximum flood is.

6 MR. GERDES: The probable maximum flood, that is
7 designed or addressed, and I can't recall the specific
8 document.

9 MR. OSWALD: This is Todd Oswald, Duke Engineering
10 and Service. That's an ANSI standard definition. I can't
11 recall exactly what the details of that ANSI standard, how
12 they define it right now. It is a value addressed. I feel
13 it is a large number of years, I cannot recall, 100,000, a
14 very large, 100,000 years or so. It's a very large number.

15 MR. BAGCHI: This is Goutam Bagchi. Our extended
16 review plan, Section 2.4, addressed that, and based on that,
17 the standard review plan was upgraded, and you really have
18 to look at the details of the definition of probable
19 maximum. It is probablistically based, however, it is a
20 physical limit as to how intense the precipitation can be.
21 It is based on that.

22 MR. CARROLL: What happened in the Mississippi
23 Valley envelope? Have you looked at that?

24 MR. GERDES: We have not specifically looked at
25 the floods of the Mississippi Valley and how that would

1 affect it. That would be site specific, the specific
2 location.

3 MR. BAGCHI: That is the reason why we have this.
4 It could be higher in some places.

5 MR. CARROLL: But would the experience in the past
6 year have been enveloped by your standard review plan?

7 MR. BAGCHI: This is B&D, very local intense
8 precipitation. It has not been exceeded last year. At the
9 Cooper site there was flooding, which exceeded the SSAP
10 stated, I believe the one million year flood. It was
11 exceeded.

12 MR. MICHELSON: If you experience the maximum
13 precipitation and there are a number of possible reasons for
14 it not draining, what is the maximum loading before you
15 start getting into an overflow through scuppers or something
16 of that sort? Or do you depend upon the drain to keep the
17 roof from collapsing?

18 MR. OSWALD: This is Todd Oswald, Duke Engineering
19 and Services. The nuclear island structure does not have
20 the parapets or anything to contain the water.

21 MR. MICHELSON: There appears to be a flat roof,
22 then, but there are no parapets?

23 MR. OSWALD: That's correct. Well, there would be
24 a very slight slope to the roof. We'd want to eliminate any
25 ponding.

1 MR. MICHELSON: Okay.

2 MR. LINDBLAD: While we are on that subject, for
3 snow load, you have a curved containment outer shell, is
4 that right?

5 MR. OSWALD: That is correct. The shield building
6 is curved. It is a spherical dome shaped.

7 MR. LINDBLAD: Is it assumed that the snow adheres
8 to the rounded roof of the containment or that it drifts off
9 onto the remainder of the deck of the rounding flat roof?

10 MR. OSWALD: The snow loading, I cannot address
11 that right now.

12 MR. MICHELSON: What ice load do you design for
13 then? What is your ice loading?

14 MR. LINDBLAD: Fifty pounds per square foot. That
15 is the snow load.

16 MR. OSWALD: The snow load was designated as 50
17 pounds, that is correct.

18 MR. MICHELSON: Ice can get extremely thick in
19 some parts of the country, several inches, in fact. This
20 may come within the realms of the 50 pounds per square inch
21 -- per square foot.

22 MR. BAGCHI: This leaves the impression that the
23 roof design has substantial margin. We have looked at the
24 margins. I just wanted to address something about the flood
25 level. Mr. Michelson, you pointed out whether or not there

1 is any requirement about the seal itself. There is not.
2 However, there is a requirement that there be no opening, no
3 opening below that level.

4 MR. MICHELSON: You mean no penetration of the
5 outer walls?

6 MR. BAGCHI: No penetrations.

7 MR. CARROLL: Yes, but I can do that with
8 cellophane.

9 MR. MICHELSON: The opening has to be sealed in
10 concrete.

11 MR. LINDBLAD: Certainly construction joints will
12 be below grade. They will have to be as tight as other
13 places to avoid seepage, and as a practical -- from normal
14 seepage, but certainly the flood, they will have to have a
15 higher design, construction joints for one.

16 MR. CARROLL: Goutan, you just finished saying
17 there were no external penetrations below?

18 MR. BAGCHI: Yes, in Chapter 3.4-2, that's the
19 page number, amendment two, I guess. It says, "No exterior
20 access openings will be lower than one foot above the grade
21 elevation."

22 MR. CARROLL: Access?

23 MR. MICHELSON: What is an access opening?

24 MR. LINDBLAD: A door or a window.

25 MR. CARROLL: Certainly there are piping

1 penetrations into the buildings.

2 MR. BAGCHI: Yes, there will be service water --

3 MR. CARROLL: Those are the seals we are talking
4 about.

5 MR. BAGCHI: It is a level of detail we have not
6 gone into. This is not an unusual construction. It is a
7 normal design for a nuclear power plant.

8 MR. MICHELSON: But you have to put the
9 requirements in. You don't have to put the design in. This
10 is an interface now, and it has to have interface
11 requirements. The requirement is it's got to withstand a
12 hydrostatic pressure.

13 MR. BAGCHI: The important thing is there is no
14 free large open area below the grade. I need to make that
15 point.

16 MR. MICHELSON: You have 30-inch water pipes
17 coming through.

18 MR. BAGCHI: But that's not a 30-inch opening.

19 MR. CARROLL: Okay, let's move ahead.

20 MR. GERDES: When in tornado design --

21 MR. CARROLL: Question. How come I don't find any
22 reference throughout the entire report to hurricanes? Is it
23 enveloped with wind and tornado parameters? We do have
24 hurricanes in the vicinity of nuclear power plants once in
25 awhile. Ask the guys at Turkey Point.

1 MR. BAGCHI: Mr. Carroll, I really have to say
2 that this is based on our regulation. General design
3 criteria addresses tornado, not hurricane necessarily. So,
4 my experience has been that tornado winds envelopes the
5 hurricane winds.

6 MR. CARROLL: Okay. That's fine with me. I was
7 just curious about that.

8 MR. OSWALD: I think that was a PRA assumption
9 also.

10 MR. GERDES: Extreme wind, basic wind speed
11 designed for 100 miles per hour for a tornado. Maximum wind
12 speed of 330 miles per hour, which 260 miles per hour
13 rotational speed, translational velocity of 70 miles per
14 hour.

15 MR. MICHELSON: Excuse me. If you are designing
16 for 330, then why do you even need to mention 110? What am
17 I missing?

18 MR. OSWALD: This is Todd Oswald, Duke Engineering
19 and Services. They have different --

20 MR. LINDBLAD: Stress criteria.

21 MR. OSWALD: The factors --

22 MR. MICHELSON: I'm only trying to relate it to
23 the previous answer that says the hurricane is bounded by
24 the tornado. Then why isn't the 110 bounded by the --

25 MR. OSWALD: Again, the tornado comes into a

1 different load combination.

2 MR. MICHELSON: We'd better talk about hurricanes
3 some more to see how they are handled. They're more than
4 110 miles per hour.

5 MR. BAGCHI: Tornado is not combined with
6 earthquake, but the wind has to be.

7 MR. MICHELSON: You are combining 110 mile an hour
8 wind with an earthquake.

9 MR. BAGCHI: Yes, sir.

10 MR. MICHELSON: What about a hurricane with the
11 earthquake?

12 MR. OSWALD: The hurricane would be combined with
13 a tornado combination.

14 MR. FRANOVICH: It is a coincidence that the
15 translational speed and velocity add up to the maximum one
16 speed?

17 MR. GERDES: No, that is not coincidence.

18 MR. FRANOVICH: That is pretty bad arithmetic
19 because these are dectors instead of the --

20 MR. GERDES: A maximum differential pressure for
21 the tornado is 2.4 psi. The rate of pressure dropped 1.7
22 psi per second, and the mission Spectra tornado -- the
23 missiles are a spectrum of missile -- are in accordance with
24 the standard review plan, Section 3.5.1.4 for missile
25 spectra two.

1 MR. MICHELSON: My big recollection is that we
2 used a three point differential. Has that been changed to
3 3.4 by the staff?

4 MR. BAGCHI: 360 Mile an hour that went with the 3
5 psi.

6 MR. MICHELSON: You dropped it to 330, and you can
7 drop the pressure. Okay.

8 MR. LINDBLAD: Mr. Bagchi, while you are standing
9 there, as I read the SER material in draft, I see a
10 reference to ABB-CE as meeting Reg. Guide 1.76, but it is
11 not clear to me that that is Reg. Guide 1.76 as modified by
12 the letter of March 25, 1988, or without the modification.

13 MR. BAGCHI: Let me say that he's from the staff.
14 The tornado wind speed in Reg. Guide 1.76 is 360. The
15 letter that you referenced was 330. In the SECY 93-87, we
16 accepted 300. ABWR is using 300 miles per hour, and ABB-CE
17 is using 330, which is the letter.

18 MR. LINDBLAD: I'm reading words that say design
19 to effect tornado effects in accordance with the interim
20 staff position in Reg. Guide 1.76, is that correct?

21 MR. SNODDERLY: That is correct. That was a
22 letter that modified the original Reg. Guide 176. So, it
23 started with 360 miles per hour, and then that letter
24 changed to 300, and then the SECY changed it to 300. ABB-
25 CE has the intermediate value of 330. We have accepted, as

1 of SECY 93-87, that it's lower than the 330 miles per hour.

2 MR. LINDBLAD: I understand that, and I'm reading
3 words, and it says, in accordance with Reg. Guide 1.76, and
4 it does not say as modified by the letter.

5 MR. SNODDERLY: It is the interim position is what
6 the letter was. The letter defined an interim position on
7 Reg. Guide 176.

8 MR. LINDBLAD: I suggest you read what you have
9 written here and ask the question.

10 MR. CARROLL: When you do ask the staff about
11 specific words, I think it is helpful to them to tell them
12 page number and paragraph.

13 MR. LINDBLAD: Thank you, Mr. Chairman, I will.

14 [Slide.]

15 MR. GERDES: The design features structures for
16 the wind and tornado, the seismic category one structures
17 are designed for the associated loading. The exterior walls
18 and roof are also designed as tornado missile barrier. The
19 dampers are qualifying due to tornado differential
20 pressures.

21 MR. CARROLL: You say the exterior walls, that
22 includes doorways and so forth in exterior walls?

23 MR. GERDES: Yes.

24 MR. CARROLL: Windows?

25 MR. OSWALD: This is Todd Oswald, Duke Engineering

1 and Services. The doorways would be protected by labyrinths
2 over the interior side.

3 MR. MICHELSON: I was thinking more of the
4 differential, not penetrations by missile, but rather the
5 differential pressure blowing the door out.

6 MR. OSWALD: Yes, the doors would have to be
7 evaluated --

8 MR. MICHELSON: Is it specified somewhere that
9 that is a design requirement, that the doors take the
10 maximum differential on the tornado?

11 MR. OSWALD: Yes, it is specified that the
12 exterior, the roof and the walls, are designed for that.

13 MR. MICHELSON: I found that. I did not find the
14 doors. That's my question. Is it specified that the doors
15 be able to withstand the pressure?

16 MR. OSWALD: It is not specifically stated that
17 the doors will be designed --

18 MR. LINDBLAD: And the ventilation systems.

19 MR. MICHELSON: There are a number of things they
20 didn't say. They just talk about the walls.

21 MR. LINDBLAD: I think we're talking to the wall
22 man.

23 MR. MICHELSON: We're talking to the concrete men,
24 not the ventilation man or the door man and so forth.
25 Clearly before we are done, I would expect to find

1 specifications for this sort of thing. Just a few words.
2 Without it, I have no assurance of how it would be designed.

3 MR. GERDES: It is a requirement that the detailed
4 design meet the site parameters.

5 MR. MICHELSON: We're not questioning the site
6 parameter. We're questioning your design. When you say the
7 walls are designed for it, fine, I accept that. How about
8 the doors, are they designed for it? And there, you remain
9 silent. And any other penetrations, ventilation
10 penetrations and so forth, you just remain silent. I assume
11 they are, and before I'm done, I'm sure they will be, but it
12 is not so as stated yes.

13 MR. PITTEBUSH: We will be glad to add an
14 appropriate sentence.

15 MR. MICHELSON: That's all it takes.

16 MR. CARROLL: What dampers are you talking about
17 in the last bullet?

18 MR. CROM: This is Tom Crom. Basically, the
19 dampers we are talking about are on any of the HVAC intakes,
20 the ductwork and the damper that would be manually closed
21 during a tornado warning would be qualified to the 2.4 psi
22 differential pressure.

23 MR. MICHELSON: In terms of the non-safety
24 ventilation systems where you may shut them down and then
25 they close, well, those dampers meet the differential.

1 MR. CROM: Any of the openings, even if it was
2 non-safety ventilation, if it is required to protect the
3 interior of the building, we'll have dampers and we'll be
4 qualified to 2.4.

5 MR. MICHELSON: It will say somewhere in the essay
6 or before we're done.

7 MR. CROM: I think every one of the NVAC flow
8 diagrams has an indication of where the dampers are. There
9 is a note that says they are qualified for the tornado
10 differential pressure.

11 MR. CARROLL: And you say the tornados in the
12 vicinity, operating procedures will say to close these
13 dampers.

14 MR. CROM: Yes. This is similar to the MacGuire
15 and Catawba sites. So, if you actually have the tornado
16 that is spotted in the line of site, you are required to
17 manually isolate those dampers. You also qualify all of the
18 interior structures for the maximum differential pressure
19 that can be obtained, should the operators fail to isolate,
20 which I believe is at about .5 psi differential pressure.
21 One of the things I like about this design compared to
22 Maguire and Catawba is we don't have any block walls. Block
23 walls are one of the biggest problem of qualification, but
24 this is all concrete reinforced walls, so there is not the
25 problems that we have seen at Maguire in Catawba.

1 MR. MICHELSON: But the problem you unit into is
2 the differentials are such that they become missiles, and
3 then maybe the adjacent safety related equipment. You've
4 got to worry about more than just the walls.

5 MR. CROM: You are correct. The doors would be
6 qualified for the same differential pressure.

7 MR. LINDBLAD: What is the design requirement for
8 structures other than seismic category one?

9 MR. CURTIS: The rad waste building, the turbine
10 generator building are designed for the earthquake in
11 accordance with seismic category one criteria. That in
12 itself will give inherent strength to withstand typical wind
13 speeds if they are made out of reinforced concrete. Is that
14 right? If they are made out of reinforced concrete, and
15 they will be are you saying?

16 MR. OSWALD: This is Todd Oswald, Duke Engineering
17 and Services. The rad waste building will be made out of
18 reinforced concrete. The turbine building is a seismic
19 category two structure which will not be reinforced
20 concrete. It will be a steel frame structure.

21 MR. LINDBLAD: And so will the siding come off in
22 a tornado or not?

23 MR. OSWALD: The siding could come off in a
24 tornado.

25 MR. CARROLL: And end up in the switch year.

1 MR. LINDBLAD: And the diesel generator -- excuse
2 me, you have a combustion gas turbine as well as that,
3 correct?

4 MR. OSWALD: That is correct.

5 MR. LINDBLAD: And is that in a separate
6 structure?

7 MR. OSWALD: It is in a stand alone structure.

8 MR. LINDBLAD: It has dampers with its air intake?
9 Will it be operable in a tornado?

10 MR. STAMM: This is Steve Stamm. The gas turbine
11 is not designed for the tornado. There is no current
12 requirement for it to be designed for a tornado, and
13 therefore, operation is not guaranteed during or immediately
14 after. The building is designed with rugged construction on
15 the order of 100 mile an hour winds. It is an enclosure.
16 If it were to come off, it probably would not actually
17 damage the internals itself. The non-category one buildings
18 that are -- the criteria as far as safety for those
19 buildings is that any potential impact for the failure of
20 those buildings by the design basis, earthquake or tornado
21 will not cause a failure of a category one structure.

22 MR. LINDBLAD: When we were talking about dampers,
23 did I understand that we said that dampers would close
24 during tornados?

25 MR. STAMM: That is for category one buildings but

1 not for non-safety.

2 MR. LINDBLAD: What about for diesel generator air
3 intake?

4 MR. CROM: The dampers on the diesel generator air
5 intake are not closed. The building and the interior
6 structures are designed for the differential pressure.

7 MR. CARROLL: But that is not true of the
8 combustion gas turbine, I take it?

9 MR. OSWALD: That is correct. That is not true of
10 the combustion and gas turbine.

11 MR. GERDES: The combustion gas turbine is a non-
12 seismic category one turbine and structure.

13 [Slide.]

14 MR. GERDES: Missile protection. Primarily, the
15 first step in missile protection is to minimize the source
16 of missiles by equipment design features that prevent the
17 generation of such missiles.

18 MR. CARROLL: How do you do that?

19 MR. GERDES: Rugged design features on valves to
20 keep the operators from becoming missiles.

21 MR. LINDBLAD: But you do not require that the
22 turbine building not have siding, is that correct?

23 MR. GERDES: I did not understand the question.

24 MR. LINDBLAD: When you say minimize, one could
25 interpret that to mean that the turbine generator

1 superstructure should be reinforced concrete.

2 MR. GERDES: The turbine generator building is a
3 non-seismic category one structure. There is no need to
4 preclude that from happening. If there is a missile that
5 occurs due to siding from blowing off, it must be
6 demonstrated that it does not impact a seismic category one
7 function.

8 MR. LINDBLAD: Are you saying this requirement in
9 this first item, it says minimize the sources of missiles
10 only applies to categories? Actually, excuse me, seismic
11 category one buildings?

12 MR. GERDES: Primarily to category one buildings,
13 structures, equipment and systems.

14 MR. LINDBLAD: I would think that the greatest
15 threat to seismic category one buildings would be missiles
16 from non-seismic category one buildings.

17 MR. GERDES: I believe probably just as large of a
18 threat may be from equipment that cannot be secured that may
19 be in the yard, and that is where you get your missile
20 spectra and what you design your structures for.

21 MR. LINDBLAD: Is there a description of this in
22 your submittal that I can look at during the lunch hour?

23 MR. OSWALD: This is Todd Oswald, Duke Engineering
24 and Services. We have identified in Section 3-4 the missile
25 spectra that we are designing for --

1 MR. LINDBLAD: I understand that, but I mean the
2 design rule that you're proposing to minimize.

3 MR. OSWALD: These are in section 3-4 of the CSAR,
4 the items that are on the presentation.

5 MR. GERDES: Better wording there may reduce the
6 potential for the sources of missiles because you cannot
7 necessarily minimize all sources of missiles. There are
8 always other features that can be established or taken, but
9 they would not be cost effective, and that is especially
10 true with non-category one structures and equipment.

11 MR. CARROLL: There has been a long experience in
12 start-up testing of people taking siding off of buildings as
13 a result of testing of the atmospheric dump system, or
14 whatever you call it, on a combustion plant. Have you taken
15 that into account in the design of the siding of the turbine
16 building?

17 MR. GERDES: The turbine building has not been
18 completely designed. We have established some design
19 criteria for that.

20 MR. CROM: This is Tom Crom. I believe you are
21 not talking about safety related. I think you're talking
22 about non-safety. This particular design, all the 55
23 percent bypass goes directly to condenser and not to
24 atmosphere.

25 MR. CARROLL: Oh, that's right on this design.

1 That's right, okay. The only point I would make is that it
2 seems like in every one of those instances, there is
3 something magic about pieces of siding that go up several
4 hundred feet in the air. They want to glide down into your
5 switchyard. I have seen that.

6 MR. GERDES: Along with the minimizing or maybe
7 again reducing the potential for the sources of the
8 missiles, accomplished largely the orient or physically
9 separate potential missile sources away from safety related
10 equipment components to the extent it's practical. The use
11 of protective shields and barriers near the source of
12 potential missiles, and not be reasonably avoided by other
13 methods is hardening of safety related equipment and
14 components to withstand the potential missiles in the areas
15 of the components.

16 [Slide.]

17 MR. GERDES: For internally generated missiles, we
18 have redundant safety systems that are physically separated
19 by divisional walls outside the containment. Missile
20 barriers are used both inside and outside containment were
21 required.

22 MR. MICHELSON: Let me ask you a question on your
23 first bullet. How many systems do you have? Two divisional
24 or four divisional arrangement?

25 MR. GERDES: Two divisional.

1 MR. MICHELSON: It's just two divisional. Okay,
2 so there's one divisional wall --

3 MR. GERDES: One divisional wall, yes.

4 MR. MICHELSON: Because there's another wall
5 showing, but only one divisional wall. So, it's really a
6 two division system.

7 MR. GERDES: That's correct.

8 MR. MICHELSON: Thank you.

9 MR. LINDBLAD: For the benefit of the other
10 members, I was confused as we looked at these missile coils
11 that Mr. Curtis is presenting, I thought we're still on wind
12 and tornado, and he apparently, as I look at the CSAR report,
13 we're talking about all kinds of missiles, and so that's why
14 I was confused on that. Thank you.

15 MR. GERDES: I may have switched gears on you
16 without strict identification. I'm sorry about that. We
17 also identified some of the features on some of the pumps,
18 motors, valves, that helped reduce the potential of missiles
19 and the design of the equipment.

20 [Slide.]

21 MR. GERDES: Pressure vessels, pressure relief
22 devices, the minimize the potential of vessels. Turbine
23 missiles, the probability of less than one time ten to the
24 minus four events per year, by maintenance considerations,
25 inspections over speed protection. Also, the orientation of

1 the turbine generator which later on in my presentation I
2 will identify or show the orientation of the turbine
3 generator building with the nuclear island missile path.

4 MR. CARROLL: On this general subject, I'm looking
5 at the FSAR page 39, and it talks about missiles that are
6 not likely. There is the induction type which are
7 relatively slow speeds, and I don't know what that means,
8 and are not prone to overspeed. Well, of course, they are
9 not, but the device they are driving can certainly drive the
10 motor to overspeed conditions under certain circumstances,
11 backflow through a pump or whatever can do that do you. So,
12 I guess I've seen this staff statement in other places, and
13 I objected to it last time I saw it, probably in ABWR, and I
14 continue to object to it because I don't think it's correct.

15 Also on that page, beginning of the next
16 paragraph, it says ABB-CE states that no missiles were
17 postulated for valves because all valve stems are divided
18 with a back seat or shoulder that is larger than the valve
19 bonnet opening. Is that true of gate valves? That sounds -
20 - is that true of load valves? That sounds like a gate
21 valve sort of statement to me.

22 MR. BORCHARDT: I would have to look at that.

23 MR. CARROLL: Please do, and also someplace else,
24 you were talking about the turbine. I found a fairly
25 positive statement that missiles from the turbine because of

1 orientation cannot cause any damage to safety related
2 equipment, and that simply is not true. The orientation
3 reduced the probability, but it does not eliminate it. I
4 will have to tell you where that statement is. Someplace
5 later on, you have got it right. In one section, you make
6 the flat statement that you cannot have damage from turbine
7 missiles.

8 MR. LINDBLAD: I thought Mr. Gerdes said he was
9 going to deal with the orientation.

10 MR. GERDES: I'll have later on in the structural
11 presentation. Just show me the orientation.

12 MR. CARROLL: I'm sure that's right. Okay, keep
13 going.

14 MR. MICHELSON: On the question of backseating, I
15 have some of the same difficulty because I could not find a
16 requirement that they use backseated valves. It only says
17 well, there is usually a backseated valve and a shoulder,
18 whatever, that's fine, but there's no requirement to use
19 backseated valves.

20 Now, if you put it in as a requirement, then I buy
21 the argument. Otherwise, I don't. Valves can be bought
22 with or without back seats. You can buy them either way.

23 MR. LINDBLAD: I have the impression that what we
24 are listening to are proven engineering design issues that
25 tend to reduce the frequency of missiles rather than

1 eliminate missiles. I do not think they are making a case
2 that the plant does not have to be designed for internally
3 generated missiles.

4 MR. MICHELSON: I was only saying that if you're
5 going to claim the you do not have valve stemmed missiles
6 because you've got back seats, that has to be a design
7 requirements. It is part of your safety evaluation. You
8 evaluated them out because you have backseated valves, but
9 there's no requirement for it.

10 MR. OSWALD: This is Todd Oswald, Duke Engineering
11 and Services. They are evaluated out when they are actually
12 eliminated. In some cases, they are eliminated. You would
13 have to account for that. We are not saying that every
14 valve will -- is not a potential missile hazard. As Mr.
15 Lindblad was saying, we are not eliminating valves.

16 MR. MICHELSON: You're designing a plant today
17 where you do not design it to put in bounding requirements
18 so that the future designer will validate essentially your
19 safety evaluation. You've got to evaluate safety today, not
20 --

21 MR. CARROLL: It sounds like the staff and CE do
22 not agree. The staff's statement is that CE states that no
23 missiles are postulated from valves because all valve stems
24 were provided with a back seat or shoulder. You're saying
25 that it's not true.

1 MR. OSWALD: This is Todd Oswald, Duke Engineering
2 and Services. I will have to see how we have got it stated
3 in there. It sounds like we need to investigate that.

4 MR. MICHELSON: It's only a matter of making it
5 clear. If they are backseated, there is no problem. If
6 they're not, you have to say something, and the staff has to
7 decide it's okay.

8 MR. LINDBLAD: He says back seat and shoulder, and
9 frequently the disk, I think, is what they are crediting as
10 being the shoulder.

11 MR. MICHELSON: Not when you break the stem. You
12 break the stem, it is a missile. It ejects out. If you do
13 not have a -- some people call it a back seat and some
14 people call it a shoulder. I think they're one and the
15 same, but all the experts may tell me I'm wrong.

16 MR. LINDBLAD: I think the case arises when you're
17 looking at relief valves, spring loaded relief valves. Do
18 they or do they not have a back seating? Generally, they
19 don't have a back seat on the spring operated.

20 MR. CARROLL: This says all valves. It does not
21 eliminate --

22 MR. MICHELSON: I found their wording in the SAR
23 fuzzy.

24 MR. LINDBLAD: Could I ask, is it thought that the
25 valve stem is the only source of missiles from a valve, or

1 will bonnet holds be missiles?

2 MR. OSWALD: This is Todd Oswald. There could be
3 the potential for bonnets becoming missiles also.

4 MR. LINDBLAD: Then why are no missiles postulated
5 from valves?

6 MR. CARROLL: I don't think he made that
7 statement. It is the staff.

8 MR. LINDBLAD: I am reading the staff's report.

9 MR. CARROLL: Which Combustion has not even seen.

10 MR. MICHELSON: I thought I had read the
11 combustion portion in Section 3.6 and then another argument
12 as to why there were no bonnet missiles. Go back and read
13 your own stuff. Come back next time and tell us.

14 MR. CARROLL: The staff knows where all of this
15 started, page 339, at the middle of the page.

16 MR. FRANOVICH: Yes, sir, we have noted.

17 MR. LINDBLAD: The combustion materials on 3.5-3.

18 MR. CARROLL: Moving on.

19 MR. GERDES: Externally generated missiles.

20 Again, I believe we have covered that.

21 [Slide.]

22 MR. GERDES: Missiles are a part of the design
23 basis for the category one structures. I don't plan on
24 going into any detail on the radiological dilution factors
25 other than to identify what those factors are for our design.

1 basis. Exclusionary area boundaries, 5/10 of a mile.
2 Population is on two miles, and the dilution factors given
3 for the time periods.

4 MR. LINDBLAD: There was some confusion in my
5 review of the CSAR design specification material as to what
6 the EAB boundary was, a half-mile or 500 meters. Can you
7 clear that up?

8 MR. GERDES: There is a discrepancy, and it is
9 taken to .0 in Section 2-3, I believe. The information in
10 the 2-3 is the correct -- the half mile and the two mile is
11 correct, and what has been used in the Amendment V to Table
12 2.0 will be corrected.

13 MR. CARROLL: How are these dilution factors used?
14

15 MR. GERDES: I'm not an expert in this area. I
16 will turn to Mr. Ritterbush.

17 MR. CATTON: When you specify that dilution
18 factor, are you placing requirements on the site?

19 MR. RITTERBUSH: Yes.

20 MR. CATTON: The site has to have more dilution
21 factor or what? You don't use it, the proposed site?

22 MR. LINDBLAD: The building orientation is also
23 included. The structures are factored into that, the
24 materials, the building weight, you think, correct?

25 MR. RITTERBUS": It depends on the particular Pi

1 over Q and the analysis being formed, but the bottom line is
2 that the parameters have to confirm it.

3 MR. CARROLL: So, if you found a site that did not
4 quite make it, it would require a COL applicant to ask for a
5 change in the rule. Remove his boundaries. This is
6 correct, isn't it? Franovich, this COL applicant will have
7 to seek an exemption and re-analyze for the higher Pi over
8 Q.

9 MR. CARROLL: I see the heading up there. Bill,
10 do you want to make some preliminary remarks about this
11 section? I notice that we have gotten --

12 MR. LINDBLAD: Mr. Gertes is going to cover it,
13 describe it, but I would like to take notice that Mr.
14 Carroll, chairman of the subcommittee did provide to me the
15 minutes of a meeting that was held three years ago, almost
16 to the day, the same materials. So, actually, reviewing
17 some of the material covered three years ago has solved many
18 of my questions that I will be asking questions about, has
19 it changed since three years ago.

20 MR. CARROLL: Let's ask that question right now.

21 MR. GERDES: There are some changes. I will
22 identify that as a go through. I believe the primary change
23 from what I presented three years ago to what I will be
24 presenting today is three years ago, we were only using one
25 control motion at a hypothetical rock outcrop for the basis

1 of the System 80+ design. Since then, we have added two
2 additional emotions. One, regulatory guide 1.6, defined
3 spectral shape, define ant, the ground surface, and also a
4 second spectral shape defined at a hypothetical outcrop, and
5 I will show those shortly.

6 MR. LINDBLAD: I would like for you to make your
7 presentation, but I would like to highlight the issues that
8 have changed in the last three years, and could I ask a
9 question? When we are talking about these projects being
10 designed in the safety category, one area for Part 3-AG,
11 ground acceleration, does that mean that if a flight is
12 selected that is in an area of low seismicity, then the .3 G
13 acceleration will be retained in all of the structures as
14 marginal, or does that mean that the SSE will be something
15 less and will be permitted to perhaps reduce the amount of
16 reinforcing steel in it.

17 The .3 G ground motion will be repaying for the
18 category one structures that have been defined for the
19 design certification. There may be able to use the site
20 specific ground site parameters with that .3 G earthquake.

21 MR. LINDBLAD: Does that apply across the board?

22 MR. GERDES: Not across the board.

23 MR. BAGCHI: Yes, Mr. Lindblad, this is Goutam
24 Bagchi. I just wanted to point out to you that the cinder
25 design offering that contains all of the category one

1 structures, primarily the nuclear island and a few other
2 non-nuclear structures. They are signed for a .3 G. The
3 structure is standard. However, the equipment, piping, all
4 of those things, are laid up on a trial basis, on a sampling
5 basis? Those are subject to changes years in the actual
6 site parameter, whatever will response better. That's what
7 they can use.

8 MR. LINDBLAD: Well, are we saying that the
9 reactor coolant piping as going to be designed for .3 G with
10 the safety reliance problem, not is that what it is?

11 MR. BAGCHI: They have looked at all of the piping
12 inside the containment for a leak before break. They have
13 given us an analysis that envelops all of the site
14 conditions presumably, and they have given us an analysis
15 that envelopes all of the site conditions, presumably
16 covering all of the site characteristics, you have
17 determined that it is feasible to make that design, and I
18 suspect you're right. They can be designed on the basis of
19 site specific response of the building.

20 MR. GERDES: I might bring out, though, that the
21 main loop piping would not change. The requirements for
22 that are primarily due to pressure requirements more than
23 the seismic requirements. So, there would be no reduction
24 in size of main loop at piping.

25 MR. LINDBLAD: I would expect that inquiries would

1 be the area. Why don't you proceed, Mr. Curtis?

2 MR. BAGCHI: Okay. The general seismic design
3 basis for the system 80+ is the select design parameters
4 that would envelope the majority of potential nuclear
5 science. You should both current and anticipated, you would
6 have both current and anticipated regulatory guidance. The
7 envelope of the site conditions -- Lindblad -- would you
8 like to explain on what the participated regulatory guidance
9 has.

10 MR. GERDES: This primarily was from a carryover
11 when we started the program and is one of the reasons that
12 in some of the controlled motions, we have included
13 significant amount of higher frequency content in those
14 control motions than what are in the regulatory Guide 1.60.
15 Since that time, there has been a lot of work in the
16 industry, demonstrating that those high frequency content
17 may not be damaging to either the equipment or structures.
18 That is an area that is believe is being looked at, I
19 believe, both by the staff and industry. We have included
20 additional high frequency content in the design of our
21 structures over and above current regulatory requirements.

22 MR. LINDBLAD: So, as I understand what you're
23 talking about now really applies only to soil structure
24 interaction issues. Is that correct? When you speak of
25 anticipated regulator guidance, you're talking about how

1 vibratory motion is communicated from the soil to the
2 structure.

3 MR. GERDES: The definition of the control motion
4 and how it is then factored into this whole structure
5 interaction analyses and, of course, that affects the
6 response of your structures for equipment component design
7 also.

8 MR. LINDBLAD: But you're not talking about stress
9 criteria and the component design.

10 MR. GERDES: No, at this time I'm not talking
11 about that.

12 MR. CATTON: Your peak ground acceleration, is
13 that in all directions?

14 MR. GERDES: The peak ground acceleration of .3 G,
15 as you will see a little bit later on, our three control
16 motions, the Reg. Guide 1.60 is .3 G, in all three
17 directions. The two control motions that are designed at a
18 hypothetical rock outcrop, the vertical is two-thirds of the
19 horizontal at the hypothetical rock outcrop. When you
20 convolute through the soil layers, though, at the foundation
21 of the structures, the vertical motion is on the equal type
22 magnitude as to what the horizontal is.

23 MR. CARROLL: How would a thermal hydraulic guy
24 know that? Is that because you're from Los Angeles?

25 MR. CATTON: There are some interesting stories

1 about the vertical acceleration. Even though low, it
2 resonates with the automobile. In some cases, the cars
3 literally jumped up the garage door.

4 MR. LINDBLAD: Mr. Gerdes, at some time as you go
5 through this, I will want to talk about soil liquefaction.
6 Do you have a slide on that at some time?

7 MR. GERDES: I do not have a slide on soil
8 liquefaction. Each potential site will have to be evaluated
9 and will have to be demonstrated by the COL applicant, that
10 they do not have the potential for liquefaction at that
11 site. That is a COL item in the SAR.

12 MR. LINDBLAD: Is it identified what criteria will
13 be used to determine satisfaction there?

14 MR. BAGCHI: They would use site specific SSE to
15 determine no liquefaction potential.

16 MR. LINDBLAD: Why is that appropriate, Mr.
17 Bagchi? It effects the nuclear island.

18 MR. BAGCHI: We said that there will be some sites
19 where no liquefaction potential at .3 G is almost impossible
20 to achieve, Southern Florida, for example.

21 MR. LINDBLAD: Is that a good argument from a
22 safety point of view?

23 MR. BAGCHI: From a safety point of view, we have
24 assured no liquefaction potential. Therefore, the structure
25 as built is not subjected to that kind of hazard.

1 MR. LINDBLAD: I'm sorry, I misunderstood what you
2 said previously. What did you say about some sites?

3 MR. BAGCHI: In the FSAR, particularly the site
4 parameter, we make it very clear that no soil liquefaction
5 potential is to be determined based on site specific SSE.

6 MR. LINDBLAD: Which will be equal to our less
7 than .3 G.

8 MR. BAGCHI: 1.5 G in Florida, that is what we
9 would accept.

10 MR. LINDBLAD: And so while the nuclear island is
11 designed for --

12 MR. BAGCHI: Substantial margin to .3 G, and then
13 has been demonstrated to have a margin of another two on top
14 of that.

15 MR. LINDBLAD: But the foundation soil under the
16 structure would not have the same margins.

17 MR. BAGCHI: That is correct.

18 MR. CARROLL: So you are basically saying that
19 South Florida is ruled out for this design?

20 MR. BAGCHI: No, sir, no. I am saying that this
21 design is perfectly acceptable. However, the potential for
22 soil liquefaction would be evaluated on the basis of the
23 site specific earthquake. Remember, not site specific soil
24 properties, but site specific earthquake is the hazard the
25 site has.

1 MR. LINDBLAD: What are you saying, is Florida
2 known for having high ground water elevation, but also a low
3 seismicity, and so the combination of low seismicity and
4 high ground water level might be compensatory.

5 MR. CARROLL: Yes, I've got you.

6 MR. GERDES: One of the areas that I want to
7 briefly cover are the selection of the design control
8 motions that I have referred to. The selection of the soil
9 profiles, the development of the models that we used in the
10 dynamic analysis, the analysis itself, and then the
11 definition of some of the typical input for structural
12 subsystems, equipment design analysis and qualification.

13 [Slide.]

14 MR. GERDES: The control motion definition.
15 Again, this is, as I pointed out before, one of the areas
16 that has changed from the three years ago. The CMS1, 2, and
17 in the next slide I will show 3. What that refers to is our
18 use of the word CMS for control motion spectrum. Three
19 years ago, what I presented was strictly what we now call
20 control motion spectrum 2. Since that time, we've added CMS
21 1, which is U.S. NRC Regulatory Guide 1.60. It is defined
22 at the surface in Freefield plant site. Horizontal peak
23 ground acceleration of .3 G and also vertical peak ground
24 acceleration of .3 G.

25 CMS 2 which I will show shortly is what was

1 presented three years ago, enriched in high frequency
2 content. It is defined at a hypothetical rock outcrop. For
3 those of you who may not be familiar with that term, I also
4 have an overhead that I will show that horizontal peak
5 ground acceleration at the outcrop. The outcrop is .3 of G.
6 The vertical peak ground acceleration is .2 G.

7 [Slide.]

8 MR. GERDES: CMS 3 is based on NUREG CR-0098,
9 spectral shape. It has been enhanced somewhat to include
10 additional high frequency content. It also is defined in a
11 rock outcrop horizontal peak ground acceleration of .3 G,
12 vertical peak ground acceleration of .2 G.

13 MR. LINDBLAD: Mr. Gerdes, these changes going
14 from one control motion to three, do I understand that they
15 are a result of working with the staff on the staff's
16 concerns?

17 MR. GERDES: We have worked with the staff on
18 this. There were concerns, I think, not only by maybe a few
19 members of the staff but also members within the industry
20 that use of a design control motion that only the one
21 control motion that is different from that that has been
22 used, the Regulatory Guide 1.60 shape for all of the newer
23 plants. It may be more difficult to convince some
24 individuals that use of the one control motion at a rock
25 outcrop may or may not cover a similar .3 G reg guide 1.60

1 shape. We worked very closely with the staff in this entire
2 seismic design program.

3 MR. LINDBLAD: So that the refinement over the
4 past year is not to narrow your conservatism but to broaden
5 the envelope of conservatism covering this. Is that what I
6 understand?

7 MR. GERDES: This really has broadened the
8 envelope and it gives us much more confidence that we have a
9 design that can be sited in most any potential nuclear site.
10 Although it is only being certified for sites for .3 G
11 earthquake, as I was told later, the capacity is there, that
12 the same design would be adequate for sites of a much higher
13 ground motion.

14 MR. LINDBLAD: So while that has broadened your
15 commercial attractiveness, it has also introduced additional
16 margin into the safety characteristics, is that correct?

17 MR. GERDES: It may have added some additional
18 margin from a margin on structural design and potential
19 cost. I would say that margin is not that great.

20 MR. LINDBLAD: So probably you are dealing with
21 the same forces within the structure as you had before but
22 you just have a broader soil description.

23 MR. GERDES: That is generally true, yes.

24 MR. LINDBLAD: Thank you.

25 [Slide.]

1 MR. GERDES: Again, in the definition of where
2 these control motions are defined, the CMS 1, which is
3 Regulatory Guide 1.60 is defined and the free field surface
4 for the CMS 2 and CMS 3. We find them as a hypothetical
5 rock outcrop. Those motions actually come out through the
6 soil layers, and this is why I say, when we look at the
7 actual motions as a spectra at the base of the foundation or
8 the surface, even though we apply the motions of the rock
9 outcrop and the vertical at that point of application is
10 two-thirds of the horizontal, then the response, when it
11 comes through the soil at the base mat or the free field,
12 those levels of input that the plant sees are approximately
13 equal in the horizontal and vertical directions for the CMS
14 2 and CMS 3 control motions.

15 MR. CATTON: Maybe you can help me understand a
16 little bit. In Los Angeles when the earthquake took place,
17 a rock outcropping was maybe six or seven miles from the
18 epicenter. That was one of the places that they had the
19 highest accelerations. That was in Tarzana, and a nursery,
20 not kid nursery, but plant nursery, and yet here I see that
21 it is reduced for the rock outcropping.

22 MR. BAGCHI: We will be talking to you and a few
23 other members of your committee about the Tarzana stations
24 recordings and so on. I do have a copy of the CDM reports.
25 It was 1.8 G, 1.2 vertical, as I recall. As I recall, the

1 vertical was still a little lower than the horizontal.

2 MR. CATTON: Those numbers were almost the highest
3 I found in the San Fernando Valley.

4 MR. BAGCHI: Yes, it was the best experiment that
5 one could ever imagine to get their hands on.

6 MR. CATTON: It was quite a ways away, in between
7 the accelerations for lower. Anyway, we're going to talk
8 about it.

9 MR. LINDBLAD: Can I ask you a question about the
10 slide that you had there? Right where your fingers are?

11 MR. GERDES: Sure.

12 MR. LINDBLAD: Right where your fingers are, the
13 left-hand side of the figure, you used the word P-wave and
14 vertical analysis. I'm sorry, is the vertical analysis
15 limited to just -- I understand P-wave to be a
16 characteristic of the original seismic effort, but it
17 doesn't shared ware motions introduce a vertical component?

18 MR. GERDES: I will let Scott's office address
19 that. He can do a better job of that than I can.

20 MR. BORCHARDT: In the horizontal motion analysis,
21 the P-wave vertically propagating has been assumed in the
22 soil analysis. In an additional study with heat lines, they
23 produced both horizontal and vertical motion. It has been
24 conducted and shown that the response spectra are not
25 different, not much different than the spectra when the

1 vertical propagating SP-wave assumption has been used. The
2 vertical propagation for SP-waves is pretty commonly done in
3 the industry to come up with the surface motion.

4 MR. LINDBLAD: I was surprised to see the word P-
5 wave on the figure. How does the P-wave enter into the soil
6 structure interaction?

7 MR. BAGCHI: For the convolution of the rock
8 outcrop motion to the surface, a P-wave is used because it
9 has different characteristics than the SV-wave, and that is
10 also vertically propagating from the rock outcrop to the top
11 of the surface.

12 MR. LINDBLAD: Thank you.

13 [Slide.]

14 MR. GERDES: This is an overview of the three
15 control motions. The CMS 1, we find at the free field
16 service. CMS 2, which was the control motion that we used,
17 which I presented three years ago. You can see it as
18 greatly enhanced in the higher frequency content. CMS 3,
19 also defined at the rock outcrop, which in the lower
20 frequency range is identical to NUREG 0098. There is
21 additional high frequency content that we have included
22 above 8 or 9 Hertz, above the 0098 requirements.

23 MR. LINDBLAD: Mr. Gertes, later as we talk about
24 activities of an operating plant or if a possible OBD
25 experience operating basis earthquake experience, there is a

1 reference to a CAV value, absolute velocity factor of 1.6.
2 Can you tell me roughly what the plant is designed for
3 compared to a CAV value of .16?

4 MR. CARROLL: And before that, tell me what CAV
5 value is because I flagged it.

6 MR. BAGCHI: I believe we have members of the
7 audience that have a better definition.

8 MR. KENNEDY: Several years ago, industry threw
9 EPRI -- attempted to find out if there was any single ground
10 motion characteristic that could correlate best with damage
11 to engineered structures, and by that, I mean structures
12 that, do you have a lateral load carrying system, sheer
13 walls, brace frame and anchored equipment. It was found
14 that there were several candidates that seemed to work best.
15 Peak ground acceleration didn't work very well. Spectral
16 acceleration in the two to 10 Hertz range worked pretty
17 well. A term called areas intensity which is just the
18 integration of acceleration BT over the full duration of the
19 time history worked pretty well. It was found the one that
20 worked best was the one we have following the CAV,
21 cumulative absolute velocity. It's simply the integral of
22 acceleration, absolute value of acceleration BT. That just
23 keeps adding up velocity, and so it keeps accumulating
24 velocity. It's purely an empirical study that shows that
25 that worked. It has a reasonable descriptor of the onset of

1 damage to engineering facilities and anchored equipment,
2 even though that equipment did not have seismic design.

3 MR. LINBLAD: Were you going to respond to my
4 question, as to what the design control motions have in the
5 way of CAV value?

6 MR. KENNEDY: Basically, they have CAV values very
7 much above this threshold value. I am not sure we ever
8 bothered even calculating what they have. They would be at
9 least two or three times this controlled one. The reason
10 why the CAV is used as a descriptor from a damage standpoint
11 is, we have found that low magnitude earthquakes like a
12 magnitude four earthquake can have very high acceleration
13 for very short durations. The very short duration just
14 doesn't create damage.

15 The time histories being used for the evaluation
16 of CE System 80 have long durations. I don't know, do you
17 have a viewgraph that shows the time histories?

18 MR. BAGCHI: I believe I do.

19 MR. KENNEDY: They are durations of strong ground
20 motion, in the neighborhood of ten seconds. This CAV value
21 was used to eliminate from consideration ground motions with
22 durations of less than one to two seconds. They will have a
23 much lower cumulative absolute velocity that would be
24 integrated over the time. They just don't build up to
25 shorter time.

1 This one will have a very much larger CAV than
2 those CAV limits. I don't know the number.

3 MR. BAGCHI: I just want reinforce Dr. Kennedy's
4 statement. Recall please, that the OBE value for this plant
5 is 1.0G and the CAV value of .16 will be one of the
6 discriminators. The other one would be the spector of
7 acceleration of two to ten hertz that has to be less than
8 .2G.

9 I believe that with respect to the CAV value of
10 1.6G second this plant would have the capability of at least
11 three times that for the SSE.

12 MR. LINBLAD: Thank you.

13 MR. CARROLL: As an aside, when the technical
14 editor goes through this will he pick up things like all of
15 a sudden we start talking about CAV values on page 318, with
16 no explanation as to what it means?

17 MR. FRANOVICH: That is the responsibility of the
18 project manager. When we get comments back from the
19 technical editor and as we go through those comments, we
20 will also be looking for technical continuity.

21 MR. CARROLL: You would agree with me, that some
22 explanation of what a CAV value is should be provided?

23 MR. FRANOVICH: I would agree with that.

24 MR. CARROLL: The next item on page 318 the
25 reference is made to the CAM shall be determined in

1 accordance with EPRI report such and such. Is that a typo?
2 Should that have been CAV?

3 MR. TERAD: That should be CAV.

4 MR. DAVIS: You thought that we had switched
5 constant air monitors?

6 MR. CARROLL: I never have understood this seismic
7 stuff.

8 [Slides.]

9 MR. GERDES: The next overhead I have is identical
10 to what I presented three years ago. It basically
11 identifies with the generation the control motion spector of
12 two, the lower frequency range we based our shape on NUREG
13 0098 for 24 inches per second per G velocity. We also
14 looked at and evaluated some information that was available
15 at that time for estimated spectral content for Eastern
16 North America, knowing the fact that there was effort to
17 identify some of this high frequency content that was non-
18 damaging to structures and equipment and believing that, and
19 knowing the fact that if we took into account all of that
20 high frequency content, we would have to greatly enhance the
21 models that we used to really respond to those high
22 frequencies which we did not believe were appropriate for
23 design.

24 We decided to follow the NUREG 0098 shape in the
25 lower area and pick up a large portion of that high

1 frequency content say, in the ten to 25 hertz region, and
2 then come down to the EPA value. This is identical to what
3 I presented three years ago.

4 The spectral shape for the horizontal by itself,
5 CMS2 vertical component again defined at the hypothetical
6 rock outcrop, is two-thirds of the horizontal.

7 [Slides.]

8 MR. GERDES: I will just go through these very
9 quickly. All of the spectral shapes for all three control
10 motions and also the spectra generated from the artificial
11 ground motions that were used in the design are shown in the
12 SAR. I just show a few of these in the overheads.

13 Also, the power spectral densities of all three
14 control motions were generated and are included in the SAR
15 material. I have shown here only the correlation of the
16 power spectral density for the CMS1, the Reg Guide 1.606
17 with the target spectral which is provided in the Standard
18 Review plan Section 371, Appendix A.

19 MR. CARROLL: This is a probably a good time,
20 before we get into the soil, to take our mid-morning break,
21 isn't it?

22 MR. GERDES: Okay, that's fine.

23 MR. CARROLL: Let's return at 10:20.

24 [Brief recess.]

25 MR. CARROLL: Let's reconvene. Even though we

1 have a formidable pile of stuff here, I have been assured
2 that we can get through it in a big hurry, right?

3 MR. GERDES: I will, if I am not stopped. The
4 material that I will be presenting next was given three
5 years ago with little or no change. The generic soil sites
6 that were considered, we looked at categories that we
7 divided into A, B, C and D.

8 Category A, actually we have soil on the sides.
9 The nuclear island is bounded right on the bed rock. We
10 also looked at soil conditions where the rock was 100, 200,
11 300 feet below the soil surface.

12 I will just show one or two of the actual assigned
13 shield wave velocities. This is case one, where the plant
14 is bounded on the rock with soil on the sides. Sheer wave
15 velocity varying from about 1,800 feet per second to 2,200
16 feet per second. The rock itself is assumed to be 5,000
17 feet per second.

18 We selected the soil profiles to try to cover and
19 envelope potential site conditions. In doing so, we looked
20 at various site conditions, layering, so we could get
21 significant impedance mismatches. We actually did obtain a
22 lot of amplification as the motions were propagated through
23 the soil layers. The actual soil profiles were selected
24 when we were looking only at the CMS2 control motion. We
25 compared then, the outer surface spectra with not only the

1 spectral shape of the control motion at the hypothetical
2 outcrop but also with the Regulatory Guide 1.60 spectral
3 shape which is defined at the free field.

4 If you look at later at your leisure the different
5 soil profiles, the numbering, some of them you will see
6 numbered like 3.5 or 1.5. The point five's come in because
7 from the original set of soil profiles we looked at the
8 spectra at the free field and compared them with the control
9 motion and the Reg Guide 1.60 spectra in areas where we
10 thought we had holes in there that we maybe did not have
11 appropriate soil profile to get amplification that would
12 challenge the structure equipment in those frequency ranges.
13 We went back and added some soil profiles.

14 As you can see, the range of the soil -- the
15 spectra at the free field from the use of control motion,
16 CMS2 as a rock outcrop, provides amplifications and soil
17 motions at the free field surface much greater than the
18 Regulatory Guide 1.60 and/or the control motion that was
19 defined at the outcrop.

20 It also showed the ground motion envelope of
21 spectra at the ground surface from the CMS3. Primarily I
22 wanted to show this because we added CMS3 control motion.
23 One of the reasons we added it was primarily to pick up some
24 additional low frequency content and amplification, although
25 there is very few structures or components that really have

1 that low a frequency content. There are some. We wanted to
2 make sure that our overall design envelope adequately
3 covered the low frequency range.

4 [Slides.]

5 MR. GERDES: The next two spectra shapes are
6 actually just an envelope then of the free field surface
7 spectra at the site location which, again, based on spectral
8 that I showed just previously, are much greater than the Reg
9 Guide 1.60 requirement by itself. I might add, this is
10 really a lower bound envelope of spectra. If you are
11 looking at spectra within a structure that you use for
12 qualification of equipment you take an upper bound so that
13 you envelope all of the spectra for qualification of
14 equipment.

15 This is really a lower bound such that if you look
16 at the spectra shape from all of the motions that we looked
17 at they actually envelope above. Similarly, the vertical
18 direction.

19 MR. CARROLL: So, what does this tell me about Reg
20 Guide 1.60, that it is not conservative?

21 MR. GERDES: No, I would not say it is not
22 conservative. I would say it is a spectral shape that is
23 refined with a broad range of amplifications across a broad
24 band. When you apply the other control motions at the rock
25 outcrop and propagate them through each of the soil

1 conditions, you get larger amplifications at specific
2 frequencies that relate to those soil properties, as would
3 occur in any real plant site.

4 I would not say that Reg Guide 1.60 is not
5 conservative. In fact, I would say Regulatory Guide 1.60 is
6 still a conservative design. Any specific earthquake is not
7 going to have frequency content across that entire band.

8 [Slides.]

9 MR. GERDES: For the site conditions that we
10 looked at then, although this has been chopped out,
11 adequately covered shear soils with shear wave velocity from
12 as low as 500 feet per second and upward, we chopped it off
13 at 3,500 feet per second. Actually, if you look at the
14 profiles we assumed 5,000 feet per second in our evaluation.
15 This is not a limit here. It extends both down and to the
16 right.

17 Just so you do not believe that there is an
18 inconsistency between our shear wave velocity that we are
19 showing here and shear wave velocity that was shown in the
20 site parameters in Table 2.0, we identify a best estimate
21 minimum shear wave velocity of 700 feet per second for our
22 seismic analyses to account for variation in soil properties
23 and uncertainties in our analyses. We have included cases
24 as low as 500 feet per second.

25 [Slides.]

1 MR. GERDES: Again, the next two overheads that I
2 have, I presented three years ago showing variation of shear
3 range of properties that were presented by Seed and Idriss,
4 and the conservative relationship selected for this project.
5 If you have any specific questions on these Dr. Idriss is
6 here, present, for any detail.

7 MR. LINBLAD: It would be a shame not to use him.

8 MR. GERDES: Variation of damping ratio is the
9 same way. The range that was published, we used the lower
10 value as a conservative bound in our analyses.

11 [Slides.]

12 MR. GERDES: The next information that I
13 presented three years ago, the model development, the
14 individual stick models that were used for various portions
15 of the structure actually were developed initially finite
16 element models were prepared for the structure for floor by
17 floor bases. Properties for each floor level were
18 determined, and then using those we developed stick models.
19 This happens to be the stick model for the internal
20 structure.

21 Similarly in your package there is a stick model
22 for the shield building. For the steel containment we could
23 not adequately obtain, or at least in our mind we could not
24 adequately get both frequency and mode shape captured in a
25 stick model. We actually used what looks like a fairly

1 detailed but yet a relatively crude finite element model, so
2 that we got better representation of the containment shell.

3 Likewise, to account for interaction effects
4 between the major components of the reactor coolant system
5 and the internal structure, both from a mass and a stiffness
6 effect, we included a simplified representation of the
7 reactor coolant system in our model, steam generators,
8 interconnected hot leg piping, 42 inch piping, very stiff
9 reactor vessel modeled into the structural model that was
10 used in the soil structure interaction analyses.

11 MR. CARROLL: The people who were developing these
12 models were given the right drawings? There is no image
13 problems here?

14 MR. GERDES: No, they were the right drawings. A
15 schematic representation of the nuclear island model -- and
16 I point out, this is just a schematic representation, the
17 soil structure and interaction analysis -- we have the
18 layered soil media. We have the representative stick models
19 of the shield building, the internal structure steel
20 containment vessel and NSSS. Also, representations on the
21 other structure portions of the nuclear island which we
22 called the annex building, which I will show later on in
23 more detail.

24 These are just two representative sticks shown in
25 the schematic representation.

1 MR. DAVIS: Excuse me. I noticed in the previous
2 slide you do not seem to have the pressure represented. Is
3 that a non-factor in these analyses?

4 MR. GERDES: The mass is represented in the
5 structure from a structural aspect, the soil structure
6 response aspect. The stiffness effects have no real effect
7 on the response of the structure. The mass of the
8 pressurizer is included, the same as the mass of the reactor
9 coolant pumps, are included in the models.

10 MR. CATTON: How well do you have to characterize
11 the soil media to do an analysis like that?

12 MR. GERDES: You mean, the specific layering and
13 depth of layers in the soil structure interaction analysis?

14 MR. CATTON: I guess you have to do an analysis
15 like that, and you have to know the soil compressibility.

16 MR. DERMITZAKIS: As far as characterizing the
17 layers, thicknesses vary from two and one-half feet to about
18 ten feet per layer and there are multiple layers, depending
19 on the depth of the site from surface to bed rock.

20 MR. CATTON: What do you do? Do you input the
21 characteristics into the analysis?

22 MR. DERMITZAKIS: It's mass density, vertical
23 velocity, horizontal velocity and material damping.

24 MR. CATTON: What do you do if one of these layers
25 is in there at an angle?

1 MR. BAGCHI: I think you did not get a
2 satisfactory answer to your question. It is a generic
3 design. There is no site. You have to rely on parametric
4 variation, what causes changes in the structural forces in
5 moments and things like that, and full response. Those were
6 looked at very carefully by the staff.

7 The representation of the soil is important. But
8 looking at what kinds of variations of different kinds of
9 layers and their properties is important to the structural
10 response. That is what guided their analysis and
11 consideration of different kinds of soil conditions.

12 MR. CATTON: My question wasn't that specific. I
13 was trying to understand how they do the calculations.

14 MR. BAGCHI: This is a generic site, generic
15 basis.

16 MR. CATTON: You have to make some assumptions
17 then?

18 MR. BAGCHI: Yes, sir.

19 MR. CATTON: Do they assume it's uniform?

20 MR. BAGCHI: They are assumed to be uniform.

21 MR. CATTON: Now, if this is anything like
22 acoustics, there's a possibility of focusing. Do they worry
23 about that or do you just put in a factor, or what?

24 MR. BAGCHI: Focusing would be related to the site
25 aspect, not just under the area under the foundation itself.

1 It is defined in terms of the hazard for the site.

2 MR. CATTON: I understand that. I am just trying
3 to get a picture of how they do it. When somebody comes in
4 and is going to build a plant, are there going to be certain
5 requirements in what they do to evaluate the goodness or
6 badness of the model?

7 MR. BAGCHI: Absolutely. That is site specific.
8 Not goodness of the model.

9 MR. CATTON: But the fact that the modeling is
10 done with a uniform soil characteristic in some depth of the
11 rock, are they going to make sure that whatever was done is
12 adequate by doing --

13 MR. BAGCHI: There is a detailed flow chart that
14 says how the site specific site has to be found acceptable.
15 Maybe Lyle could give you that.

16 MR. GERDES: Also, for the models that I showed
17 were for the nuclear island which of course is the most
18 detailed dynamic model. Also, for other category one
19 structures the diesel fuel storage structure component
20 cooling water structure which are in the vicinity of the
21 nuclear island, we used two-dimensional models that we could
22 capture and account for the interaction of the nuclear
23 island to the soil to the other category one structures.

24 So that, the response of the other category one
25 structures do account for the interaction affects from the

1 nuclear island.

2 MR. CARROLL: You jogged my memory when you
3 mentioned diesel fuel oil storage. Where is the oil for the
4 gas turbine stored? Is that in the same storage or
5 different

6 MR. GERDES: That is in a separate storage that
7 would be in the vicinity of the gas turbine building.

8 MR. CARROLL: What is its seismic requirements?

9 MR. GERDES: I cannot answer if we have identified
10 specific seismic requirements for that.

11 MR. LINBLAD: Is it buried or above ground, which?

12 MR. CARROLL: I think it is buried.

13 MR. LINBLAD: Then liquefaction is a bigger
14 problem than anything else. Don't worry about it if it is
15 buried.

16 MR. GERDES: I believe we will have to get back to
17 you on that question.

18 [Slides.]

19 MR. GERDES: In the dynamic analysis soil
20 structure interaction analysis the computer program used was
21 the SASSI computer program. Again, that is a state of the
22 art soil structure interaction analysis code. To the best
23 of my knowledge it is the soil structure interaction code
24 that is being used by all three vendors for advanced nuclear
25 design.

1 MR. CATTON: Is the diesel storage above ground?

2 MR. GERDES: The diesel fuel storage structure is
3 essentially below ground.

4 MR. MICHELSON: Below ground?

5 MR. CROM: It is a sunken building. Seventeen
6 feet is the base.

7 MR. MICHELSON: A sunken grade building.

8 MR. CROM: The mat of the building is 17 feet
9 below grade.

10 MR. MICHELSON: Is it completely covered with
11 dirt, the building, the structure?

12 MR. CROM: No, the building comes up.

13 MR. MICHELSON: A hole in the ground, and you put
14 the building in the hole. You do not berm it back up again.

15 MR. CROM: Yes. In other words, it is regraded.
16 We don't just leave a trench around the building.

17 MR. MICHELSON: Is it completely covered when you
18 are done?

19 MR. CROM: The building comes up above the grade
20 level.

21 MR. MICHELSON: How far?

22 MR. CROM: I will have to look at the dimensions.
23 It's in the SAR.

24 MR. MICHELSON: I didn't find it on the site plan.

25 MR. GERDES: I may have figures later on in the

1 presentation that deals essentially with what those
2 distances are.

3 MR. CARROLL: I just opened to it. You have not
4 numbered your figures. I cannot tell Carl where to go.

5 MR. MICHELSON: I am looking at Volume 1.

6 MR. CARROLL: I am looking at a figure in the
7 package.

8 MR. GERDES: I will get you that figure later,
9 unless you have a specific question on it for this portion
10 of the presentation.

11 MR. CATTON: It looks like it's all concrete, too.

12

13 MR. GERDES: Yes.

14 MR. LINBLAD: Yes, it is.

15 MR. CARROLL: Let's move on.

16 [Slides.]

17 MR. GERDES: Again, the general design process and
18 amplification of the control margins for the process itself,
19 some of which I have gone over already. The development of
20 the model including the definition of the soil properties,
21 definition of the control motion. This happens to be CMS1
22 which is designed right at the free field soil surface. The
23 output from the dynamic analysis then are acceleration,
24 velocities, loads, placements that are used as input for the
25 structural subsystem and equipment analysis.

1 The CMS2 and 3 application is very similar. as far
2 as exactly the same in the development of the model. As
3 pointed out before, the control motions that we find in the
4 hypothetical rock outcrop propagated up through the soil
5 area through the free field -- again, that free field motion
6 is used as input at the free field surface in the SASSI
7 computer analysis.

8 Next, I will just show some of the typical
9 response spectra. There are a number of them in your
10 package. I am not going to show them all. For each of the
11 control motions for each of the three directions analyses
12 were performed for each of the soil conditions. This
13 happens to be response at the top of the basemat for the
14 Regulatory Guide 1.60 control motion, east/west direction.
15 As you can see, the response of the structure for each of
16 the identified soil profiles is quite different.

17 Of course, for the design purposes the envelope
18 that is used for design, the dash line, if you have any
19 question on that, the dash line represents the case for a
20 fixed base analysis where the control motion was applied
21 directly to the base of the structure.

22 MR. LINBLAD: What is your expected period of the
23 building?

24 MR. GERDES: That varies, from structure to
25 structure.

1 MR. LINBLAD: For the nuclear island.

2 MR. DERMITZAKIS: The overall nuclear island from
3 fundamental frequencies, about 700.

4 MR. LINBLAD: Thank you.

5 MR. CARROLL: Now, we have north, south, east and
6 west for each case. Wouldn't it make a difference how the
7 equipment was oriented? I see you get a different spectrum
8 with north/south versus east/west. How do you know what
9 direction the earthquake is coming from?

10 MR. GERDES: Well, the difference in response to a
11 large extent is the fact that your structures are not
12 symmetrical. They are going to respond differently in the
13 different directions.

14 MR. CARROLL: The free field --

15 MR. GERDES: Essentially the same.

16 MR. CARROLL: Essentially the same, all the way
17 around. It's just the way the building --

18 MR. GERDES: They are statistically independent
19 but they envelope the same design spectra.

20 MR. CARROLL: I got you.

21 [Slides.]

22 MR. GERDES: In the interest of time, unless there
23 is a question, I will not go through the next set of spectra
24 that I have in the package. They are just similar, just
25 sets of spectra for different locations for the various

1 directions.

2 You get past the individual spectra, I have the
3 envelope spectra for some selected locations. This happens
4 to be the elevation in the control room, north/south
5 direction. This is an envelope of response for the analyses
6 from all of the site profiles for all three control motions.

7 [Slides.]

8 MR. GERDES: Similarly, east/west direction.
9 Again as you can see, the responses are somewhat different.
10 It's primarily the fact that the structures are not
11 symmetrical in the two directions. Again, I will not show
12 them all. This happens to be similar envelope of spectra.
13 This is in the interior structure of the containment at
14 elevation 146.

15 This happens to be response spectra for the diesel
16 fuel storage structure, elevation 78, north/south direction,
17 five percent damping. Again, I showed the envelope spectra
18 for the other two.

19 MR. CARROLL: The fuel tanks themselves survived.

20 MR. GERDES: Yes.

21 [Slides.]

22 MR. GERDES: Next, I will not expect you to be
23 able to read this. There is in the package, this.

24 MR. CATTON: With these kinds of analyses, how
25 much resolution do you get with respect to inside the

1 building for example? The reason I ask is, we were just
2 experiencing an earthquake as you well know. What I found
3 very interesting was, inside the structure there were local
4 load points where, apparently there as shaking. The
5 amplitudes were much different than anywhere else.

6 In this very fine structure one of the people that
7 everybody here knows, David Okrent, his office was
8 devastated and the offices on either side were just fine.
9 That means the resolution of about 15 or 20 feet.

10 MR. LINBLAD: He stacks his books higher than
11 everybody else.

12 MR. GERDES: The spectra that I am showing are
13 envelope spectra at different floor elevations which, of
14 course, the structures are fairly rigid in the plane of the
15 floors. For any equipment that would be located on wall
16 panels you would have to do a more detailed analysis of that
17 or at least an evaluation for that piece of equipment and
18 take into account the flexibility of that wall panel with
19 the natural frequency and response characteristics where, if
20 they are in the amplified region.

21 MR. CATTON: If you look at a floor for example,
22 if this was a floor, you look for node points within it, or
23 you just move the whole floor as a rigid rectangular
24 surface.

25 MR. GERDES: In the plane of the floor it responds

1 rigidly. We also look at floor flexibility for the floor
2 direction.

3 MR. ESFANDOR: Generally, the corner offices seem
4 to have more damage. In generating the infrastructure the
5 extremes of the floor elevation, because the response was
6 also included and added, extremes of the structure already
7 incorporated.

8 MR. GERDES: Keep in mind, these structures are
9 extremely rugged structures, compared to office buildings
10 that you may be looking at and evaluating in the recent
11 California earthquakes.

12 MR. LINBLAD: I think I have seen similar reports
13 as to what you were talking about. I think the thing to
14 recognize is that librarians find that after they have
15 anchored the bookcases the bookcases survive very well but
16 all of the books are on the floor. The same thing is going
17 to happen. We are here talking about anchored equipment
18 rather than loose equipment.

19 MR. CATTON: I understand the difference. In this
20 particular case his bookcases were probably anchored better
21 than most. They ripped right out of the wall. For some
22 reason his office is about midway along one wall. I don't
23 know whether it was because the kinds of deformation that
24 the building underwent that happened to be some kind of a
25 node point or midway between two node points, so that he got

1 the maximum amplitude which was quite a variation within the
2 single level of the building.

3 MR. GERDES: I guarantee you, it was not designed
4 to the same criteria that we are designing to.

5 MR. CATTON: I know that. Still, the resolution I
6 think -- the question is not --

7 MR. GERDES: That's why I say, when you get into
8 detailed design and specific equipment that may be located
9 where you have vertical floor flexibility or where you may
10 have amplification due to wall panels, it has to be evenly
11 weighted.

12 MR. CATTON: Another example was in one of the
13 overpasses. Right in the center of the overpass it was
14 almost two G's vertical. That was due to flexibility. The
15 overpass is a very rigid structure.

16 MR. GERDES: The site acceptance criteria which
17 was referred to earlier, first of all, for any specific site
18 it --

19 MR. CARROLL: This is the flowchart that Goutom
20 mentioned.

21 MR. GERDES: Yes. For any specific site the
22 applicant will have to define the site characteristics. The
23 site evaluations that are required of past plants will still
24 be required for certified plants. We have two different
25 arms shown down here, one for a rock site and one for a soil

1 site.

2 Based on the site characteristics the applicant
3 will have to develop site specific spectra, either at the
4 rock or at the free field surface at the site location. For
5 a rock site you would compare the site specific rock spectra
6 to the envelope, CMS1, CMS2, CMS3 spectra. That is because
7 of the System 80 plus for rock sites has been evaluated with
8 each of these three control motions being applied directly
9 through the base of the structure.

10 For a specific soil site you would compare the
11 site specific surface spectra and the horizontal directions
12 and vertical directions to the envelope of the CMS1, 2 and 3
13 surface spectra. In either case, the rock site or the soil
14 site, if that comparison shows that the site specific
15 spectra are enveloped for what was used in the design of
16 System 80 plus. The site is enveloped by the System 80 plus
17 envelope that has been used. Design System 80 plus is
18 certified for that site. It is true, for either a rock site
19 or a soil site.

20 If they are not totally enveloped the evaluation
21 is done by comparing responses to the site specific
22 requirements to some selected locations which are defined in
23 CSAR Section 2.5. If there are no amplifications more than
24 ten percent over the design envelope then the System 80 plus
25 design is adequate.

1 If it exceeds by more than ten percent at any
2 location then the site is not enveloped by the System 80
3 plus design. That does not mean that the System 80 plus
4 design may not be adequate for that site. Definitely, a
5 site specific evaluation would have to be performed to show
6 that the structure's components are adequate for that site.

7 [Slides.]

8 MR. GERDES: Next, it may be a little bit out of
9 order from what the schedule identifies. This concludes the
10 portion that I had on the seismic. I believe Dave Finnicum
11 has arrived. I believe this is the appropriate portion for
12 him to present on briefly, what was performed for a seismic
13 margin assessment, before we go into some of the structural
14 designs.

15 MR. CARROLL: That would be fine.

16 MR. FINNICUM: My name is Dave Finnicum. I am the
17 probabilistic risk assessment project manager for System 80
18 Plus. I have been with CE since 1975, and have been
19 involved in the reliability risk assessment of nuclear power
20 plants throughout all of that time. My work experience
21 began in 1969 in the aerospace industry, where I was also
22 involved in reliability and risk assessment.

23 [Slides.]

24 MR. FINNICUM: What I am going to talk about is
25 the seismic margins assessment performed for System 80 Plus.

1 Basically, we started out working -- we did a probabilistic
2 seismic margins assessment rather than the EPRI standard
3 approach. We started out by using our Level 1 fault tree
4 models, and modifying them to add in seismic value of
5 components and structures and components within the model.

6 We then looked at the structures to identify
7 structural values that could affect our equipment. From
8 that, we developed a list of seismic equipment for which we
9 would need fragility information.

10 We then constructed our seismic event trees. The
11 seismic event tree started out with a hierarchy tree based
12 on the NUREG CR-4840 methodology which is the NUREG 1150
13 external events evaluation. We started with the most severe
14 element as the highest on the hierarchy and working to
15 essentially a transient. Then, for each of the elements on
16 that hierarchy tree we developed a standard event tree for
17 use with our fault tree models.

18 What we then did is constructed the overall fault
19 tree, consisting of our representation of the seismic event
20 tree for the initiator, and used the fault tree linking to
21 get the cutsets for that core damage sequence for seismic
22 event. During this portion we essentially set the failure
23 rate for seismic events at .01, just so that we could
24 generate cutsets.

25 At this point in time the HCLPF values our high

1 confidence/low probability of failure values were generated
2 for the structures in System 80 Plus and the components for
3 which we had seismic failures in the models. The values
4 were calculated using the EPRI CDFM methodology. They were
5 calculated using a review level earthquake of .6G and using
6 the modified 0098 spectral shape.

7 The structural response curve that was shown here
8 was used as a basis for calculation of our HCLPF values.
9 The base case we did was the CMS2 control motion for the
10 rock side. We also did comparison analysis for selected
11 other spectra in the soil cases.

12 [Slides.]

13 MR. FINNICUM: Once we had the HCLPF value for the
14 components and structures we pulled these into the cutsets
15 we had generated from the fault tree models to generate the
16 HCLPF values at the cutset level and at the core damage
17 sequence level, and finally at the plant level. In this
18 case we were using the MIN-MAX approach. In this case the
19 HCLPF for a sequence cutset is defined to be the maximum of
20 the HCLPF of the components within that sequence.

21 For an overall sequence the HCLPF for that
22 sequence is the minimum of the HCLPF for all of its cutsets.
23 Finally, the HCLPF for the plant is the minimum of all of
24 the sequence HCLPF's. We also had cutsets containing both
25 seismic failures and random failures. These were tracked

1 separately. What the fixed cutset shows is the probability
2 of handling a lower plant HCLPF should a selected set of
3 random failures also occur.

4 [Slides.]

5 MR. FINNICUM: Basically, the results we were able
6 to demonstrate is a plant HCLPF of 0.73G for the CMS3 site,
7 which was the limiting site. This is as compared to the
8 goal of 0.5G which is 1.67 times the design basis
9 earthquake. The dominant contributor in the model was
10 seismically induced sliding and overturning of the
11 containment shell which was assumed to result directly in
12 core damage.

13 The second dominant seismic sequence was a LOCA in
14 excess of ECCS capability with an HCLPF of 0.86G. In this
15 case it was assumed that a seismically induced failure of
16 the steam generator supports would result in failing of the
17 RCS cooling piping and lead to a LOCA that was not
18 mitigated, and also leading directly to core damage.

19 MR. LINBLAD: Was there any indication in the
20 scenarios that you developed that an earthquake would cause
21 some instability in the neutron flux of the reactor itself?

22 MR. FINNICUM: No, we did not look at that.

23 MR. LINBLAD: You did not look at it, or you
24 rejected it?

25 MR. FINNICUM: We modeled the ATWS. We did not

1 model the neutron instability.

2 MR. CATTON: Why would you ask that, because you
3 shake the internals?

4 MR. LINBLAD: I asked that, because I had seen
5 something in the staff's proposal SER following an OBE
6 experience to watch the reactor flux and I was troubled by
7 that, wondering whether the designer thought it could
8 happen.

9 MR. CATTON: I believe the staff is going to
10 address that question.

11 MR. BAGCHI: I can offer one reason for that. We
12 were looking at both OBE inspection of the plant. As a
13 matter of fact, in Japan it was experienced in a BWR.
14 Whether or not it is feasible in a BWR, I think not.

15 MR. CARROLL: While we are still on this one, what
16 you are referring to is on page 3-20 -- it jumped out at me,
17 too. It does state that a check of the reactor's stability
18 should be made.

19 MR. LINBLAD: It wasn't clear to me whether this
20 was following the earthquake or in the course of the
21 earthquake. Could I ask the staff if that is what was
22 intended?

23 MR. BAGCHI: I am sorry sir, one more time.

24 MR. LINBLAD: The references to a plant inspection
25 and the added staff comment on top of what the EPRI report

1 called for was that the control room should watch the flux
2 monitors, neutron monitors, to see if there was an
3 instability present, to see that they were stable.

4 My question is, does this happen during the
5 shaking of the earthquake or following the earthquake, when
6 the plant inspection is being done.

7 MR. BAGCHI: We were trying to cover the incident
8 that might happen following the earthquake. In an actual
9 event what happened was, the reactor was shutdown as a
10 result of this additional flux.

11 MR. LINBLAD: Did we know it was the flux, or
12 perhaps the instrumentation?

13 MR. BAGCHI: We knew it was not instrumentation.
14 We asked that.

15 MR. LINBLAD: The intention is to examine the
16 meters, not during the earthquake but following the
17 earthquake.

18 MR. BAGCHI: That is correct.

19 MR. CARROLL: Why did this particular reactor
20 scram, presumably because of high flux? What caused the
21 high flux?

22 MR. BAGCHI: Earthquake, as a contributor, is what
23 is speculated. Nobody knows the real reasons.

24 MR. CARROLL: Did you look around?

25 MR. BAGCHI: No. It must have been splashing

1 water inside the vessel, but who knows where the LOCA was.

2 MR. CARROLL: You probably know what the level was
3 with instrumentation.

4 MR. BAGCHI: Instantaneously.

5 MR. CATTON: It is difficult to imagine sloshing
6 inside.

7 MR. LINBLAD: Mr. Bagchi, when you speak of the
8 neutron flux being stable, do you mean it in the sense of
9 oscillations or just at the same level as before the
10 earthquake?

11 MR. BAGCHI: Oscillations, any indication that the
12 core is not stable.

13 MR. LINBLAD: Stable, in the sense of oscillation
14 of radial or axial --

15 MR. BAGCHI: Yes.

16 MR. LINBLAD: Thank you.

17 MR. MICHELSON: I have a seismic question. Are we
18 designing or selecting sites that have a potential for
19 ground movement? By that, I mean ground cracking or
20 whatever?

21 MR. BAGCHI: I think in the parameters it is
22 excluded.

23 MR. MICHELSON: You do not take a site where there
24 can be any relative motion of the earth?

25 MR. BAGCHI: Yes, sir.

1 MR. LINBLAD: That is called vibration.

2 MR. MICHELSON: Let me tell you what I am worried
3 about, and then I will tell you it is a non-problem. We are
4 going to use a gravity feed from the fuel oil tanks out in
5 the yard to the diesel engines, and that is going to be a
6 small pipe, and inch and one-half or something, probably not
7 very big. It could be six inches. That is a big pipe. I
8 thought it would be smaller than that.

9 The gravity line will not be buried in the ground?

10 MR. BAGCHI: The pipe will not be buried in the
11 ground by itself. It goes through a tunnel.

12 MR. MICHELSON: No.

13 MR. CROM: It's described in the diesel fuel
14 section, and it will be in a tunnel.

15 MR. MICHELSON: You need to correct your drawing.

16 MR. CROM: It does not appear in the drawing
17 because the locations would be site specific.

18 MR. MICHELSON: I just looked at it on the
19 drawing. It shows on the drawing to the tank building.

20 MR. BAGCHI: I can share with you what we did.
21 The staff review asked these questions, and it turned out
22 that the piping design criteria for interior piping is
23 supposed to conclude the effects. If there is any
24 deterioration of the soil causing a change between two
25 anchor points that is included in design.

1 MR. MICHELSON: I guess I cannot tell positively.
2 It just says that it is going to exit in structures
3 underground -- exits and entrance will be adjusted.

4 MR. BAGCHI: The System 80 requirement will not
5 allow them to put the pipe --

6 MR. MICHELSON: I am asking for this design.

7 MR. BAGCHI: Yes, sir.

8 MR. MICHELSON: I can find out somewhere by
9 reading it? I would not find it out with this drawing.

10 MR. CROM: I believe it is in the diesel fuel oil
11 section.

12 MR. MICHELSON: I am looking at the plant drawing.

13 MR. CROM: I understand. It's not in the
14 structure section, it's in the system, Chapter 9.

15 MR. MICHELSON: If there is a chase it ought to be
16 shown as a structure interfacing with the building. It does
17 not.

18 RITTERBUSCH: We will help you either find it, and
19 if it is not clear we will make it clear.

20 MR. MICHELSON: You ought to make the drawing
21 clear, as well.

22 MR. CARROLL: You had a question.

23 MR. DAVIS: I forgot what it was. On page 19.57
24 the statement that you made is that you did not change the
25 operator error rates in your seismic margin assessment to

1 account for the increased stress, the potentially increased
2 stress during a seismic event. Do you think this would make
3 a difference, if you had tried to account for that? Did you
4 do a sensitivity study on human error rates as part of this
5 analysis?

6 The reason I ask is, there has been some recent
7 activity in that area and some are trying to account for
8 detrimental effect on human errors due to the seismic event
9 itself.

10 MR. FINNICUM: No, I did not do a sensitivity
11 analysis on that. I have recently heard of these studies
12 where I believe the treatment is to increase the operator
13 error rate by an order of magnitude. In the basic plant
14 HCLPF it would not be effective. Again, this is purely
15 seismic contribution. In the mixed cutsets it would not
16 affect the HCLPF portions. We did not look at that per se.
17 It could be looked at.

18 MR. DAVIS: Thank you.

19 MR. CARROLL: Moving on.

20 MR. LINBLAD: Thank you.

21 MR. GERDES: In the structural design I have some
22 figures that I will show later. The seismic category one
23 nuclear island structures are divided up. Although it is
24 really one integral building we address it as two separate
25 areas. In the reactor building itself are the major

1 components and there are the steel containment building,
2 shield buildings, the subsphere area and the containment
3 internal structures. Nuclear annex, again, some of the
4 major areas is CVCS maintenance areas, fuel area, diesel
5 generator area, emergency feedwater, main steam valve and
6 control areas.

7 Non-nuclear island, structure seismic category
8 one, station service water pump structure was not part of
9 the certified design. It is site dependent. We have
10 identified in the SAR some design criteria, the diesel fuel
11 storage structure, component cooling water, heat exchanger
12 structure and tunnel, and buried cable tunnels and conduit
13 banks.

14 Seismic category two structures, rad waste
15 building, turbine building, outdoor tank --

16 MR. LINBLAD: What has to be preserved with the
17 buried cable tunnel?

18 MR. GERDES: The tunnel itself has to maintain
19 structural integrity.

20 MR. LINBLAD: And, water tight integrity?

21 MR. GERDES: It cannot be flooded; am I correct?

22 MR. OSWALD: That is correct. It is also
23 particularly for missile protection, the tunnels, where you
24 would have two related cables particularly going out to the
25 auxillary structures off the main nuclear island.

1 MR. LINBLAD: I am trying to picture the seismic
2 for the cable tunnel aside from the site missile damage.
3 You say it is mostly missile protection.

4 MR. OSWALD: That is correct.

5 MR. CARROLL: What is a conduit bank?

6 MR. OSWALD: Just like a cable tunnel, you may
7 have conduit running through there instead of just cables.

8 MR. LINBLAD: You are saying that all vaults have
9 concrete covers rather than checker plate; is that basically
10 right?

11 MR. OSWALD: For seismic category one conduit bank
12 or cable tunnel it would be concrete.

13 MR. MICHELSON: I could not find them on drawings.
14 Maybe there are drawings that show them. Are these at grade
15 level and below, or are they very deep? Are they various
16 elevations below grade?

17 MR. TOKELSON: Generally, they are buried
18 underground.

19 MR. MICHELSON: That's okay, to get from one
20 structure to another. But you are saying then, they never
21 go any deeper than a couple of feet underground?

22 MR. TOKELSON: Generally, that's true.

23 MR. MICHELSON: Then, go down to the 50 foot
24 elevation before they enter the building.

25 MR. OSWALD: There are some conduit banks, cable

1 conduit banks, that are attached to the nuclear island
2 structure. The intention of those tunnels are to route
3 cable between structures and to get cable outside of the
4 nuclear island. They go down. They stop at elevation 70.
5 They don't go down to 50 right now on the design.

6 MR. MICHELSON: They are still going 20 feet
7 underground.

8 MR. OSWALD: That is correct. They are vertical
9 at that point, and are attached to the nuclear island.

10 MR. MICHELSON: You have penetrations for the
11 nuclear island? That's where I would like to know that
12 those penetrations are qualified for emergencies which can
13 happen. Any tunnel can spring a leak and it could be
14 totally flooded. You have no assurance that you can keep
15 the water out of both sides. You assume one side could
16 become flooded.

17 MR. OSWALD: These tunnels are an integral part of
18 the nuclear island themselves.

19 MR. MICHELSON: How can they be, when they go out
20 to the structures that are many feet away?

21 MR. OSWALD: Once they reach the elevation where
22 they would go out, that is correct.

23 MR. MICHELSON: If you wanted to evaluate the
24 safety of these interconnecting tunnels one has to have
25 enough knowledge of them to know where they are and so

1 forth. Is that anywhere in the SSAR? Can I find these
2 tunnel routings and elevations somewhere?

3 MR. GERDES: That tunnel routing would be somewhat
4 site specific.

5 MR. MICHELSON: Let me just say, the routing at
6 the interface with the seismic category one structure, that
7 would not be site specific unless you are also changing it
8 with the site. That is a different animal. You have to
9 have an interface.

10 MR. STAMM: I don't think we specifically show the
11 tunnels. There is no question, they obviously need to be
12 designed to hydraulic pressure based on the design site
13 parameters that we talked about. Given the connections
14 although not specifically, they have to be flexible to allow
15 for differential movement plus the hydraulic pressure.

16 MR. MICHELSON: And, to deal with the non-seismic
17 piping that might be in there. Depending on the particular
18 tunnel, if there is not seismic piping, penetration can
19 still happen.

20 MR. STAMM: That is correct.

21 MR. MICHELSON: There has to be no motion to
22 prevent penetration. I don't find these words anywhere.
23 Tell me where they are, and I will read them.

24 MR. STAMM: We will see if we can come up with
25 references. I am not sure they are all there.

1 MR. LINBLAD: While you are there responding to
2 this, we were talking earlier about a site with high
3 groundwater in it. There is a requirement by the staff that
4 the site be de-watered with a safety grade de-watering
5 system. Does that include sumps as well, deep sumps to de-
6 water.

7 MR. GERDES: We are not aware that there is a
8 requirement for a de-watering system. In fact, we have no
9 requirement for a de-watering system.

10 MR. LINBLAD: I am sorry, I misspoke. I will look
11 and see what I thought I understood.

12 MR. CARROLL: I thought I read it in the same
13 place somewhere, Bill.

14 MR. LINBLAD: I will look at the reference and
15 bring it up later in the day.

16 MR. GERDES: Some of the major codes and standards
17 for the category one structures, concrete ACI 349
18 supplemented by 318.

19 MR. MICHELSON: Excuse me. One more thing I did
20 not get to on the previous slide. You talked about the
21 component cooling water heat exchanger structure. Do we
22 know where that tunnel is? That has some big energy piping
23 in it, I assume. The pumping station is someplace with the
24 nuclear island.

25 MR. GERDES: Again, specifically, there is not a

1 specific location.

2 MR. MICHELSON: Do you know what elevation it
3 comes into the building?

4 MR. OSWALD: That tunnel is specifically
5 identified on the drawings. That is one of the items that
6 goes down and runs vertically.

7 MR. MICHELSON: Outside the nuclear island? It
8 shows where it interfaces with the nuclear island?

9 MR. OSWALD: It shows where it interfaces with the
10 vertical shaft into the nuclear island. I don't believe you
11 will find the horizontal run out to the component cooling
12 water structure itself on these drawings.

13 MR. MICHELSON: I am in total ignorance, so at the
14 next break you can tell me what you are talking about.

15 MR. GERDES: Again, to identify some of the major
16 codes and standards used for the concrete and structural
17 design. Also, locations for loads and load combination
18 requirements.

19 [Slides.]

20 MR. GERDES: The number of pictures depicting the
21 nuclear island structures, again, these are all in the SAR.
22 Before, when I referred to the reactor building, this
23 portion of the building here, this is the subsphere shield
24 building steel containment internal structures. Integrated
25 with that is the surrounding structures which we often refer

1 to as the nuclear annex which, again, has specific
2 maintenance areas, control room areas. These are identified
3 on the drawings and the SAR.

4 MR. MICHELSON: With the control room you go down
5 to what you call the final instrument equipment room,
6 roughly at the 50 foot elevation? I see no flood barriers
7 protecting it from the balance of the nuclear island. Are
8 there some, but I just don't see them. I see the three hour
9 fire barrier.

10 MR. CROM: There are barriers, and I will show
11 them to you in my presentation for internal floods.

12 MR. MICHELSON: The drawing is not quite right.

13 MR. CROM: It is shown on elevation 50, the flood
14 barrier between --

15 MR. MICHELSON: That is elevation at 50 in the
16 drawing.

17 MR. CROM: You need to look at the plant
18 elevation. I will show it to you during my presentation.

19 MR. MICHELSON: I will take your word for it, for
20 the moment.

21 [Slides.]

22 MR. GERDES: This is the plant elevation at the
23 top of the basemat.

24 MR. MICHELSON: That's not elevation at 50. Now,
25 I guess you are going to show me where the flood barriers

1 are or somebody else will.

2 MR. GERDES: Tom is going to address this in his
3 presentation.

4 MR. MICHELSON: There is another thing there
5 identified there as the divisional walls. As near as I can
6 tell, that goes straight down the middle of the building
7 more or less. That is the only wall you call a divisional
8 wall?

9 MR. GERDES: This is the divisional wall, correct.

10 MR. MICHELSON: Whenever I hear somebody talking
11 about the divisional wall it is just that wall; is that
12 correct?

13 MR. GERDES: Yes.

14 MR. MICHELSON: Essentially, this is a two
15 division plant with a barrier between the two divisions.

16 MR. GERDES: Yes.

17 MR. CATTON: What about the north/south line?

18 MR. MICHELSON: They don't count that.

19 MR. CATTON: It isn't a containment --

20 MR. CROM: Mr. Michelson, you say it is two
21 divisional. However, the additional redundancy -- and,
22 again, I will get into it in my presentation.

23 MR. MICHELSON: I appreciate there is redundancy
24 within the two divisions. But for flooding purposes it is
25 two divisions.

1 MR. CROM: It can be treated both ways, and I will
2 go into that in my presentation.

3 MR. MICHELSON: There's more to it than meets the
4 eye here.

5 MR. GERDES: Again, what I have here are just the
6 figures that are in the SAR. This happens to be a nuclear
7 island structure plant at the operating floor. As
8 identified earlier in my presentation, the purpose of this
9 overhead is strictly to identify the location and
10 orientation of the turbine building itself with respect to
11 the nuclear island structure, and the identification of the
12 low trajectory turbine missile path.

13 MR. MICHELSON: How much differential motion do
14 you expect to be in the turbine building nuclear island, and
15 the same question for the rad waste building. You show the
16 six inch gap. You expect differential motion?

17 MR. GERDES: You always have a small amount of
18 differential motion that will be dependent on the specific
19 site itself. These are very rigid structures. The motion
20 itself, I don't have that number. It has been calculated.

21 MR. MICHELSON: Particularly for the rad waste
22 building, if you are getting differential motion how do you
23 protect the piping that is going through the walls?

24 MR. GERDES: That is accounted for, and that is
25 part of the piping design criteria. You account for the

1 differential motion.

2 MR. MICHELSON: Is there some kind of a flexible
3 penetration. There is too short of a distance to put a
4 flexible pipe in. It has to be some sort of a flexible
5 penetration. I couldn't find any discussion. We need a
6 discussion of how the penetrations -- if you don't have any
7 motion great. But, I suspect you do.

8 MR. STAMM: I think I can answer that. The piping
9 is not designed -- what we have is design criteria. The
10 differential motion goes into the design criteria. There
11 are two basic ways of taking that up which are to design the
12 system with sufficient flexibility or put in some kind of
13 expansion connection. That would be done on a case by case
14 basis.

15 The six inches was selected because we have a very
16 high confidence that would conservatively envelope any
17 motion of the two buildings.

18 MR. MICHELSON: It will keep the buildings from
19 having a problem, but that does not necessarily take care of
20 the piping. I assume the six inch gap can have groundwater
21 in it. It's not a water excluded area. Unless there is a
22 spec that says this gap will actually have a damper on it,
23 you can't get any water in it and so forth. Is this a water
24 excluded area, or can groundwater be in the gap between the
25 buildings.

1 MR. STAMM: The six inch gap itself is not
2 watertight. However, the pipe tunnels where we would have
3 pipe tunnels going from one building to another, would be
4 watertight connections.

5 MR. MICHELSON: Those tunnels had better take the
6 relative building motion. It's hard to build a tunnel
7 between two concrete walls that can withstand the
8 differential motions. You can get the flavor of my concern,
9 and I hope the staff does.

10 MR. BAGCHI: Mr. Michelson, we have asked for
11 details of a tunnel design. It did not yet show up in the
12 SSAR. We expect it to show up. The dynamic pressure on the
13 tunnel walls is going to be very substantial. Also, the
14 criteria actually calls for a combination of actual motion
15 to relative motion.

16 MR. MICHELSON: I did not find it, but when we get
17 it we can talk about it.

18 MR. CARROLL: Back to the turbine missile drawing.
19 You have a favorable orientation. Would you agree with the
20 staff's statement, that with respect to the reactor building
21 the turbine system is created so that any possible turbine
22 missile will not strike the reactor building, any
23 postulated?

24 MR. GERDES: Any reasonably postulated turbine
25 missile has a reasonable possibility of occurring. I would

1 not say that -- you could not hypothesize that there could
2 be some missile coming out of the turbine.

3 MR. LINBLAD: Mr. Gerdes, your description of the
4 turbine missile path is limited to low trajectory. Is there
5 some other missile path, other than the low trajectory
6 missile path?

7 MR. GERDES: I believe that is the only one. I am
8 not a turbine expert.

9 MR. LINBLAD: Why is the descriptor required on
10 the drawing? It suggests to me that there must be a high
11 trajectory turbine missile path.

12 MR. CARROLL: Poor choice of terminology.

13 MR. GERDES: Turbine missile path.

14 MR. LINBLAD: I think maybe that's the proper
15 terminology. That's what I am trying to understand.

16 MR. DAVIS: Is it because there's not any
17 equipment in the high trajectory path?

18 MR. LINBLAD: What goes up must come down.

19 MR. DAVIS: You are suggesting damage on re-entry,
20 but it will be out, away from the building, won't it?

21 MR. LINBLAD: Never mind.

22 MR. CARROLL: The staff statement that I was
23 concerned about is on page 3-41.

24 MR. FRANOVICH: Yes, the staff has noted that.

25 [Slides.]

1 MR. GERDES: Likewise, the purpose of this
2 overview is to show the orientation of the rad waste
3 building, again, with the nuclear island structures.

4 MR. LINBLAD: Is there any requirement that this
5 structure not fall within the turbine missile path of the
6 previous -- you only show the relationship of the nuclear
7 island.

8 MR. GERDES: The turbine building is over here.
9 The turbine missile paths are over in this area.

10 MR. LINBLAD: Thank you.

11 [Slides.]

12 MR. GERDES: In your package you have a view of
13 the component building water heat exchanger structure, the
14 diesel fuel storage structure. There was a question
15 regarding the embedment. It does not give a dimension of
16 the above ground here, but you can get a general
17 interpretation of the portion that was embedded and the
18 portion that is above ground.

19 MR. CARROLL: About half in and half out. The
20 equipment room is for the transfer pumps.

21 MR. STAMM: The equipment room is for the supply
22 pumps, off flow from the tank and ventilation equipment.

23 MR. GERDES: The equipment room itself is non-
24 seismic category one. The rest of the stuff here is seismic
25 category one, the rest of the structure.

1 MR. STAMM: Also, recirculation and the cleanup
2 loop.

3 MR. CARROLL: You are going to provide us with
4 some information on the fuel storage for the combustion gas
5 turbine.

6 MR. GERDES: Yes, we will. The analysis of the
7 structure, it uses static finite element model in general,
8 for the nuclear island. For seismic you use equivalent
9 static methods using the dynamic analysis results. These
10 results include the effect of structure to structure and
11 soil to structure interaction. Also, apply other global
12 loads, mass of destruction equipment, tornado, wind, large
13 pipe rupture, large fluid masses.

14 From the large global finite element models we use
15 local models to perform the more detailed analyses to
16 account for local effect. This is out of plane bending
17 effects. The schematic of the nuclear island finite element
18 model that was developed for applying global loads was to
19 get a loading for the structural elements.

20 [Slides.]

21 MR. GERDES: The results from the seismic results
22 from the seismic analysis, the maximum accelerations were
23 applied to this finite element model to determine loads
24 throughout the structure. We also compared the overall base
25 shears and moments on this structure with the total base

1 shear end moment, when you sum up the base shears and
2 moments from each of the stick elements from the dynamic
3 analysis model.

4 We have a minimum conservatism of about 30 percent
5 over maximum shears of moments that were developed from any
6 of the soil cases from the dynamic analysis. We have an
7 additional conservative factor of about 35 percent built in.
8 For some soil cases it's greater than that.

9 MR. LINBLAD: Mr. Gerdes, this is quite a massive
10 foundation involved in this. But as I understand your
11 description, you have not taken any advantage of
12 considerations that are sometimes called incoherences or
13 chill effects; is that right?

14 MR. DERMITZAKIS: Incoherence effects were
15 considered and was the parametric study concerning inclined
16 waves as the source of the seismic motion. Therefore, using
17 inclined waves in one part of the structure is different
18 than the part of the structure at the right end. The
19 structure response spectra showed very little difference
20 when they were developed using the computed motion.

21 MR. LINBLAD: Let me ask my question a different
22 way. You have not reduced peak ground accelerations into
23 the building by virtue of incoherence assumptions.

24 Mr. DERMITZAKIS: No.

25 MR. LINBLAD: Thank you.

1 [Slides.]

2 MR. GERDES: In addition to obtaining the overall
3 structural loads and load requirements we also selected
4 certain areas which we performed detailed design. In the
5 nuclear island we selected 13 structural areas for detailed
6 design. We also evaluated all of the shear walls, that they
7 could adequately or were adequately sized to accommodate the
8 required loadings.

9 Non-nuclear island, we looked in detail at diesel
10 fuel storage structure.

11 MR. CARROLL: But not the tunnel?

12 MR. GERDES: Component cooling water heat
13 exchangers and tunnel. We only looked in detail at one
14 tunnel cross section.

15 MR. CARROLL: Do you think that envelopes the
16 tunnel, for example, for the diesel fuel storage?

17 MR. GERDES: Again, we are not performing detailed
18 design of all of the structures for certification. We are
19 selecting what we determined to be critical areas to
20 evaluate so that when the final detailed design is performed
21 the arrangement and size of the structures were adequate.

22 MR. CARROLL: The COL holder will have to do a
23 detailed analysis of the tunnel connecting the diesel fuel
24 storage to the --

25 MR. GERDES: The COL applicant will have to

1 perform the detailed design of all of the structures. He
2 has to meet the design criteria that have been identified
3 for certification in the SAR.

4 MR. CARROLL: Can I find design criteria for the
5 tunnel, connecting the diesel fuel storage to the nuclear
6 island?

7 MR. GERDES: Yes, there are design criteria.

8 MR. CARROLL: I will find that if I look in the
9 right place in the SAR?

10 MR. GERDES: Right. Also, there is an Appendix in
11 Section 3.8 dedicated to the design criteria for seismic
12 category structures, Appendix 3.8(a) that has all of the
13 criteria for seismic category one steel and concrete
14 requirements.

15 MR. CATTON: When you treat the seismic input is
16 wave length a consideration? The distance between the
17 peaks, is that a consideration?

18 MR. GERDES: That was the incoherence argument.

19 MR. CATTON: But whether you can reduce the impact
20 would depend on the wave length.

21 MR. LINBLAD: I think Mr. Kennedy wants to
22 respond to that.

23 MR. KENNEDY: In the design the ground motion is
24 assumed to be vertically propagating, so it arose at all
25 times in the foundation at the same time. For the design

1 process there is no statistical incoherence of the ground
2 motion. There is no horizontal spatial variation in the
3 ground motion.

4 Wave length is an important parameter in the
5 design analyses, in arriving at the size of the finite
6 elements for the soil structure interaction analysis. They
7 must be small enough so that they properly propagate the
8 waves that you are trying to propagate.

9 I do want to correct, we did the margin review.
10 We did take credit for statistical incoherence of the ground
11 motion in coming up with the HCLPF margin numbers. We did
12 not take credit for that in the design.

13 MR. CATTON: What about horizontal propagation?

14 MR. KENNEDY: As Stavros indicated, there were
15 some parameter studies done in which we put waves in at an
16 inclined angle. We convinced ourselves that putting the
17 vertically propagating waves in gave us floor spectra, that
18 we looked at all of these sites and enveloped the results.
19 The design analysis all worked with vertically propagating
20 waves.

21 MR. CATTON: What is the wave? I don't have that
22 number right here. I can go back and calculate it.

23 MR. GERDES: It depends on each soil case.

24 MR. IDRIS: The question is, what is the wave
25 length. The wave length would depend on the velocity of the

1 material and on the frequency you are looking at.

2 MR. CATTON: I understand that.

3 MR. IDRIS: Typically we have velocities from 500
4 to 3,500 and frequencies of interest are around -- we take
5 about 1,000 feet per second. We have about eight hertz,
6 1,250 feet, 135 feet. That is sort of the middle range.

7 MR. CATTON: It is about the same order as the
8 building size. That's where the analysis would get really
9 interesting.

10 MR. IDRIS: It is more conservative. If you go
11 the vertically propagating wave every point there is not
12 incoherence.

13 MR. CATTON: I would have thought that worse case
14 would be that one -- acceleration is oscillation. You get
15 an upward acceleration and then it is downward.

16 MR. IDRIS: We were looking at the horizontal.
17 The translation is reduced. We create some other modes.

18 MR. CATTON: When you look at the vertical the
19 wave length is the same order as the building. One edge of
20 the building is downward and the other is upward.

21 MR. IDRIS: Then, you are looking at the
22 vertical. That's what you see with the line wave.

23 MR. CATTON: The wave length is on the order of
24 125 feet. Wouldn't that see the different edges of the
25 building being sort of ratcheted up and down.

1 MR. IDRIS: The base is being oscillated. There
2 is no change across the base. As the propagate to the model
3 they are automatically accommodating these differences.

4 MR. CATTON: I understand from the viewgraphs we
5 just saw, I understand the finite element and how you treat
6 the building. I also thought that a lot of this is quite
7 different when the wave lengths are of the same order. The
8 wave length is the order of 100 feet and the building -- I
9 have to worry about each edge of the building being hit out
10 of phase. Wouldn't that cause a problem?

11 MR. IDRIS: The wave length that goes through --
12 however, the wave itself is hitting the side is influenced
13 by the wave that is underneath, which is around five times
14 bigger. Therefore, the wave length is five times longer.
15 That is why the incoherence was not that important. The
16 passage of the wave -- the earthquake is some distance away.
17 The waves comes to the site first through the higher
18 velocity medium and then it propagates to the site.

19 The effect of the incoherence is actually more
20 controlled by the vertical velocity, which was a minimum of
21 5,000 and as high as 8,000, in which case the wave length is
22 much higher. That would be about 5,000, again, using the
23 eight hertz about four or 500 feet.

24 MR. CATTON: The wave length -- the building size,
25 the ratio is about five.

1 MR. IDRIS: On that order.

2 MR. KENNEDY: There are a couple of facts here.
3 If we are worrying about variation of ground motion from
4 location to location there is variation of the ground motion
5 between two locations rather close together. There are two
6 causes. One, is the inclined nature of the waves coming to
7 the site so that they arrive at each of these spots at a
8 slightly different time. That has a horizontal wave speed
9 that is up at the very high velocity that Idriss just
10 mentioned, 5,000 feet per second. We can see that from
11 differential range.

12 Another source is just the statistical variation
13 of the wave pass, the specific locations. We find that
14 really starts affecting the ground motion rather
15 substantially above about ten hertz. It has very little
16 effect on ground motion less than about ten hertz.

17 The effect of this ground motion, if it comes to
18 our building, it will bring about inertial effects which are
19 the big effects. The worst way to bring this ground motion
20 in is such that it is seeing the same motion at the same
21 time. That's why we typically with the vertically
22 propagating wave models it's because the entire basemat is
23 subjected to the exact same motion, that will tend to give
24 you the highest inertial effects.

25 You will get from spatial variation in the ground

1 motion, you will get twisting of the basemat. That will
2 reduce the overall translation of this one LOCA region to
3 respond more, but the overall will respond less. Similarly,
4 for vertical if you have got wave passage effects are
5 incoherent you will get some rocking. Your overall vertical
6 uplift -- accelerations will be less. You will actually
7 lower the inertial effects.

8 You will create some differential displacement
9 effects that you are mentioning. These buildings are very
10 stiff basemats to accommodate that kind of an effect. The
11 studies that have been done on these types of buildings
12 indicate the most severe design conditions come when you
13 treat it as a vertically propagating wave.

14 MR. CATTON: Thank you.

15 MR. CARROLL: Since I have you two up here, I
16 would like to ask a question. Is there anything that has so
17 far come out on the misnamed Northridge Earthquake, the
18 impact on how it should be designing nuclear power plants
19 from a seismic point of view?

20 MR. IDRIS: We are collecting a lot of
21 information. We are collecting a lot of information
22 regarding ground motions and behavior of specific
23 structures. As far as the ground motions, that's where we
24 have gotten the most information so far.

25 The indications are that the level of safety is

1 somewhat higher than would have been expected in similar
2 size earthquakes, similar in nature earthquakes. This is
3 the third major threat we have had in Southern California in
4 the last ten years. It is not unheard of to have -- the
5 nature of the ground motion appears to be a little more
6 energetic than we would have expected, not as high as some
7 people have been speculating. I think it is more like 20
8 percent.

9 What effect would that have on a nuclear plant
10 constructed based on these attributes, is really nothing.
11 This hypothesizes a motion. It says we are going to design
12 for that motion and that motion if it is exceeded, then you
13 have do something else. So far on any future plant, it has
14 no effect, because you will be putting the plant in a site
15 where you expect a certain level of shaking.

16 For what we look at in terms of future ground
17 motions at a specific site there is an effect. How big of
18 an effect, I think it is premature to say. We only look at
19 peak accelerations. The full spectrum, which is what we
20 should all look at, only ten recordings have been digitized.
21 There is not enough information yet to really make any
22 conclusions.

23 I have looked at those ten. There is one that has
24 a surprise -- in Santa Monica. There are ones that have
25 been digitized. As far as the damage that has occurred I

1 think lessons we have learned before for the bridges or the
2 sheer failure occurs and things like that as far as
3 buildings, I understand some steel structures have suffered
4 damage.

5 Again, I am going to the areas that are really not
6 my field, for liquefaction. Where we would expect that it
7 did occur -- on top of that it really does not affect this
8 particular situation.

9 MR. KENNEDY: In the structures area, I think that
10 there are several things that are being learned that will
11 affect all kinds of design. One is, now that we have a
12 large computer power and can do dynamic analyses and
13 sophisticated analyses of buildings, maybe we have taken too
14 much advantage of that and shaved out too much of the margin
15 in the design of at least some of our competitive designs
16 that go into California.

17 You see, all old designs that have massive shear
18 walls, massive brace frames, come through very well. Modern
19 designs that do not have such massive shear walls and such
20 massive brace frames have not done as well. Maybe we have
21 to raise the design loads, because we now know how to do the
22 analysis better. I do not think that really affects nuclear
23 power plants because they do have the massive shear walls
24 and the massive brace frames.

25 I think the other issue that has come out of the

1 Northridge Earthquake is, there is some indication of damage
2 to the steel structures that was not expected prior to that
3 earthquake. It looks like, because of those damages, it is
4 logical to have expected the damage. I don't think we did
5 expect it. I think we are going to have to spend more
6 attention on the design of connection details in steel
7 structures. There is indications that welded and other
8 types of connection details did not perform as well as
9 expected.

10 MR. CARROLL: We learned quite a bit from the
11 Sylmar earthquake, the one that caused all of the damage at
12 the Sylmar converter station, things like control room and
13 false ceilings falling down and things like that. How did
14 that converter station come through this?

15 MR. IDRIS: There are three things that are
16 affected very heavily during Sylmar. I will comment on a
17 couple of them. One was the dam, it had a major landslide.
18 That was replaced by a new dam, well compacted dam. It
19 performed extremely well. It moved about three inches, the
20 San Fernando Dam. The old dam which was left in
21 place and for flood control did have liquefaction all over
22 again and moved about a foot, and so did the upper dam. The
23 Genson filtration plant which was next door, suffered a lot
24 of damage in 1971 and has since been somewhat fixed. It
25 suffered some movement but not as much as 1971.

1 The third area was the Sylmar substation. I
2 understand there was a great deal of damage there.

3 MR. KENNEDY: I have not been to the Sylmar
4 converter station. I have talked to people who have been
5 there, and I have been told that the damage is the same kind
6 of damage that happened in the 1971 San Fernando earthquake.
7 It was very extensive damage. I think switchyards are
8 vulnerable.

9 MR. CARROLL: I can understand the mercury filled
10 rectifiers having some problems, but how about the more
11 prosaic things like control room ceilings?

12 MR. KENNEDY: We still have ceilings coming down
13 in earthquakes. I do not know whether that happened at
14 Sylmar but I know of several places where hung ceilings came
15 down. It still is an issue that needs to be considered in
16 nuclear power plants, safety wiring of the hung ceilings. I
17 think any modern nuclear power plant is doing that.

18 MR. LINBLAD: Let's be sure that on the record,
19 Sylmar is recognized to be a unique type of substation
20 involving direct current transmission rather than the normal
21 alternating current transmission, and has totally different
22 equipment in place.

23 MR. IDRIS: The Sylmar hospital suffered a great
24 deal of damage. It was redesigned in the 1970's to a
25 significant higher level of shaking. It has actually steel

1 shear walls in fact, and suffered practically no structural
2 damage. It did have some problems with its sprinkler
3 system.

4 MR. ESFANDOR: We did have a chance to go to the
5 Sylmar station after the earthquake. The structural system
6 itself, the control room in general, did very well. There
7 was a tremendous amount of damage in the surroundings. The
8 steel structure supporting that were perfectly braced,
9 resulting from the fire earthquake. They all did well.
10 Other than the ceramic damage, everything else was
11 architecturally sound.

12 MR. CARROLL: The control room ceiling did not
13 come down this time?

14 MR. ESFANDOR: I did not see the control room.
15 Looking from the glass, it looked like it was okay.

16 MR. IDRIS: The Pacoima dam is northeast of the
17 substation. It is an arched dam, sitting in a very steep
18 valley. The recording in 1971 was in one of the abutments
19 which looks something like this. I wish I knew that we were
20 going to make this discussion. I had a picture taken
21 shortly after the earthquake.

22 The new one is one and one-half -- I was talking
23 about the Pacoima dam which is an arch concrete dam. On the
24 abutment which is very steep, that is where they had the
25 recording in 1971, which was recorded G. It is recorded at

1 this same location at about one and one-half G. Down at the
2 base of the dam now they have a recording of about one-half
3 G.

4 Also, there is a station downstream about one-
5 half a mile or so downstream. It's almost a free field
6 station. There is a recording. They have about 18 channels
7 recording. It is fully instrumented. I don't pay much
8 attention to the structural elements. There was a 2.3G at
9 the crest of the dam itself.

10 MR. CARROLL: Thank you. That was very
11 interesting. Mr. Gerdes, I don't understand why you aren't
12 able to finish on schedule. You were to be finished by
13 12:00. How much more time do you have?

14 MR. GERDES: I think we can go through the rest
15 of the structural work in ten or 15 minutes.

16 MR. CARROLL: Let's do that.

17 [Slides.]

18 MR. GERDES: There were some mentions of the
19 structures that were identified which may have been
20 appropriate for some of the category one structures. But
21 for the nuclear island the dimensions are something like 434
22 feet by 326 feet, so we have a very large massive structure
23 here, much larger than the dimensions that were identified
24 when we were talking about wave lengths.

25 [Slides.]

1 MR. GERDES: I identified a number of areas that
2 we looked at and performed detailed design, and determined
3 what the rebar requirements were. The primary purpose of
4 this was to identify and confirm that the arrangement which
5 we had defined in our arrangements were really adequate to
6 withstand the envelope of design loads that we were
7 subjecting it to. When we got to the detailed design of the
8 structures we would not find out that we needed to
9 increase the size of the shear walls significantly that
10 would change the dynamic response to the structures.

11 These areas are identified in the package. They
12 are also identified and discussed in more detail in Appendix
13 3.8(b). Unless there are specific questions that you might
14 have, I am just going to go on over the rest of the
15 identification on these areas.

16 For certain other areas we define design
17 requirements and interface requirements that we didn't do
18 detailed design, rad waste building, turbine building,
19 station service building, auxillary, dikes, station service
20 water pump structure. These design requirements are
21 identified in Appendix 3.8(a), as identified earlier.

22 [Slides.]

23 MR. GERDES: A very detailed analysis was
24 performed for the spherical steel containment vessel. The
25 description of this vessel, the type, it is a steel sphere,

1 SA 537 Class 2, diameter of 200 feet, one and three-quarter
2 inch thickness with a two inch band at the transition region
3 where it goes into the concrete, a volume of 3.34 times ten
4 to the sixth cubic feet.

5 The codes and standards that were considered in
6 the detailed design of this vessel are identified in general
7 as very typical codes and standards. Design conditions, we
8 looked at normal operating, temperature 110 degrees
9 fahrenheit, inadvertent containment actuation which is the
10 condition that is critical for buckling consideration, 100
11 negative pressure vacuum of 2 psi.

12 MR. LINBLAD: I would like to understand what that
13 means.

14 MR. GERDES: The two pound vacuum condition, what
15 exists before the containment spray actuation. Or, is it
16 the result of -- that is a result of the containment spray
17 actuation. I might add, in the buckling analyses this was
18 considered in conjunction with the seismic event.

19 MR. LINBLAD: What are the initial conditions
20 prior to the containment spray actuation?

21 MR. GERDES: Essentially normal operating
22 conditions.

23 MR. LINBLAD: How much steam in the structures?

24 MR. GERDES: I don't really have that.

25 MR. LINBLAD: What is the partial pressure of

1 steam at that time?

2 MR. OSWALD: I am not sure of the numbers. Actual
3 value came out to be something like 1.81 psig. We rounded
4 up to two, for the structural analysis.

5 MR. LINBLAD: How much steam is being condensed?

6 MR. OSWALD: I am not sure, without the details of
7 that analysis.

8 MR. CATTON: Is it just cool down of the air,
9 because the spray water is cold?

10 MR. CARROLL: No.

11 MR. LINBLAD: I would think that if you had a
12 steam leak and you have lived with that and vented off some
13 of the air, that your partial pressure of steam will have
14 grown.

15 MR. CARROLL: Is there anything that limits the
16 negative pressure to two psi?

17 MR. LINBLAD: Are there vacuum breakers on the
18 containment?

19 MR. GERDES: No, there are not.

20 MR. CARPENTINO: If I understood the question, the
21 negative pressure is determined by assuming that the
22 containment is at 100 percent relative humidity to begin
23 with and low pressure. You inadvertently turn on maximum
24 spray flow rate at the coldest temperature that you can have
25 the spray water temperature, at two psi.

1 MR. LINBLAD: It is a partial temperature at 110
2 degrees fahrenheit.

3 MR. CARPENTINO: Yes. I seem to have created an
4 equilibrium.

5 MR. CATTON: So, why is the final temperature 110
6 degrees?

7 MR. OSWALD: The 110 degrees was used for the
8 containment material properties. The containment steel
9 itself could not have developed much of a uniform
10 temperature much beyond what it was operating at. This was
11 structural analysis and not the thermodynamic analysis for
12 the design basis accident that you are looking at here.

13 MR. CATTON: For your calculation of the minus
14 two, the environment temperature would be whatever the spray
15 temperature is; is that what you did?

16 MR. OSWALD: The containment material properties
17 were used for 110 degrees.

18 MR. CATTON: I am trying to understand what you
19 did to get the minus five. Did you cool the containment air
20 to the spray temperature, and that's what is the pressure?

21 MR. CARPENTINO: The thermodynamic analysis
22 started out at the high temperature, high relative humidity.

23 MR. LINBLAD: What temperature was that prior to
24 the actuation?

25 MR. CARPENTINO: I think it was 110. I have to

1 check that. I do not know for sure.

2 MR. CATTON: What is the pressure when it is in
3 equilibrium with the spray? Is that where you get the minus
4 two?

5 MR. CARPENTINO: Yes. We run it out until the
6 pressure is in equilibrium. We have taken the pressure as
7 far as it is going.

8 MR. CATTON: The only question is then, is 110
9 appropriate.

10 MR. OSWALD: Again, the 110 was for material
11 properties from the containment materials. I think in
12 Chapter 6 and subsequent meetings here the design basis
13 chapter, that maybe you will be enlightened.

14 MR. LINBLAD: We need a tech spec environmental
15 temperature, yes.

16 MR. GERDES: Pressure 53 psi.

17 MR. CARROLL: That is LOCA.

18 MR. GERDES: Either LOCA or steam line, I am not
19 sure which was controlling there. Each was about the same
20 for the steam line break.

21 MR. CARROLL: You have conveniently skipped over
22 the last item.

23 [Slides.]

24 MR. GERDES: The containment was also evaluated
25 for postulated combustible gas loading.

1 MR. OSWALD: That was a 10 CFR 50.44, 50.34
2 analysis. On other note, the 76.5 psi was added. In our
3 analysis we added a 76.5 with the 53 and evaluated a
4 containment response at about 129.

5 MR. LINBLAD: At what service level?

6 MR. OSWALD: We looked at service level C
7 stresses.

8 MR. LINBLAD: Thank you.

9 MR. CATTON: The design basis temperature of 290
10 degrees F, that's LOCA, isn't it?

11 MR. OSWALD: That is correct.

12 MR. CATTON: Actually, steam line break determines
13 this 290 degrees is an average volume temperature, is that
14 correct?

15 MR. OSWALD: That is correct.

16 MR. CATTON: There will be significant
17 stratification at the top that is going to be quite a bit
18 higher temperature than down at the bottom. How do you
19 accommodate that in your analysis?

20 MR. BAGCHI: I think this is best left for the
21 severe accident.

22 MR. CATTON: This is not a severe accident.

23 MR. BAGCHI: I understand that.

24 MR. CARROLL: It is covered in Chapter 19.

25 MR. BAGCHI: That is the best place to ask for

1 these types of questions. That's when people are prepared
2 to give you some answers that are going to be meaningful.

3 MR. CARROLL: You are happy to wait?

4 MR. CATTON: I am not happy, but I will wait.

5 This is a stratification that exists and it can be
6 significant.

7 MR. CARROLL: I know that.

8 MR. BAGCHI: As a structural engineer, let me
9 understand what your concern is. What is the stratification
10 going to do to the structure?

11 MR. CATTON: What it is going to do is, you have
12 temperature variation from the bottom to the top.

13 MR. BAGCHI: Understood.

14 MR. CATTON: The thermal stresses --

15 MR. BAGCHI: We have not looked at that
16 explicitly. That does not give me any concern. This,
17 combined with the pressure, is fine for the capability of
18 the -- we are talking about temperature stresses that are
19 secondary stresses. Even over the less large surface --

20 MR. CATTON: Don't get mad at me. This is my
21 business.

22 MR. BAGCHI: As a structural engineer, I don't
23 understand.

24 MR. CATTON: In Quench River when they did the
25 analysis of the steel shell it turned out that this was a

1 problem. Stratification from bottom to top could be a
2 problem. If the average temperature is 290 degrees -- I
3 don't know how much stratification --

4 MR. BAGCHI: The biggest concern would be at the
5 joint where the steel is coming down into the concrete,
6 where you have a significant change in geometry. The
7 stresses were looked at for that discontinuity.

8 MR. CATTON: Just to make sure --

9 MR. BAGCHI: The thermal stress was not covered.

10 MR. CATTON: When you do your thermal stress
11 analysis you do not vary the temperature from the basemat to
12 the top of the dome?

13 MR. BAGCHI: We do not. We account for a
14 condition --

15 MR. CATTON: Let me continue the question. You
16 had 150 degree temperature variations from the basemat to
17 the top of the dome. Would that give you a headache?

18 MR. BAGCHI: I don't think so.

19 MR. CATTON: Does anybody know?

20 MR. DAVIS: They look at temperatures as high as
21 500 F in severe accidents.

22 MR. CATTON: That does not give them a problem?

23 MR. BAGCHI: No, sir.

24 MR. CATTON: I don't know if the variation in
25 temperature --

1 MR. BAGCHI: The buckling problem, that was looked
2 at very carefully. The results were corroborated.

3 MR. CATTON: I will ask again, when we get to
4 severe accidents.

5 MR. CARROLL: I bet you will.

6 MR. GERDES: The analyses discussed test
7 condition, design condition, ASME service level conditions,
8 stability, ultimate capacity, combustible gas loading and
9 also the sliding and overturning, potential sliding and
10 overturning of the steel shell.

11 [Slides.]

12 MR. GERDES: Just some indication of the three
13 dimensional finite element model, the steel dome that was
14 used in the analyses. The remaining slides that I have
15 present the loading categories, the load combinations
16 allowable, maximum calculated stresses. These results are
17 identified in Section 3.8 of the SAR. The description of
18 the analyses is thoroughly defined in that section.

19 Unless there are any other questions, that
20 finishes my presentation.

21 MR. CARROLL: Are there any further questions for
22 Mr. Gerdes?

23 MR. DAVIS: Mr. Chairman, let me ask you something
24 real quick. There is a reference in Chapter 19 to the FSER
25 to an Appendix 19, which is purported to be a listing of all

1 of the issues that have come up in the staff's review. I
2 could not find that in the material that was sent to me.

3 MR. FRANOVICH: The final version does have
4 Appendix 19(a). It is only related to PRA questions
5 identified in the DSER. It has made it into the final
6 version, not the version that you received.

7 MR. DAVIS: Would it be possible for me to get a
8 copy of that?

9 MR. FRANOVICH: Certainly.

10 MR. CARROLL: Anything else?

11 [No response.]

12 MR. CARROLL: Let's recess until 1:25.

13 [Whereupon, at 12:25 the Subcommittee recessed, to
14 reconvene at 1:25 p.m., this same day.]

15

16

17

18

19

20

21

22

23

24

25

1 MR. FRANOVICH: No. I think we are.

2 MR. CARROLL: Oh, okay.

3 MR. FRANOVICH: Mr. Bagchi is still here, so --

4 MR. CARROLL: Yes. Okay. But not flood, in-
5 service testing or high energy lines?

6 MR. FRANOVICH: No. That will be tomorrow
7 morning.

8 MR. CARROLL: Tomorrow morning.

9 MR. DAVIS: Well, when are we going to get to the
10 important part, the PRA? Doesn't sound like you've left any
11 time for that, Mr.

12 MR. CARROLL: Tomorrow.

13 MR. LINDBLAD: We're talking about deterministic
14 schedule and he's talking about his probabilistic schedule.

15 MR. CARROLL: It will happen at 8:35 tomorrow
16 morning.

17 MR. LINDBLAD: Probabilistically.

18 MR. CARROLL: Probabilistically.

19 Okay. Are we all -- everybody happy with the way
20 we've ordered things?

21 Okay? All right. Ivan's questions.

22 MR. CATTON: Is that what you just gave me?

23 MR. CARROLL: Yes.

24 MR. CATTON: I guess the first one was the SER --

25 COURT REPORTER: Microphone, please.

1 MR. CARROLL: Mike. Go ahead.

2 MR. CATTON: The first question dealt with the SER
3 on the codes being used by combustion. I have it. I
4 haven't had a chance to look at it.

5 The second is the three-dimensional studies done
6 at Oak Ridge on temperature distributions in the vessel
7 wall. And the staff says it is presently reviewing the
8 thermohydraulic and structural integrity aspects of thermal
9 stratification for plume generation. Can't ask for any more
10 than that.

11 MR. CARROLL: Now tell me what you're looking at
12 so I can follow.

13 MR. CATTON: Well, it's something that Doug gave
14 me. It says "NRC Staff Responses to ACR's questions on the
15 System 80 Plus Standard Plant Design.

16 MR. CARROLL: Do I have this, Doug?

17 MR. CATTON: And there are basically two
18 questions.

19 MR. CARROLL: Oh, okay.

20 MR. CATTON: The first question was about the
21 paper presented at the SMER conference by the people from
22 Oak Ridge, and the second was the SER's for the torque code.
23 The CETOPD code and there's something -- CEN139AP
24 statistical combination of uncertainties. I have the SER.
25 I'll take a look at it. At least I think that's what I

1 have.

2 MR. CARROLL: And that was the --

3 MR. CATTON: September 14th, 1976.

4 MR. CARROLL: How long would it take you, Ivan, to
5 go through what they've written here so we could --

6 MR. CATTON: I don't know. I think --

7 MR. CARROLL: -- let the staff go home.

8 MR. CATTON: Why don't you let them go home then.
9 If I come upon something we can communicate it to them. How
10 does that sound?

11 MR. FRANOVICH: That's fine on the SER's for the
12 three topical reports. We don't have Reactor Systems Branch
13 people here today anyway. I was going to say there was one
14 question on the 60-year design life. We do have several
15 people here waiting to respond. I realize that wasn't your
16 question.

17 MR. CATTON: There was one other thing before they
18 take the microphone away from me, and that's this question
19 about the ATHOS code that they use for steam generators.

20 We're having problems getting a copy of the models
21 and correlation document. I think it's -- I wrote it down
22 here.

23 The one I would like to see is referenced
24 somewhere. Every report that's three volumes there's a co-
25 user, a -- I forget what they are, but one of the deals with

1 the models of correlations or the basis for the ATHOS code.
2 I would like to see that.

3 I would like to see that. Does the staff rely on
4 that in any way?

5 MR. FRANOVICH: No. The ATHOS code was not used
6 for to make a safety decision for steam generator II
7 ruptures. There was provided -- some information was
8 provided in part of the steam generator II rupture analysis
9 but the topical reports from EPRI were not submitted on the
10 document list to my knowledge.

11 MR. CATTON: Then I'm not going to be able to see
12 it, so I'll ask you another question then. How did you deal
13 with the critical velocity that leads to fluid elastic
14 instabilities?

15 What did you do? It's a different steam
16 generator.

17 MR. FRANOVICH: Again, we don't have the
18 appropriate people to discuss that, but we didn't review
19 ATHOS code in any detail.

20 MR. CATTON: I understand that answer.

21 MR. FRANOVICH: We had a different emphasis on a
22 review. Rather than two ruptures and looking at
23 thermohydraulic performance on the secondary, we looked at
24 it from the SECY paper position which was more of reducing
25 the likelihood of containment bypass. And there are a

1 number of design features offered on system 80 plus to
2 reduce the likelihood of containment bypass.

3 MR. CATTON: Maybe we're not talking the same
4 language. The question of fluid elastic instability leading
5 to tube ruptures is what I would like to address. Now, if
6 it's an existing steam generator, that's one thing. But as
7 I understand it, the CE system steam generator is different.

8 How did you conclude that that's not a problem or
9 did you even look at it?

10 MR. BAGCHI: This is Goutam Bagchi. I can only
11 offer you one insight. We had a staff meeting yesterday and
12 the Materials Branch folks told me that they don't use ATHOS
13 code at all. And best of my knowledge, the Plant Systems
14 folks don't use it at all either. But there is a
15 circulation ratio of 3.7 for this system 80 plus as opposed
16 to 3.0 for Palo Verde. So there is high recirculation.

17 So the kinds of problems that have been
18 encountered in Palo Verde are not likely to occur in System
19 80 plus. But beyond that, I just --

20 MR. CATTON: Well, you just said the recirculation
21 ratio is higher?

22 MR. BAGCHI: Higher.

23 MR. CATTON: That means the cross-flow through the
24 tubes is higher. If that's the case, then you could well
25 move closer to the critical velocity. So I don't think I

1 could come to the same conclusion that you just did.

2 MR. BAGCHI: Critical velocity for the tube
3 vibration, you mean?

4 MR. CATTON: That's right.

5 MR. BAGCHI: Well, I was addressing another
6 problem. The problem I was addressing is crack buildup and
7 cracking of the tubes as a result of that.

8 MR. CATTON: A couple of the problems that have
9 been experienced have been the result of fluid elastic
10 instability.

11 MR. DAVIS: Are you talking about one rupture
12 leading to several or --

13 MR. CATTON: Well, the first thing is -- see,
14 there's a threshold and the threshold is a critical
15 velocity. What happens is the amplitude of the tube
16 vibrations grows very slowly as you increase the cross flow
17 or increase the recirculation ratio. But there's a big knee
18 in the curve and it turns up very dramatically at some
19 specific critical velocity.

20 MR. BAGCHI: I would like to answer that.

21 MR. CATTON: I would like to know what that
22 critical velocity is for the CE steam generator. And then I
23 would like to know what the actual velocity is to decide how
24 much margin you have.

25 MR. BAGCHI: I will find out about the critical

1 velocity and what the natural frequency is.

2 MR. CATTON: When I asked CE this question they
3 told me that the ATHOS code was used. If the ATHOS code was
4 used to evaluate that, I'd like to see it. But if you
5 didn't evaluate it. I think you ought to.

6 MR. BAGCHI: No. We did not evaluate the ATHOS
7 code.

8 MR. DAVIS: Ivan, are you talking about -- I'm
9 sorry. I'm not understanding this -- increased likelihood
10 of steam generator rupture --

11 MR. CATTON: Yes.

12 MR. DAVIS: -- or propagation of rupture to other
13 tubes?

14 MR. CATTON: Well, I think you have to take it one
15 at a time. There is a question of propagation. And I
16 think if you take a look at the Bahamas incident, you'll see
17 that there's whole bunch of tubes broken but that was a
18 result, I think, of one of them whipping around once it had
19 broken.

20 MR. DAVIS: CE makes the argument in the PRA, if I
21 read it right, that one tube is limiting and that if you get
22 more than that you're better off because you need to get the
23 pressure of the primary down if you lose high pressure
24 injection.

25 MR. CATTON: I don't know.

1 MR. DAVIS: But that might not be related to this.

2 MR. CARROLL: Does combustion having any comments
3 on this?

4 MR. FRANOVICH: Yes.

5 MR. CATTON: What I don't understand is the strong
6 concern that the fluid elastic stability tube rupture
7 engendered in Japan and almost the lack of interest here.

8 MR. RITTERBUSCH: There is no lack of interest.
9 This is Stan Ritterbusch, ABB.

10 There is no lack of interest on the part of ABB on
11 steam generator performance and especially the secondary
12 site thermohydraulics. We use version 2 of the ATHOS code.
13 We do have the documentation. It's not proprietary. It's
14 our understanding that the results are very, very close to
15 those that you would obtain with version 3, which is, I
16 believe, the current state-of-the-art documented by EPRI.

17 MR. CARROLL: Well, you say it's not proprietary,
18 Stan? Why can't Ivan get a copy of it?

19 MR. RITTERBUSCH: It's my understanding that a
20 copy of the ETHOS 2 code documentation can be purchased from
21 EPRI.

22 MR. CATTON: You got to be kidding. You're
23 expecting me to buy it? They usually put prices on those
24 things of \$100,000 or more.

25 MR. RITTERBUSCH: No. I didn't --

1 MR. CATTON: Have you looked at the prices inside
2 the cover of the EPRI documents?

3 MR. RITTERBUSCH: No, not at all. What we can do,
4 when our people from Chattanooga come April 5th and 6th we
5 can bring the two volumes and we can get the details sorted
6 out at that time.

7 MR. CATTON: All right.

8 MR. LINDBLAD: For less than \$100,000.

9 MR. CATTON: Some of the prices on that inside
10 cover will just blow your socks off.

11 Yes. I'd like to see it. I would like to have it
12 in advance, but if I can't, I can't, I guess.

13 MR. CARROLL: Is there some way Ivan could get it
14 in advance?

15 MR. RITTERBUSCH: He could come to Chattanooga.

16 MR. CATTON: Is there's some other way I could get
17 it in advance?

18 MR. CARROLL: Apparently not.

19 MR. RITTERBUSCH: I'll find out. If we had more
20 than one copy of the documentation, of course. We've got
21 one set. We'll check into it and work something out.

22 MR. CARROLL: I guess there's huge copyright stamp
23 on the side of the cover also.

24 MR. RITTERBUSCH: That's correct.

25 MR. CARROLL: Okay. So we've dealt with the

1 Catton questions.

2 MR. CATTON: Sort of.

3 MR. CARROLL: Sort of. For the time being.

4 Now, did I understand from the staff that you have
5 people here that can address the 60-year design life that
6 would like to go off and do something useful?

7 MR. FRANOVICH: There is written response to that
8 one, but -- that one particular question. But we also have
9 other people available from Plant Systems Branch to discuss
10 any other questions you may have on that response.

11 MR. CARROLL: Well, what I'm looking for is -- are
12 there people that could answer the questions and then go
13 back to work that we could release if -- or are they going
14 to be here anyway?

15 MR. LINDBLAD: Are you trying to reinvent
16 government here?

17 MR. FRANOVICH: No. I think they were planning on
18 staying here for only about another hour. Go through leak-
19 before-break and depart. So, --

20 MR. CARROLL: Okay. Well, let's -- so what are
21 the -- leak-before-break is one topic. What else are there
22 here --

23 MR. FRANOVICH: That's basically it. After that we
24 get into severe accidents and they -- as far as I know, they
25 won't be here.

1 MR. CARROLL: Okay. But they're -- how about the
2 60-year life thing that you brought up?

3 MR. FRANOVICH: That's why I was recommending that
4 if we can take a look at the response, if the response needs
5 any further clarification, we could discuss that now.

6 MR. CARROLL: Okay. Charlie, are you happy with
7 the response?

8 MR. WYLIE: Well, yes. I read the response. I
9 don't have any problem with what the staff has written. My
10 question really is the applicant in that there are bits and
11 pieces of what the applicant, the COL applicant, has to do
12 to achieve 60-year design life program control, I call it.

13 EPRI, in the URD outlined what they thought was an
14 acceptable program for management of a 60-year design life
15 by the COL holder and it seems to me that there ought to be
16 identified in the COL license information section, wherever
17 that is. And in the interface requirements it brings this
18 together to assure that the applicant set up such a program
19 similar to what EPRI has described.

20 MR. RITTERBUSCH: I guess that -- Stan
21 Ritterbusch, again. I think that question was directed at
22 the applicant, so I'd like to try and respond.

23 The work that we present in CESSAR/DC for design
24 certification is that work necessary to show compliance with
25 regulations and the standard review plan and so on and so

1 forth. We are familiar with the EPRI/URD requirements. We
2 provide in the System 80 plus design those design features
3 that we think will enable us to comply with the EPRI/URD
4 requirement and where it's important for safety reasons, we
5 provide certain specifications in CESSAR/DC.

6 But what I'm really getting to is that the details
7 of the life management plan and the maintenance plans are
8 part of commercial proposals and work that would be
9 accomplished in the final stages of plant design and plant
10 procurement.

11 MR. WYLIE: Well, to maintain a plant with its
12 design basis requires that you manage -- and I don't argue
13 what you say in your chapters about how you're going to do
14 it. It sounds acceptable. They're scattered throughout the
15 SSAR. But it only appears reasonable that you identify it
16 to the COL applicant and then place a requirement that he
17 has to set up such a plant and pull these things together to
18 maintain this throughout the life of the plant.

19 It has to be done early. He can't wait until
20 later to do it.

21 MR. RITTERBUSCH: I agree that there's information
22 throughout the SSAR, but most of it is summarized in the
23 design reliability assurance program, so that is the focal
24 point for all the reliability and maintenance type
25 requirements and interfaces. And in fact, I believe there

1 is an action item that the COL applicant look at our product
2 from our reliability assurance program.

3 MR. WYLIE: Oh, I understand that. But --

4 MR. CARROLL: It's in here.

5 MR. RITTERBUSCH: Yes, it's in there. This is the
6 same thing.

7 MR. WYLIE: What's the reluctance to saying in the
8 COL license information section, whatever that is, or the
9 interface requirement, that a COL applicant has to establish
10 a design life control program.

11 MR. RITTERBUSCH: Well, I mean, it could be done,
12 but we established an agreement with NRC staff some
13 groundrules or consideration for definition of what would go
14 on the COL applicant list and what goes on that list are
15 items that are important to the staff's safety conclusion.
16 And further more, items that are well defined enough so that
17 a COL applicant can turn to the various sections of
18 CESSAR/DC and find out the specific details of what he needs
19 to do.

20 If is something open-ended such as a maintenance
21 program, which is really in the utility's purview and not
22 ours, then we would not provide a lot of detailed
23 specifications on that program.

24 MR. CARROLL: Well, Charlie, you're talking about
25 a life management program.

1 MR. WYLIE: That's correct.

2 MR. CARROLL: And there is a COL applicant
3 commitment or action item or whatever for the reliability
4 assurance program. Is that not right? And doesn't that
5 take care of, Charlie, life management?

6 MR. WYLIE: Is that identified as a COL action
7 item?

8 MR. CARROLL: The RAP?

9 MR. WYLIE: D-RAP, particularly.

10 MR. CARROLL: What about O-RAP or D-RAP?

11 MR. RITTEBUSCH: Yes. D-RAP is our method of
12 providing input to O-RAP.

13 MR. CARROLL: And that is a COL applicant action
14 item?

15 MR. RITTEBUSCH: That's correct.

16 MR. CARROLL: Well, so, is it a semantics problem?
17 You're calling it a life management program and they're
18 talking --

19 MR. WYLIE: No. I don't think so. I don't think
20 so. Maybe we need to study this more, but it seems like to
21 me that it's not specifically identified that the COL
22 applicant can set up a program to do what I said.

23 MR. RITTEBUSCH: I would agree that D-RAP does
24 not resolve what Mr. Wylie is asking here today. I guess
25 what I'm saying is that it wasn't our intent to address all

1 of the EPRI/URD requirements in CESSAR/DC. In fact, what
2 happens for commercial proposals is the URD requirements are
3 referenced in proposals and then we have to demonstrate our
4 compliance with the URD requirement.

5 So it's through the commercial proposal process
6 that we pick up items that are not specifically covered in
7 the safety related documentation, such as we have in
8 CESSAR/DC.

9 MR. WYLIE: Well, I've read pretty much -- I think
10 I've read most of it where you say what actions are required
11 to maintain the design life of components and replace them
12 and so forth. That's in the SSAR. But it seems to me that
13 there should be something said regarding license -- COL
14 license information or interface requirements. That they
15 establish a plan that pulls all this stuff together.

16 MR. RITTERBUSCH: One thing we can do is add to
17 our D-RAP program a statement that would indicate that the
18 utility must look at the EPRI/URD. I could not obligate the
19 utility to do anything, so it would essentially be a
20 reminder, a pointer to the utility. But I think it would be
21 outside our scope to require that the utility have such
22 programs.

23 MR. WYLIE: Well, that would be satisfactory, I
24 would think. It's really a flag saying you've got to do it.
25 And then it is incumbent on the staff then to look to see

1 whether they've done it or not.

2 If you're going to maintain the design basis
3 throughout the life of the plant, you've got to have some
4 management of the agent.

5 MR. RITTERBUSCH: We believe -- well, I guess we
6 have to ask what is the design basis figure referring to.
7 If it's a safety related design basis, NRC staff has made
8 sure that we've taken care of that. And that goes for the
9 D-RAP program.

10 MR. WYLIE: But only if you maintain that plant
11 and replace items when they're needed to be replaced and you
12 refurbish items when they need to be replaced and so forth.
13 You say you're going to do that all the way here.

14 MR. RITTERBUSCH: Correct.

15 MR. WYLIE: And that places that burden on the COL
16 holder. I don't see the reluctance to say he's going to do
17 it.

18 MR. CARROLL: The reluctance is that combustion
19 can't really speak for the COL.

20 MR. WYLIE: But they do it all the way through
21 here. They say the COL holder will do this and thus and
22 such all the way through here.

23 MR. RITTERBUSCH: We can separate a little bit
24 from the way we've been doing COL action items and we can
25 say that the COL applicant needs to go look at the EPRI/URD

1 and determine whether they want to -- the details of how
2 they want to implement these programs. But it's not really
3 anything more than a flag.

4 MR. WYLIE: I think it would be worth a flag to
5 alert them and to alert the staff that 15-20 years from they
6 that they go back and look at this thing. They just don't
7 do that.

8 MR. RITTERBUSCH: Possibly -- we can add a flag.
9 That's easy. So I'll make some words and we'll propose a
10 statement somewhere in our documentation.

11 MR. CARROLL: Okay. All right. Shall we move on
12 to leak-before-break?

13 MR. MICHELSON: Before you move on, we were
14 discussing some of these questions but not others.

15 MR. CARROLL: Only because in one case Ivan's not
16 going to be here --

17 MR. MICHELSON: The others are going to be covered
18 later.

19 MR. CARROLL: -- tomorrow.

20 MR. MICHELSON: Well, there's one that I'd like to
21 ask about now then.

22 MR. CARROLL: All right.

23 MR. MICHELSON: That's the use of water for oil
24 fires.

25 MR. CATTON: And the response we got was they had

1 called the University of Maryland and --

2 MR. CARROLL: Couldn't find the report.

3 MR. CATTON: Well, there isn't a report. The work
4 is underway by Quintieri for us.

5 MR. CARROLL: If you talked to him, he should have
6 been able to tell you that.

7 MR. CROM: This is Tom Crom. We talked to both
8 Dr. Quintieri and Dr. Milke and they did not -- at least did
9 not give us any insight on the work that was being done.

10 MR. MICHELSON: They didn't claim it wasn't being
11 done?

12 MR. CROM: No, no they did not.

13 MR. MICHELSON: I thought the inference was in the
14 reply they didn't even talk about it.

15 MR. CROM: Yes. Maybe we misunderstood you. We
16 thought there was paper that was already out.

17 MR. CATTON: No, there's not a paper out. But they
18 were doing the work. Jim Quintieri --

19 MR. CARROLL: Received the actual funding.

20 MR. CATTON: Yes. And he has done a study of use
21 of water on diesel oil fires. He's came to some rather
22 negative conclusions. Now he's supposed to bring that to us
23 what -- in May?

24 MR. MICHELSON: We're unaware of any paper being
25 developed the way your answer says. I don't believe that

1 that's possible.

2 MR. CATTON: Well, your answer isn't right.

3 MR. MICHELSON: It cannot be right.

4 MR. CROM: We talked to Dr. quintieri. He did not
5 lead us that he was working on anything. We can take that
6 response out of there and we can talk after he comes to his
7 conclusion, and we can talk about it later.

8 MR. MICHELSON: Let's check his billing.

9 MR. CATTON: Yes. That's right. If he hasn't
10 done anything, I'd really like to know about it.

11 MR. MICHELSON: He has some preliminary results,
12 but his preliminary results don't look too good.

13 MR. CROM: When we find out what his results are,
14 we'll be glad to address each one.

15 MR. CATTON: Maybe somebody from CE would like to
16 attend our subcommittee meeting when we address these
17 issues.

18 MR. RITTERBUSCH: I guess I can find from Doug Coe
19 when that is?

20 MR. CATTON: Yes. Or from Dudley.

21 MR. COE: Well, right now it's being considered
22 for May 10th, but I'm not sure that that's the date.

23 MR. CATTON: We wanted it to be May 10th but I
24 guess there are some people who are having schedule
25 problems, so we're not quite sure.

1 MR. RITTERBUSCH: I'm a little uncomfortable with
2 the way that was left. We will -- I mean, we have a
3 schedule and I'm not sure whether ongoing work -- you know,
4 if results come in in June or July or whenever. I'm a
5 little uncomfortable with saying that our review is -- or
6 implying that our review may be open until the results of
7 that program.

8 MR. CATTON: Well, if their conclusion were
9 looking good, I wouldn't worry about it. But the thing is
10 you're being informed now that the use of water on a diesel
11 oil fire looks like it's a problem. So I think you know
12 about it now.

13 MR. CARROLL: That is tier 1 material isn't it,
14 Stan? So it could be -- I mean, you're not talking about
15 something that's --

16 MR. RITTERBUSCH: But you're also supposed to be
17 making a final safety determination, too, and until you've
18 got some of these things settled it's very difficult to make
19 it. You can't make it without knowing the answer.

20 MR. CARROLL: Well, there are alternatives.

21 MR. MICHELSON: Well, leave it an open item in our
22 letter. That's another alternative.

23 MR. LINDBLAD: But we also have to hear Dr.
24 Quintieri's concern. Right now it's not articulated it all.

25 MR. CATTON: All I have is preliminary

1 information.

2 MR. LINDBLAD: So we really need to hear.

3 MR. CATTON: And we will hear in May.

4 MR. CARROLL: Well, just hypothetically, if it was
5 August --

6 MR. CATTON: We'd switch to another means of fire
7 suppression.

8 MR. LINDBLAD: Why?

9 MR. CATTON: If water doesn't work.

10 MR. LINDBLAD: What if we just don't care one way
11 or the other until August?

12 MR. MICHELSON: Then we have to decide.

13 MR. CARROLL: How will we deal with it, Ivan?

14 MR. LINDBLAD: I mean, your remark really does not
15 have any explanation.

16 MR. CATTON: Why it may not be any good?

17 MR. LINDBLAD: Yes. I mean, Dr. Quintieri doesn't
18 judge for us.

19 MR. CATTON: No, he doesn't.

20 MR. LINDBLAD: The suitability of the --

21 MR. CATTON: That's fine. Fine. I agree. I'm just
22 indicating that preliminary calculations have shown that
23 there may be a problem. And that means that you have to
24 take a good look at it. And I'm not sure it's our job to
25 take a look at it.

1 MR. LINDBLAD: I guess I'd like to see what the
2 problem is before --

3 MR. CATTON: I guess the problem is the generation
4 of steam and then the steam condensing. I don't recollect
5 all of the details.

6 MR. RITTERBUSCH: I would like to add a comment.
7 I just want to be very clear that we believe that the proper
8 method of fire protection for this design is the water
9 suppression system as described. And we would like the
10 review closed out on that basis. If it turns out that
11 there is some new research result that comes in at some
12 future time NRC staff is well capable of bringing that to
13 the attention to people holding an FDA. There's a process
14 to be gone through if new issues arise.

15 MR. MICHELSON: No, not really, unless you want to
16 make it a Commission action. We've got finality when we
17 issue the certificate. That's final.

18 MR. CARROLL: When do we write our letter?

19 MR. CATTON: June 2.

20 MR. RITTERBUSCH: June. Yes.

21 MR. CATTON: And as far as our letter is
22 concerned, we have time.

23 MR. DAVIS: Does the fire protection system meet
24 NRC requirements the way it's now designed?

25 MR. CATTON: Yes.

1 MR. DAVIS: Oh, it does?

2 MR. CARROLL: Well, there are a lot of plants out
3 there that use water for the diesel oil fire. We're getting
4 them but --

5 MR. MICHELSON: We also question whether water was
6 the right -- you know, on the ABWR it's --

7 MR. DAVIS: You mean foam.

8 MR. MICHELSON: Foam. Yes. But water was
9 questioned there and that's what first got us started,
10 because we said, well, you know, maybe someone said water
11 was the only way.

12 MR. CATTON: I guess there's just a complete lack
13 of analysis in this area. It's just follow the guidelines
14 that basically were generated 50 years to, 60 years ago.

15 MR. LINDBLAD: The analysis may be weak but
16 there's a lot of experience, isn't there?

17 MR. CROM: This is Tom Crom. Let me address that a
18 little bit. We have not talked about fire protection. We
19 will April 5th and 6th. We are not using a methodology from
20 50 years ago. We are not using combustible loading. We are
21 proposing using linear heat rate analysis, new fire
22 methodologies, new computer codes that have been generated
23 most recently from the University of Maryland and so forth.

24 We're not talking about using any of the
25 combustible loaded calculations. We're going to use linear

1 heat rate type analysis.

2 MR. CARROLL: Okay. So I guess we'll just let
3 this play out. We'll be hearing more about fire protection
4 next month. So let's get on with leak-before-breaks.

5 MR. MICHELSON: Well, before we do that, have we
6 covered everything on this item then or can we bring up the
7 rest of it later.

8 MR. CARROLL: The fire protection?

9 MR. MICHELSON: Yes. I have a couple of questions
10 on it as well.

11 MR. CATTON: I think if it's on the fire protection
12 area I'd like to hear it.

13 MR. CARROLL: Okay. Do it, Carl.

14 MR. MICHELSON: Yes. This isn't very long.

15 On the bottom of page 50, the last couple of
16 lines, it says that the generator is air cooled and it's
17 going to have a NEMA 125A, whatever that is -- or NEMA
18 1.25.A.

19 MR. CROM: That's the requirement for it to be
20 drip proof.

21 MR. MICHELSON: Yes. I'm not acquainted with that
22 particular number, NEMA enclosure, but I ask you just one
23 question. Is that enclosure rated with the generator
24 operating? In other words, can it draw its normal cooling
25 air through in a real fog and still work?

1 MR. CROM: Not for long-term. Our response on it
2 earlier is that most fires in the diesel generator room will
3 occur with operators are there and the detection will be
4 done and be put out by manual means.

5 MR. MICHELSON: But I think you probably missed
6 was the thrust of the question to begin with, and it didn't
7 get articulated here very well in the statement of the
8 question. And that is, the concern was this is a non-
9 seismic fire protection scheme and what happens if it
10 inadvertently actuates. And then it gets into the question
11 of the seismic qualification of the nozzles and so forth.
12 And then we wonder, well, maybe the equipment is well
13 protected to begin with.

14 And you said yes, it was drip proof and so forth
15 and I wondered what that really meant. So you went back and
16 checked and I don't think this kind of enclosure will handle
17 it.

18 MR. CROM: You're right. It will only protect for
19 short-term.

20 MR. MICHELSON: A very short-term.

21 MR. CROM: But the thing that we discussed in our
22 response is most fires, operators will be present because
23 any time the diesel generator is being tested or if it's
24 running, there will be operators at the local control panel.

25 MR. MICHELSON: If you have a fire at that time

1 then you start addressing it and you presumably do it all in
2 a timely fashion. But if a fire is in that compartment, I
3 never had any question about the viability of the generator.
4 I assume it's probably --

5 MR. CROM: Yes. The previous response on the
6 seismic was that the probability is extremely low that there
7 will be an inadvertent actuation since we are using pre-
8 action sprinklers and that the piping is seismically rugged.

9 MR. MICHELSON: And then the argument about the
10 pre-action is when we started getting into this whole
11 question, well, is that the way to address an oil fire.

12 MR. CROM: That's correct.

13 MR. MICHELSON: The real experts that I've talked
14 to say no, that isn't the way you address it, even if you
15 want to use water. You don't do it one sprinkler at a time
16 on an oil fire. You've got to do a whole area. And that's
17 where you get into these arguments.

18 I've looked at this thing for 20 years now and
19 I've talked to a lot of utilities, including Duke and so
20 forth back before your day, perhaps. And each utility had
21 their own way, their own experts, and they knew that was the
22 only way to do it.

23 MR. CROM: Let me -- if it's okay, I'd like to
24 address this next meeting. I'm going to bring the fellow
25 that has done all the Duke plants from McGuire, Catawba and

1 Iconi from day one.

2 MR. MICHELSON: Were they all done with water?

3 MR. CROM: No. The older plants did not. They
4 used gaseous systems and those have been outlawed based on
5 halon type systems.

6 MR. MICHELSON: No. They used CO2, I think.

7 MR. CROM: Yes. That's correct. CO2. That's
8 correct.

9 MR. MICHELSON: That's not outlawed.

10 MR. CROM: Yes. But they've had a lot of
11 instances in McGuire plants where we have taken people out
12 on stretchers because those have inadvertently gone off.

13 MR. MICHELSON: You've got CO2 in your spreading
14 rooms and so forth I think you have, too, don't you?

15 MR. CROM: That's correct. It's not a pleasant
16 sight when you see those people coming out.

17 MR. MICHELSON: It's got a risk. It's got a risk.
18 So do oil fires have a risk.

19 Okay.

20 MR. CARROLL: Is that all your questions on fires?

21 MR. MICHELSON: That's all.

22 MR. CARROLL: Okay. Mr. leak-before-break, it's
23 all yours.

24 MR. PECK: My name is Daniel Peck. I am the
25 Director of Mechanical Engineering at ABB Combustion

1 Engineering at Windsor, Connecticut. I'm going to summarize
2 the application of leak before a break on the System 80 plus
3 piping.

4 System 80 plus has used the traditional LBB method
5 on five different pipes, all of which are inside
6 containment. What is perhaps not traditional about the
7 leak-before-break that we have done is that the lines are
8 not yet built.

9 In the past, leak-before-break has always been
10 applied to existing piping or piping that was under
11 construction. What I will be showing you is how we have
12 defined a set of requirements for the System 80 plus piping
13 designer to assure that the as-designed and as-built piping
14 will in fact satisfy traditional LBB criteria.

15 MR. MICHELSON: Just to make sure I understand,
16 clearly this is inside of containment. Are you proposing to
17 apply it all presently outside of containment?

18 MR. PECK: No, sir.

19 MR. MICHELSON: How about the penetration lines
20 such as main steam and feed water which are both inside and
21 outside of containment? Are you applying it outside of
22 containment there?

23 MR. PECK: Inside only, .

24 MR. MICHELSON: What do you do about the zone
25 between isolation valves and high energy lines?

1 MR. PECK: There is an anchor at each of the lines
2 where it penetrates the containment so that the effects are
3 indeed physically limited to inside containment.

4 MR. MICHELSON: You essentially, if I understand
5 the SAR correctly, have essentially said there are no breaks
6 in these penetration lines between the isolation valves and
7 that it's sort of even better than leak-before-break. It
8 will not even break.

9 MR. PECK: That is the subject for tomorrow's high
10 energy line break.

11 MR. RITTERBUSCH: Briefly, those pipes have guard
12 pipes on them.

13 MR. MICHELSON: Everyone will be guarded? Main
14 steam?

15 MR. RITTERBUSCH: I'm going to wait until our
16 representative get back, but I think so. High energy lines
17 have the guard pipes.

18 MR. MICHELSON: Okay. That will do it.

19 [Slide.]

20 MR. PECK: Here's what I'm going to tell you. I
21 would like to discuss which pipes we have applied leak-
22 before-break on System 80, what we use it for, what is the
23 basis for choosing the lines that have LBB, how we have
24 demonstrated LBB in the impact on System 80 plus of the LBB.

25 MR. CARROLL: And then when you finish all that

1 you're going to tell us what you told us.

2 MR. PECK: That is the Army way.

3 These are the five lines.

4 [Slide.]

5 MR. PECK: The main coolant lip piping. There are
6 two 42 inch lot legs, four pump discharge legs. These are
7 30 inch. Four pump suction legs, also 30 inch. These are
8 carbon steel with stainless steel cladding.

9 Surge line, 12 inch of stainless steel. There are
10 two 16 inch shutdown cooling lines of stainless steel, four
11 direct vessel injection lines, 12 inches stainless and the
12 four main steam lines, 28 inch carbon steel, the inside
13 containment portions of these lines.

14 The next set of --

15 MR. MICHELSON: The feed water line will not have
16 leak-before-break?

17 MR. PECK: The feed water line will not have leak-
18 before-break applied to it.

19 MR. CARROLL: Did I learn somewhere that you were
20 leaving the option open to the COL holder to apply it
21 outside of containment?

22 MR. RITTERBUSCH: We are not aware of any such
23 option.

24 MR. PECK: We have not made that statement except
25 as it may generally apply to all licensees.

1 Brief schematic of the main coolant loop. I think
2 you're all familiar with that, but you can see the hot legs,
3 the pump discharge legs and the suction legs, pump suction
4 legs.

5 [Slide.]

6 MR. PECK: This is a schematic of the surge line.
7 It runs from one of the hot legs around the steam generator
8 over to the pressurizer.

9 MR. CARROLL: With a sloped line?

10 MR. PECK: It has a sloped line. This is the
11 direct vessel line to our four direct vessel injection
12 lines. They directly inject into the reactor vessel
13 annulus. They run over to where they split for the safety
14 injection tank and run over to the containment penetration
15 for the high pressure safety injection.

16 This is the shutdown coolant piping.

17 [Slide]

18 MR. PECK: There are two shutdown cooling lines,
19 one off of each, the bottom of the hot leg out through
20 containment.

21 MR. MICHELSON: Does your leak-before-break start
22 right at the interface with the primary containment?

23 MR. PECK: Yes. There is an anchor here at the
24 shield building.

25 MR. MICHELSON: That is outside of primary

1 containment.

2 MR. PECK: There is ballast attachment to the
3 primary containment over to the anchor.

4 MR. MICHELSON: And so it starts at the anchor?

5 MR. PECK: It is anchor to anchor. The rules for
6 leak-before-break is anchor to anchor. The other end is
7 where it attaches to the main pipe.

8 MR. MICHELSON: I just did not see the penetration
9 design. It looked like there was a pipe anchored.

10 MR. PECK: It does not show.

11 And then finally we have the main steam piping.
12 There are two steam lines off of each steam generator. This
13 shows one steam generator. And again, there is an anchor at
14 the shield building with billow seals to the primary
15 containment. So it is the portion from the anchor at the
16 shield building to the top of the generator, the steam line
17 that we are applying leak-before-break.

18 [Slide]

19 MR. PECK: What do we use it for? Leak-before-
20 break is used to eliminate dynamic load events, postulated
21 pipe breaks. It does not eliminate containment pressure
22 temperature effects of design basis pipe breaks. It does
23 not eliminate emergency core cooling system requirements and
24 does not eliminate environmental qualification requirements
25 of design basis pipe breaks.

1 So it's only used for the dynamic load effects.

2 MR. CARROLL: So you have not taken advantage of
3 it to lengthen the time it takes for the emergency diesel
4 generators to come up?

5 MR. PECK: No.

6 MR. CARROLL: Why not?

7 MR. PECK: We only use it for dynamic load effects
8 because those are the regulations. The current regulations
9 make this distinction between what it is applied to and what
10 it is not applied to.

11 [Slide]

12 MR. PECK: The basis for the choice of these lines
13 is that first, we must show that they are qualified because
14 they are not susceptible to any of these types of effects:
15 water hammer, creep, erosion, corrosion, fatigue or
16 environmental conditions.

17 So we start first with a set of pipes that are not
18 susceptible to these effects. Then we must show that they
19 satisfy various evaluation criteria with margins that are
20 prescribed. A margin of 10 on leak detection capability; a
21 margin of 2 on crack length; and a margin of square root of
22 2 on loads.

23 These are all prescribed in the standard or
24 traditional NRC requirements for leak-before-break. New Reg
25 1061 Volume 3.

1 MR. LINDBLAD: What is your leak detection rate
2 and can it be masked by other --

3 MR. PECK: The leak detection rate is the standard
4 leak detection rate in accordance with New Reg 1.45, one
5 gallon per minute sump monitoring for the primary system.
6 We also monitor the condensate cooler for the effect of
7 condensation for steam that might be in the atmosphere of
8 the containment.

9 I will show you a little more in detail.

10 This slide just gives a numerical statement of the
11 acceptance criteria. We must postulate a crack length which
12 will leak 10 times the leak detection system capability, so
13 it is a one gallon per minute leak detection system. Then
14 we have postulated a 10 gallon per minute crack, leak size,
15 leakage crack size, and then we show that that crack size is
16 less than critical crack size, for a square root of 2 times
17 the maximum loads.

18 And also twice that crack length is less than
19 critical crack length for the maximum loads. Maximum loads,
20 for example SSE.

21 The process we used for System 80 plus piping was
22 first to confirm that piping system satisfies the
23 qualifications, not susceptible to those various phenomena.
24 Then we defined LBB acceptance criteria based on parametric
25 studies for use by the piping designers.

1 The method that we've developed requires
2 definition of only the pipe size and the material. Material
3 properties and pipe size. The routing of the pipe is not
4 defined in order to come up with the acceptance criteria.
5 The piping designer will then define the pipe routing and
6 demonstrate that he meets the acceptance criteria.

7 We have demonstrated that we meet these criteria
8 for each of the five pipes with preliminary designs of each
9 of the pipes. The main loop pipe is not preliminary but the
10 other piping, the branch line piping, is not final designed
11 at this time. But we have demonstrated that there is a
12 design which will satisfy the LBB criteria for each of the
13 piping.

14 MR. LINDBLAD: Is the final piping designer
15 permitted to call for welded lugs on your piping?

16 MR. PECK: For example, for support hangars?

17 MR. LINDBLAD: Yes.

18 MR. PECK: I guess that would be a standard piping
19 design feature.

20 MR. LINDBLAD: So your evaluation has included all
21 kinds of restraints on the piping?

22 MR. PECK: It is considered standard piping
23 design, nothing in particular. No lug per se because it is
24 not a final design at this time.

25 MR. MICHELSON: But you're keeping stress levels

1 down to some criteria which I assume is buried in the second
2 bullet.

3 MR. PECK: The requirements are basically ASME code
4 requirements. If you start putting too many lugs in the
5 wrong places --

6 MR. LINDBLAD: You will get stress
7 intensifications.

8 MR. PECK: But the normal design will catch you on
9 that. This would not cause any change in your normal design
10 practice and I will show you the type of acceptance
11 criteria.

12 The final design only needs to confirm the
13 material properties are within the parameters that were used
14 to develop the acceptance criteria. We also included in
15 CESSAR the methods for developing the criteria in case the
16 piping designer chooses to go with a different material than
17 what we assumed. Maybe a better material comes along and he
18 would like to use it. Well, the method for developing the
19 LBB acceptance criteria are built into the CESSAR so that he
20 can develop those criteria for the new material property.

21 If he chooses the material property that we use
22 the parametric study, he merely needs to show the material
23 properties fall within the range that we selected. And then
24 he, of course, has to check the as-built design for the
25 actual loads that are in the piping.

1 MR. LINDBLAD: Piping frequently includes valves.
2 In your discussion do they include valves and bonnets?

3 MR. PECK: Valves are not treated per se in LBB.
4 They're simply part of the piping run.

5 MR. LINDBLAD: And so are they covered by the same
6 ASME criteria and stress intensification?

7 MR. PECK: Yes. They would be covered by ASME
8 code for normal design. But there is no special breakout
9 criteria for the valves on LBB.

10 MR. LINDBLAD: Let's say valve stems. Are they
11 covered by ASME code requirements?

12 MR. PECK: I'd have to say it's an ASME valve.
13 That's all I could say.

14 MR. MICHELSON: They don't cover the stems but
15 they cover the gates even though those aren't --

16 MR. PECK: This is an example of the acceptance
17 criteria that we have developed. The example I have chosen
18 is one of the figures that is in CESSAR. All the pipes and
19 all of the materials that we have used are in CESSAR. And
20 what is plotted here is for the surge line, a TIG weld for
21 SSE load versus normal operating load.

22 So as the piping designer does his design and he's
23 showing that he's meeting all the other ASME code stress
24 requirements, he then goes into this chart and says, what is
25 my normal operating load at the point of evaluation for LBB

1 and what is my SSE load at that location.

2 If he is below the line he has passed LBB, so
3 built into this chart are all of the requirements for the
4 different margins on load and crack length. One of these
5 lines is the margin load. The other line is the margin on
6 crack length. And so as long as he's below both of those
7 lines then he knows his design has passed LBB for that
8 particular pipe for that particular material.

9 Now what has been the impact on the design for
10 System 80 plus of using the LBB? Well, you know System 80
11 plus is based on System 80, which is implemented at Palo
12 Verde. Palo Verde was originally designed assuming pipe
13 breaks in the main loop and before they got their operating
14 license we went through the leak-before-break and we
15 demonstrated that the main loop pipes passed leak-before-
16 break for Palo Verde. They were able to then remove pipe
17 whip restraints and things like that.

18 But when we passed the LBB, removed the pipe whip
19 restraints, we did not change anything else in the plant.
20 The basic System 80 plus design main loop retains all the
21 size and strength that the System 80 had, so we've not
22 withdrawn any margin for showing that we pass leak-before-
23 break.

24 Rather, what we've done is used that margin for
25 additional seismic margin because now the System 80 plus is

1 a higher seismic design requirement.

2 Most of the things are sized as big as they are
3 for stiffness for seismic considerations. We have not
4 removed any strength. We have removed pipe whip restraints
5 and features that are only there for pipe break effects.

6 And of course, we have also eliminated a lot of
7 analysis for various effects of dynamic loads, blow down
8 loads, subcompartment loads, jet impingement loads. There's
9 a lot of analysis that is not required to be done.

10 Which kind of brings us to the bottom line of why
11 do we want to do this anyway?

12 [Slide]

13 MR. PECK: What are the benefits of leak-before-
14 break? Especially on the branch line piping we believe that
15 it has improved reliability of the system by not requiring
16 very close fitting pipe whip restraints. A lot more
17 accessibility for in-service inspection and maintenance.

18 Reduced personnel exposure because you do not have
19 to go in and inspect pipe whip restraints. You can also
20 have reduced personnel exposure because you have more access
21 for inspection of things that you do have to look at.

22 Obviously reduced construction and time and cost;
23 very important to the owner.

24 And there will be reduced refueling times because
25 we are now able to -- we don't have to have wide open spaces

1 for a blow down and reactor cavity pressurizations so we can
2 put in a permanent fuel seal and have a faster refueling
3 time.

4 This again is important to the owner.

5 MR. LINDBLAD: Did I not recall that one of the
6 reasons for the reactor cavity annulus being open was to get
7 ventilation air past the insulation, reactor insulation, for
8 recooling and the like? What does the concrete get to
9 without --

10 MR. PECK: Well, there are cooling passages
11 designed into the concrete to bypass around the perimeter
12 pool seal, so you trade one thing for another. So we have
13 now had to design in air passages for cooling.

14 MR. LINDBLAD: That you would not have had before.

15 MR. PECK: Yes, yes. But the benefit is that you
16 don't have to remove and replace that seal and you have a
17 quicker refueling time. So it's a tradeoff.

18 MR. LINDBLAD: But you have to plug the air
19 passages.

20 MR. PECK: No. The air passages would be in the
21 seal so you could close the seal off with hatches or they
22 could be through the concrete. That is kind of a design
23 detail that has to be worked out, or both.

24 Questions?

25 MR. CARROLL: I have a question of the staff, I

1 guess. I am looking at page 3A-74 and I find the incredible
2 statement that carbon steel main steel lines have a
3 successful and expensive operating history. Thousands of
4 years of nuclear P and BWR's and fossil power plants.

5 Now it really bothers me that the staff doesn't
6 understand that we for the last 60 years use superheated
7 steam in fossil power plants and you don't use carbon steel.

8 That doesn't give me a lot of confidence that they
9 know what they're doing when they tell me a lot of other
10 things that I understand less well than that.

11 MR. TARAO: In the '50s, yes it is true in the
12 fossil plants the design for the main steam line increases
13 temperature from about 600 to 1100 degrees Fahrenheit.

14 MR. CARROLL: 1930, maybe?

15 MR. TARAO: That is a little before my time.

16 MR. CARROLL: Yes. 1930 they were using 1000
17 degree superheated, 1000 degree reheat in a plant that I'm
18 very familiar with.

19 MR. TARAO: My understand is around the '50s. But
20 there were many plants that had main steam lines that ran at
21 a 600 degree Fahrenheit that used carbon steel piping. And
22 some of those plants are still operating today. And there
23 have been no failures in the carbon steel piping for the
24 plants that run at 600 degree Fahrenheit. That's all we're
25 trying to say. There were fossil plants that ran at about

1 the same temperatures as nuclear plants, 600 degrees.

2 MR. CARROLL: No, there weren't. All fossil
3 plants used superheat. Using superheat started in the '30s.

4 MR. TARAO: The reheat piping always ran at 600
5 degree.

6 MR. CARROLL: No.

7 MR. TARAO: Those are carbon steel. Those have
8 good operating experience with carbon steel piping. Now we
9 said main steam and I still hold that there were main steam
10 piping designed to 600 degrees Fahrenheit before the '50s.

11 MR. CARROLL: I think that may be true of the
12 sugar mill industry where they used saturated steam, but it
13 certainly is not true of utilities. They have been using
14 superheat since the '30s. Believe me.

15 MR. TARAO: The discussion in the paragraph dealt
16 with erosion corrosion, first of all. And the point that
17 we're trying to discuss at that point was the use of carbon
18 steel is probably the best material for erosion corrosion at
19 this time. We don't want to go do a crow molly type of
20 material for the main steam piping.

21 MR. CARROLL: All I want you to do, David, is get
22 rid of the reference to main steam piping when you talk
23 about fossil fuel plants. I mean, I agree with what you're
24 saying. It's just that it was not used for main steam
25 piping. Saturated steam.

1 MR. TARAO: All right. We will take out the
2 fossil plants, if you don't like fossil plants.

3 MR. MICHELSON: Well, it's simply not true. Do it
4 for your own protection, not because we don't like it.

5 MR. CARROLL: Any other questions or comments for
6 either the staff on combustion or leak-before-break?

7 MR. LINDBLAD: He was going to tell me more about
8 the leak detection system and how it might be masked by
9 other leaks in the plant.

10 MR. CARROLL: Yes, he was.

11 MR. PECK: Here's a chart that shows the process
12 that you go through with a PWR to determine what is
13 happening if you're looking for leaks.

14 [Slide]

15 MR. PECK: You determine the leakage from the
16 containment sump and cooler condensate monitoring. Those
17 are two places where you collect water that might accumulate
18 inside the containment. One is the sump and one is
19 condensate from the cooler.

20 If it is less than one gallon per minute, then no
21 action is required. If it is not less than one gallon per
22 minute, if it is greater than one gallon per minute, then
23 you subtract identified leakage and you may have a non-
24 leakage source.

25 There's some valve on some drinking fountain

1 somewhere that you're going to fix next time you get to it
2 when you're shut down for some other reason. It is not a
3 safety line but you know what it is. It's identified
4 leakage. I don't know.

5 Subtract identified leakage from the total and you
6 see whether you have less than one gallon per minute. If
7 not, then you perform a water inventory balance on the
8 primary system and determine how much of this leakage is
9 coming from the primary system.

10 MR. LINDBLAD: How long does that take?

11 MR. PECK: Every 72 hours and it takes some
12 portion of the shifts to do. Generally it is done at night
13 when the plant is stable.

14 Is it about four hours? About four hours to do an
15 inventory balance.

16 Now, if the unidentified leakage is less than one
17 gallon per minute and still no action, if it is greater than
18 one gallon per minute then you correct for steam generator
19 tube leakage if you have known leakage from primary to
20 secondary side. You would be able to quantify that and you
21 can subtract that.

22 If you do all of that and you still are not less
23 than one gallon per minute, then there is tech spec that
24 says you must determine whether you've got integrity in your
25 reactor coolant pressure boundary. And if you don't, you

1 have to shut down by tech spec limit.

2 The tech spec limit is basically one gallon per
3 minute on the primary side.

4 MR. LINDBLAD: I gather from this that this a
5 process that could conceivably take one or two days to
6 really go through the chart.

7 MR. PECK: I don't think so.

8 MR. LINDBLAD: In any case, can you tell me how
9 fast cracks would grow of concern.

10 MR. PECK: It would probably take about a thousand
11 years and I'm not kidding. Several lifetimes.

12 MR. LINDBLAD: We are talking about a crack that
13 has already begun to leak.

14 MR. PECK: Yes. You'd have to have a crack
15 leaking. And these cracks, in size, are something like 15
16 to 20 inches long in order to leak at this 10 gallon per
17 minute design number. Very large cracks.

18 MR. LINDBLAD: How long before it would run at
19 that rate?

20 MR. PECK: It could sit there for several times 60
21 years, go up and down the full life of the plant, all
22 cycles, and wouldn't grow appreciably.

23 MR. LINDBLAD: Thank you.

24 MR. CARROLL: That is not in our package. Could
25 you give that to Doug so he can make copies for us?

1 MR. PECK: Yes. I have an extra copy.

2 MR. CARROLL: Anything more on the issue of leak-
3 before-break? All right.

4 I guess we are now on the subject of severe
5 accidents.

6 MR. MICHELSON: High energy and low energy --

7 MR. CARROLL: Tomorrow or late this afternoon.

8 MR. MICHELSON: After everybody else has gone?

9 MR. CARROLL: I'll be here.

10 [Pause.]

11 MR. SCHNEIDER: My name is Ray Schneider. I am a
12 consultant for severe accidents analysis at ABCE for both
13 PRA and Fluid System Groups for the deterministic severe
14 accidents. I've worked in the area of thermohydraulics for
15 about 25 years, 20 of which have been at Combustion
16 Engineering. And for the past 15 years I've been involved
17 with beyond design basis events in severe accident
18 activities for CE operational plants and events BRW's.

19 MR. CARROLL: We will try not to hold the fact
20 that you've spent a career in hydraulics against you.

21 MR. SCHNEIDER: I appreciate that. I do deal with
22 BRW people as well.

23 So we are going to be talking about severe
24 accident analysis performed at CE for a number of different
25 applications.

1 We perform severe accident analysis primarily to -
2 - with the intent of demonstrating compliance with SECY 93-
3 087 issues and 10 CFR 50.34(f) post TMI requirements. In
4 addition, severe accident analysis has been used to support
5 the level 2 quantification for the PRA.

6 We are mainly going to focus this morning on the
7 deterministic issues and the issues associated with SECY 93-
8 087 and the URD, the EPRI utility requirements document.

9 MR. LINDBLAD: Do we have a quorum on hydrogen
10 control if Ivan is not at the table? Okay.

11 MR. SCHNEIDER: We're going to be addressing a
12 number of the SECY issues. The first one we're going to get
13 on the agenda is hydrogen control and then another issue
14 which is high pressure core melt ejection. Mitigation of
15 steam explosions was not a separate SECY issue but it was
16 within the SECY discussions, so we pulled that out as an
17 individual item to discuss.

18 Mitigation of core concrete interactions will be
19 discussed, and then we will discuss overall containment
20 performance with a primary emphasis on overpressure failure
21 because we will be discussing containment performance all
22 along as we go through the other phenomena.

23 And at this point we're going to review some
24 information in terms of what the PRA came out with in terms
25 of containment capability, and then we're going to talk

1 about instrumentation and equipment survivability during
2 severe accidents.

3 [Slide]

4 MR. SCHNEIDER: Okay. The purpose of the System
5 80 plus response to SECY 93-087 is to demonstrate -- to
6 limit the containment concentration to less than 10 volume
7 percent in containment. Demonstrate the ability of
8 containment to accommodate the consequences of 100 percent
9 oxidation of the fuel clad. And tacit in all of this is
10 reducing the capacity for containment failures in general
11 and early containment failures in particular.

12 System 80 plus has a lot of features which
13 contribute to our ability to meet these goals, one of the
14 most important of which is the large containment volume.
15 It's approximately 3.4 or 3.3 for million cubic feet. It
16 ensures that even without hydrogen control features the
17 maximum uniform concentration in the containment will be
18 less than 13 volume percent, which is -- you know, given 100
19 percent oxidation of the fuel clad, which is a relatively
20 low level for that amount of oxidation. And we feel this
21 gives us substantial margins to issues associated with
22 detonations and its easily capable of handling deflagration
23 of that level.

24 Hydrogen mitigation systems are included as well
25 with a pressure relief dampers associated with the IRWST and

1 these will function to provide additional confidence to
2 preclude hydrogen detonations within the containment.

3 Containment arrangement promotes natural
4 circulation and mixing. We'll discuss that in a minute. And
5 we have very few in-containment enclosures but those
6 enclosures that we have are vented to prevent local
7 accumulations of hydrogen.

8 MR. CARROLL: What happens to the 13 percent if I
9 oxidize all of the zirc?

10 MR. SCHNEIDER: It would go up by about 2 percent.
11 If you oxidize every bit of zirc in the core because we have
12 zirc alloy grids and guider tubes that would go up to 15
13 percent.

14 [Slide]

15 MR. DAVIS: How do the IRWST pressure relief
16 dampers affect -- how does that aid in hydrogen mitigation?

17 MR. SCHNEIDER: It prevents collection, minimizes
18 the collection of hydrogen in the IRWST. It prevents level
19 pocketing. You want to make sure you get -- we have a
20 direct flow path from the -- from our rapid depressurization
21 system into the IRWST. So it is possible for that to be the
22 initial release point for hydrogen. You want to make sure
23 you have the ability to vent the IRWST.

24 MR. CARROLL: What operates the dampers?

25 MR. SCHNEIDER: By directional pressure, any

1 directional pressure above a few PSI will open it. What
2 will open it is the steaming and the IRWST.

3 MR. CARROLL: And that is the only way out, the
4 IRWST?

5 MR. KRESS: Did consideration of hydrogen
6 concentration go into selection of the volume of your
7 containment at all?

8 MR. SCHNEIDER: Absolutely. That was the primary
9 consideration early on. The reason it comes out as 13
10 percent is because the way the old regulations are
11 interested is that 13 percent would be the maximum level for
12 100 percent clad and that was the guidance at that point
13 when the containment was designed.

14 MR. KRESS: How much bigger would it be if that
15 were 10 percent?

16 MR. SCHNEIDER: Maybe about --

17 MR. CARROLL: Go ahead, Ray, finish your sentence.
18 I wanted to add something to your answer.

19 MR. SCHNEIDER: It would be proportional, another
20 million cubic feet possibly.

21 MR. RITTERBUSCH: What I wanted to indicate was
22 that the containment size is also impacted by construction
23 practices and experience. So we knew what previous
24 containments were and we did not want to go too far above
25 that. So there was some judgment that we wanted to stay

1 reasonably close to the spherical designs that had already
2 been constructed.

3 MR. SCHNEIDER: I did not mean to imply that it
4 was the driving consideration.

5 We've also done a few things in the containment
6 that we feel make it relatively capable of mixing. What we
7 have essentially done is have like -- basically have the
8 steam generators, cavities or tunnels work as a chimney in
9 effect. We've also noticed that all the hydrogen sources
10 are located -- well, actually all the hydrogen or steam
11 sources would be located well low in the containment and
12 basically directed out the steam generator tunnels.

13 We've surrounded the whole RCS and most of the
14 containment with a crane wall which is generally solid
15 except at the very bottom. And essentially to promote a
16 recirculation pattern to allow some degree of mixing in
17 general in the containment.

18 MR. KRESS: Are those lines drawn on there a
19 result of some calculation or just an artist's conception?

20 MR. SCHNEIDER: Both. This is an artist's
21 conception. We have since done calculations which indicate
22 that this is the most likely dominant path. It is not the
23 only pathway. All the steam -- and this is not the only
24 flow path and it's not the only way steam can circulate or
25 the only way that steam and hydrogen can circulate

1 throughout the containment. But from the analyses we have
2 done it looks like the most logical. It seems to confirm
3 what we would naturally believe in how we intend to design
4 it.

5 Part of it is because you have all of your heat
6 sources basically located in the steam generator region.
7 And so we have some confirmatory kinds of calculations, but
8 we do not want to count on the calculations. Basically it
9 is the design that we think promotes it.

10 MR. LINDBLAD: Are you saying that there is a heat
11 transfer to the containment shell at the top of the crane
12 there? I understand how you add heat. I don't understand
13 how you lose heat in the downcomer.

14 MR. SCHNEIDER: It's not so much that you lose it
15 in the downcomer. What's going to drive it is the
16 relatively hot steam that is coming out of the RCS at the
17 bottom. And ultimately that will drive its way up and you
18 will still have a more dense mixture. The outside, it will
19 be a little cooler because you're losing energy as you go
20 further up. You are going to have a small delta P.

21 MR. LINDBLAD: It seems like it would come to
22 equilibrium in a little while unless you're pulling a lot of
23 heat out of the containment shell. Is there ventilation
24 between the shell and the shield building?

25 MR. SCHNEIDER: There is heat transfer between the

1 shell and the shield building. It is not specifically
2 ventilated. It can be but you are not counting on
3 ventilation for it. What you're counting on -- that's not
4 even counting on. But one thing that will occur is the lag
5 between the fact that the steel shell remain cooler for a
6 certain period of time as you're heating up. So it will
7 serve as a condensing source for some time and cool the
8 mixture.

9 MR. KRESS: At the time that you are generating
10 significant amounts of hydrogen you really don't have any
11 steam left.

12 MR. SCHNEIDER: Your whole containment is full of
13 steam at that time.

14 MR. KRESS: Most of it is condensed by then. If
15 you look at the calculations, by the time you are generating
16 all of that hydrogen that come out you basically condense
17 most of the steam already.

18 So I was wondering if this was the result. That's
19 why I asked the question about those patterns. Were they the
20 result of the calculation that looked at the conditions that
21 existed -- well, when the hydrogen is being generated in
22 severe accident.

23 MR. SCHNEIDER: You're not going to condense the
24 steam unless you have the sprays. So you're saying when you
25 have the sprays on? If you have the sprays on, then the

1 whole system is going to be a well mixed system anyway.
2 It's going to be -- you know, you're not going to be able to
3 maintain -- it only takes a few PSI delta P to drive these
4 flows through the containment. And if you have the sprays
5 going you're going to mix up the containment pretty well.

6 This is kind of a conceptualization if you don't
7 have the sprays going.

8 You're not going to condense the steam without the
9 sprays.

10 MR. LINDBLAD: As I understand you have not
11 modeled it or analyzed it to satisfy yourself that it will
12 occur; is that right? It is intuition more than analysis.

13 MR. SCHNEIDER: We have done multiple, multi-
14 nodal analysis with MAAP-4 like up to 25 nodes and we have
15 taken great care to make sure that we don't have any unusual
16 currents that will artificially mix the system.

17 MR. LINDBLAD: And that shows the circulation?

18 MR. SCHNEIDER: It shows as a pattern that you can
19 get. This is one of the patterns for a period of time. As
20 I say, it is not the only pattern but it is one of the
21 dominant patterns that we could expect to see and that seems
22 to be confirmed.

23 What the analyses do confirm, though, is well
24 mixing, regardless of what the patterns are.

25 MR. CATTON: I don't know anything about MAAP-4,

1 but when you look at this particular configuration you can
2 sort of imagine that the steam generator is heating the
3 surroundings and that would cause a flow of hot steam air or
4 whatever up into the top region. You would almost block the
5 recirculation.

6 And it seems to me when that occurs you would be
7 getting recirculation back through from outside. You show
8 your arrows coming down around the shell and it isn't. It
9 seems to me that you're going to heat up the upper part and
10 you're going to get recirculation out to the outside.

11 MR. SCHNEIDER: Well, we don't -- I don't know
12 what is going to maintain the driving head. The hot gases
13 collect up in the top and they slowly will fill, coming down
14 around the outside.

15 MR. KRESS: Basically, MAAP is incapable of
16 calculating that and I wondered if you had some other
17 calculation that showed that.

18 MR. SCHNEIDER: MAAP-4 is totally incapable of
19 calculating. MAAP-4 has a generalized containment model.
20 We do not use MAAP-4 containment. We use the generalized
21 containment feature that was developed as an enhancement to
22 MAAP-4 which is very much in the same way contained, or
23 maybe we use the 25 node model to represent the system,
24 including the IRWST. I actually have a picture of it.

25 MR. CATTON: The support for the crane is

1 essentially in impervious wall. Isn't that correct?

2 MR. SCHNEIDER: Right. Yes.

3 MR. CATTON: I bet what you would get is
4 recirculation within those walls with some leakage to the
5 outside.

6 MR. CARROLL: It is not an impervious wall.

7 MR. CATTON: For the most part it is.

8 MR. SCHNEIDER: What we believe we've found is
9 that very, very small delta P's are sufficient to cause
10 sufficient mixing such that regardless of the direction at
11 any given time we don't see very much than a few PSI or a
12 few degrees difference in the upper portions of the
13 containment.

14 We do see differences here and we see differences
15 here and we may see differences in this region and in the
16 cavity, but we don't see differences in this general region.

17 MR. CATTON: I have a little bit of trouble with
18 that.

19 MR. DAVIS: How important is the assumption on
20 your subsequent severe accident calculations?

21 MR. SCHNEIDER: Not at all.

22 MR. DAVIS: That's what I thought. So let's move
23 right along.

24 MR. CATTON: It maybe they're going to put things
25 in to control --

1 MR. DAVIS: They've got 80 igniters.

2 MR. CARROLL: Forty redundant igniters is what
3 they have. They have 80 total.

4 MR. DAVIS: At 40 locations.

5 [Slide]

6 MR. SCHNEIDER: We will show you the figures. We
7 have 80 igniters strategically located within the
8 containment to a set of criteria. Virtually every major
9 area is covered with igniters and we have multiple levels on
10 the key areas along the main where we expect the dominant
11 flows. Like the steam generator tunnel has multiple levels
12 of burning because you're going to have most of the steam
13 going up, most of the hydrogen going up and we want to make
14 sure you catch it.

15 We have two redundant electrical trains. The
16 igniters and cables will be designed to basically survive
17 their own operation, survive hydrogen burns. I believe they
18 are category one seismic. They are not going to fall down
19 on you and they will operate through seismic events.

20 High expected system availability. They have
21 diverse powering through offsite power emergency diesels,
22 combustion turbine as well as batteries.

23 MR. DAVIS: Are these batteries their own or are
24 these the station batteries?

25 MR. SCHNEIDER: Basically there is the division

1 battery dedicated to have power to the igniters, so it is
2 guaranteed they will have power to them.

3 MR. DAVIS: I'm looking at the loss of offsite
4 power sequence where the batteries last about eight hours.
5 And then you would lose igniters after that time also?

6 MR. SCHNEIDER: It depends upon the number of
7 igniters you power. It will last for the life, the duration
8 of the batteries, yes.

9 MR. CARROLL: You have an option as to how many
10 you power?

11 MR. SCHNEIDER: Yes. You can control that, I
12 believe, from -- if you have to from the panels, I think.

13 Tom?

14 MR. RITTERBUSCH: I think there's one thing we
15 need to bring out at some point in this discussion, Ray, and
16 that is that the priorities for using the igniters. We
17 really rely on the combustion turbine to provide the power.

18 Tom wants to take over here.

19 MR. CROM: Yes. There are several power sources
20 for the igniters. The first one, of course, is offsite
21 power if it is available.

22 Second, the next one would be the diesel
23 generators. The third source would then be the combustion
24 turbine and finally would be the batteries.

25 Now we power these off the division batteries, not

1 the channel batteries and we size these batteries to
2 basically take the five starts of the diesel generator
3 before the air supply runs out -- starting air supply runs
4 out.

5 And then on top of that, size it for the eight
6 hours for the hydrogen igniters. So that the batteries are
7 sized for both the five starts of the diesel generator and
8 for powering the igniters, the minimum set, which I believe
9 is 17 for each division for eight hours.

10 MR. CARROLL: It is out of place but since you're
11 up there, tell me why I need batteries to run the auxiliary
12 feed water?

13 MR. CROM: Why do you need them?

14 MR. CARROLL: Yes.

15 MR. CROM: It depends on what kind of governor you
16 end up getting. That is correct. Basically it would be for
17 speed control. Now, you could get a mechanical hydraulic
18 governor but that would run wide open unless you sent an
19 operator down there to adjust the speed. But then he
20 wouldn't know what a steam generator level is.

21 The more critical thing would be the steam
22 generator level because he wouldn't know where to control
23 the speed of the turbine.

24 MR. CARROLL: It would make a more reliable
25 system.

1 MR. CROM: The old mechanical hydraulic control
2 error on speed control and they are somewhat questionable if
3 they are safety related. And the came out with electronic
4 hydraulic.

5 Now what would be ideal is if you had a
6 combination, but I don't know the manufacturer that supplies
7 one yet. But you could have some sort of adjustable
8 electronic device on mechanical hydraulic governor that
9 would control it off of them rather than just electro
10 hydraulic.

11 MR. CARROLL: Why not just put a little generator
12 on the turbine and make its own electricity?

13 That was just -- I thought that was the answer
14 but, okay. Move along.

15 MR. CROM: In addition, the igniters are part of
16 the technical specifications with surveillance and
17 operability requirements and they are included in the
18 reliability assurance program, so they have a high degree of
19 reliability to be available.

20 [Slide]

21 MR. CROM: The igniter system design considers
22 three basic functions: system maintainability where we want
23 to make sure that the igniters can be located where they can
24 be reached and replaced so that operation of the system does
25 not become an undue burden to the utility. Redundancy and

1 reliability, as you said. And we have the batteries like
2 that and placement criteria.

3 [Slide]

4 MR. CROM: And part of that is based on insights
5 from experimentation as well.

6 The maintainability requirements will basically
7 have a system that is sufficient, but with no more igniters
8 than absolutely necessary to perform its function, and
9 primarily that is an operability issue and maintainability
10 issue for the utilities igniters to be located with the
11 reasonable expectation of maintainability and surveillance
12 so they can actually check them to make sure the equipment
13 is functioning and replace the igniters when necessary, if
14 necessary.

15 Redundancy comes in two ways. One is through
16 power but the other is also through the way we locate the
17 igniters. Typically the igniters are located with multiple
18 levels of burning and dominant flow paths. But actually
19 it's not just dominant. It's also secondary flow paths as
20 well. Pairs of igniters cover similar regions. Igniter
21 pairs are powered by independent power sources so there is a
22 high reliability of the system functioning to be able to do
23 its job.

24 MR. KRESS: When you say to cover similar regions,
25 do you mean pairs of igniters in the same regions?

1 MR. SCHNEIDER: Sometimes they can be located in
2 close proximity but other times it may just be that we would
3 have one located on the north region of the containment and
4 maybe the other one on the south, so if you lose one, if it
5 is an open region you will have the other one in a slightly
6 different location as long as the region is open.

7 MR. LINDBLAD: Help me a little bit. These are
8 basically hot wires, is that correct?

9 MR. SCHNEIDER: These are glow plugs.

10 MR. LINDBLAD: They generate heat or are they in
11 the chimney, so they develop circulation through a chimney?

12 MR. SCHNEIDER: Most of these igniters are in the
13 steam generator flow path actually so they are naturally in
14 that tunnel because that's where we predict to be the
15 dominant flow path through the system. Otherwise they are
16 located throughout the containment. There are no other
17 closed or chimney areas in the containment.

18 So in terms of the placement criteria, we have
19 looked at the containment in multidimensionals and we had
20 like two dimensional or three dimensional drawings drawn up
21 and we located what we believe to be the potential flow
22 paths to the containment. Along all dominant and secondary
23 flow paths we placed igniters, which basically resulted in
24 igniters being placed virtually in every region that even
25 resembled an enclosure.

1 In the vicinity and above the hydrogen sources we
2 specifically provided hydrogen igniters so that they could
3 be as close to the source as possible as well as multiple
4 levels above that.

5 MR. KRESS: How did you determine dominant and
6 secondary flow paths?

7 MR. SCHNEIDER: Basically the dominant flow path
8 is where you are going to have the stem generator tunnel.
9 There are not that many paths and we will go through the
10 figures in a minute. There are not that many paths through
11 the containment. It is a relatively channeled flow, with
12 the major flow path being up through the steam generator,
13 steam generator tunnels, and since that is the source of
14 where your pipe breaks are likely to be, that is the source
15 of where your hydrogen is likely to be released from. That
16 is basically the source of the IRWST events. It seems to be
17 the most logical place to do multilevel burning.

18 By the time that you got to the very top of the
19 steam generator, you had a very good chance of having burnt
20 all of the hydrogen, and then we will have two or three
21 regions above that to cover it as you go to the upper
22 regions of the containment. We wanted to make sure that
23 they were far enough below solid surfaces so that the
24 burning could be as effective as possible. If you put them
25 too far up against the solid surfaces, the burns are not

1 going to be very effective.

2 We tried to locate them, except for possibly in
3 the dome in about a 50,000 cubic foot region which the
4 experimental data indicates, based on event, you can handle
5 about one igniter has been demonstrated to handle 75,000
6 cubic feet, something of that general order.

7 MR. CATTON: I see no mention of doorways. There
8 is a school of thought that says you do not want to put an
9 igniter in a downstream side.

10 MR. SCHNEIDER: I don't have any doorways.

11 MR. CATTON: I just mean a place where you have a
12 contraption in the flow. Let's go through the pictures.

13 MR. SCHNEIDER: Let's go through the pictures.
14 The containment is not like what you're used to seeing in
15 the German designs. I think that there is not -- let's go
16 through the figures. We will get to that right now as a
17 matter of fact. There is about 11 slides.

18 The first slide will show the overall view of at
19 least one elevation cut through the containment, just to
20 give you an idea of reference levels, and then there are
21 five slides which basically are planar cuts at the various
22 levels looking down on the containment, and then we have
23 multidimensional cuts which are cut generally around this
24 location in the containment, and as you look through all of
25 it I think you can get a feel for where you might expect

1 flow to be and why we feel reasonably confident with the
2 placement of the igniters.

3 [Slide]

4 MR. SCHNEIDER: Going from the bottom up, if we
5 look on the two dimensional plane, and we may have to go
6 back and forth with these to get a feel for where everything
7 is, but let's get an idea of the placement and the way the
8 system is structured. Going from the bottom up, this is a
9 cut basically taken in the cavity region, just the cavity
10 itself. The reactor vessel is placed here. We're looking
11 down the rafter cavity toward this chamber would be here.
12 You do not see the breach hatcher in this junction, and
13 igniters are placed basically in that region to cover
14 potential for post-vessel breach.

15 MR. CARROLL: Toward the breach chamber? This is
16 DCH.

17 MR. SCHNEIDER: No, it is a phenomenon toward the
18 breach chamber. It's a physical structure in the next
19 section. It is not really -- it is. It is a debris
20 accumulation chamber.

21 [Slide.]

22 MR. SCHNEIDER: As we move up the containment,
23 this is basically a cut through the containment where you
24 have the cavity region with a planar cut through it and the
25 IRWST surrounding it. The spargers are located in this

1 general region with the piping. Spargers go down and it
2 covers a large fraction of the IRWST and igniters are
3 located along the walls in order to maintain easy
4 accessibility and maintainability in mounting of the
5 igniters, and they will be located well above, or at least
6 above the water level.

7 [Slide]

8 MR. SCHNEIDER: This represents the first floor of
9 the containment, so now as you are marching up, you have a
10 cut in item three which is right across the 91'9" elevation.

11 [Slide]

12 MR. SCHNEIDER: This is basically the -- what you
13 call -- basically it is the first floor, what you call
14 basement floor, whatever. The steam generator tunnels are
15 found in this general region. The IRWST events are also
16 provided in that general region to the underneath, within
17 the steam generated tunnel.

18 We have not really an enclosure but a room -- it
19 is an enclosure -- a room for the let-down heat exchanger
20 and both of these have ended on the top.

21 [Slide]

22 MR. SCHNEIDER: Each of these rooms have igniters
23 of their own should they somehow become a preferential
24 source of hydrogen accumulation, which we believe to be
25 unlikely.

1 The exit from the cavity is right out here.
2 Igniters are located by either side of the cavity except
3 this represents the lower elevation of the crane wall. This
4 represents the only -- one of the few elevations where you
5 have a penetration through the crane wall itself. At about
6 the seven foot elevation above this, the walls will stop and
7 these will come to be manways that you walk into and these
8 would represent the only way for flow to get back in.

9 [Slide]

10 MR. SCHNEIDER: We move up to the next floor,
11 which is 115 elevation. The steam generator tunnel, this is
12 located in here. It's not shown but it is graded in a steam
13 generator tunnel areas. This is primarily solid, with the
14 exception of, I believe, a solid with the exception of this
15 area, which has, I think, a grade, and maybe this area,
16 which has a grade. So there is not a lot of bypass flow
17 that you would expect in these regions. Most of the flow is
18 going to come here and enter and exit in these regions.

19 This represents the pressurizer enclosure, which
20 has its own separate igniters associated with it. This
21 represents the outer region of the annulus. This is
22 primarily solid with flow holes along the side, and some
23 additional grades may be over there.

24 [Slide]

25 MR. SCHNEIDER: This covers the remainder of the

1 containment. It is basically opened all the way down from
2 the 257 elevation all the way down to the 156. Again, the
3 steam generator tunnel coming straight up, the pressurizer
4 enclosure would be closed on the top and have relatively a
5 decent size venting or vents or exit holes along the sides.

6 Igniters are located where it would vent. Again,
7 igniters located again in the steam generator tunnel heavily
8 ignited in that region. This represents the missile shield
9 for the steam lines and igniters are located above that
10 elevation but there's not a enclosure underneath. It is
11 basically a missile shield.

12 MR. CATTON: So you put your igniters near the
13 exit from the chamber on the outside?

14 MR. SCHNEIDER: I believe this was on the inside
15 and the outside. We have some on the outside and a handful
16 on the inside so it is covered in both regions.

17 MR. CATTON: If I remember right, wasn't there a
18 description that you put it inside because of the concern
19 about the jetting that was observed at Frankfurt?

20 MR. SCHNEIDER: These are located inside the
21 enclosure and there is one located outside the enclosure as
22 well.

23 MR. CATTON: The one that is outside is near the
24 vent for that compartment. Shouldn't that one be on the
25 inside?

1 MR. SCHNEIDER: It is a pressurizer compartment.
2 The only way that one is ever going to see a hydrogen
3 accumulation is if you have the actual break in the
4 pressurizer itself, so we felt that that was kind of a low
5 enough probability. We really were not concerned about that
6 being a major contributor. It's the only pipe there. It is
7 an unlikely pipe to go.

8 MR. CATTON: Is there anywhere else where you can
9 put it outside the compartment where the hydrogen is
10 generated?

11 MR. SCHNEIDER: There were no other compartments
12 that even resembled enclosures like this one, and again,
13 looking straight down, you see nothing else except
14 relatively open areas and this being the -- let's see. This
15 is probably, has to be the crane wall, the outer side here.

16 MR. DAVIS: How much of the surge line for the
17 pressurizer is in that compartment, Dave, remember?

18 MR. SCHNEIDER: Just the entrance section. There
19 is a lot of residual piping because if you look, if you just
20 basically look at this location to the RCS, the surge line
21 has got to come off of the hot leg, which is probably here.
22 So it goes underneath this area and then there is a small -
23 - not really enclosure area but there is a small concrete
24 section where the pipe will turn up, so very little of it is
25 actually in this enclosure.

1 There is some of it located well down in the
2 section where the piping will move in, but the area where it
3 comes in is not nearly as closed as it is in the top.

4 MR. DAVIS: The only reason I'm asking, even
5 though the accident may not be initiated by a surge line
6 break, that surge line by some calculations is expected to
7 fail due to over temperature and hot gases recirculating
8 through the pressurizer.

9 MR. CARROLL: In the leak-for-break presentation,
10 there was a schematic piping schematic that gives you some
11 sense of that.

12 MR. DAVIS: There is not much of that in that
13 compartment, I guess.

14 MR. SCHNEIDER: I believe we have igniters placed
15 where the search line is located. Let's see if we can see
16 that.

17 MR. DAVIS: It does not sound like a problem. Why
18 don't you go ahead.

19 MR. LINDBLAD: I must have missed something. Why
20 is there a solid roof over the pressurizer?

21 MR. SCHNEIDER: The pressurizer, because probably
22 a missile shield, I would guess. That is about the only
23 reason I can think that we have one.

24 Tom, solid roof?

25 MR. CROM: Yes, I believe the solid roof is for

1 the missile protection for the PROVs and things like that on
2 top of the pressurizer.

3 MR. LINDBLAD: But the pressurizer room is vented
4 for line breaks?

5 MR. CROM: Yes, it is vented on the top.

6 MR. LINDBLAD: It is vented toward the top?

7 MR. SCHNEIDER: Towards the top.

8 MR. CROM: Not on the top. It is towards the top
9 on the sides.

10 MR. LINDBLAD: Thank you.

11 [Slide]

12 MR. SCHNEIDER: Now we have basically a similar
13 set if you want to go through the containment three
14 dimensionally. This is basically again the cut through the
15 lower containment IRWST areas showing the surge lines as you
16 see the surge line piping that goes all the way down, and it
17 has holes up and down the sparger.

18 MR. CARROLL: Do you have enough sense of this,
19 Ivan, or do you want to go through the three dimensionals?

20 MR. CATTON: I like the three dimensional much
21 better than the flat ones.

22 MR. CARROLL: But do you have enough sense about
23 what they are doing to allow us to skip them?

24 MR. CATTON: I can just go through these myself, I
25 guess. How many more do you have?

1 MR. SCHNEIDER: About four more. If you want to
2 look at it yourselves, feel free to do so. It is here at
3 your disposal. The NRC felt very strongly that this gave
4 them a good feel for the containment and we think it gives
5 us a good feel also.

6 MR. CARROLL: I almost suggested that we start
7 with the three dimensional but I didn't want to interrupt
8 you.

9 MR. CATTON: I think it would have been better to
10 have started with them.

11 MR. SCHNEIDER: That's what the NRC said also.

12 MR. CATTON: And you would use shading too.

13 MR. SCHNEIDER: As you can see, you can see the
14 guardings and the steam generator tunnel and basically
15 minimum access areas on the side. You can see where the
16 access for the staircase is and the like. The exits for the
17 cavity is here, two big louvered doors on each side. Here
18 is your let-down heat exchanger -- it is vented on top. I
19 do not see the vent in this picture. It could be an older
20 picture.

21 There is a staircase opening and this is one of
22 the few ways that you can enter the second floor from the
23 outside of the crane wall on this side and this side, so
24 these are actually doorways into the crane wall but that is
25 about it.

1 [Slide]

2 MR. SCHNEIDER: And again, the pressurizer cut-
3 through. The venting of the pressurizer is right here on
4 either side and that represents the vent and you would have
5 a solid wall here. It is just another view of pretty much
6 the same thing showing relatively limited access on the non-
7 dominant flow paths.

8 [Slide]

9 MR. SCHNEIDER: This is just another view of
10 pretty much the same thing. Again, the mavic area. That is
11 your cavity exit. And again, steam generator tunnels.
12 Again, limited access except through the steam generator
13 department.

14 [Slide]

15 MR. SCHNEIDER: And then finally this just gives
16 you a layout of the piping, not the search line piping but
17 at least the piping for the discharge of the IRWST of the
18 safety depressurization system.

19 [Slide]

20 MR. SCHNEIDER: So we have tried to address this
21 issue. We believe pragmatically by trying to make sure that
22 we have covered all of the dominant regions we believe we
23 have put enough igniters in to control any kind of hydrogen
24 concentration and having a large enough volume we believe
25 helps us so that our initials right to begin with is not

1 very significant.

2 Having very few enclosures prevents the
3 possibility of substantial accumulation, and having, we
4 think, the chimney kind of effects we think is going to help
5 us in potential mixing. We have also looked at the issue in
6 the event the igniter system does not function. We looked
7 at limiting burns at 13 volume percent to see if they were
8 concerned, and even at 13 volume percent, we -- actually we
9 don't exceed by quite some margin the ASME "C" levels.

10 [Slide]

11 MR. SCHNEIDER: We did do some contrimatory work
12 and I do not want to get into this in any depth. We did not
13 rely on this for analyses, but we did dc some, as I said,
14 multinodal map calculations with a generalized containment
15 model. We took tremendous amounts of care. We were
16 heightened to the sensitivity of the poor performance of
17 MAP, generalized models on gas in predicting HDR.

18 We felt that if we worked at it and modeled as
19 precisely and as carefully as possible so as to minimize any
20 unnecessary flows that we would be able to get a rough idea
21 as to what might happen when we modeled the igniter system,
22 so the first part of the effort, a substantial part of the
23 effort was placed into getting a system that did absolutely
24 nothing, where nothing happened to it, and that is not easy.

25 When you deal with small delta Ps, you can

1 actually get very easily flows going through the system
2 because your nodes and flow paths do not quite match up, and
3 if you are not very careful, you get artificial flows. So
4 we took a lot of care not to get those artificial flows.

5 Then in addition we played a game scene. What we
6 noticed that HDR was that if you injected from an upper
7 region, you got stratified flow above the region you ejected
8 but not below. What we did was artificially increase the
9 volume of the cavity to about the size of the first major
10 node above the cavity. We looked at the concentrations in
11 those two regions, and in injecting that -- and if you had a
12 design like that, we actually did convince ourselves and we
13 had -- unfortunately I don't have a slide of it. We
14 actually showed that you would get a concentration of nearly
15 zero in the cavity, with a very high concentration above.

16 Then we started doing the analyses, and so we have
17 a feel that at least the model itself is not going to kill
18 us from the outset. There is a lot of effects that we
19 understand the models cannot do and we are not relying
20 heavily on them but we are looking for some insights. Is
21 the containment going to be generally not well mixed, and if
22 we take care in at it, we've got the feeling that it was
23 going to be generally well mixed.

24 We looked for gradients and the biggest gradient
25 would be the ones associated with possibly the steam

1 generator tunnels, all along its pathway, and possibly if
2 you have a direct injection into IRWST and expect some
3 gradient there. But on the whole there was nothing that
4 gave us the feeling that there was any concern.

5 The system looked like it would operate very
6 effectively. The models for the igniters were independently
7 verified by past tests on maps, so we're reasonably
8 comfortable with what we came up with. It was nothing that
9 really -- after you ended up looking at all the results,
10 there was nothing that did not -- that violated our
11 intuition.

12 MR. KRESS: Refresh my memory. Map for
13 containment model is a control volume model with lump
14 rounders in it?

15 MR. SCHNEIDER: Yes.

16 MR. KRESS: So when you divided your containment
17 up into nodes or volumes, were those boundary lines
18 represented? Did they represent real solid volumes or were
19 they phantom lines drawn just for wherever you wanted a
20 node?

21 MR. SCHNEIDER: We took great care to do it as
22 physically accurate as possible. We were concerned if we
23 did not come up with a decent analysis we could not believe
24 the results at all. Now we believe we can believe the
25 results a little. We have like 25 nodes and 37 junctions.

1 MR. KRESS: They represent 25 separate regions
2 that have walls?

3 MR. SCHNEIDER: I'll give you a feel. Not all of
4 them represent walls. We broke the dome up into a handful
5 of regions but mostly they did not.

6 The other thing is, I have to be careful. You
7 know, I am saying map four because it is most familiar. But
8 there are detail differences between what we actually did
9 and what map four actually has, and what map four may
10 becoming in the future. So the work was done by Mark Hatton
11 and his people. To a great extent they took their version
12 of the generalized containment model.

13 I personally believe is superior to the one on map
14 four but it is basically very similar. The care taken in
15 modeling it basically is important, and as you can see, we
16 have the steam generator regions. We do have lower
17 compartments based on floor levels. We modeled the IRWST as
18 a multiple three node region with not very much mixing here,
19 but where we allowed the spargers to be credited, the floor
20 regions for the annular compartment, pressurizer
21 compartment, so we tried to do a decent job to get a feel
22 for what was going on.

23 As I said, it confirmed what we kind of suspected.
24 If in the long term hydrogen concentrations can be
25 maintained four or five percent, maybe five, six, seven

1 percent, at any rate in that range. And I guess that's
2 truly about it.

3 There are also 37 heat sinks. They divided up the
4 heat sinks in order to not put too much energy in any one
5 area and not kind of artificially generate a thermal plume.

6 MR. HATTON: And you say that you have checked to
7 see that map four would reproduce some of the results from
8 HDR?

9 MR. SCHNEIDER: No. What we did is we did --

10 MR. CATTON: My recollection is that the lump
11 perimeter was poor. You needed to do something.

12 What did you do that is more?

13 MR. SCHNEIDER: I think what we did that is more
14 is that at the beginning we took great pains to make sure
15 that we did not get artificial mixing. Ten to the minus
16 fifth, delta p's. If you were not very careful exactly how
17 you lined up all of these junctions, you artificially
18 created a density-driven flow just by modeling.

19 We took great pains to make sure that you do not
20 generate density driven close through the modeling process,
21 so we think the difference is the care taken in modeling,
22 and part of the reason is we knew they had a problem before.
23 They may not have been as sensitive to it when they do a
24 blind experiment, so as a result and the concern, we decided
25 that we were not going to use this if you could not get at

1 least something that represented a good steady state.

2 MR. CATTON: What I don't understand is how do you
3 know you got it when you didn't make any comparisons?

4 MR. SCHNEIDER: We felt comfortable we can
5 reproduce.

6 MR. CATTON: Is this because you feel that you are
7 better than anyone else who does it? They were all pretty
8 much a failure.

9 MR. SCHNEIDER: We understand that.

10 MR. CATTON: The only code that did any good like
11 the one at Los Alamos. ATM? I don't remember the name of
12 it, but the one that came out at Los Alamos. HMS. That's
13 right. The HMS code was one of the few that did well.

14 MR. SCHNEIDER: There are a few other things. HDR
15 is a much more complicated facility.

16 MR. CATTON: I understand. That's why it is a
17 good test.

18 MR. SCHNEIDER: We were not trying to necessarily
19 test out the code. We figured the question would be, how do
20 you know that you -- how can you prove that this code will
21 predict stratification? We wanted to convince ourselves
22 that if we modeled it properly and if we did something that
23 looked like an HDR-type thing in our facility, we would
24 indeed predict the large stratification and indeed we did.

25 So we felt that since we could predict

1 stratification if it occurred, if it did not occur, we're
2 going under the assumption that the models aren't good
3 enough to give us an idea of the level of mixing. There's
4 not much more we can push to. This is only for
5 confirmation. We did not rely strongly on it but felt it
6 was something we should do to convince ourselves --
7 basically to address some issues that have come up in the
8 past ACRS meetings and we felt that this was a reasonable
9 way of doing it at a reasonable level of effort.

10 We did not feel comparison to HDR was required.
11 We wanted to make sure that if stratification could occur in
12 our facility that we could predict it.

13 MR. CATTON: So what you did was use judgment
14 instead. Not necessarily bad if your judgment is good.

15 MR. KRESS: Did you take essentially the same
16 containment model and vary the nodal structure to see if you
17 got different answers?

18 MR. SCHNEIDER: Yes, this is probably -- well, we
19 took -- we did a lot of modeling early on in the process to
20 make sure we did not get artificial mixing. The first test
21 that we performed basically mixed everything. They
22 ultimately traced that down to the fact that the nodes were
23 not lining up perfectly. After maybe about a month they
24 were able to get the nodes to line up such that if you let
25 the model sit and do absolutely nothing to it, nothing

1 happened.

2 Now that may seem like a small thing but sometimes
3 that is real difficult. We got the thing to basically sit
4 there and be perfectly stable, and then at that point that
5 would be the point that we would start doing the
6 initializations. Otherwise you ended up with very small
7 differences that can drive these flows substantially.

8 Then we artificially increased the cavity region
9 to about the size of the upper compartment region, and since
10 we were not getting much stratification with such a small
11 cavity, we said, what happens if I make that very big? If I
12 make that very big, which is something that a simulator and
13 HDR type thing, we had a large region above and below it, we
14 did indeed get quite substantial stratification.

15 MR. CATTON: When you do one of these
16 calculations, do you start with a type of stratification one
17 might expect if it is a LOCA type sequence? There is
18 stratification in the containment before you start. I
19 gather than answer is no.

20 MR. SCHNEIDER: I'm trying to understand why you
21 think there should be a lot of stratification with respect
22 to a LOCA.

23 MR. CATTON: That's what they experienced in HDR.
24 It was very hot on top and it stayed very hot.

25 MR. SCHNEIDER: These are relatively open

1 containments. It is somewhat alien or different for me to
2 think about these things being very different, having very
3 nonuniform behaviors because what drives, what normally
4 drives the LOCA is the fact that your containment is pretty
5 much a saturation. The only way you would make it hot is to
6 have some super-heated regions at some point, and since
7 there is no way of getting super-heated steam in a LOCA
8 transient, there's got to be something unique about the way
9 HRD did it to get super heat, or maybe something unique
10 about -- maybe the structure where they were able to
11 condense or something at the bottom, but normally it is
12 different. It is not something that --

13 MR. CATTON: There are whole lots of tests they
14 run to show that the top part of the containment getting
15 extremely hot relative to the bottom.

16 MR. KRESS: When you ran the test --

17 MR. CATTON: High temperatures in one place
18 relative to another.

19 MR. KRESS: When you run the calculations, this is
20 an integral calculation with a full sequence, so it will
21 generate its own thermo-hydraulics, its own initial
22 conditions. You are asking, had it stratified before. If
23 it was, it would have calculated it, is the point.

24 MR. CATTON: I think the only saving grace is 80
25 igniters.

1 MR. KRESS: That helps.

2 MR. SCHNEIDER: That was the brunt of it. This is
3 only here for -- well, maybe it should be here, whatever.

4 MR. CARROLL: We would like the slide you have
5 been talking about, since it is not in your package. While
6 we are still on hydrogen control, as long as you are putting
7 80 igniters in, why aren't you putting in the auto-
8 catalytic gadgets also?

9 MR. SCHNEIDER: They are not seismically
10 qualified. They act too slowly. We are not sure of their
11 performance. We are not 100 percent sure anyone would
12 accept them if we put them in.

13 MR. CARROLL: I like those answers. The other
14 thing you need --

15 MR. CROM: You need to look at the size of what
16 you're proposing. These things are like five by five by
17 three foot boxes and we are talking the same lumber here
18 that we would need of those in the amount of space, and just
19 everything else. The other thing is the testing. What we
20 read on them is it does not look real beneficial there
21 either.

22 MR. CATTON: A couple of us attended a meeting in
23 Germany. They came to the conclusion that the catalytic
24 reactors are what should be used and that igniters were too
25 speculative, particularly the possibility of deflagration

1 being initiated. Nobody -- they were not too concerned
2 about detonation because they felt the highly variable
3 environment that detonation would not occur but deflagration
4 could, and that if you did not place the igniters properly,
5 you could initiate it.

6 I believe they're going to recommend that the
7 catalytic reactors be used and igniters -- there is still
8 question as to whether they should be used or not.

9 MR. SCHNEIDER: That might be the right decision
10 for the German plants. They are more compartmentalized.
11 They have areas that could propagate flows in with
12 accelerations. It is not that we disagree with their
13 judgment. We do not think it is the right thing for our
14 plant.

15 MR. CARROLL: Add to your list the good German
16 catalytic converter on my Porsche has disintegrated and it's
17 going to cost me \$1,200 to get a new one.

18 [Laughter]

19 MR. CARROLL: The next topic is the limiting burn
20 pressure. So that is sort of separate, I guess? Why don't
21 we take our break at this point and pick that up when we
22 come back? Ten minutes.

23 [Recess.]

24 MR. CARROLL: Let's reconvene.

25 MR. SCHNEIDER: As the last part of the hydrogen

1 analysis, what we wanted to demonstrate is if we had the 13
2 volume percent uniformly accumulated within the containment,
3 that the resulting deflagration from that would still be
4 well below the containment service level C limits. So we
5 calculated the hydrogen pressure based on AICC and we burned
6 from the maximum flammable condition for the containment to
7 get the maximum initial --

8 MR. CATTON: How much steam did you have in it?

9 MR. SCHNEIDER: That's what we'll do next. What
10 we did is we started off with a 13 volume percent dry,
11 relatively dry, with a couple of weight percent, couple of
12 volume percent steam, and then started to add steam into the
13 mixture, so we had a constant hydrogen mix, but the volume
14 percent dropped, and this is the flammability line.

15 We calculated the combustion pressure, which is on
16 this scale, as a function of the steam concentration, the
17 hydrogen volume concentration. Either percent, or 10 to the
18 minus 2. Both of these might apply. We went down the
19 regime of adding steam to the mixture and then calculated
20 the AICC pressure.

21 Even as we go beyond the no combustion point where
22 you go beyond flammability -- when you get to about six,
23 maybe seven volume percent, you start getting into the
24 incomplete combustion range. We still assumed AICC and then
25 we still took it even, and as you get to just beyond the no

1 combustion point, the final pressure for volume percent
2 mixture in this containment is 100 psi with C, 140 psi.

3 We have, we feel, a substantial margin for that.
4 That is a reasonably limiting evaluation, we believe, so our
5 conclusion was the assessment of the post-burn containment
6 performance indicates that the system 80 design features
7 successfully mitigate the severe accident threat.

8 MR. CARROLL: Now Ivan, why don't you take a look
9 at the topics in the next slide here. One of the first ones
10 also. And I assume you're ready to talk about any of them?

11 MR. SCHNEIDER: Yes.

12 MR. CARROLL: Why don't we pick the ones you would
13 like to hear this afternoon, Ivan?

14 MR. CATTON: What about all of them? Why don't
15 you just start and go.

16 MR. CARROLL: I don't know if we can get all of
17 them in. It's five minutes to four. Steam explosions?

18 MR. CATTON: I would like to see the excess steam
19 explosions, core concrete interactions.

20 MR. SCHNEIDER: Ex-vessel steam explosions. I put
21 excess. It should have been ex-vessel. Ex-vessel steam
22 explosions we treated probablistically. We don't have a
23 deterministic treatment of in-vessel steam explosions.
24 We've reviewed basically what was done by the SERG, as did
25 the steam explosion review group that concluded that that

1 was applicable.

2 We used that set for values of probability of
3 containment failure and we had a multiple probability of
4 containment failure depending on the low pressure versus one
5 conducted at high pressure. We propagated it into the PRA.

6 MR. CATTON: It is a steam explosion review group.
7 That's been 10 or 15 years ago.

8 MR. SCHNEIDER: It's been some time but it was
9 supporting new reg 1150. Maybe about eight years ago.

10 MR. CATTON: It was quite a ways, quite a while
11 ago.

12 MR. CARROLL: The staff did something more recent.

13 MR. SCHNEIDER: We did also look at the German
14 risk report. I guess --

15 MR. CATTON: I'm not sure the Germans believe
16 their risk report. At Karlsruhe there are 32 people who are
17 working in this area of steam explosions, and it is not so
18 much that you blow the lid off but you also have the
19 possibility of knocking the lower end off, and then the
20 acceleration of the vessel rocket.

21 What have you done about this? You just put the
22 number and put it into your PRA?

23 MR. SCHNEIDER: Right now we don't have, we don't
24 feel that the in-vessel steam explosion is a credible
25 containment threat. It is in the PRA at something like 10

1 to the minus --

2 MR. CATTON: There is more to the in-vessel steam
3 explosion than the Alpha mode failure of your containment,
4 and you could argue that that probability is low, but that
5 is basically all that this particular group address.

6 MR. SCHNEIDER: Right.

7 MR. CATTON: But there are other things. There
8 was a momentary surge and pressure in the lower cavity. You
9 could argue that your cavity is much bigger and it would be
10 nice if you did it, and there is also the thrust that you
11 would have on the vessel if you ruptured and whether or not
12 your supports could take it. Have you done all these
13 things?

14 MR. SCHNEIDER: Partially. We looked at rocket
15 failure as a separate issue.

16 MR. CATTON: And you concluded that it is strong
17 enough to handle?

18 MR. SCHNEIDER: Yes. Basically rocket failure --
19 we did not look at the full failure of the lower head. We
20 looked at the failure of a typical lower head failure for a
21 lower head level plant.

22 MR. CATTON: That is a hole the size of my thumb.

23 MR. SCHNEIDER: It is a hole a couple of feet. We
24 looked at 20 square feet and based on 20 square feet we were
25 able to indicate the thrust without it being that great. We

1 used the German calculations using RELAP for their upper
2 thrust and scaled it down for our areas.

3 MR. CATTON: What does RELAP calculate thrust?

4 MR. SCHNEIDER: Basically they calculated the
5 impulse of a lower head falling off in order to estimate the
6 loadings on their support structure in one of their
7 containment analyses, and what we did was basically use
8 their data with their prediction, scaled it for our
9 particular areas, looked generally at what our supports
10 were.

11 We have very messy hot links that generally could
12 take and the clove legs and kind of came to the conclusion
13 that it is still going to be -- even with a 20 square foot
14 hole in the bottom, and I believe that is the number we
15 used. I have to double check that. It is unlikely that
16 there's going to be any substantial -- that you're going to
17 be able to lift a million pound vessel 100 feet. The
18 kinetic energy just was not there.

19 MR. CATTON: What about the momentary pressure
20 spike in the lower cavity?

21 MR. SCHNEIDER: Our cavity is very robust. It
22 will handle well over 100 pounds. We did do a full failure
23 of the lower -- of the cavity and the cavity pressure is
24 going to be -- I've got to be careful about the numbers. We
25 did the analysis. The cavity pressure for a steam-driven

1 release is a lot lower than you would have gotten
2 traditional for the blow-down of steam-water mixture, which
3 they used to analyze the massive double-ended bricks for.
4 This cavity is bigger and stronger than any cavity that we
5 have designed in the past.

6 So I believe we looked at it. It has been an
7 issue that I have not looked at for a long time because it
8 was kind of dismissed because we had substantial margin. I
9 was even considering maybe taking it out because nobody
10 seemed to have any interest in it, but we did actually some
11 compartment pressure analysis of a break in the lower head
12 of the -- a break in the lower head of the vessel,
13 pressurizing the cavity and because of the large vent, the
14 large volume, we're okay. I don't think there is a problem.

15 The modeling is in CESSAR.

16 MR. DAVIS: I think part of the argument that I
17 got out of the PRA was that you do not have very many high
18 pressure mount sequences because you have got a safety grade
19 depressurization system, and for a lot of cases you go
20 through an aggressive cooldown of the primary system when
21 you start getting into problems. So there's very low
22 probability of a high pressure melt sequence, isn't that
23 true?

24 MR. SCHNEIDER: Yes, that is true. You run into a
25 problem when you talk phenomena versus probabilistic risk. I

1 wear both hats. He asked me if it's a phenomenon problem.
2 I will tell you what the phenomenon is, but probablistially
3 it has risk significance.

4 MR. CATTON: If both sides go away then it's
5 really low-risk, and that's what would be nice to hear too.

6 MR. DAVIS: Okay.

7 MR. CARROLL: It doesn't sound to me like what
8 this stuff says about in-vessel steam explosions, beginning
9 on page 19-169 really reflects the current state of the art.

10

11 MR. LINDELAD: Fossil plants again?

12 MR. CARROLL: They're hanging their hat on NUREG-
13 1116, and this CSNI meeting in January, which you say people
14 are now re-thinking. January '93.

15 MR. CATTON: That was not the meeting I was
16 talking about. That is not the one that the gentleman up
17 here referred to. It was something called a severe accident
18 review group that formed. I thought it was 10 years ago,
19 that concluded that it was very low probability. It was a
20 bunch of people like me who didn't know anything about steam
21 explosions.

22 MR. CARROLL: That is what NUREG 1116 is about.

23 MR. SNODDERLY: I was one of the contributors.
24 Really what we have hung our hat on is, as Dr. Catton said,
25 it sort of took place about 10 years ago and then there was

1 another meeting that was attended by one of the contractors
2 for the ACRS, members of research NRR, and from experts from
3 all over the world. It headed by Professor Theofanos.

4 MR. CATTON: That was the meeting at Santa Barbara
5 and the conclusions there were not very conclusive.

6 MR. SNODDERLY: I would agree, but one point that
7 did come out was that there would be limited, not mass
8 involvement, because if you go to the next paragraph we melt
9 mass involvement because of the structures in the lower
10 head, i.e., the CIC guide tubes in the lower baffle plate
11 would break up the melt mass, and because of the limited
12 melt mass would limit the size of the in-vessel steam
13 explosions.

14 That is one of the conclusions we drew, and one of
15 the things that we are really basing our conclusion on.

16 MR. CATTON: How come I don't have a chapter 19?

17 MR. CARROLL: You've got one at home.

18 MR. CATTON: Oh, that's that big, thick --

19 MR. CARROLL: Do you want to read your words from
20 mine and see what you think of them?

21 MR. SNODDERLY: That would be the last paragraph
22 right before section -- right before ex-vessel steam
23 explosions.

24 MR. CATTON: What led them in Germany to sort of
25 revitalize this concern and to put so much resources into

1 it? Do you know?

2 MR. SNODDERLY: I believe that would maybe be the
3 beta experiment.

4 MR. CATTON: The beta experiment certainly helped
5 because there it showed how you could get total mass
6 involvement.

7 MR. SNODDERLY: And I think that there was a
8 pressurization because of a limited vent area that caused -
9 - that caused it to force back.

10 MR. CATTON: Correct me if I'm wrong, Tom. Didn't
11 we hear that what happened is that somehow melt got into the
12 water and pressurized where the water was outside of the
13 region where everything was supposed to be occurring, and
14 that pressure then drove the water into the melt?

15 MR. SNODDERLY: And kept it in that confined
16 geometry.

17 MR. CATTON: It was just driving the water into it
18 that caused the problem. How can we preclude that in other
19 circumstances?

20 MR. SNODDERLY: I personally don't think that
21 we're going to have that because of the limited vent area,
22 forcing the water back.

23 MR. CATTON: Look at Three Mile Island, where you
24 almost melted through into the annulus. Then it begins to
25 sort of look like the beta experiment. Anyway, I don't

1 personally think the alpha mode is a concern, and if they
2 have evaluated these other things, the only question then is
3 the 20 square feet. How do you come to 20 square feet as
4 the area that you used?

5 MR. SCHNEIDER: Well, our best estimate was
6 something on the order of one, and we did some kind of a log
7 normal type of fit down to full vessel size and I think we
8 took it -- I've got to go back. I think it is just standard
9 deviation. We decided to go to the upper end but it just
10 did not generate enough thrust.

11 MR. CATTON: Okay. I don't need to hear any more.

12 MR. CARROLL: Okay. Well, do you like what the
13 staff has said? Do you think that is appropriate language
14 for an FSER?

15 MR. CATTON: I have not seen this in NUREG 1116.
16 Oh, that is the SERG report. Well, the fact that they refer
17 to that report makes me a little nervous.

18 MR. BARRETT: I am Richard Barrett with NRR staff.
19 I guess our thinking was that in the original 90-016 we
20 really did not address steam explosions, and I think
21 probably that was because of the low importance they had in
22 NUREG 1150. After we started the reviews, we recognized
23 that this could be a problem and we went back and revisited
24 it, based on the SERG report, and Mike Snodderly attended
25 the meeting in Santa Barbara and his report on what the

1 conclusions were was that if we were going to deal with this
2 issue, we would gain a lot more by concentrating on the ex-
3 vessel. That seemed to be the consensus of the experts.

4 MR. CATTON: The last part where they talk about
5 the structure in-core instrument tube guides that is below
6 the core plate probably does more to eliminate a large steam
7 explosion in that region than anything else because we heard
8 about that too. Apparently some experiments have been done
9 and you have a lot of metal tubes and so forth that makes it
10 somewhat incoherent and that reduces the peak. I guess we
11 go to ex-vessel.

12 MR. SCHNEIDER: Okay, I'm happy.

13 [Slide]

14 MR. SCHNEIDER: The purpose of ex-vessel steam
15 explosion studies was, one, again, to comply with the goal
16 to minimize early containment failures. It was not any
17 specific goal in ex-vessel steam explosions and addressed
18 the observations made in some of the NUREG 1150 containment
19 performance analysis, and can induce a containment failure
20 possibly via failure penetrations.

21 [Slide]

22 MR. SCHNEIDER: So we attack this on multiple
23 fronts, and actually resulted in a lot of design analysis,
24 and actually even some design improvements, if you will, for
25 severe accidents. Basically, if you remember the cavity

1 design, it is this huge cavity that sits at the relative
2 bottom. Maybe let me pull up the figure again, with a
3 massive amount of concrete around it.

4 We just have a couple of views of it. This is the
5 lower portion of the cavity. The cavity is the region
6 inside here, including some of the stuff going up to there,
7 so it is a pretty massive structure.

8 MR. CATTON: How thick is the concrete?

9 MR. SCHNEIDER: About 10 feet.

10 [Slide]

11 MR. OSWALD: It is six foot at the thinnest
12 portions at the very sidewalls. It is six foot at the
13 thinnest.

14 MR. DAVIS: You're talking about a steam explosion
15 which results when the molten core exits the vessel and
16 enters the cavity.

17 MR. SCHNEIDER: Yes.

18 MR. DAVIS: Which may or may not have water in it.

19 MR. CARROLL: Which is supposed to have water in
20 it.

21 MR. DAVIS: No, because that is a manual system
22 and they can either wait or they can put it in afterwards.
23 And if this is a problem, they can put it in -- isn't that
24 correct? It is a manual system. Your accident management
25 strategy can put it in before and after.

1 MR. SCHNEIDER: Right now we are comfortable with
2 putting it in -- because of the structural design and we
3 will talk about that in detail. We are not really concerned
4 about a steam explosion. Basically the bottom line is you
5 can damage the cavity, virtually eliminate the bottom
6 portion of the cavity and there's enough cantilever support
7 and re-bar shear that will still hold up the vessel so that
8 at the moment we think there is enough robustness in the
9 design.

10 MR. CARROLL: Your strategy would be to flood the
11 cavity where there is indication that you have core melting?

12 MR. DAVIS: But you have the flexibility to adjust
13 that?

14 MR. SCHNEIDER: Yes. Should a different
15 interpretation ever become available, we can, which is a
16 unique feature of the system 80-plus design.

17 MR. CATTON: So you plan to try to save the
18 vessel, to turn the vessel into a crucible with flooding?

19 MR. DAVIS: The flood will not get up to the
20 vessel.

21 MR. SCHNEIDER: It is basically just to break the
22 core room up and to cool the core itself. Unfortunately, in
23 the process of going through the earliest slide to get the
24 containment picture, I misplaced the slide I was just
25 showing you so I will have to read it to you. The system-

1 80 plus reactor vessel can be supported without the presence
2 of a lower cavity wall, and in addition we have corbels, and
3 let's see if I can use the picture up here.

4 MR. CARROLL: You've got a better one further on.
5 We tend to do that to people. This is a test.

6 [Laughter.]

7 MR. SCHNEIDER: We have corbels, which are pretty
8 massive, and reinforced with re-bar at the top and bottom.
9 The only reason they are reinforced at the bottom is for the
10 steam explosion loading, and basically it is a reasonably
11 massive structure. This contained impulse loads pretty
12 close to psi seconds, which is pretty high, like 1,000 psi
13 loading over a period of time.

14 If we fail the lower cavity, this is all gone,
15 there is enough residual re-bar shear strength to maintain
16 this in a cantilevered mode and hold up the reactor vessel.

17 MR. CATTON: What was the impulse again?

18 MR. SCHNEIDER: The corbels itself can take close
19 to 4.6 psi seconds. The walls are not quite as robust and
20 we will talk about that in a minute. But should you fail
21 the walls, you still have enough strength in the re-bar on -
22 - that's from the adjacent structure to maintain integrity
23 of the -- or main support of the reactor vessel so that
24 you're not going to be pulling. This is not going to be
25 moving so far out of its location that it will pull

1 penetrations out of the containment.

2 MR. CATTON: Where did the 4.6 come from?

3 MR. SCHNEIDER: We did detailed structural
4 analyses.

5 MR. CATTON: You have the structure there and then
6 you ask yourself.

7 MR. SCHNEIDER: I'm telling you what the
8 structures can take.

9 MR. CATTON: There are lots of tools available to
10 do calculations once you have made some assumptions as to
11 what the impulse might be. Have you done that?

12 MR. SCHNEIDER: In a manner of speaking. We
13 decided that the state of the art was fine, but what we felt
14 is we could get a good handle by using basically the depth
15 charge impulse loadings with equivalent TNT energy
16 transformation, so we did basically a similar thing for
17 NUREG 1150. Basically we used the cold underwater explosion
18 impulse and determined, based on so many pounds of corium,
19 with such superheat and conversion efficiencies, what the
20 size impulses would you get propagated as a spherical
21 basically depth charge.

22 MR. CATTON: I understand how to do that part.
23 It's just the energy conversion. When you put the .03 did -
24 - what was the impulse?

25 MR. SCHNEIDER: It depends on the mass. We can

1 talk about that. Basically what we concluded was, based on
2 a .03, and I will have that in the next slide and we can
3 talk about it a little more if you wish, will survive a one-
4 half PSIA, which is equivalent to a 10,000 pound mass
5 participation at three percent.

6 MR. KRESS: How much total mass is in the core?

7 MR. SCHNEIDER: The core has a total mass of about
8 350,000 pounds. So, it is not a large fraction of the
9 total mass, but remember the explosion is only going to be a
10 millisecond phenomena and so that you're not going to have a
11 lot of mass at any given time.

12 MR. CATTON: It turns out that it is going to be
13 longer than a millisecond.

14 MR. SCHNEIDER: Of that order, you're not going to
15 have a lot of mass that is going to be able to accumulate in
16 a short amount of time. A lot of it is going to lose super
17 heat, plus a lot of it is going to be contained within the
18 mass itself. Not all of it is going to participate. Be
19 that as it may, 10,000 pounds can participate and your
20 cavity still stands with best estimate analysis. We looked
21 at this probabilistically. That is basically the level at
22 which we can withstand. This is kind of a demonstration
23 that we can withstand that much.

24 MR. CATTON: Did the Staff do any calculations?
25 They did for ABWR. Did they do it for this also?

1 MR. SNODDERLY: Yes, we did.

2 MR. CATTON: What kind of mass did you assume?

3 MR. SNODDERLY: I can get that in one second.

4 MR. CATTON: Did you use the Texas Code again?

5 MR. SNODDERLY: Yes.

6 MR. CATTON: Tom, I think we're going to have to
7 take a look at that Texas Code.

8 MR. SNODDERLY: We assumed a melt composition of
9 5,000 kilograms of UO₂, 13,000 kilograms of zirconium, and
10 28,000 kilograms of steel molten. Then what we did was for
11 the best estimate case we assumed a three centimeter single
12 penetration failure of essentially one instrument and we got
13 loadings that showed you would not fail the cavity walls.

14 Now, we did some sensitivity studies on that and
15 we boosted it up to eight penetrations failed for one
16 penetration of -- essentially of going through three
17 centimeters diameter to about seven centimeters diameter.
18 It showed that it would exceed the capacity of the cavity
19 walls at the finis portion that Todd Oswald mentioned, that
20 six foot region.

21 But because calculations done by Duke showed that
22 you could fail that cavity wall and still support the
23 structure and the connecting penetrations and preserve
24 containment integrity, we felt that that was acceptable.

25 MR. KRESS: Did the significance of the number of

1 penetrations failed that is because Texas treats this as a
2 jet going into the water?

3 MR. SNODDERLY: Yes, sir, a gravity pour.

4 MR. BEHBAHANI: Ali Moni, from Accident Evaluation
5 Branch. You can also have high mass injections if you have
6 higher pressure in the reactor vessels. So, in addition to
7 gravity flow, you can have higher velocity flow.

8 MR. CATTON: How much corium did you say or zirc
9 that was in the mixture? 5,000 tons of UO₂, 13,000
10 kilograms of something.

11 MR. SNODDERLY: It was conservatively kilograms.
12 13,000 kilograms of zirconium, 28,700 kilograms of steel.

13 MR. CATTON: 28,000 of steel. Now, in Texas, how
14 do they treat the zirc? Do they react it?

15 MR. SNODDERLY: We would have to get that for you.
16 This report right now is in draft form. We expect it is
17 also being reviewed by two other reviewers, Mike Cordini of
18 the University of Wisconsin and another professor at Georgia
19 Tech.

20 MR. CATTON: Who at Georgia Tech, Abdul Kalik?

21 MR. SNODDERLY: Once we get that final report we
22 will put in on the docket and submit it to the ACRS and then
23 we can, hopefully, answer any questions you have. I believe
24 the zirconium is molten. It is just treated as molten
25 zirconium.

1 MR. CATTON: It looks like it makes up at least 30
2 percent of your mix. So the temperature of the zirconium is
3 going to be very important.

4 MR. SNODDERLY: We also did sensitivity studies on
5 the temperature of the melt. We had it with 100 degrees
6 super heat in the base case in one of the sensitivity
7 studies. We did it with 200 degrees super heat. So 2,800
8 degrees and 3,000 degrees.

9 MR. CATTON: What did you take as a water
10 temperature in the cavity?

11 MR. BEHBAHANI: 363.

12 MR. CATTON: Was it saturated?

13 MR. SNODDERLY: Just beyond saturated.

14 MR. CATTON: Because it is very interesting as you
15 change the water temperature the possibility of the
16 zirconium entering in in a real rapid way goes up. You
17 actually get a sharp transition and the rate of reaction
18 curve as you increase the water temperature.

19 MR. KRESS: You increase energetics as you go down
20 in the subcooling.

21 MR. CATTON: It is a trade off. You reduce the
22 temperature of the energetics from the thermal interaction
23 get more exciting but you damp the chemistry, and somewhere
24 in the middle it gets really exciting. I think, Tom, we
25 should take some time and take a look at what they've done

1 because we keep hearing about the Texas Code as the tool of
2 choice for the Staff.

3 MR. SNODDERLY: Dr. Catton, one other point of
4 interest might be that those initial conditions that we
5 chose were based on the Levi analyses.

6 MR. CATTON: The who analyses?

7 MR. SNODDERLY: Levi. And then what we did was -
8 - what our contractor did then was scale that for the System
9 80+.

10 MR. CATTON: So you assumed 40 to 60 percent or
11 something of the core was molten?

12 MR. SNODDERLY: Right.

13 MR. CATTON: Then you broke a hole in it, a small
14 hole?

15 MR. SNODDERLY: That's right, then entered into
16 five and half meters of water, which would be the most water
17 that you could have. Really it can to me what you really
18 gain from this code, or at least what I gained as far as an
19 insight, is the sensitivity to number of penetrations, the
20 amount of melt mass involvement, and number two the deficit
21 of the pool.

22 So if you lower the pool from five and a half
23 meters to four and a half meters, you have a significant
24 drop in loadings, and then from four and a half to three and
25 a half. So it is very sensitive to pool depth.

1 That is really I think why we did the analysis was
2 to get some feel of the loadings. By no means do we think
3 that these are the exact loadings. These are what I would
4 term ballpark kind of figures to see how -- we have a good
5 feeling for how much the walls would handle.

6 We were trying to get a feel for what type of
7 loaders we were going to be talking about and I think we
8 accomplished that with this. I think this was the best tool
9 that we felt was available at the time and that we had
10 access to.

11 MR. CATTON: You understand that no two code gurus
12 agree?

13 MR. SNODDERLY: No, sir. That is why also we are
14 having the Office of Research. They are running the IFCI
15 Code.

16 MR. CATTON: Which code?

17 MR. SNODDERLY: That was the code that I believe
18 that was developed by Sandia National Laboratory, and we
19 have not gotten those. I have not personally seen those
20 results yet but that will be interesting to see, how those
21 codes compare.

22 MR. CATTON: One of the reasons I asked this
23 because the numerics in the Texas Code preclude the
24 development of the strong shocks. So, really, whether the
25 results are any good depends on whether it is a shock

1 loading or just the sort of pressure rise that is maintained
2 for some small period of time.

3 MR. SNODDERLY: I believe the Texas Code is based
4 on the experiments that were done by Cordini at Wisconsin
5 and I believe one of those did involve a shock wave so that
6 he is attempting to model shock waves with this code.

7 MR. CATTON: That is something we should discuss
8 when we take a look at the code.

9 MR. KRESS: How did the results of your
10 calculation compare with this 10,000 pounds of mass at .03
11 conversion efficiency? Was it higher, lower, close to it?

12 MR. SNODDERLY: The mass would be -- we got
13 similar loadings but for much less mass. Ours were more
14 conservative.

15 MR. KRESS: Which is implied that .03 might be
16 wrong or something.

17 MR. SNODDERLY: Yes, that would be my conclusion.
18 But I just want to end with one point. These calculations
19 are done purely. These are secondary calculations. We
20 really drew our safety conclusion on the fact that even if
21 the cavity wall is destroyed, the reactor vessel and the
22 containment integrity will be preserved, and that was the
23 safety finding.

24 Now, we also did the supplementary calculations
25 because these tools were available and we felt that it was a

1 good idea. But the safety finding is that FCI is not a
2 problem because even if the cavity wall fails, the reactor
3 vessel can be supported by the surrounding structures, and I
4 think you got a good feel for that from the picture that you
5 saw with the thick walls and the wind walls extending to the
6 ends of containment. That is where most of the load is
7 going to be taken.

8 MR. KRESS: Is that a judgment call or was that
9 based on calculations also, that the support was really
10 there?

11 MR. SCHNEIDER: DC calculations with ACII
12 standards without the conservatism. So best estimate ACI-
13 349.

14 MR. CARROLL: Now, how big a steam explosion is
15 needed to do in the corbels?

16 MR. SCHNEIDER: Huge. Corbels -- we have
17 reinforced the corbels as a result of the initial analyses.
18 We have put additional rebar in. It is about three times as
19 strong. It takes an impulse about three times as strong as
20 the cavity wall. We're dealing with something about four
21 and a half PSI impulse which is probably -- I don't have a
22 number here. I think you're dealing with something closer
23 to maybe 30, 40 thousand pounds, 50 thousand pounds,
24 something in that general range. It is a lot bigger. There
25 is a substantial difference.

1 The corbels are not going to be fully immersed for
2 the things. They may not be fully loaded.

3 MR. LINDBLAD: What percentage of steel roll is in
4 the corbels? Are they asked to respond ductilely? Or is
5 there more steel in there than concrete?

6 MR. SCHNEIDER: No, there is -- I don't know if we
7 went above any normal type or reinforcing. The
8 reinforcement was kind of normal. What they normally don't
9 do is they normally would not reinforce the lower portion of
10 a concrete structure if they don't expect loads on it, and
11 since now they may expect loads on it they reinforced it to
12 withstand loadings.

13 MR. LINDBLAD: Two way loads, loads up and down?
14 All right.

15 MR. KRESS: But the entire safety case for this
16 rests on the fact that you're not going to fail those
17 corbels and you're going to hold the vessel up with them.
18 Based on the fact that there is some level of steam
19 explosion that won't fail. It seems to me like it is a
20 still a little loose there. You have to get a technical
21 basis for how big of a steam explosion you really expect,
22 how big a steam explosion or fail the corbels, and compare
23 those two. I suspect you have done that but it is a little
24 loose to me right now.

25 MR. SCHNEIDER: Our best estimate hole size

1 failure to estimate the mass involved in the event, our best
2 estimate hole size failure is approximately a square foot,
3 and that is kind of based on more or less like a TMI bulge
4 with about a foot in diameter or something. So that with a
5 square foot -- with a square foot hole your ending up with
6 approximately I think 10,000 pounds of mass going down about
7 15 feet. So, if you assume that that amount of mass all
8 interacts at once, that is kind of a rough way of estimating
9 the mass at any given time.

1 MR. CARROLL: You've also got a backup position
11 and that is do not flood first.

12 MR. SCHNEIDER: Yes.

13 MR. KRESS: I don't know if that is a backup
14 position or not because you've made the decision to flood
15 first. On what basis was that decision made? You know it
16 seems to me like if it didn't matter whether you flooded
17 first or later you would always decide to flood later. You
18 must have decided that there was a reason.

19 MR. CARROLL: If I was not worried about steam
20 explosions, I would always flood first.

21 MR. KRESS: But if you're worried about --

22 MR. CATTON: What you could do is put a limited
23 amount of water in first. Let the steam explosion take
24 place and then put the rest. That way you could control the
25 magnitude impulse.

1 MR. CARROLL: Which steam explosion?

2 MR. LINDBLAD: How long would you wait for the
3 steam explosion to happen?

4 MR. CARROLL: And how long would you wait for
5 Number 2 to happen?

6 MR. DAVIS: Let me ask you this, what if the
7 corbels fail?

8 MR. SCHNEIDER: There are a whole bunch of
9 multilayers of things which we did not credit because we
10 felt comfortable. But the thing is that other
11 considerations.

12 [Slide.]

13 MR. SCHNEIDER: These things we did not do details
14 on. You do have additional support. We really do have a
15 relatively thick hot leg, which is almost as a structural
16 member.

17 So, there is always the potential of just having a
18 thing bend and sag without major motions. Even if you fail
19 the reactor vessel, the steam generator rotational bulk
20 prevent very much -- the steam generator keys will prevent
21 very much rotation of much of the adjacent piping.

22 So, we're not going to expect significant
23 displacement of this location of piping in the RCS, and even
24 if you do, it is more likely to fail the piping inside
25 containment than at the penetration because the penetrations

1 are reinforced. The first level is the cavity is not going
2 to fail. If it does, it can still possible be supported by
3 this.

4 Even if it does, the piping may not get enough
5 rotation because piping failure -- even if the piping fails,
6 it is more likely to fail in containment. We did treat it
7 probabilistically also where we actually overestimated. We
8 did not credit any of this stuff, overestimated the impact,
9 and the way it turns out this is probably one of our most
10 dominant containment failures only because we conservatively
11 treated what might be viewed as a potential. But
12 probabilistically we are created the fact that maybe
13 through some unforeseen reason there is a small probability
14 of this actually occurring. So it does turn out to be a
15 contributor.

16 We have looked at it in a continuous spectrum of
17 various positions. We think that this is about as robust of
18 steam explosion you're going to get. We think it is pretty
19 good.

20 MR. CARROLL: Now, in our review of ABWR, they
21 have, of course, do not flood until they get melt in the
22 cavity. They also made quite a point of the fact that it
23 would be an extremely low probability that there would be
24 water in the cavity because of the designer of their plant
25 from any other source. Can you say the same thing?

1 MR. SCHNEIDER: Yes. All of our water will go
2 into the hold up volume, which will, basically, feed back
3 into the IRWST, and if you do not open those valves, it is
4 not going to get into the cavity. You need to flood the
5 valves to get in.

6 MR. CARROLL: So you're backup of not flooding
7 first is viable in that sense. Okay.

8 MR. CATTON: I guess if you flooded it, you sort
9 of take care of the core concrete interaction.

10 MR. SCHNEIDER: We believe so.

11 MR. BARRETT: I would like to point out that the
12 Staff's review of this severe accidents was based on
13 preflooding. One of the concerns we would have if there was
14 not preflooding would be the operability of those valves
15 following steam explosions in excessive events.

16 MR. KRESS: You may not have that option.

17 MR. BARRETT: Our finding if the option were still
18 open that they may have a dry cavity, we would want to take
19 a second look at that.

20 MR. CARROLL: Do you have a response to that or do
21 you agree?

22 MR. SCHNEIDER: I agree. We do plan on
23 preflooding and we have not. We don't have any current
24 plans of not flooding the cavity. We think it is a more
25 realistic and pragmatic approach. We are not at all sure

1 how much we would want to drive the design because the
2 potential of steam explosions at this stage of knowledge and
3 considering the robustness of the design. If you were ever
4 getting into that situation, I think right now I think most
5 people feel that you would rather break up the debris and be
6 able to cool it as before you started attacking and eating
7 away your concrete.

8 MR. CARROLL: If you can put the steam and
9 explosion issue to bed, I totally agree.

10 MR. SCHNEIDER: As I said, we believe that with
11 the multiple levels we have reasonable confidence that it is
12 a really low likelihood that steam explosion will fail this
13 containment in a realistic sense. How do you put realistic
14 into severe accidents?

15 MR. CARROLL: Tom, you keep saying this is
16 something that we will have to put on notice to look at? Is
17 this a combustion list or is this a more general list?

18 MR. CATTON: In my view, it is a more general list
19 because this is the second time we have heard that this
20 particular code has been used for coming to some conclusion
21 about steam explosions. So I think Tom's Severe Accident
22 Subcommittee ought to hear about it.

23 MR. CARROLL: Cordini, of course, was with up in
24 Portland.

25 MR. CATTON: But Cordini is the one who developed

1 the code.

2 MR. CARROLL: He told us quite a bit about it at
3 that time.

4 MR. CATTON: Not really.

5 MR. CARROLL: All right. So if you had to cast a
6 vote today, are you happy with the situation of X vessel
7 steam explosions that combustion has portrayed?

8 MR. CATTON: My reaction is that it is probably
9 okay because it is so robust.

10 MR. KRESS: But that case has not been made clear
11 that it is okay.

12 MR. CATTON: If I had to cast a vote as I stand
13 right here, that is where I would come down. I certainly
14 would like to have the two calculations that you refer to in
15 front of me. What is the maximum possible impulse that you
16 could expect? What is the impulse that this thing could
17 withstand? What is the expected impulse so that you sort of
18 look at the numbers?

19 Now, they're talking 4.6 psi seconds is what the
20 corbels can withstand. Right off the top, I don't know if
21 that is a big number or a little number. I would have to
22 look at some of the calculations.

23 MR. KRESS: I think that is a big number.

24 MR. SCHNEIDER: A thousand pounds for five
25 milliseconds.

1 MR. CATTON: It depends on who you're doing
2 business with. But in Pascal seconds or something or
3 others. I think they have made a better case than I have
4 heard for any other system.

5 MR. KRESS: I think the Staff has made a
6 relatively good case based on Texas because the real
7 questions you end up with is what is the efficiency of the
8 conversion and how much mass is involved, and there is no
9 real way to attack that a priori. But with a code like
10 Texas it gives you a little handle on that. We need to look
11 at the physics involved.

12 MR. CATTON: With a code like Texas has this jet
13 injected into the pool. So it means it is a rate limited
14 process where it is adding into the pool. And there are lot
15 of cases that we both know about --

16 MR. KRESS: It is a delayed explosion. Explosion
17 and you have to worry about that thing.

18 MR. CATTON: That's fine. There are also
19 assumptions that go into it. The assumptions are the
20 globular sizes before the steam explosion, the globular
21 sizes are fragments after the shock has passed it --

22 MR. KRESS: That is not an assumption that part.
23 That is calculated. There is a globular size before that is
24 calculated.

25 MR. CATTON: They are both input. They are not

1 calculated. I would sure like to see how they do that.
2 There ain't nobody that knows.

3 MR. CARROLL: We need to get you to the mike if
4 you're going to be on the record.

5 MR. CATTON: This is a shock passing across a
6 droplet and I don't think anybody knows how to do that
7 really well.

8 MR. BEHBAHANI: The fragmentation formula was
9 based upon Corotas experiments at Israel, and too much of
10 the Corotas experiments they have fragmentation based on
11 that. As you said, there are some constants in there that
12 you have to play around with and they match up those
13 constants such that they get matched up. They result in the
14 Corotas experiments.

15 MR. CATTON: That is one set of experiments, one
16 set of materials. There are lot of parameters, diameters
17 for and after the heat before and after, there is chemistry,
18 there is all these things.

19 MR. KRESS: That is why I say it is still pretty
20 loose.

21 MR. CATTON: That's right.

22 MR. CARROLL: Okay. Have you've concluded?

23 MR. SCHNEIDER: I will.

24 MR. CARROLL: He sat down.

25 [Laughter.]

1 MR. SCHNEIDER: It is our belief, based on the
2 robustness of the design, that X vessel steam explosions
3 will not compromise our V support and, consequently, don't
4 pose a significant risk of containment failure. As I said,
5 it is treated probabilistically. It is included in our PRA
6 with a higher level of capability for failing than we
7 actually -- than we necessarily believe. But it is there.
8 It does show up.

9 [Slide.]

10 MR. CARROLL: So, you're going to talk about that
11 when we talk about PRA when you have your other hat on?

12 MR. SCHNEIDER: Dave, is going to talk about the
13 stuff with the other hat. A lot of it depends on how the
14 compositions go.

15 MR. CARROLL: This is the next point you wanted to
16 hear about, Ivan?

17 MR. CARROLL: I think so.

18 MR. SCHNEIDER: Let's get the cover slide. The
19 goal here was to provide coolability of the corium debris in
20 the reactor cavity as a physical system and we have the
21 cavity flood system protecting the containment pressure
22 boundary, which is going to be the lower shell, the lower
23 portion of the shell, and the applicable guidance is
24 provided a means to flood the reactor cavity, protect the
25 steel shell with concrete, have a large floor area for

1 potential corium spreading, and demonstrate that you have
2 about a day for containment integrity even with core
3 concrete attack for a probable scenario.

4 The design features applicable to this are
5 relatively large cavity floor area which limits the average
6 for uniform depth to approximately ten inches.

7 MR. CARROLL: How does that relate to the utility
8 requirements document?

9 MR. SCHNEIDER: It is a little less. It is a
10 slightly less than .02.

11 MR. CARROLL: 80 percent of it?

12 MR. SCHNEIDER: It is about 80 percent of it. The
13 cavity flooding system is capable of flooding the reactor
14 cavity to approximately 11 feet, and again, the water is
15 expected to fragment, cool and scrub the debris. Cavity
16 floor is constructed with a minimum of three feet of
17 limestone based concrete, either limestone common sand or if
18 they choose, it is pure limestone. But because the cavity
19 is so -- because the system is so large we're not really
20 worried about the carbon dioxide content of this because it
21 is a better resistance. It better resists erosion to
22 protect the containment shell.

23 We have robust upper cavity design. So, again,
24 erosion of the lower pedestal is not a major concern. The
25 additional 15 feet of concrete remains as a barrier below

1 the shell before you get to the floor.

2 MR. DAVIS: What kind of concrete is that?

3 MR. SCHNEIDER: That is not specified. That could
4 be whatever the COL applicant decides.

5 MR. DAVIS: If it were limestone, would you still
6 not have a problem with CO2?

7 MR. SCHNEIDER: At that point we wouldn't. But at
8 that point, it is not going to matter. There is still a lot
9 of volume. What we find is the sequences that go that deep
10 -- that would go that deep into the containment is generally
11 because you have lack of water. If you don't have the
12 water, you're not going to be able to pressurize the
13 containment substantially by just adding CO2 even if you add
14 I would say tens of thousands or twenty thousand pounds of
15 just CO2 contribution.

16 MR. DAVIS: I thought when we were looking at the
17 ABWR there was a difference between the Staff's evaluation
18 and some of the Brookhaven reviews that I looked at, and as
19 I recall in the Brookhaven review, even with water over the
20 mount there was still substantial erosion of the concrete.

21 MR. SCHNEIDER: There was erosion of the concrete.
22 It does not prevent it. A lot of it depends on -- we will
23 get into the modeling versus the morphology.

24 MR. CATTON: It was a big difference because with
25 the ABWR the molten materials are on top of the concrete and

1 then the water comes in and it crusts. What they're doing
2 is they're putting the water first so it fragments. Then
3 the question becomes one of dry out. But this thing is only
4 ten -- what did you say, that it was ten inches deep?

5 Refraction is 40 percent, so maybe it is 20 inches
6 deep with its rubble bed if you have water over it. So what
7 they have done is they are assuring that they the quench
8 stuff, which is a lot different than what GE is doing. With
9 the ABWR you can not be sure. I think they are sure.

10 MR. SCHNEIDER: Not only that --

11 MR. CATTON: Reasonably sure.

12 MR. SCHNEIDER: We have also analyzed it as if it
13 didn't. We have decided that because of the uncertainties
14 in the calculations and some questions that we basically
15 based the 24 hours on a layered non-debris bed.

16 MR. CATTON: Human error. You may open it up too
17 late.

18 MR. SCHNEIDER: Okay. Whatever.

19 MR. CATTON: When it is ten inches from the bottom
20 of the cavity, how much of the core is that?

21 MR. SCHNEIDER: 100 percent.

22 MR. CARROLL: The 11 feet is still below the
23 bottom of the vessel.

24 MR. SCHNEIDER: Yes.

25 MR. CARROLL: How much? Do you know? A couple of

1 feet?

2 MR. SCHNEIDER: About --

3 MR. CARROLL: I see a 63 up at the narrow end
4 there.

5 MR. SCHNEIDER: Basically, it goes to maybe it is
6 a little more than 11. Maybe it is 13 or 14. Basically,
7 what will happen the IRWST level will drop a little bit. It
8 will go to maybe a foot or so below the bottom of the
9 vessel, maybe two feet below the bottom of the vessel,
10 something on that order.

11 MR. CATTON: Did you consider flooding up over the
12 lower end?

13 MR. SCHNEIDER: For the instrument that designs,
14 they don't. It was considered. Stan, do you want to handle
15 that?

16 MR. RITTERBUSCH: It was not seriously considered.
17 We understood that as an option when we were designing the
18 volume of the IRWST and we made a decision to keep the
19 maximum level well below the reactor vessel from the
20 beginning. One of the things we considered was inadvertent
21 operation. We did not want the water touching the vessel,
22 you know, for inadvertent operation.

23 MR. CARROLL: You would probably have to buy a new
24 vessel if you did that.

25 MR. CATTON: At Indian Point they flooded the

1 cavity and didn't even know it.

2 MR. KRESS: You said you did some calculations
3 where you assumed the debris was not coolable.

4 MR. CATTON: That is what he is going to tell us
5 about.

6 MR. KRESS: Did that include some scrubbing
7 calculations of the pool for the fission products as they
8 went up through it?

9 MR. SCHNEIDER: We treated that as a separate
10 issue on fission product removal. We handled it differently
11 as part of the PRA, and these are, basically, deterministic
12 calculations done to estimate maximum climbings of erosion
13 and nothing else.

14 MR. KRESS: You used the MAAP Code for that?

15 MR. SCHNEIDER: No, we did not believe MAAP was
16 the appropriate tool of choice for this. What we felt
17 wasn't going with the state of the art best tool around. We
18 used CORCON Mod 3. MAAP cannot be forced to give a layered
19 behavior I don't believe and we wanted to make sure that we,
20 because of all the sensitivity in the base, that we treated
21 the thing as a layered debris.

22 Basically, the cavity -- you probably have a good
23 view of it at this point -- relatively large surface area
24 with a core debris chamber at this point. Below there is
25 about five feet of concrete in the central region going to

1 about three feet in this general region. There is another
2 picture, another view in a minute.

3 The elevation for the bottom of the basement is
4 about 40. It is about 22 feet total before you actually get
5 to the soil.

6 MR. CATTON: Is that an open area where it says
7 elevation 50?

8 MR. SCHNEIDER: This is the SI Pump Room. In the
9 PRA we did consider the possibility of ingression into it.
10 You do not get enough radial erosion without PRA types of
11 assumptions.

12 [Slide.]

13 MR. SCHNEIDER: This is a top view of the cavity.
14 This is the sump -- the sump different from what you may
15 have seen for the other designs. The sump is very shallow.
16 It is only a foot deep. It still has 3.2 feet of concrete
17 below the bottom of the sump to the steel shell.

18 MR. DAVIS: What are the ICI plates that you
19 talked about in the PRA?

20 MR. SCHNEIDER: The instrumentation tubes coming
21 out the bottom and core instruments. They get pulled out
22 the bottom of the vessel.

23 MR. CARROLL: GE dealt with the sump by I guess
24 putting in some restrictions so that you would get the melt
25 freezing before it got into the sump.

1 MR. SCHNEIDER: We were happy we didn't have to do
2 that. We dealt with the sump by having a very shallow sump
3 and having enough concrete below so that their sump was
4 deeper and with very little concrete below it. Plus, it is
5 basaltic. It goes quicker.

6 So we had actually ANL do calculations where they
7 simulated the sump kind of effect and where they simulated
8 the base effect using CORCON Mod 3, and even the sump
9 calculation in that small region, subsequently about 16
10 square feet. But even in the small region it did not get to
11 the shell position for over 24 hours based on CORCON Mod 3
12 calculations with a slightly increase corium build up in the
13 sump region.

14 Had we gone -- we had toyed with the idea of going
15 with a basaltic design here and we were toying with freezing
16 type of designs and taps and covers. We don't have to do
17 that.

18 [Slide.]

19 MR. SCHNEIDER: But we did specific limestone so
20 that gives us the added nodule. We wanted to demonstrate
21 that with minimum debris coolability -- so even with water
22 on the debris with minimum debris coolability the cavity
23 erosion would not reach the embedded containment shell for
24 about 24 hours. We had to impose analytical restrictions,
25 which were primarily imposed by the NRC in terms of trying

1 to force a MACE type of environment on us.

2 So the initial attack at the lower shell implies
3 containment failure. We think that is a conservative
4 assumption to begin with, but that is, basically, the goal.
5 Only concrete above the steel shell is credited and no
6 credit for debris fragmentation. So, the debris morphology
7 was not favorable to heat transfer.

8 [Slide.]

9 MR. SCHNEIDER: The tools selected for this
10 analysis was CORCON Mod 3. I don't have the list but it is
11 one of the -- it has at least some degree of pedigree as a
12 national lab tool. It has followed the history of core
13 concrete experiments for years. It is the Mod 3 version of
14 it. It is capable of "realistically" considering the
15 limiting case of layered morphologies where you can have
16 layered melts and the changing of layers. It considers all
17 of the exothermic reactions and all of the chemical processes
18 that go along with it

19 We did analysis for both flat cavity floor and
20 sump regions. The analyses was done by ANL consultants. We
21 assume the vessel breach occurs three hours following
22 reactor trip, which is very early, like you're following a
23 large LOCA without SI. 100 percent of the core inventory is
24 deposited on the cavity floor. We credited decay energy
25 released due to volatiles into the corium mixture. We

1 assumed that there was zirc oxidation going on while in the
2 vessel and as it passed through the water. So we assumed 75
3 percent of that zirc alloy oxides into the concrete.

4 MR. KRESS: Would you vary that number as a
5 sensitivity calculation?

6 MR. SCHNEIDER: I don't believe so.

7 MR. KRESS: That is a real dragger for core
8 concrete interactions. How much of that zirc is unoxidized?

9 MR. SCHNEIDER: We're dumping it in with the pool
10 of water above it. The question was steam explosion are
11 that virtually all of it will oxidize. The question with -
12 - I'm sorry. The question with how much oxidation and
13 hydrogen generation is virtually all going to oxidize. But,
14 basically, we're not oxidizing all of it. There is still a
15 good amount not oxidized.

16 It will affect the course of the event, probably
17 several hours. But I would not expect it to be the
18 redominant and it this point because it is not like you can
19 make it zero. The credible number you are dealing with has
20 got to be at least 50 to 75 or maybe 50 to 100.

21 MR. KRESS: Or to be conservative, maybe 25.

22 MR. SCHNEIDER: We believe we are conservative
23 enough by having the layered debris bed 100 percent on the
24 core in three hours.

25 MR. KRESS: You're right. It is conservatism.

1 MR. SCHNEIDER: With those calculations the time
2 it takes to actually erode the three feet of concrete was 30
3 hours for the flat area, 3.2 feet of concrete, which is the
4 sump depth, 24 hours.

5 [Slide.]

6 MR. SCHNEIDER: So, we feel reasonably comfortable
7 with that level of assumptions that we need the -- that
8 we've demonstrated the ability of System 80+ to provide the
9 24 hours of containment integrity called for in SECY 93-
10 087. That's it. Not a big story.

11 MR. DAVIS: In this case, even if you erode to the
12 containment shell, what would happen?

13 MR. SCHNEIDER: Nothing.

14 MR. DAVIS: There is no release path. You've got
15 another 15 feet below that.

16 MR. SCHNEIDER: We did make a conservative
17 assumption for some of the transients probabilistically to
18 assume that you can erode about eight feet or so radially
19 into the pump room. But we expect really the main
20 trajectory to be down. There will be radial erosion, but we
21 think it is really going to be unlikely it is going to
22 migrate all the way over to the pump room. But we do
23 consider it as part of the PRA.

24 MR. DAVIS: Thank you.

25 MR. CATTON: I'm happy.

1 MR. SCHNEIDER: It is quarter to. Any particular
2 topic?

3 MR. CATTON: I guess containment performance is
4 next. You might as well work your way on through.

5 MR. SCHNEIDER: Okay.

6 MR. KRESS: Well, you might want to go back to the
7 DCH. We skipped it. Let's go back to the DCH.

8 MR. LINDBLAD: That is not very long.

9 MR. SCHNEIDER: No, it is not long.

10 [Pause.]

11 MR. SCHNEIDER: Prevention of direct containment
12 heating. Again, the purpose is to comply with the utility
13 requirement document guidance, to minimize the potential for
14 events leading to high pressure melt ejection, and minimize
15 the potential for direct containment heating. Along with
16 that, it is complying with specific guidance of 93-087 to
17 provide a reliable depressurization system and to provide a
18 cavity design feature to decrease the amount of ejected core
19 debris that reaches the upper containment.

20 [Slide.]

21 MR. SCHNEIDER: The relative design features that
22 tie into this is a rapid depressurization system, which is a
23 manually operated system that will the operator for the
24 Control Room to depressurize the RCS in advance of vessel
25 breach. Our reactor cavity design, which you have seen a

1 few times already, with a large convoluted reactor cavity
2 vent and a debris accumulation chamber, and even when you
3 get out of that, the HVAC provides a nice accumulation
4 position for debris also.

5 Cav' v flood system, which is clearly, if it is
6 operationable, you would expect that to do a really good job
7 of quenching a lot of the debris when that is operationable
8 and the large containment volume again has a capability of
9 withstanding large pressure, will give you more mass and
10 more capability to withstand pressure increases or energy
11 inputs.

12 MR. CARROLL: Why do you feel comfortable with a
13 manual initiation of the depressurization system?
14 Historically, on boiling water reactors at least, that has
15 always been an automatically initiated system.

16 MR. DAVIS: Which the operator can over ride, of
17 course.

18 MR. RITTERBUSCH: One of the primary
19 considerations was the unreliability of inadvertent
20 openings during normal operation.

21 [Slide.]

22 MR. CARROLL: I guess one other feature we did not
23 talk about when we talked about high region that again is an
24 operator action is the notion that the containment can be
25 vented through the hydrogen purge valves unfiltered.

1 MR. SCHNEIDER: We do not view that as a hydrogen
2 issue. It is more that we used a hydrogen recombiner lines
3 for venting. It is more of an overpressure capability.

4 MR. CARROLL: That be as it may, how do you feel
5 about -- who is going to make that decision?

6 MR. SCHNEIDER: Well, we, basically, do not feel
7 that anyone should make that decision. We do not think --
8 it is not part of our strategy. It is there should the
9 utility decide on using it at their own discretion. It is
10 not something that we embed within our accident management
11 guidance and it is not something that we would necessarily
12 recommend. But it is a capability that is there. We were
13 asked to show that it is there and we did.

14 MR. CARROLL: It makes me nervous.

15 MR. CATTON: It is unfiltered. That does kind of
16 make me nervous.

17 MR. SEALE: It gives the governor the option,
18 doesn't it?

19 MR. CARROLL: He isn't going to open it.

20 MR. LINDBLAD: Are you going to show us the large
21 convoluted reactor cavity vent on this picture?

22 MR. SCHNEIDER: Yes, I think so.

23 MR. DAVIS: Before you do that, I have another
24 question on the safety system, and maybe this is a question
25 for tomorrow. But I notice on page 19.4-24 you say that the

1 safety depressurization system could be used for the small
2 LOCAs with failure at the safety injection system, but it
3 was not considered in the PRA.

4 MR. SCHNEIDER: Dave is standing up already. He
5 wants to answer that.

6 MR. CARROLL: They did not say it. The Staff said
7 that. Oh, it is in the PRA also in Volume 17.

8 MR. DAVIS: That would be the preferred method to
9 do it rather than using aggressive cool down method that
10 they do consider in the PRA, but I may be missing something.

11 MR. FINNICUM: This is Dan Finnicum with ABB. In
12 the Level 1 portions, the safety depressurization valves are
13 used for the feed and bleed cooling portion and the small
14 break LOCA analysis. With opening up the safety
15 depressurization valve, there was a concern that by
16 introducing essentially a medium break LOCA there that the
17 loss of inventory back to the IRWST might not cover the core
18 before we were able to bring the pressure down fast enough
19 to get the RHR pumps on.

20 MR. DAVIS: So the procedures call for aggressive
21 secondary cooling rather than use of the safety
22 depressurization system?

23 MR. FINNICUM: Yes. That is in the function of
24 recovery area. That does not include the rapid
25 depressurization for that scenario.

1 MR. DAVIS: Thank you.

2 MR. SCHNEIDER: The way the cavity is designed is
3 that corium leaving the vessel has a few options. It can
4 up, fail the pool seal, and out, or the other path is going
5 through the tunnel where the inertia we expect to carry a
6 lot of the debris into this general area where it would be
7 hopefully be trapped. It can turn up. Then it has to turn
8 on to go up a staircase, and then once it goes up the
9 staircase, you go against the solid closed roof with
10 louvered vents.

11 So, it ultimately blows out the vents and then
12 turns in either direction and then you, basically, on an
13 area where you're isolated from the above floors. So,
14 whatever you have done, if you don't trap it here you're
15 going to, basically, lose most of the energy and you're
16 going to trap it right around this area even if you trap it
17 in this region of the containment. So, you're not going to
18 have very much DCH contribution.

19 While we do say that the entrainment -- we expect
20 very low entrainment from this geometry. We have actually
21 analyzed it with considerably higher levels of entrainment
22 than we expect. So --

23 MR. LINDBLAD: What is convoluted about it?

24 MR. SCHNEIDER: It is a multiple path where we
25 have a lot of changes in directions, a lot of recirculation

1 potential flows. There is another breaker flow out here
2 which could have the recirculation in the instrument area,
3 which has a very high pressure seal table which will not
4 fail.

5 It just gives you a lot of pathways where the
6 debris has to turn, and you're trying to pull very dense
7 material which has its own inertia going in all different
8 directions through all of these turns and we feel it is not
9 going to be able to follow very effectively and get any
10 place near the upper containment or get much even outside
11 this HVAC room.

12 MR. LINDBLAD: You describe it as being large as
13 well. You mean it is lengthy or that it has a big cross
14 section?

15 MR. SCHNEIDER: Big volume. The volume is
16 generally large. The pressures will not be -- will not
17 necessarily build up very large pressures inside because it
18 has a high volumetric. I guess I don't remember the exact
19 volume but it is relative to existing cavities. It is a lot
20 bigger. I think it is over 10,000 cubic feet.

21 [Slide.]

22 MR. SCHNEIDER: We have also decided that --
23 again, to demonstrate its capability deterministically, we
24 played some conservative games. We looked at single and two
25 celled models, direct containment heating models, which

1 generally take the corium and either mix in one region or
2 two regions, depending on the assumptions. We assume the
3 splits are -- we assumed that the -- we didn't credit the
4 rapid depressurization systems so we had the corium at high.
5 We had the vessel, which we breached at high pressure. We
6 only marginally credited debris retention.

7 So we assumed that any of the debris -- 50 percent
8 of the debris disbursed went directly into the upper
9 containment and 60 percent of the instantaneous corium mass
10 was injected, which is a high fraction of the corium, on the
11 upper end of the NUREG-1150, the injection -- core amount
12 injections following vessel breach curves.

13 When we did it we did it two different ways and
14 both of them concluded that the shell stresses -- the
15 pressures would be well below Service Level "C" allowables,
16 even given this set of conservative assumptions. We also
17 did something similar probabilistically where we looked at a
18 whole spectrum of potential cases where we varied most of
19 these parameters and several more parameters across the
20 board and came to the conclusion of a very low conditional
21 probability of containment failure given high pressure.
22 High pressure is not going to be a high probability state
23 following prior vessel breach. So, we are reasonably
24 confident this is going to be a noncontributor to
25 containment damage.

1 MR. CATTON: You did these estimations with a
2 cavity filled with water?

3 MR. SCHNEIDER: No. We're assuming the cavity, if
4 it was filled with water, the cavity would quench it because
5 there is so much water down there. We did it assuming it
6 the cavity was dry. If there was water in the cavity --

7 MR. CATTON: I'm trying to remember what the
8 results with Sandia study were and I don't, whether water
9 was good or bad.

10 MR. SCHNEIDER: I spoke to Pilchy yesterday I
11 guess for a different reason. He is a believer that a lot
12 of water is good. A little bit of water could be a problem,
13 but he is not even sure of that. So his feeling would be
14 that -- and I don't want to quote him, but I think the
15 Sandia people will tell you a lot of water in the cavity is
16 going to be good. We're talking about 60,000 gallons.

17 What that does is it gives us the steam explosion
18 problem. You have to balance. So, you just basically
19 transfer one issue to another.

20 MR. CATTON: When you did your steam explosion
21 calculation, did you put 2,500 psi behind the jet?

22 MR. SCHNEIDER: We did ours based on total best.

23 MR. CATTON: That's right. The Staff, you put
24 2,500 psi behind the jet.

25 MR. SNODDERLY: No, we didn't.

1 MR. CATTON: That would be an interesting
2 calculation, wouldn't it?

3 MR. SNODDERLY: I don't know if the Texas Code
4 could handle that. We could investigate that to see if it
5 could.

6 MR. CATTON: It would be interesting to see what
7 you get.

8 MR. SCHNEIDER: What we did --

9 MR. CATTON: I understand that.

10 MR. SCHNEIDER: Okay.

11 MR. CATTON: As long as we're using words like
12 bounding and things like that, we ought to have, indeed, the
13 bounding calculation.

14 MR. DAVIS: This could go on forever, Ivan.

15 MR. CATTON: Then don't use the words bounding.

16 MR. DAVIS: These are low probability.

17 MR. CATTON: Don't use the word bounding.

18 MR. SCHNEIDER: A low probability -- we selected a
19 low probability conditions. I apologize.

20 MR. CARROLL: Or it is low probability until it
21 happens.

22 MR. DAVIS: Then it still can be low.

23 [Slide.]

24 MR. SCHNEIDER: Do you want any further discussion
25 on direct containment heating or shall I move on?

1 MR. CATTON: Not I.

2 MR. CARROLL: Okay. Now, what do you want to talk
3 about, Ivan?

4 MR. CATTON: The next thing on the list is
5 containment performance.

6 MR. CARROLL: All right.

7 [Slide.]

8 MR. CATTON: Now, we're back on track now.

9 [Discussion off the record.]

10 MR. SCHNEIDER: The number and system may break
11 down after the next disk. The containment integrity was
12 addressed from reliability and overpressure failure. The
13 goals here were to demonstrate high containment reliability,
14 which Dave will talk a little bit more about and I have some
15 small information from that here, and with sprays
16 unavailable to demonstrate that containment will maintain
17 its role as a reliable leak point barrier for approximately
18 24 hours under the more likely severe accident challenges.
19 I believe that is pretty much the wording in SECY 93-087.

20 [Slide.]

21 MR. SCHNEIDER: Again, the applicable features are
22 highly reliable. Redundant containment spray system, fast
23 running backup pumps via shutdown cooling system so that we
24 can, if need be, realign if we lose a containment spray
25 pump, realign the pump through the shutdown cooling system.

1 We have redundant power supplies, off site power,
2 emergencies diesels, and combustion turbine. We have a
3 large containment volume which is very useful to mitigating
4 the pressurized -- the rate of pressurized.

5 There is alternative pressure control cooling
6 capabilities.

7 [Slide.]

8 MR. SCHNEIDER: We have non-class E-1 fan coolers,
9 which are available. We have external spray capability,
10 which will extend the time for pressure control to get other
11 systems online and we have vent capability via purge line.
12 But these are all low probability systems.

13 MR. CARROLL: The fan coolers are environmentally
14 qualified?

15 MR. SCHNEIDER: No. It is more just to show that
16 they are there. They are not environmentally qualified
17 specifically. But there is a lot of transients where it if
18 you lose power, you still may not have very severe
19 environments and they still may be able to perform a
20 function. What they are is oversized typically. So, while
21 they are basically HVAC for ventilation fan coolers, they
22 have been kind of designed so they can, after a certain
23 amount of time, function as a diesel containment heat
24 removal system.

25 MR. CARROLL: Where our famous perch line

1 unfiltered vents?

2 MR. SCHNEIDER: It is there if you need it to hold
3 the pressure in something. If you are anticipating
4 containment failure and you should decide for some reason
5 that you want to vent because you cannot get any of your
6 other systems back online to control pressure, it is there
7 and it will, basically, level the pressure off at 80 to 100
8 pounds.

9 MR. CARROLL: What are they big enough for?

10 MR. SCHNEIDER: It will level pressures off at
11 about 80 to 100 pounds after about 24 hours. It is not
12 going to, basically --

13 MR. CARROLL: Because it is fairly small.

14 MR. SCHNEIDER: These are small.

15 MR. CATTON: Do these go up through the plant
16 vent? Are they monitored?

17 MR. SCHNEIDER: I don't recall.

18 MR. CROM: This vent that we are talking about is
19 really an alternative for hydrogen purge. It purges into
20 the annulus. The only way that it would be filtered and
21 typically designed even on current plants is if your
22 hydrogen recombiners fail. You would purge in the annulus
23 and then your annulus ventilation would then do the clean up
24 and the mixing in the secondary containment, and that would
25 be going out the plant if the system is operational.

1 MR. LINDBLAD: I would think your radiation
2 instrumentation would be saturated from direct shine as
3 well. It would be pretty hard to keep that operable.

4 MR. SCHNEIDER: There has been no credit taken of
5 this capability at all in any of the analyses. It is just
6 kind of showing it for completeness.

7 MR. CARROLL: I think if it was my plant I'd find
8 some three inch pipe caps and weld them on.

9 [Laughter.]

10 [Slide.]

11 MR. SCHNEIDER: There was a point that this was a
12 strong NRC interest that we have the ability.

13 MR. CARROLL: There is a requirement that you have
14 to have a means of penetrating the containment on ABWR,
15 isn't that right?

16 MR. RITTERBUSCH: We are taking an exception from
17 that regulation.

18 MR. CARROLL: You're using this as an argument
19 that says you --

20 MR. RITTERBUSCH: No.

21 MR. CARROLL: You're just taking an exception?

22 MR. RITTERBUSCH: It is creased within the
23 diameter.

24 MR. CARROLL: The Staff has agreed to the
25 exception?

1 MR. BARRETT: We have not specifically focused on
2 that exception, but I think that it would be agreeable. Our
3 basic finding regarding pressurization is that we believe
4 that it will be quite a long time before you challenge the
5 pressure capability of this containment, even in a case --
6 the one that Ray analyzed -- namely, the one with no sprays.
7 I think the worst case we analyzed was the 56 hours to reach
8 Service Level "C."

9 We don't exclusively deal with what happens after
10 that in our FSER, but I think that the way we feel about it
11 is that by that time there will be plenty of help available
12 and the capability of regaining some form of heat removal,
13 such as internal sprays, which in addition to heat removal
14 will also give you fission product removal.

15 So, from our perspective, this vent does not come
16 close to playing the important role that the containment
17 overpressure protection system plays for the PWR. Even in
18 the BWR, we allow the -- in the ARWR we allow General
19 Electric to take exception to the rule because the ABWR
20 containment overpressure protection system is not a three
21 foot vent.

22 MR. DAVIS: As I recall, it is ten inch.

23 MR. BARRETT: That's correct. So, I don't see any
24 reason why we would have any objection whatsoever to seeing
25 you taking an exception to this rule. This vent, from our

1 perspective, would be perhaps for some period of time long
2 after you've regained control of the container to take
3 measures to perhaps vent some hydrogen, perhaps vent some
4 small amounts of atmosphere.

5 MR. CARROLL: But the three foot hatch in the
6 containment does not necessarily imply three foot vent. It
7 is a number picked out of the air years ago, isn't it?

8 MR. BARRETT: That is correct, and it was simply
9 to allow the option. We are allowing ABWR to take exception
10 to that based on the calcs. I don't see any problem with
11 ABB taking the exception because, basically, their control
12 mechanism is the very large volume of the containment.

13 [Slide.]

14 MR. SCHNEIDER: So, we've performed some
15 deterministic analysis to show the minimum time of
16 containment failures is more than 24 hours. Here we used
17 MAAP.3. We feel this is applicable for this application,
18 which basically is a large energy balance. We went to our
19 spectrum of severe accident transients within it. We did
20 not credit spray operation and we based containment failure
21 on ASME Service Level "C" stresses.

22 MR. KRESS: Could I ask the Staff if they intend
23 to audit those calculations with MELCOR or contain or
24 something like?

25 MR. SNODDERLY: Yes. We have contracted

1 Brookhaven to perform analyses using MELCOR. To date, they
2 have done six run for six sequences. They have analyzed
3 small break and mean break LOCAs; steam generator tube
4 ruptures with one and two and five tubes, station blackout,
5 wet and dry cavity; and the LOCA sequences, wet and dry
6 cavity.

7 Those timings appear to be -- it would be fair to
8 portray them in reasonable agreement. We are not seeing
9 anything unusual in the times. That was our QA check.

10 MR. KRESS: Thank you.

11 MR. SCHNEIDER: Our results showed containment
12 failure times greater than approximately than 24 hours for
13 some limiting cases. I think I was eliminating large LOCAs
14 with actuation of the cavity flood system. So you always
15 had enough steam getting into the containment to pressure
16 you.

17 MR. DAVIS: Excuse me. There is a statement in
18 Volume 23, page 19.9-4. You've got a case where the
19 containment failed by overpressurization after 41 hours. Is
20 this the same calculation that you're talking about here?

21 MR. SCHNEIDER: I don't know. 19.9?

22 MR. DAVIS: Yes. Dash 4.

23 MR. FINNICUM: That was --

24 MR. DAVIS: it is close enough.

25 MR. FINNICUM: That was an early calculation done

1 with a Level 1 PRA where we were looking primarily at
2 containment failure before a core melt where we had safety
3 injection. Essentially, the RCS was intact, but we had no
4 containment heat removal. It was a MAAP calculation. It
5 was in the range of about 40 to 41 hours.

6 MR. DAVIS: Thank you.

7 MR. SCHNEIDER: This is the one were you fail
8 containment before you melted the core so that the core melt
9 would occur after. That way, subsequently, was a very low
10 probability, much lower probability.

11 [Slide.]

12 MR. SCHNEIDER: I will make a few PRA comments
13 because the SECY 93-087 has a containment integrity goal and
14 unless you want to wait until for the PRA presentation
15 tomorrow --

16 MR. TYREL: Is this better with it? Dave thinks
17 so. Okay.

18 MR. FINNICUM: I will present the same
19 information.

20 MR. SCHNEIDER: So you want to drop this one? No,
21 okay.

22 [Slide.]

23 MR. SCHNEIDER: The overall conclusion is that the
24 containment meets the deterministic goals for overpressure
25 failures of the 24 hours and Dave will demonstrate tomorrow

1 that it is robust with respect to a severe accident, it has
2 a high probability of maintaining containment integrity
3 following severe core damage event, and the resultant CCFPs,
4 conditional containment failure probability, are consistent
5 with the stated goals of SECY 93-087. That completes the
6 PRA presentation.

7 I guess the last section would be equipment
8 instrumentation and survivability.

9 MR. CARROLL: Do you want a break about now?

10 MR. DAVIS: How long will this take?

11 MR. SCHNEIDER: Without any questions, it
12 shouldn't take too long.

13 [Laughter.]

14 MR. SCHNEIDER: I will leave it up to you fellows.
15 You can go want to go on through or not.

16 MR. CARROLL: I was thinking of adjourning for the
17 day and picking up tomorrow.

18 [Discussion off the record.]

19 MR. CARROLL: Would it help anybody to finish up
20 today in terms of who has to be in here in the morning? You
21 and Mike would like us to finish up?

22 MR. BARRETT: If possible, yes.

23 MR. CARROLL: Then let's do it. All right, let's
24 do it.

25 MR. SCHNEIDER: Equipment survivability. The

1 goals that comply with SECY 93-087 and the additional
2 requirements of 10 CFR 50.34 requirements. They require
3 that we define the instrumentation equipment for achieving
4 and maintaining a safe shutdown and maintaining containment
5 integrity, to define the minimum SECY that applies to that,
6 demonstrate the high confidence that the instrumentation
7 will survive severe accident conditions for a period needed
8 to perform its functions, and as a subset consider the
9 effect of 100 percent oxidization of fuel cladding on
10 equipment survivability.

11 In order to establish environments, we reviewed
12 events progressions for in vessel recoverable and
13 unrecoverable event sequences.

14 [Slide.]

15 MR. SCHNEIDER: To a large extent we used -- we
16 would use snap and judgment in order to estimate the
17 behaviors, define minimum equipment set for achieving and
18 maintaining a safe shutdowns on the conditions when your
19 lower head is going to remain intact so you can have a
20 recoverable sequence, define minimum equipment set for
21 maintaining integrity should your vessel lower head fail in
22 addition, and use analytical experimental methods to
23 establish local severe accident environment, and then we
24 compared the severe accident environments with the EQ
25 envelope in establish supplementary guidelines to guarantee

1 equipment survivability.

2 [Slide.]

3 MR. SCHNEIDER: The next couple of pages are lists
4 of equipment. For the instrumentation required for severe
5 accident mitigation and prevention we divided it into
6 categories of instrumentation that is useful prior and
7 instrumentation that is more important post-vessel breach or
8 are more important in both sequences.

9 The UHJTC stands for the unheeded junction thermal
10 couple, which is located in the upper head of our design,
11 which is part of our reactor vessel level monitoring system.
12 What this essentially does is it is able to give you a load
13 of reliable and high confidence survivable temperature
14 measurement capability for the reactor vessel following
15 recovery.

16 RCS or pressurizer pressure were intended to give
17 you some indication of the plan pressure for recoverable
18 sequences. SI flow injection clearly make sure you're
19 getting water, emergency feedwater flow to make sure that it
20 can remove heat through the steam generators. Same thing
21 with the steam generator water level, IRWST water level, to
22 make sure that you're not dumping the stuff outside of
23 containment basically, and again, hydrogen monitor to
24 control what is happening with the hydrogen radiation
25 monitoring, mostly of later interests to determine if you

1 want to take any actions with regard to high radiation
2 levels and containment pressure, again, which is a useful
3 parameter to determine the closeness of potential
4 overpressure failures.

5 We have on the list containment temperature, which
6 is helpful, but we kind of view it as nonessential and it
7 was not given the some of the same stringent requirements as
8 the rest of this equipment, and containment spray flow,
9 which you need to make sure that your spray is functioning.

10 MR. KRESS: Could I ask if you had some sort of
11 criteria that you used to make the judgement as to which
12 instruments and devices were required for this?

13 MR. SCHNEIDER: In '79, I was involved with ICC
14 NUREG-737 responses for adequate core cooling
15 instrumentation. So, clearly, based on that review, we kind
16 of felt like the operator is going to need in order to
17 control -- in order to control the plant -- we wanted to
18 make sure is, basically, he has the ability to get feedwater
19 or some inventory source in both pressure and SI flow,
20 provide those guidance because if your pressure is too high
21 you can't get your SI flow in.

22 So, these, basically, give you some guidance of
23 inventory into the vessel. This provides you the energy
24 balance for heat removal. So, you need these two to make
25 sure that you're getting energy out.

1 The HJPC gives you an idea of the level of super
2 heat you might have in the vessel. This, basically, just
3 supplies the level of the inventory. So, what we're
4 basically looking for is tracking where the water is, where
5 it is going to go, and what it is doing.

6 MR. DAVIS: What instrument does he use to decide
7 if he floods the cavity or not?

8 MR. SCHNEIDER: This is actually post that. The
9 ICCI instrumentation is a much more extensive list. This is
10 a subset of that. That list you would use the core rates of
11 thermal couple or a combination of the full RVLMS, reactor
12 vessel monitoring system.

13 This is a minor subset of only a system where you
14 have substantial core uncovering. You know you are in the
15 core damage sequence, and this is what you need if you can
16 potentially recover it. You may have gotten to the point
17 where you have melted your core exit thermal couples at this
18 point. You may have gotten to the point where some of the
19 RVLMS thermal couples may be gone. This is the minimum set
20 --

21 MR. CARROLL: By then you have already flooded the
22 cavity.

23 MR. SCHNEIDER: Yes, we flooded the cavity.
24 Right. So, this is a subset of that much larger set of
25 instruments. I got carried away there.

1 MR. KRESS: I'm not sure I'm still clear on this.
2 If I look at this list and ask the question, if those things
3 are not -- that do not survive the severe accident
4 conditions, am I in trouble?

5 MR. SCHNEIDER: No. Regulation requires that we
6 provide -- 10 CFR 50.34(F) requires that we define this set
7 of instrumentation. We let the operators know what -- the
8 applicant know what instruments are going to be useful. We
9 take special precautions to see that they survive.

10 What the operator is going to do is he is going to
11 take any available water source and try to get it in. So he
12 is going to try to start his HPCIs. Regardless of what the
13 pressure says, he is going to try to pump it in.

14 If he cannot get it in, he can tell that pretty
15 easily by the way the HPCIs are going to run. If the HPCIs
16 are not running or if his SI is not running, it is not going
17 to do him much good. Same thing with the emergency
18 feedwater. It is not so much measured in the flaw. You
19 want to know that your emergency feedwater system is
20 functioning. Those things help get confidence, but you do
21 all the same actions.

22 The operator would naturally get emergency
23 feedwater to the steam generators. He would naturally try
24 to get as much inventory as he can into the RCS. So by and
25 large, he is going to do all of these things functionally

1 regardless of what the instrumentation says. But it is good
2 to know if the instrumentation is there, it may minimize any
3 confusion that he has in doing his action. It may help
4 guide it. It may reduce the stress, do all these other
5 things.

6 But, in essence, if he loses this, does he lose
7 the farm? Lose the equipment -- if he loses the equipment
8 he loses the farm. If he loses the instrumentation, he can
9 still survive.

10 MR. KRESS: So if I search through the PRA event
11 tree and look for places where these devices would impact on
12 the sequence reaction, I would not be able to find them?

13 MR. SCHNEIDER: For one good reason. We do not
14 credit this in vessel recovery in the PRA.

15 MR. KRESS: That takes care of the top five.

16 MR. SCHNEIDER: All of these then are -- the only
17 reason that you need the hydrogen monitor is, basically, to
18 know what hydrogen concentration you have. You have your
19 igniter systems on. If the igniters weren't working, it is
20 going to do its job. You need containment pressure only to
21 do venting. We don't credit venting --

22 MR. KRESS: But you turn on the hydrogen monitors
23 manually. Is it based on that reading?

24 MR. SCHNEIDER: Right now it is going to be based on
25 the core exit thermal couple exceeding 700 degrees well

1 before.

2 MR. KRESS: So they're already on.

3 MR. SCHNEIDER: Yes.

4 MR. BARRETT: If I could just add a word, in
5 addition to the criteria that ABB articulated for choosing
6 these instruments, we requested that they include additional
7 instruments for the simple reason that we felt that in an
8 advanced reactor, if there were an accident at that vessel
9 we did not feel that we should be blind, that there should
10 be some minimum set of information that would be available
11 to those people trying to manage the accident both on site
12 and also for the purpose of taking protective measures. So
13 if there is not a clear nexus to some of these instruments
14 to specific operator actions or accident management
15 accidents. They are there simply because we thought it was
16 prudent.

17 MR. LINDBLAD: But some of these locations, some
18 of these parameters will have local values rather than
19 distributed single values. You're only asking for a single
20 measurement of the containment temperature. Is that right?

21 MR. SCHNEIDER: We only have two in the whole
22 containment normally Right?

23 MR. LINDBLAD: But you would expect that there
24 would be many different temperatures inside the containment
25 after a severe accident.

1 MR. SCHNEIDER: If you had control of the
2 containment and your sprays are operating and everything is
3 going fine, you really would. If things are going very
4 right, the pressure is up, your temperatures are really
5 reading high, there may be a distribution. But that will
6 give the operator the idea that the sprays are not on and
7 the containment is not functioning as it should. The goal
8 is to control or turn the event. Everything tells the
9 timing for evacuation.

10 MR. LINDBLAD: Then you can sense the temperature
11 by feeling the outside of the shell, putting a thermal
12 couple on the outside of the shell rather than on the
13 inside, and that would be a good averaging of containment
14 temperature.

15 [Slide.]

16 MR. SCHNEIDER: Again, the equipment that he needs
17 has much the same logical. The equipment you want is that
18 which will provide inventory, remove heat, and in essence,
19 we also have -- okay, for recovery the event. In order to
20 respond to the event the rapid depressurization system which
21 is actuated early and will function prior to vessel breach
22 the cavity flooding system, which is intended to be actuated
23 early, the hydrogen mitigation system --

24 MR. CARROLL: Is there a significance to the
25 arrows with the bent top?

1 MR. SCHNEIDER: Those are runs. Those are notes
2 for actuated and performs function early. Sorry about that.
3 Hydrogen mitigation system -- containment penetration
4 integrity is an individual item that we called out as trying
5 to attempt to make sure that that is going to survive as
6 long as reasonable. Containment spray system is a critical
7 system and the shutdown cooling system primarily is a back
8 up to the containment spray system, not so much as the
9 shutdown cooling system function itself.

10 MR. CATTON: How do you decide what the
11 environmental conditions are that the penetration has to
12 deal with?

13 MR. SCHNEIDER: What we have basically done is use
14 MAAP analyses to get a rough idea of the global temperatures
15 we're going to expect in the containment.

16 MR. CATTON: That is more than global
17 temperatures, isn't it? You have to do the same thing? Did
18 you use something like MAAP.4?

19 MR. SCHNEIDER: We used that to get a feel for the
20 general temperature gradients because remember this is on
21 the outside of the region. The penetrations are going to
22 be in the annular regions where we really don't expect to
23 have a very large -- the higher temperatures. The higher
24 temperatures we expect mostly inside, if we're going to have
25 them, inside the crane wall.

1 MR. CATTON: I thought your circulation patterns
2 showed the hot gases rising right up to the top coming down
3 around the other side? You can't have it both ways.

4 MR. SCHNEIDER: We don't get large gradients. The
5 only high temperatures we have noticed are those inside the
6 tunnels themselves, and outside the gradients are not that
7 substantial.

8 MR. CATTON: What about the top of the dome?

9 MR. SCHNEIDER: It does not show as being a lot
10 different.

11 MR. CATTON: That is because you're using MAAP.4.
12 You've got to be using a finite difference code if you want
13 to put the penetrations up there that will do you some good
14 or if you put penetrations that survive. You're going to
15 have to know what the temperature distribution is.

16 MR. SCHNEIDER: What we're trying to count on is
17 one, the robustness of the penetrations themselves and the
18 fact that most of these penetrations are inside and outside
19 containment.

20 MR. CATTON: Don't you have to demonstrate the
21 robustness of the penetrations?

22 MR. SCHNEIDER: Sandia has done a real good job of
23 testing a whole series of penetrations. For example, EPA,
24 electrical penetrations assemblies, can withstand something
25 in the order of 700 degrees on the inside for 10 hours.

1 That is well above anything we could ever expect mainly
2 because what holds it is all of the interior seals fails but
3 the exterior fails hold.

4 Our air locks will have seals on both sides. The
5 O rings seals around main equipment hatches, a double O ring
6 design, has been tested to handle about 600 and some odd
7 degrees before failure. We are dealing with temperatures
8 that we feel are in the 300 to 350 range before we get to
9 containment failure. So for the majority of the sequences
10 we are dealing with, we are well below most of these levels.
11 The EPA thing I misstated. It is like about eight days at
12 700 degrees.

13 So there is a general robustness of the equipment.
14 We don't have all of the details of exactly what environment
15 it is going to be in, but remember there is thermal lag
16 associated with these large penetrations themselves.
17 Thermal lag -- the penetrations have large steel pieces of
18 steel, the physical process.

19 MR. CATTON: That triggers another nerve.

20 MR. SCHNEIDER: Just the physical process, the
21 time delay associated with heating up massive amounts of
22 steel penetrations. So, we are reasonably comfortable that
23 based on the existing design the penetrations will last --
24 you're probably going to fail the overpressure -- will fail
25 the containment before you fail the penetrations.

1 So we are not uncomfortable --

2 MR. CATTON: Is there anything you're worried
3 about just above the steam generators?

4 MR. SCHNEIDER: No. The penetrations -- there is
5 no penetrations in the upper region.

6 MR. CATTON: At all?

7 MR. SCHNEIDER: No. The only thing you would have
8 -- the highest you could get is the main steam line, which
9 has like metal bellow penetrations, and those are not going
10 to be very susceptible to temperature transients.

11 MR. CATTON: If you have nothing up there, then
12 stratification will not be a problem.

13 MR. DAVIS: It will be good for it. It puts the
14 temperature where you don't have a problem.

15 MR. SEALE: You will have all of the high energy
16 up there.

17 MR. DAVIS: The mixing assumption is conservative.

18 MR. CATTON: That's true, but you've got to be
19 careful, especially if you're buying or selling, Pete.

20 [Slide.]

21 MR. SCHNEIDER: What we did do is that we felt
22 that we could not just look at global effects. We tried to
23 get a rational logic for looking at the potential for local
24 effects which are driven, we felt, more by combustion
25 processes. We felt local effects might occur near igniters

1 and near hydrogen sources. Global effects would be driven
2 by convected processes. We assume that is going to govern
3 the bulk of the containment. So, we do take some credit for
4 local effects. But we do not do detailed local
5 calculations.

6 [Slide.]

7 MR. SCHNEIDER: What we did do though is we tried
8 to do whatever we could to reduce the effect of local
9 environments on the instrumentation. So the goal was to,
10 basically, move the instrumentation -- well as is naturally
11 the case, most of the instrumentation is located away from
12 where we would expect the hottest environments. As a matter
13 of fact, most of the sensors and cabling really starts from
14 the point outside the crane wall.

15 So, we wanted to rely primarily on instrument
16 equipment and instruments with transmitters located as far
17 away as possible from the hydrogen sources based on the HCOG
18 data, which was the Hydrogen Control Owners Group.

19 GE did a compartmentalized test with igniters.
20 Based on their data, they indicated that about one and a
21 quarter scale feet away from their igniters the environment
22 could be considered global. But within that region you can
23 get locally higher temperatures.

24 So we put a placement restriction that the scale
25 value would be five feet. So, we put the placement

1 restriction that within ten feet of all igniters we have to
2 remove equipment and cables to be at least ten feet from
3 igniters.

4 The other thing is that we did not want for a
5 potential diffusion flame. We did not want the equipment to
6 directly see a continuously burning flame. So we gave an
7 instruction that for those pieces of the equipment that will
8 be in the direct line of sight of igniters that we feel
9 thermally shield, radiatively shield the equipment and the
10 cables.

11 For post VB sequences most of the equipment --
12 after you reach the vessel, post vessel breach sequences,
13 the bulk of the equipment relied on for mitigation is
14 primarily located outside the containment, which has no
15 local effects at all.

16 [Slide.]

17 MR. SCHNEIDER: Global environments were to be
18 expected away from igniters. For any containment
19 instrumentation, global environments were primarily were
20 established with MAAP.3(b). We did uniform modeling,
21 basically, with the generalized model. You see, we did that
22 with the hydrogen.

23 MR. CATTON: You cannot use a code like MAAP.3 for
24 this. It is a displacement process. The hot materials are
25 going to rise up and displace downward. That is not the way

1 those codes work.

2 For example, I could have absolutely uniform
3 pressure across the top, about midway between the deck and
4 the crane wall, absolutely uniform pressure, and I will have
5 movement of the air and the hot stuff will rise up to the
6 top, slowly displace down. MAAP does not do that.

7 MR. SCHNEIDER: It does not do the right phenomena
8 but there are no hot sources to drive any annulus where the
9 equipment is located.

10 MR. CATTON: What is the MAAP Code doing? It is
11 giving you delta P to make it work.

12 MR. SCHNEIDER: It has a delta P.

13 MR. CATTON: And the delta P is phony.

14 MR. SCHNEIDER: Yes, to some extent. What it does
15 tell you is what is what is driving this is the absolute
16 steam in the containment will drive the saturation pressure
17 generally of the containment as long as you don't have the
18 super heater --

19 MR. CATTON: You don't a code for that.

20 MR. SCHNEIDER: I'm not saying you need a code.
21 We used MAAP for estimating the global effect and the
22 primary effect of the energy balance. Hence, as we approach
23 containment failure, containment failure is going to be a
24 saturated steam environment at about 350 degrees F. At
25 about 350 pounds or something of that order. So we don't

1 feel the code was critical but we used that for timing and
2 when we had a reference they want to see a calculation of
3 it, and so it does a good job.

4 MR. CATTON: If they want to see a calculation
5 then you will give them one.

6 MR. SCHNEIDER: It is their right. We didn't do
7 anything wrong. It makes sense.

8 MR. CATTON: If you stick in there to determine
9 environmental conditions that are bothersome when it is
10 followed by MAAP.

11 MR. SCHNEIDER: Okay.

12 MR. CATTON: If you want environmental conditions
13 you have to do it another way. If you want to know what
14 they are throughout the containment. The only thing that
15 MAAP will do probably correctly is the pressure because you
16 just dump everything in.

17 MR. SCHNEIDER: That's all what I really needed.
18 It has the pressure right. It has about the right mass of
19 water and saturation, which is the reasonable assumption, is
20 going to have about the right temperature. You're not going
21 to expect -- it is not going to do it into detail. Maybe I
22 will be 20 or 30 degrees off. The regions where this
23 equipment it is probably going to be off in a good
24 direction. The equipment is located away from the energy
25 sources and down low.

1 MR. CATTON: I would buy that.

2 MR. CARROLL: You picked on him, Ivan, for doing a
3 calculation because the Staff wanted one. Not that part GE
4 and the pool swell issue --

5 [Laughter.]

6 MR. CATTON: It is not over yet.

7 MR. SCHNEIDER: So, basically, we view these as
8 global energy balances basically. What we found is within
9 the first 24 hours the containment provided some degree of
10 flooding without even sprays. One maintained a pressure
11 below about 90 psia and maintained temperatures about 330
12 degrees F. At containment failure the temperature is
13 expected to be below 350 and below 140 psia. The design
14 basis --

15 MR. CATTON: How sensitive is containment failure
16 to the temperature of 350?

17 MR. SCHNEIDER: Not at all. That is, basically,
18 the saturation condition. It is not a steel shell
19 temperature. It is more that when I get this pressure I'm
20 going to get about that temperature. The equipment is
21 mainly a temperature --

22 MR. CATTON: If I had, for example, 250 degrees on
23 the bottom and 550 up on the top, would the failure pressure
24 be different?

25 MR. SCHNEIDER: Of containment?

1 MR. CATTON: I don't know how to get a measure of
2 that. We know that the temperature in the containment is
3 not going to be uniformed. It is going to be hotter up in
4 the top than it is in the bottom. If you're calculating an
5 average value of 350, what is the maximum?

6 MR. SCHNEIDER: It is about 340 on the bottom,
7 maybe 360 or someplace on the top. You cannot get very
8 large differences.

9 MR. CATTON: Why?

10 MR. SCHNEIDER: Because you have the large delta P
11 differences. That is driven -- but the same thing because
12 what drives the delta P is the mass of water and the
13 pressure of steam. So if you had those differences, delta
14 P, you would have those driving poles to move them around.

15 MR. CATTON: Somehow I don't understand.

16 MR. LINDBLAD: Not if the top is hot and the
17 bottom is cold.

18 MR. CATTON: It is going to return to motion.

19 MR. SCHNEIDER: Remember, the steel shell is
20 layers everything. It is the coolest portion. How are you
21 going to get the top to, basically, get the super heated
22 steam, super heated steam on the top?

23 MR. LINDBLAD: With radiation. Radiant energy.

24 MR. SCHNEIDER: All the corium is located in the
25 cavity covered with water.

1 MR. CATTON: Well, that is certainly true. So
2 what you are doing is --

3 MR. SCHNEIDER: Basically, a steaming calculation.

4 MR. CATTON: It is strictly a steaming
5 calculation.

6 MR. SCHNEIDER: It is more elaborate, but that is
7 essentially what it amounts to.

8 MR. CATTON: I have to buy that if the source of
9 the hot steam is put on the bottom and it is like my coffee
10 pot.

11 MR. CARROLL: As long as there is water in it.

12 MR. CATTON: As long as there is water in it.

13 MR. SCHNEIDER: We wanted to look at the
14 distribution of the senses to see what is going to be
15 affected by what. The only thing inside the crane wall
16 would be the thermal couple that comes right out of the top
17 of the upper head, and that is only has -- basically, that
18 can survive very high temperatures, and the cabling is only
19 exposed to the crane walls, but only the upper portion of
20 the crane wall. So, it shouldn't be in that bad of shape.

21 Everything else is located outside the crane wall
22 for sensors. Most of the stuff is also located in the
23 subsphere. For the radiation monitor we have something
24 located in the outside of the crane wall. But it is also
25 backed up by the post-accident sampling system, which is

1 located in the subsphere itself.

2 MR. LINDBLAD: What is the subsphere?

3 MR. SCHNEIDER: The portion of the containment
4 building that is located below the sphere but because we use
5 up all the available space in the -- it has a common
6 basement and there are rooms below.

7 MR. CATTON: It is not in containment.

8 MR. CROM: It is not in containment. The
9 subsphere is where all of the ECCS pumps are located, which
10 is under --

11 MR. CATTON: You mean below the sphere?

12 MR. CROM: That is correct.

13 MR. CARROLL: Sub -- submarine.

14 MR. SEALE: Subnormal.

15 [Laughter.]

16 [Slide.]

17 MR. SCHNEIDER: Again, in terms of the equipment,
18 the only equipment located inside the crane wall is going to
19 be that which is going to be actuated early or has been
20 environmentally qualified to survive the burns. Most of the
21 residual equipment will be located outside the crane wall.

22 Some pieces have now -- for the containment spray
23 system, the only thing inside the crane wall containment are
24 the containment spray headers, which should not be subject
25 to much of the loading containment penetrations both inside

1 and outside the crane wall, inside and outside the
2 containment.

3 So, by and large, a large fraction of what we are
4 expecting to survive will survive by virtue of its location,
5 not being in the containment. The remainder of it will
6 survive because it is going to be reasonably well qualified
7 by the design basis itself, plus special restrictions on
8 placement.

9 In addition, it is located in one of the most
10 favorable positions on the other side of the crane wall. So
11 we think that there is a high confidence that the equipment
12 will be available to be called upon should the operator ever
13 need it for the situations.

14 MR. LINDBLAD: When you were showing the hydrogen
15 mitigation system, both sensors and cables, how many sensor
16 locations do you have.

17 MR. SCHNEIDER: 80. Oh, sensors locations, no.
18 Sensors are outside of containment. They are what two?
19 They are on the recombiner. They are on the recombiner
20 skid.

21 MR. CROM: I believe it is two but I do not recall
22 right off hand.

23 MR. LINDBLAD: So most of is cabling for the
24 igniters.

25 MR. SCHNEIDER: Oh, yes. It is cabling.

1 MR. LINDBLAD: Thank you.

2 MR. SCHNEIDER: The result of a thermal
3 environment, we believe that the equipment instruments
4 required for achieving and maintaining a safe shutdown will
5 have a high confidence of surviving a recoverable severe
6 accident and equipment sensors, transmitters, and cables
7 located outside the containment will just survive virtually
8 any severe accident. That is really the story.

9 MR. CARROLL: Any questions.

10 MR. DAVIS: I have a quick one. It is related to
11 some previous discussion about the containment. One of the
12 down sides of having such a huge steel shell as a
13 containment means you get a substantial thermal expansion as
14 the containment starts to heat up and the growth can be
15 quite large.

16 There is a discussion in Volume 24 about the shell
17 growth as the temperature increases and this opens up a leak
18 in pads between the penetrations and the shell. But it was
19 not clear to me how that was accounted for in the analysis.
20 Do you have some leak grade versus temperature analysis that
21 you were using for the risk assessment?

22 MR. SCHNEIDER: The reason I went to Service Level
23 "C" for the minimum yield stresses, we keep the containment
24 in the elastic range. Once it gets into the plastic range
25 we are assuming it will start to fail probabilistically, and

1 the only way that it is treated in the PRA would be to be
2 treated by having material property variation on the modules
3 of elasticity on the shell and the yield point stress -- the
4 yield point stress. So, that has a variation in it based on
5 the material property.

6 Once you go past yield, once you go into the yield
7 portion of the curve, we have not credited any strained
8 hardening. We assume that will grow. That will be a
9 failure because we do not have the detailed drawings that we
10 show that we can prove that it won't.

11 MR. LINDBLAD: It sounds like you're talking about
12 pressure dilution rather than temperature expansion. Is
13 that correct?

14 MR. SCHNEIDER: Any kind of separation. We look
15 at the whole temperature range. I think what he was -- the
16 concern was that once you get above a certain stress, you
17 can have --

18 MR. LINDBLAD: Why would there be any different
19 stress with the temperature expansion if the shell is free
20 to expand and the stress intensity will remain the same?

21 MR. SCHNEIDER: I think he was quoting from a
22 section referring to the pressure. Am I misinterpreting
23 something?

24 MR. DAVIS: It was more of a temperature problem
25 as I read it and what I could not find out is how does the

1 leak rate vary as the temperature increases during a severe
2 accident?

3 MR. SCHNEIDER: It really should not. Until you
4 get beyond yield, you will not have any problem.

5 MR. DAVIS: This says that the leak pads will open
6 up between the penetration and the shell as the shell
7 temperature increases.

8 MR. CARROLL: I think those are preexisting
9 leakage paths.

10 MR. KRESS: Generally, if you have a percent
11 volume per day, you don't know where it is. You can ration
12 the area change and assume that that leakage goes with the
13 area change.

14 MR. DAVIS: What was done on the PRA on leak rate
15 versus temperature?

16 MR. SCHNEIDER: Dan?

17

18

19

20

21

22

23

24

25

1 E V E N I N G S E S S I O N

2 MR. FINNICUM: When we looked at the PRA up to the
3 temperature that they were assumed to fail, we did not look
4 at any leak change in leak rate at that temperature. It was
5 then assumed to be catastrophic failure.

6 MR. DAVIS: What was that temperature?

7 MR. FINNICUM: About 400 degrees, something like
8 that.

9 MR. SCHNEIDER: It is really not a temperature.
10 We used 350 degrees for -- that's right -- 350 degrees for
11 the failure yield stress to establish where the failure of
12 the yield stress would be, the temperature associated with
13 it. 350 degrees, which is, basically, the equivalent
14 temperature you would expect in containment on a global
15 basis and steaming to give you about the same pressure
16 loading to correspond to failure.

17 MR. DAVIS: The leak rate is still the same at
18 that temperature?

19 MR. SCHNEIDER: We did not do anything on that.

20 MR. CARROLL: Okay. Any other questions? All
21 right, Doug would have us deal with Ivan's part.

22 MR. CATTON: I'd like to take a look at the
23 questions and I think there are some -- that Chad should
24 take a look at them. I'm not sure if I asked the questions
25 or not, but if I did I asked them so that Chad could listen

1 to the answers. It had to do with copper and a few other
2 things.

3 For the most part, I have no problem with their
4 answers. I guess in the one case -- that was Oak Ridge?
5 That was for the Staff.

6 MR. COE: The three dimensional analysis study.

7 MR. CATTON: Let me quickly go through these.
8 There was a question about the core vibrations and they
9 indicated their velocities are lower. So there is no
10 problem. I don't have any problem with that. We have those
11 that are still sort of open with -- I would like to see the
12 models of correlation document.

13 MR. CARROLL: I did notice that they used a Zuber
14 correlation.

15 MR. CATTON: Then it has to be good.

16 MR. COE: Page 40?

17 MR. CATTON: Page 40. Page 40 was the criteria to
18 size the lower grid flow points. It sounds good to me.

19 MR. LINDBLAD: I have a question about that later.

20 MR. CATTON: Explain the differences between
21 SCU&D&B convolution methods? I guess I'm just bothered by
22 the use of the convoluted method. I read through it and it
23 sounds like they are using the sum of the squares or
24 something, thermal couples. They address some issues that I
25 recall from years ago so I have no problem with that. Where

1 is the next one?

2 MR. COE: 47.

3 MR. CATTON: Page -- ABBCE regarding improvement
4 in reactor vessel improvement. I think Shack should take a
5 look at that.

6 MR. CARROLL: Does Shack know what you learned in
7 Germany?

8 MR. CATTON: Probably not. But if he could read
9 the trip report. I was referring to another trip report and
10 actually this here part of the trip to Germany is back here.
11 Charlie -- it is not fair to ask him.

12 Let's see. The last one is post-action radiation
13 monitors. I don't think I asked that question. The answer
14 sounds okay to me.

15 MR. CARROLL: I will figure out whether I asked
16 it.

17 MR. CATTON: How does the answer sound to you?

18 MR. CARROLL: I have not read it again. I read it
19 once.

20 MR. KRESS: What is your problem with convolution?
21 It is a tried and try --

22 MR. CATTON: Convoluted and nobody can understand
23 what it is. I'm happy with the answers.

24 MR. COE: The Staff also responded to your
25 question regarding the three dimensional analysis studies

1 done at Oak Ridge that might indicate a less margin. You
2 looked at that too?

3 MR. CATTON: Yes.

4 MR. CARROLL: Okay. Do we have any more business?
5 We should go on the record, stay on the record for --

6 MR. LINDBLAD: I move that we recess.

7 MR. CARROLL: Then we are in recess.

8 [Whereupon, at 6:06 p.m., the meeting in the
9 above-entitled matter was adjourned.]

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings
before the United States Nuclear Regulatory
Commission
in the matter of:

NAME OF PROCEEDING: ACRS ABB CE Plant Design

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, MD

were held as herein appears, and that this is the
original transcript thereof for the file of the
United States Nuclear Regulatory Commission taken
by me and thereafter reduced to typewriting by me
or under the direction of the court reporting
company, and that the transcript is a true and
accurate record of the foregoing proceedings.

Barbara Whitlock
Official Reporter
Ann Riley & Associates, Ltd.

INTRODUCTORY STATEMENT BY THE
ABB-CE STANDARD PLANT DESIGNS
SUBCOMMITTEE CHAIRMAN
MARCH 8, 1994
BETHESDA, MARYLAND

The meeting will now come to order. This is a meeting of the Advisory Subcommittee on ABB-CE Standard Plant Designs. I am Jay Carroll, Subcommittee Chairman.

The ACRS Members in attendance are: I. Catton, P. Davis, T. Kress, W. Lindblad, C. Michelson, R. Seale, and C. Wylie.

The purpose of this meeting is for the Subcommittee to continue its review of the ABB-CE System 80+ Standard Plant Design.

Mr. Doug Coe is the cognizant ACRS Staff Member for this meeting.

The rules for participation in today's meeting have been announced as part of the notice of this meeting previously published in the Federal Register on February 23, 1994 as modified March 1, 1994.

A transcript of the meeting is being kept and will be made available as stated in the Federal Register Notice. It is requested that each speaker first identify himself or herself and speak with sufficient clarity and volume so that he or she can be readily heard.

We have received no written comments or requests to make oral statements from members of the public.

(Chairman's Comments - if any)

We will proceed with the meeting and I invite Mr. Charles Brinkman of ABB-CE to begin the presentations.

ABB Combustion Engineering System 80+™ Standard Plant

Chapter 3 Design of Structures, Components, Equipment, and Systems

Leak-Before-Break
Technology Application
ACRS March 8, 1994

System 80+ Standard Plant Leak Before Break

- What pipes have LBB applied in System 80+?
- What is LBB used for?
- What is the basis for choosing lines for LBB?
- How is LBB demonstrated for System 80+?
- What is the impact of LBB on System 80+?


System 80+ Standard Plant Leak Before Break Applications

- Main coolant loop piping
 - 2 hot legs (42" carbon steel)
 - 4 pump discharge legs (30" carbon steel)
 - 4 pump suction legs (30" carbon steel)
- Surge line (12" stainless steel)
- 2 shutdown cooling lines (16" stainless steel)
- 4 direct vessel injection lines (12" stainless steel)
- 4 main steam lines (28" carbon steel)


Note: All lines are inside containment

System 80+ Standard Plant


Isometric View of Reactor Coolant System




System 80+ Standard Plant Surge Line



System 80+ Standard Plant Shutdown Cooling Piping



System 80+ Standard Plant Main Steam Piping



System 80+ Standard Plant Leak Before Break Applicability

- LBB analysis used to justify elimination of dynamic load effects of design basis pipe breaks (DBPBs).
- LBB analysis does not eliminate:
 - Containment pressure-temperature effects of DBPBs.
 - Emergency core cooling system requirements for effects of DBPBs.
 - Environmental qualification requirements for effects of DBPBs.

System 80+ Standard Plant Choice of Application Piping

Basis for choice of lines for LBB

- Qualified based on not being susceptible to:
 - Waterhammer
 - Creep
 - Erosion
 - Corrosion
 - Fatigue
 - Environmental Conditions

- Satisfies LBB evaluation criteria:
 - Margin of 10 on leak detection rate
 - Margin of 2 on crack length
 - Margin of $\sqrt{2}$ on loads

System 80+ Standard Plant LBB Acceptance Criteria

$L < L_c$ for $\sqrt{2}$ x maximum loads

$2L < L_c$ for maximum loads

where:

- L = Crack length which would leak 10 times the leak detection system sensitivity at normal operating conditions.
- L_c = Critical crack length


System 80+ Standard Plant Evaluation Process

- Confirm piping system satisfies qualifications for applicability of LBB.
- Define LBB acceptance criteria based on parametric studies for use by piping designers.(Method Requires definition of only pipe size and materials.)
- Demonstrate capability to design to LBB acceptance criteria by complete preliminary design of System 80+ piping.
- Confirmation of material properties and final as-built design will be performed at construction stage.

System 80+ Standard Plant LBB Piping Evaluation Diagram

ALWR Surge Line (TIG), $A_c = .02 \text{ in}^2$

SSE x 10⁻⁶ (in pounds)



System 80+ Standard Plant LBB Impact on Design

- System 80 (implemented at Palo Verde Units 1,2 & 3) was originally designed and built to withstand dynamic effects of design basis pipe breaks.
- LBB analyses justified removal of pipe restraints for main loop pipes.
- Inherent capability to withstand dynamic effects is maintained in System 80+ design.
- Unused capability provides additional seismic design margin.

System 80+ Standard Plant Leak Before Break Benefits

- Improved reliability of piping system due to elimination of restraint structures which may restrain normal thermal expansion.
- Improved accessibility for in-service inspection and maintenance of piping and equipment in vicinity.
- Reduced personnel exposure due to improved accessibility and no need to inspect and maintain restraints.
- Reduced construction time and costs.
- Reduced refueling times and less personnel exposure due to ability to install a permanent pool seal over reactor cavity annulus.

ABB Combustion Engineering System 80+™ Standard Plant

Section 19.11 "Severe Accident Analysis"

Raymond E. Schneider

**ACRS ABB-CE Standard Plant Designs
Subcommittee
March 8-9, 1994**

- System 80+ Standard Plant
- System 80+ Severe Accident Analysis



System 80+ Standard Plant Goals of Severe Accident Analyses

- Purpose:
 - Demonstrate compliance with regulatory issues defined in SECY-93-087 and 10CFR50.34 (f)
 - Support PRA Level II quantification

System 80+ Standard Plant

SECY-93-087 Severe Accident Issues

- Hydrogen control

- Prevention of high-pressure core melt ejection (and direct containment heating)
- Mitigation of ex-vessel steam explosions
- Mitigation of core-concrete interactions
- Containment performance (overpressure failure)
- Instrumentation and equipment survivability

System 80+ Standard Plant

Hydrogen Control



System 80+ Standard Plant Hydrogen Control

- Purpose:


- Limit uniform containment hydrogen concentration to <10 volume percent
- Demonstrate ability of containment to accommodate the consequences of 100% oxidation of the fuel clad
- Reduce potential for containment failures

System 80+ Standard Plant Hydrogen Control

- Design Features:

- Large containment volume (3.4 million ft³) ensures that, even without hydrogen control features, the maximum hydrogen concentration is less than 13%.
- Hydrogen mitigation system including igniters and IRWST pressure relief dampers function to preclude hydrogen detonation within the containment.
- Containment arrangement promotes natural circulation and mixing
- "In Containment" enclosures vented to prevent local hydrogen accumulation

System 80+ Standard Plant Hydrogen Control



Dominant Post Accident Natural Circulation Pattern for System 80+

System 80+ Standard Plant Hydrogen Mitigation System (HMS)

- 80 Igniters
 - Strategically located within the containment
 - Two redundant electrical trains
- Igniters and cables designed to survive
 - Hydrogen burns
 - Seismic events
- High expected system availability
 - Powered by diverse power sources including offsite power, emergency diesels, combustion turbine and batteries
 - Technical specifications address surveillance and operability
 - Included in Reliability Assurance Program

System 80+ Standard Plant Hydrogen Igniter Placement Criteria

- Igniter system design considers

- System maintainability
- redundancy/reliability
- Placement criteria

System 80+ Standard Plant

Detailed Hydrogen Igniter Placement / Design Criteria


- System maintainability requirements
 - No more igniters to be included in system than necessary
 - Igniters located with reasonable expectation of maintainability and surveillance

System 80+ Standard Plant

Detailed Hydrogen Igniter Placement / Design Criteria


- Redundancy and system reliability objectives require
 - Multiple levels of burning in dominant flow paths
 - Pairs of igniters to cover similar regions
 - Igniter pairs powered via independent power sources
- Placement criteria requires igniter to be placed
 - Along all dominant and secondary flowpaths
 - In vicinity and above hydrogen sources
 - In all compartments
 - About 10 feet below solid surfaces
 - So as to control hydrogen in volumes of 50,000 cu. ft. except in dome

System 80+ Standard Plant Hydrogen Igniter Placement/Layout




ABB

System 80+ Standard Plant Hydrogen Igniter Placement/Layout



Plan View of Reactor Cavity


System 80+ Standard Plant Hydrogen Igniter Placement/Layout



Plan View of Reactor Cavity and IRWST




System 80+ Standard Plant Hydrogen Igniter Placement/Layout



Plan View at El. 91'+9"

ABB


System 80+ Standard Plant Hydrogen Igniter Placement/Layout



Plan View at El. 115'+6"

ABB


System 80+ Standard Plant Hydrogen Igniter Placement/Layout



Plan View El. 257' through 146'




System 80+ Standard Plant Three Dimensional Plant Layout




VIEW OF IRWST AREA
"LID" AT FL. EL. 91'+9"
HAS BEEN REMOVED FOR CLARITY


System 80+ Standard Plant Three Dimensional Plant Layout




System 80+ Standard Plant Three Dimensional Plant Layout



System 80+ Standard Plant Three Dimensional Plant Layout



System 80+ Standard Plant Three Dimensional Plant Layout



ISO VIEW OF IRWST AREA
AND PRESSURIZER AREA

ABB

System 80+ Standard Plant

System 80+ Hydrogen Control

- Performance Results

- HMS igniters and IRWST pressure relief dampers control uniform global hydrogen concentration < 10 volume percent
- In the event HMS does not function, the limiting hydrogen burn pressure will not exceed containment pressures associated with ASME Level "C" stress allowables

System 80+ Standard Plant HMS Performance Analysis

- **Objective:**

- Provide confirmatory assessment of igniter placement and develop insights on system performance.

- **Methodology:**

- Develop detailed System 80+ containment model using MAAP-4 "generalized containment model"
- Normalize model to eliminate "phantom" flows

- **Insights**

- Igniters are successful in reducing containment wide hydrogen concentration

System 80+ Standard Plant

Calculation of Limiting Burn Pressure

- Objective:

- Demonstrate that deflagrations resulting from the combustion of hydrogen equivalent to 100% oxidation of zircaloy will not threaten containment integrity


- Methodology

- Calculate hydrogen pressure based on AICC assumptions
- Full range of initial conditions considered including worst credible "non inerted" burn containment condition

- Conclusion

- Post burn containment pressure will not exceed ASME Service Level "C" stress allowables. Therefore, containment failure due to hydrogen deflagration threat not credible

System 80+ Standard Plant System 80+ Hydrogen Control



○ 100% Fuel Clad △ Post-Burn Pressure □ Flammability Limit

Containment pressure associated with AICC combustion of hydrogen produced following a hypothetical 100% oxidation of active fuel cladding
(Service Level C Pressure ~140 psia)

ABB

System 80+ Standard Plant Conclusions

- *Assessment of the post burn containment performance indicates that System 80+ design features successfully mitigate this potential severe accident threat*

System 80+ Standard Plant SEYC-93-087 Severe Accident Issues

- Hydrogen control
- Prevention of high-pressure core melt ejection (and direct containment heating)
- Mitigation of ex-vessel steam explosions
- Mitigation of core -concrete interactions
- Containment performance (overpressure failure)
- Instrumentation and equipment survivability

System 80+ Standard Plant

Prevention of Direct Containment Heating/High Pressure Melt Ejection

System 80+ Standard Plant Prevention of Direct Containment Heating

Purpose:


- Comply with ALWR Utility Requirements Document (URD) guidance to minimize potential for events leading to a high pressure melt ejection and minimize potential for direct containment heating
- Comply with specific guidance of SECY-93-087 and URD:
 - Provide a reliable depressurization system
 - Provide cavity design features to decrease the amount of ejected core debris that reaches the upper containment

System 80+ Standard Plant High Pressure Core Melt Ejection (HPME)

Relevant Design Features for HPME Prevention / Mitigation

- Rapid Depressurization System (manually operated from the Control Room) allows for depressurization of RCS prior to vessel breach
- Reactor cavity design with a large convoluted reactor cavity vent and a core debris accumulation chamber
- Cavity Flood System
- Large containment volume

System 80+ Standard Plant Reactor Cavity Design



Elevation View of Reactor Cavity



System 80+ Standard Plant DCH Deterministic Analyses

- Purpose: provide bounding estimates of containment pressure rise due to DCH.
- Methodology:
 - Single and two cell DCH models (similar to Pilch) employed
 - Analyses performed do not credit RDS and only marginally credit cavity debris retention characteristics of the design.
- Assumptions:
 - (1) Pre-VB RCS pressure 2500 psia
 - (2) 60% instantaneous corium mass ejection from the RCS
 - (3) 50% dispersal into upper containment
- Result: Peak containment pressures produce shell stresses below ASME Service Level "C" allowables

System 80+ Standard Plant

Conclusion

- *As a consequence of System 80+ design features, the associated containment threat caused by high pressure melt ejection poses a negligible contribution to plant risk*

System 80+ Standard Plant

SECY-93-087 Severe Accident Issues

- Hydrogen control
- Prevention of high-pressure core melt ejection (and direct containment heating)
- Mitigation of ex-vessel steam explosions
- Mitigation of core-concrete interactions
- Containment performance (overpressure failure)
- Instrumentation and equipment survivability

System 80+ Standard Plant
Mitigation of Ex-Vessel Steam Explosions

System 80+ Standard Plant Mitigation of Ex-Vessel Steam Explosion

- Purpose

- Comply with SECY-93-087 goal to minimize early containment failures
- Address NUREG-1150 Containment Performance observation that Ex-Vessel Steam Explosions (EVSE) can fail the RV supporting structure and potentially induce a containment failure via failure of penetrations

System 80+ Standard Plant Mitigation of Ex-Vessel Steam Explosion

- Design Features

- Robust upper cavity and corbel structural design
- The System 80+ RV can be supported without the presence of the lower cavity wall
- RV corbels (which support the RV) are reinforced to withstand high dynamic EVSE loadings

System 80+ Standard Plant Deterministic Assessment of EVSE

- Purpose: Quantify potential EVSE loadings on the reactor cavity walls following ejection of corium into a water filled reactor cavity
- Methodology:
 - Magnitude of EVSE based on TNT equivalent impulse
 - Mass of corium
 - Superheat
 - Efficiency of energy conversion process ($\epsilon \approx 0.015$ to 0.03)
 - Structural dynamic analysis of lower cavity and corbels


System 80+ Standard Plant

Deterministic Assessment of EVSE

● Results

- EVSE Loads will not fail cavity walls provided Corium mass involved in a single explosion < 10,000 lbm
- Structural analyses demonstrate that sufficient vertical shear would be available in connecting rebar to support the RV even if the lower reactor cavity wall is eliminated
- Reinforcing the RV corbels ensures survival of lower supports from direct impact loadings

System 80+: Mitigation of Ex-Vessel Steam Explosions Deterministic Assessment








Load paths for RV support following loss of lower reactor
cavity walls

ABB






1

IMAGE EVALUATION TEST TARGET (MT-3)








1

IMAGE EVALUATION TEST TARGET (MT-3)









1

IMAGE EVALUATION TEST TARGET (MT-3)



1

IMAGE EVALUATION TEST TARGET (MT-3)



System 80+ Standard Plant Deterministic Assessment of EVSE

- Other considerations (not credited in deterministic assessment)
 - Additional support to the RV can be provided by the 2 hot legs and 4 cold leg pipes
 - SG keys prevent significant rotation of SG therefore loss of support of RV will not result in a significant dislocation of piping connected to RCS or the SG
 - RCS displacements are more likely to fail piping within the containment than at the containment penetrations.

System 80+ Standard Plant Deterministic Assessment of ESVE

- **Conclusions**
 - *Ex-Vessel steam explosions in the System 80+ reactor cavity will not compromise RV support and consequently do not pose a significant risk of containment failure*

System 80+ Standard Plant

SECY-93-087 Severe Accident Issues

- Hydrogen control
- Prevention of high-pressure core melt ejection (and direct containment heating)
- Mitigation of ex-vessel steam explosions
- Mitigation of core-concrete interactions
- Containment performance (overpressure failure)
- Instrumentation and equipment survivability

● System 80+ Standard Plant
● Mitigation of Core Concrete Interactions

System 80+ Standard Plant

Mitigation of Core Concrete Interactions

● Purpose:


- Provide coolability of corium debris retained in the reactor cavity
- Protect containment pressure boundary
- Applicable guidance SECY-93-087 and ALWR URD:
 - Provide a means to flood the reactor cavity
 - Protect steel shell with concrete
 - Large floor area for corium spreading
 - One day minimum containment integrity goal

System 80+ Standard Plant Reactor Cavity and Basemat Design Features

● Design Features

- Large cavity floor area (limits average corium debris depth to approximately 10 inches)
- Cavity Flooding System capable of flooding the reactor cavity to a depth of approximately 11 feet. Water pool is expected to fragment, cool, and scrub debris
- Cavity floor constructed with a minimum of 3 feet of limestone based concrete to resist erosion and protect containment shell
- Robust upper cavity design can support RV following complete erosion of lower pedestal
- Additional 15 feet of concrete below steel shell as a barrier to release of radiation to the soil



System 80+ Standard Plant Containment Basemat



ABB

System 80+ Standard Plant Reactor Cavity Layout

Plan Approx. Elevation 70+0



Section from 90° to 270°



System 80+ Standard Plant Deterministic Assessment of CCI

- Goal (SECY-93-087)

- Demonstrate that with minimum debris coolability, cavity floor erosion will not reach the embedded containment shell for about 24 hours

- Imposed Analytical Restrictions

- Initial attack of lower shell implies containment failure
- Only concrete above steel shell credited
- No credit for debris fragmentation. Debris morphology not favorable to heat transfer

System 80+ Standard Plant Deterministic Assessment of CCI

- Methodology for calculation of the erosion of cavity floor
 - Tool selected for deterministic assessment was CORCON-MOD3
 - Code verified against CCI experiments
 - Capable of "realistically" considering limiting case of a layered morphology
 - Analyses considered flat cavity floor and sump regions

System 80+ Standard Plant Deterministic Assessment of CCI

- Analytical assumptions

- Vessel Breach (VB) occurs at 3 hours following reactor trip
- 100% of core inventory corium deposited on the cavity floor
- Decay energy credits prior release of volatile fission products
- 75% of zirconium oxidized prior to concrete contact

System 80+ Standard Plant Deterministic Assessment of CCI

Results of Coron - MOD3 Calculations

	<u>Time of erosion to steel shell</u>
Cavity Flat Area	30 hrs
Sump*	24 hrs

* Erosion to 3.2 FT

System 80+ Standard Plant

Deterministic Assessment of CCI

- Conclusions

- Assessments of concrete erosion demonstrate the ability of the System 80+ design to provide 24 hours of containment integrity.

System 80+ Standard Plant SECY-93-087 Severe Accident Issues

- Hydrogen control
- Prevention of high-pressure core melt ejection (and direct containment heating)
- Mitigation of ex-vessel steam explosions
- Mitigation of core-concrete interactions
- Containment performance (overpressure failure)
- Instrumentation and equipment survivability

-
- **System 80+ Standard Plant
Containment Overpressure Failure**



System 80+ Standard Plant Containment Overpressure Failure

- Objective

- Comply with SECY-93-087 goals:

- Demonstrate high containment reliability
- With sprays unavailable, demonstrate that the containment will maintain its role as a reliable, leak-tight barrier for approximately 24 hours under the more likely severe accident challenges

System 80+ Standard Plant Containment Overpressure Failure

● Features

- System 80+ includes a highly reliable containment heat removal system
 1. Redundant containment spray system with Class 1E backup pumps via the SCS
 2. Redundant power sources including offsite power, emergency diesels, and combustion turbine
- Large containment volume for mitigating pressure rise

System 80+ Standard Plant Containment Overpressure Failure

- Alternate pressure control/cooling capabilities
 - Non-Class 1E fan coolers
 - External spray capability provides extended time for pressure control
 - Containment vent capability via purge lines

System 80+ Standard Plant

Containment Overpressure Failure Deterministic Evaluation

Objective

- Show minimum time to containment failure of more than 24 hrs

Methodology

- Containment failure times computed using MAAP 3.0 B
- Spectrum of transients considered
- No spray operation credited
- Containment failure based on ASME Service level C stress allowables

System 80+ Standard Plant

Containment Overpressure Failure Deterministic Evaluation

Results

- Containment failure times > 48 hours
- Limiting transients result from Large LOCA with actuation of Cavity Flooding System (CFS)

System 80+ Standard Plant

Probabilistic Aspects of Containment Failure

- PRA employed to demonstrate compliance with SECY-93-087 overall containment integrity goal
- Based on PRA the conditional containment failure probabilities (CCFPs) associated with core damage sequences were evaluated as follows:

Criteria	1-CCFP
Containment releases do not exceed DBA values for 24 hours	0.98
Containment precludes large fission product release	0.973
Containment leaktight indefinitely	0.886

- Consistent with SECY-93-087, the System 80+ containment has a high probability of maintaining containment integrity following a core damage event.

System 80+ Standard Plant Containment Overpressure Failure

● Conclusions

- Containment meets the deterministic SECY-93-087 containment integrity goal for containment overpressure failures.
- Probabilistic analyses indicate that System 80+ is robust to a spectrum of severe accidents and has a high probability of maintaining containment integrity following a severe core damage event. Resulting CCFPs are consistent with stated goals of SECY-93-087.

System 80+ Standard Plant

SECY-93-087 Severe Accident Issues

- Hydrogen control
- Prevention of high-pressure core melt ejection (and direct containment heating)
- Mitigation of ex-vessel steam explosions
- Mitigation of core-concrete interactions
- Containment performance (overpressure failure)
- Instrumentation and equipment survivability

- System 80+ Standard Plant

Instrumentation and Equipment Survivability

System 80+ Standard Plant Equipment Survivability

Purpose

- Comply with requirements of SECY-93-087 and 10CFR50.34(f)
 - Define instrumentation/equipment for achieving and maintaining safe shutdown and maintaining containment integrity
 - Demonstrate high confidence that the instrumentation/equipment will survive severe accident conditions for a period that is needed to perform its intended function
 - Consider effect of 100% oxidation of fuel cladding on equipment survivability

System 80+ Standard Plant Equipment Survivability

Methodology

- Review event progression for "in-vessel" recoverable and unrecoverable severe accident scenarios
- Define minimum equipment set for achieving and maintaining safe shutdown (vessel lower head intact)
- Define minimum equipment set for maintaining containment integrity
- Use analytical methods and experimental data to establish expected local and global severe accident environments
- Compare resulting severe accident environments with DBA EQ envelope and establish any supplementary guidance

System 80 + Standard Plant instrumentation required for severe accident mitigation and prevention

INSTRUMENT	REQUIRED PRE-VESSEL BREACH	REQUIRED POST-VESSEL BREACH
UHJTC	√	-
RCS PRESSURE OR PZR PRESSURE	√	-
SI FLOW	√	-
EFW FLOW	√	-
SG WATER LEVEL	√	-
IRWST WATER LEVEL	√	√
HYDROGEN MONITOR	√	√
RADIATION MONITOR	√	√
CONTAINMENT PRESSURE	√	√
CONTAINMENT TEMPERATURE	√	√
CS FLOW	√	√

System 80 + Standard Plant equipment required for severe accident mitigation and prevention

EQUIPMENT	PRE-VESSEL BREACH	POST-VESSEL BREACH
SAFETY INJECTION SYSTEM	✓	-
EMERGENCY FEEDWATER SYSTEM	✓	-
CONTAINMENT ISOLATION SYSTEM	✓ ¹	-
RAPID DEPRESSURIZATION SYSTEM	✓ ¹	-
CAVITY FLOODING SYSTEM	✓ ¹	-
HYDROGEN MITIGATION SYSTEM	✓	✓
CONTAINMENT PENETRATION INTEGRITY	✓	✓
CONTAINMENT SPRAY SYSTEM	✓	✓
SHUTDOWN COOLING SYSTEM	✓	✓

1-ACTUATED AND PERFORMS FUNCTION PRIOR TO VB

System 80+ Standard Plant Definition of Severe Accident Environment

- Local vs global effects
 - Local effects
 - Driven by combustion processes
 - Near igniters
 - Near hydrogen sources
 - Global effects
 - Driven by convective processes
 - Governs bulk of containment

System 80+ Standard Plant

Equipment Survivability Severe Accident Environment

- Consideration regarding local environmental conditions
 - Reduce effect of local environments on instrumentation / equipment
 - Rely primarily on equipment and instruments with transmitters / sensors and cables located away from potential hydrogen sources
 - Based on HCOG data all required instruments are located a minimum of 10 feet from igniters to reduce influence of local igniter burn environments
 - Instruments to be shielded from thermal radiation from active igniters
 - For post-VB sequences the bulk of equipment relied upon for accident mitigation located outside of containment

System 80+ Standard Plant

Equipment Survivability Severe Accident Environment

- Global Environments

- Uniform temperatures expected away from igniters and other sources of burning
- For "In-Containment" instrumentation/equipment, global environments primarily established using MAAP 3.0B
- Verified uniform modeling using generalized containment model

System 80+ Standard Plant DCH Deterministic Analyses

- **Purpose:** provide bounding estimates of containment pressure rise due to DCH.
- **Methodology:**
 - Single and two cell DCH models (similar to Pilch) employed
 - Analyses performed do not credit RDS and only marginally credit cavity debris retention characteristics of the design.
- **Assumptions:**
 - (1) Pre-VB RCS pressure 2500 psia
 - (2) 60% instantaneous corium mass ejection from the RCS
 - (3) 50% dispersal into upper containment
- **Result:** Peak containment pressures produce shell stresses below ASME Service Level C allowables

System 80+ Standard Plant

Equipment Survivability Severe Accident Environment

- Results of Assessment of Thermal Environment
 - Equipment / instruments required for achieving and maintaining a safe shutdown have a high confidence of surviving a recoverable severe accident.

Thermodynamic Parameter	Bounding Severe Accident Environment		DB EQ
	< 24 hours	At containment failure	
Temperature (F)	<330	<350	~330
Pressure (psia)	<90	<140	<90

- Equipment with sensors, transmitters and cables located outside of containment have a high confidence of surviving any severe accident.

System 80 + Standard Plant

Distribution of required sensors/cables

instrumentation	req'd post- vb	location		
		inside crane wall	outside crane wall	subsphere
JHJTC	no	√		
RCS OR PZR Pressure Sensor	no		√	
SG Water Level	no		√	
Radiation Monitor	yes		√	√*
Containment Pressure Sensor	yes			√
Containment Temperature Sensor	yes		√	
Containment Spray Flow	yes			√
Safety Injection Flow	no			√
Emergency Feedwater Flow	no			√
IRWST Water Level	no			√
Hydrogen Monitor	yes			√

* -PASS

System 80 + Standard Plant

Distribution of required sensors/cables

instrumentation	req'd post- vb	location		
		inside crane wall	outside crane wall	subsphere
safety injection system	no			√
emergency feedwater system	no			√
containment isolation system	no		√ ¹	√
rapid depressurization system	no	√ ¹		
cavity flooding system	no	√ ¹		
hydrogen mitigation system	yes	√ ²	√ ²	
containment penetrations	yes		√ ³	√ ³
containment spray system	yes		√ ⁴	√
shutdown cooling system	yes			√

1: actuated and completes function prior to harsh environment ; 2: designed to survive local continuous hydrogen burn

3: penetration designed to withstand severe environment ; 4: spray piping/nozzles only

System 80+ Standard Plant

Equipment Survivability Severe Accident Environment

- Results of assessment of thermal environment
 - Equipment/instruments required for achieving and maintaining a safe shutdown have a high confidence of surviving a recoverable severe accident
 - Equipment with sensors, transmitters and cables located outside of containment have a high confidence of surviving any severe accident

System 80+ Standard Plant Equipment Survivability

Conclusions

- System 80+ instrumentation necessary for achieving and maintaining a safe shutdown condition and maintaining containment integrity will survive exposure to a spectrum of severe accidents for sufficient period to perform its intended function

System 80+™ Standard Plant Meeting Technical Support

ABB-CE

W. Bak
C. Brinkman*
F. Carpentino
M. Cross
D. Finnicum*
L. Gerdes*
C. Hoffman
J. Longo, Jr.
D. Peck
S. Ritterbusch*
R. Schneider*
E. Siegmann

DE&S

T. Crom*
T. Oswald

SWEC

S. Stamm
D. VanDuyne

Consultants

E. Idriss
R. Kennedy
M. Kenton


S. Dermitzakis

S. ~~Est~~ Estandar

* Speaker

ABB

System 80+ Standard Plant Nuclear Island Finite Element Model



System 80+ Standard Plant Structures

Detailed Design


- Nuclear Island

- Thirteen structural areas identified for detailed design
- All shear walls evaluated

- Non-Nuclear Island

- Diesel fuel storage structure
- Component cooling water heat exchanger structure and tunnel


System 80+ Standard Plant Nuclear Island - Detailed Design Areas



PLAN AT ELEV 50+0


ABB

System 80+ Standard Plant Nuclear Island - Detailed Design Areas



ABB


System 80+ Standard Plant Nuclear Island - Detailed Design Areas



PLAN AT 1:15+6

ABB


System 80+ Standard Plant Nuclear Island - Detailed Design Areas



SECTION A-A

ABB

- System 80+ Standard Plant
- Nuclear Island - Detailed Design Areas



SECTION B-B

ABB

System 80+ Standard Plant Structures

- Design requirements and/or interface requirements developed
 - Radwaste building
 - Turbine building
 - Station service building/ auxiliary boiler structure
 - Outdoor tank dikes
 - Boric acid, holdup and reactor makeup water
 - Station service water pump structure

**System 80+
Containment Vessel**

System 80+ Standard Plant Steel Containment Vessel

Description

- Type Steel sphere
- Material SA-537, Class 2
- Diameter 200 feet
- Thickness 1.75 inch with two inch band at transition region near base
- Free volume 3.34×10^6 cubic feet

System 80+ Standard Plant Steel Containment Vessel

Codes and Standards

- 10CFR50 - General Design Criteria
- 1989 ASME Boiler and Pressure Vessel Code, Section III, Subsection NE "Class MC Vessels"
- NUREG-0800 - Standard Review Plan
- Regulatory Guide 1.57
 - Design limits and loading combinations for metal primary reactor containment systems
- Regulatory Guide 1.61
 - Damping values for seismic design of nuclear power plants
- Regulatory Guide 1.84
 - Design and fabrication code case acceptability
- Regulatory Guide 1.92
 - Combining model responses and spatial components in seismic response analysis

System 80+ Standard Plant Steel Containment Vessel

Design conditions

● Normal operating

- Temperature: 110⁰ F
- Pressure: 0 psig

● Inadvertent containment spray actuation

- Temperature: 110⁰ F
- Pressure: -2.0 psig (vacuum)

● Design basis

- Temperature: 290⁰ F
- Pressure: 53.0 psig

● Combustible gas loading

- Temperature: 290⁰ F
- Pressure: 76.5 psig

The ABB logo consists of the letters 'A', 'B', and 'B' in a bold, sans-serif font. Each letter is contained within a square frame, and the frames are arranged in a row.


System 80+ Standard Plant Steel Containment Vessel

Analyses

- Test condition
 - Elastic three dimensional finite element analysis
- Design condition
 - Elastic three dimensional finite element analysis
- ASME service level conditions
 - Elastic three dimensional finite element analysis, except Level A which is an elastic axisymmetric finite element analysis
- Stability
 - Large deflection analyses with three dimensional finite element model
- Ultimate capacity
 - Elastic axisymmetric finite element analysis
- Combustible gas loading
 - Elastic axisymmetric finite element analysis
- Sliding & Overturning
 - Time history lumped mass stick model

- System 80+ Standard Plant
- Three Dimensional Finite Element Model

Steel Containment Vessel



SIDE VIEW

TOP VIEW



System 80+ Standard Plant Analysis Results

Steel Containment Vessel

Load Categories	Loading	Allowable Stress Intensity (ksi)		Maximum Calculated Stress Intensity (ksi)
		Limit	Value (ksi)	
Test Condition	D+L+P _t +T _t	0.75S _y	44.3	22.4
Design Condition	D+L+P _s	1.0S _{mc}	22.0	20.1
Level A	D+L+P _s	1.0S _{mc}	22.0	20.1
	D+L+P _s +T _s	Note 1.	146.0	77.0
Level D	D+L+P _s +E'	S _t	47.6	31.4
Construction	D+L+C	0.9S _y	54.0	12.8
Combustible Gas	D+L+P _s +P _g	S _y	52.5	48.1

Notes:

1. Simplified Elastic Plastic Analyses used for secondary stress evaluation per ASME Code Section NE-3228.3

System 80+ Standard Plant Stability Analysis Results

Steel Containment Vessel

Load Categories	Loading	Calculated Safety Factor	Required Safety Factor
Level A	$D+L+P_s+T_s$	3.0	3.0
Level C	$D+L+P_c$	2.7	2.5
Sliding and Overturning	$D+L+E'$	2.4	1.1

System 80+ Standard Plant Ultimate Pressure Capacity

Steel Containment Vessel

Temperature (°F)	Loading	Pressure (psig)	Stress Intensity (ksi)	Yield Stress (ksi)
150	D+L+P _u	156	57.4	57.5
290		142	52.5	52.5
350		138	51.0	51.1
450		132	48.8	48.8

ABB Combustion Engineering System 80+™ Standard Plant

*Site Parameters, Seismic Design,
Structural Design*

Lyle D. Gerdes

March 8&9, 1994

ABB

System 80^r_™
Site Parameters

System 80+ Standard Plant External Floods

- **Site Parameters**

- Grade elevation - 90'+9" (Reference)
- Maximum groundwater level - two feet below grade
- Probable maximum flood (PMF) level - one foot below grade

- **Design Features**

- Concrete construction joints sealed with waterstops
- External penetrations below grade sealed
- Doors/accesses at least one foot above grade
- Seepage will end up in sumps in basement through floor drains

System 80+ Standard Plant Wind and Tornado

Site Parameters

- Extreme wind-basic wind speed 110mph

- Tornado

Maximum wind speed	330 mph
Rotational speed	260 mph
Translational velocity	70 mph
Radius	150 ft
Max. differential pressure	2.4 psi
Rate of pressure drop	1.7 psi/sec
Missile spectra	SRP 3.5.1.4 Spectra II

System 80+ Standard Plant Wind and Tornado

Design Features

- Design Seismic Category 1 structures for associated loading and exterior walls and roof designed as tornado missile barriers
- Dampers qualified to tornado differential pressures

System 80+ Standard Plant Missiles

Protection

- Minimize the sources of missiles by equipment design features that prevent missile generation
- Orientation or physical separation of potential missile sources away from safety related equipment and components
- Containment of potential missiles through the use of protective shields and barriers near the source
- Hardening of safety related equipment and components to withstand missile impact where such impacts cannot be reasonably avoided by the above methods

System 80+ Standard Plant Missiles

Internally Generated Missiles

- Redundant safety systems physically separated by divisional wall outside containment
- Missile barriers used inside and outside containment where required
- Auxiliary pumps and motors
 - Induction type, relatively slow speed, rotor contained by stator, pumps impellers contained by casing
- Emergency feedwater pumps
 - Overspeed protection (electrical and mechanical), enclosed in separate room
- Valves
 - Stems have backseat or shoulder larger than bonnet opening, MOV and manual valve stems retained by threads, operators prevent stem ejection

System 80+ Standard Plant Missiles

Internally Generated Missiles

- Pressure Vessels
 - Moderate energy (275 psig) or less, pressure relief devices installed where necessary
- Turbine Missiles
 - Probability less than $1.0E-4$ events per year by maintenance and inspections, overspeed protection, orientation

System 80+ Standard Plant Missiles

Externally Generated Missiles

- Missiles generated by natural phenomena
 - Tornado missiles are part of the design basis for Seismic Category 1 structures, systems and components

System 80+ Standard Plant Radiological Dilution Factors

<u>Distance</u>	<u>Time Period</u>	<u>Dilution Factor</u> (sec/cubic meter)
EAB (0.5 mile)	0-2 hours	1.00×10^{-3}
LPZ (2.0 miles)	0-8 hours	1.35×10^{-4}
LPZ (2.0 miles)	8-24 hours	1.00×10^{-4}
LPZ (2.0 miles)	1.4 days	5.40×10^{-5}
LPZ (2.0 miles)	4-30 days	2.20×10^{-5}

Seismic & Structural Design

System 80+ Standard Plant Seismic Design Bases - General

- Design parameters envelope the majority of potential nuclear sites
- Both current and anticipated regulatory guidance considered
- Envelope of site conditions considered
 - Rock
 - Shallow soil
 - Deep soil
- SSE peak ground acceleration - .30G

System 80+ Standard Plant Design Process

- Selection of design control motion(s)
- Selection of soil profiles
- Development of dynamic models
- Dynamic analysis
- Definition of input for structural, subsystem and equipment design, analysis and qualification

Control Motion Definition

System 80+ Standard Plant Control Motion Definition

● CMS1

- USNRC reg 1.60 spectral shape
- Defined at surface in free field
- Horizontal PGA = .30G
- Vertical PGA = .30G

● CMS2


- Enriched in high frequency content
- Defined at rock outcrop
- Horizontal PGA = .30G
- Vertical PGA = .20G

System 80+ Standard Plant Control Motion Definition

- CMS3


- NUREG/CR-0098 spectral shape (enhanced)
- Defined at rock outcrop
- Horizontal PGA = .30G
- Vertical PGA = .20G

System 80+ Standard Plant Site Response




System 80+ Standard Plant CMS1, CMS2, CMS3


System 80+ CONTROL MOTIONS
Damping = 5%




System 80+ Standard Plant Generation of Control Motion CMS2




System 80+ Standard Plant Generation of Control Motion CMS2




System 80+ Standard Plant CMS2 Control Motion Spectrum - H1



System 80+ Standard Plant CMS2 Control Motion Spectrum - H2




System 80+ Standard Plant CMS2 Control Motion Spectrum - V




System 80+ Standard Plant Average Power Spectral Density - CMS1

Power Spectral Densities
Synthetic Time Histories vs. SRP Target
Horizontal Directions




Definition of Generic Soil Profiles


System 80+ Standard Plant Assigned Shear Wave Velocities - A1




System 80+ Standard Plant Assigned Shear Wave Velocities - B1



System 80+ Standard Plant Assigned Shear Wave Velocities - B2




System 80+ Standard Plant Assigned Shear Wave Velocities - B3




ABB


System 80+ Standard Plant Assigned Shear Wave Velocities - B4




System 80+ Standard Plant Assigned Shear Wave Velocities - C1




System 80+ Standard Plant Assigned Shear Wave Velocities - C2




System 80+ Standard Plant Assigned Shear Wave Velocities - C3




System 80+ Standard Plant Assigned Shear Wave Velocities - D1




System 80+ Standard Plant Assigned Shear Wave Velocities - B1.5



System 80+ Standard Plant Assigned Shear Wave Velocities - B3.5




System 80+ Standard Plant Assigned Shear Wave Velocities - C1.5




System 80+ Standard Plant CMS1 Comparison with CMS2


Horizontal Ground Surface Motions




System 80+ Standard Plant Spectra at Ground Surface - CMS3, H1



System 80+ Standard Plant Envelope of Free Field Surface Spectra-Horizontal




System 80+ Standard Plant Envelope of Free Field Surface Spectra-Vertical




System 80+ Standard Plant

Range of Shear Wave Velocities - All Cases Considered




ABB

System 80+ Standard Plant Variation of Shear Modulus




System 80+ Standard Plant Variation of Damping Ratio




Model Development

System 80+ Standard Plant Stick Model of Internal Structure




ABB


- System 80+ Standard Plant
- Stick Model of Shield Building



System 80+ Standard Plant Model of Steel Containment




System 80+ Standard Plant Representation of Reactor Coolant System




System 80+ Standard Plant

Schematic Representation of Nuclear Island Model



System 80+ Standard Plant Coupled Interaction Model




Dynamic Analysis

System 80+ Standard Plant Soil - Structure Interaction Analysis

- Computer program used:
 - SASSI (System for Analysis of Soil - Structure Interaction)
- General approach
 - Compute a site response
 - Computation of foundation independences
 - Solution of structural problem


System 80+ Standard Plant Application of Control Motions - CMS1



ABB


System 80+ Standard Plant

Application of Control Motions - CMS2 & CMS3




**In-Structure
Response Spectra**


System 80+ Standard Plant Basemat Spectra - CMS1, E-W, 5%




System 80+ Standard Plant Basemat Spectra - CMS1, N-S, 5%




System 80+ Standard Plant Basemat Spectra - CMS1, V, 5%




System 80+ Standard Plant Basemat Spectra - CMS2, E-W, 5%




System 80+ Standard Plant Basemat Spectra - CMS2, N-S, 5%




System 80+ Standard Plant Basemat Spectra - CMS2, V, 5%




System 80+ Standard Plant Basemat Spectra - CMS3, E-W, 5%




System 80+ Standard Plant Basemat Spectra - CMS3, N-S, 5%




System 80+ Standard Plant Basemat Spectra - CMS3, V, 5%




System 80+ Standard Plant Control Room - CMS1, E-W, 5%




System 80+ Standard Plant Control Room - CMS1, N-S, 5%




System 80+ Standard Plant Control Room - CMS1, V, 5%




System 80+ Standard Plant Control Room - CMS2, E-W, 5%




System 80+ Standard Plant Control Room - CMS2, N-S, 5%




System 80+ Standard Plant Control Room - CMS2, V, 5%




System 80+ Standard Plant Control Room - CMS3, E-W, 5%




System 80+ Standard Plant Control Room - CMS3, N-S, 5%




System 80+ Standard Plant Control Room - CMS3, V, 5%




System 80+ Standard Plant Control Room - N-S, 5%



System 80+ Standard Plant Control Room - E-W, 5%




System 80+ Standard Plant Control Room - V, 5%



ABB


System 80+ Standard Plant Interior Structure - Elev. 146, N-S, 5%



System 80+ Standard Plant Interior Structure - Elev. 146, E-W, 5%




System 80+ Standard Plant Interior Structure - Elev. 146, V, 5%




ABB


System 80+ Standard Plant DFSS Elev. 78 - N-S, 5%




System 80+ Standard Plant DFSS Elev. 78 - E-W, 5%



System 80+ Standard Plant DFSS Elev. 78 - V, 5%



System 80+ Standard Plant Site Acceptance Criteria for Ground Motion



ABB

Seismic Margin Assessment

System 80+ Structures

System 80+ Standard Plant Nuclear Island Structures

Seismic Category 1

- Reactor Building
 - Steel containment vessel
 - Shield building
 - Subsphere
 - Containment internal structures

- Nuclear Annex
 - CVCS/Maintenance area
 - Fuel area
 - Diesel generator areas
 - EFW/ Main steam valve house areas
 - Control areas

System 80+ Standard Plant Non - Nuclear Island Structures

Seismic Category 1

- Station service water pump structure (site dependent)
- Diesel fuel storage structure
- Component cooling water heat exchanger structure and tunnel
- Buried cable tunnels and conduit banks

Seismic Category 2

- Radwaste building
- Turbine building
- Outdoor tank dikes

System 80+ Standard Plant Structures

Codes and standards

● Concrete

- ACI-349 (1990) supplemented by ACI-318 and NRC staff positions on anchor bolt design

● Steel

- ANSI/AISC N690 (1984)

Loads and load combinations


● Concrete

- ACI-349 (1990)

● Steel


- ANSI/AISC N690 (1984)

System 80+ Standard Plant Nuclear Island Structures - Section A-A




- ▲ THE INACTIVE WASTE STRUCTURE IS LOCATED ADJACENT TO THE NUCLEAR ANNEX
- ▲ THE TURBINE BUILDING IS LOCATED ADJACENT TO THE NUCLEAR ANNEX

System 80+ Standard Plant Nuclear Island Structures - Section B-B




System 80+ Standard Plant

Nuclear Island Structures - Plan at Top of Basement




System 80+ Standard Plant


Nuclear Island Structures - Plan at Operating Floor



System 80+ Standard Plant Turbine Building






System 80+ Standard Plant Radwaste Building




System 80+ Standard Plant CCW Heat Exchanger Structure






LEGEND	
	• BOPWAY
	VERTICAL ACCESS SHAFTS
	• COLUMN
	• FLOOR BARRIER
	• 3-IN FINE BARRIER
	• 3-IN FINE AND FLOOR BARRIER



System 80+ Standard Plant Diesel Fuel Storage Structure



LEGEND	
●	DOORWAY
⊗	VERTICAL ACCESS SHIFTS
□	COLUMN
▨	FLOOD BARRIER
▤	3-IN FIBC BARRIER
▧	3-IN FIBC AND FLOOD BARRIER



System 80+ Standard Plant Structures

Analyses

- Static finite element model
 - Seismic - Equivalent static methods using dynamic analysis results. Includes the effects of structure to structure and soil to structure interaction.
 - Other global loads - Mass of structure and equipment, tornado, wind, large pipe rupture loads, large fluid masses

- Local models
 - Local effects particularly out-of-plane loads