NRC FORM 366 (12-81) 10 CFR 50	LICENSEE EVENT REPORT	APPROVED BY OMB
CONTROL BLOCK:	T T T T T T T T T T T T T T T T T T T	PE ALL REQUIRED INFORMATION)
O 1 P A S E S 1 2	0 0 - 0 0 0 0 0 - 0 0 3	4 1 1 1 1 1 4 57 CAT 50
CON'T O 1 SOUNCE L 6 0 5	0 0 0 3 8 7 0 1 2 0 1 8 DOCKET NUMBER 48 89 EVENT DATE	2 8 1 2 3 0 8 2 9
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) O 2 During the Startup Test Program, it was discovered that Tech. Spec. surveillance		
0 3 requirement 4.7.6.3	.2.a (CO ₂ storage tank level) was n	not included in any sur-
0 4 veillance procedure	. No significant occurrences took	place as a result of this
0 5 event. Fire extinguishers and hose reels are available in the areas protected by		
0 6 the CO ₂ systems. La	ater surveillance of the tank showe	ed the level to be at 60%
	quirement only 25% level).	
0 8		**
cook c	A 12 X 13 Z Z Z Z Z 14 SEQUENTIAL REPORT NO.	SUBCODE SUBCODE Z 15 Z 16 Z 16 Z 20 REVISION
17 REPORT 8 2 -	0 6 8 0 3	TYPE NO. 0
G 18 Z 19 Z 20	METHOD HOURS (22) SUBMITTED FORM	N 24 Z 25 Z 9 9 9 43
The event was caused by human error as the result of failing to include the		
surveillance in Weekly Surveillance Operating Log (S0-00-008). The procedure		
was revised to include the appropriate checks on the CO ₂ storage tank level.		
1 3 Shiftly, daily and	weekly surveillance procedures were	reviewed against Tech.
1 4 Spec. requirements	to verify no other items were misse	ed.
1 5 B 28 0 4 0 29		rnal Review (32)
ETTINIO INIO		SATION OF RELEASE 36
7 8 9 10 11 PERSONNEL EXPOSURES	N/A	N/A
FT	PTION (39) N/A	
PERSONNEL INJURIES NUMBER DESCRIPTION (41)	N/A	***
LOSS OF OR DAMAGE TO PACILITY	9301110251 821230	80
	PDR ADDCK 05000387 PDR	80
PUBLICITY DESCRIPTION 45	N/A	NRC USE ONLY
NAME OF PREPARER _	L. A. Kuczynski	HONE (717) 542-2181 ×240