

JAN 07 1983

Docket No. 50-315
Docket No. 50-316

American Electric Power Service Corporation
Indiana and Michigan Electric Company
ATTN: Mr. John E. Dolan
Vice Chairman
Engineering
2 Broadway
New York, NY 10004

Gentlemen:

Our recent inspection of October 20-22, 1982, Inspection Report No's. 50-315/82-18 and 50-316/82-18, determined that brochures containing nuclear plant emergency information as distributed from the Warren Dunes State Park Manager's office did not adequately inform the park's transient population of any emergency situation at the D.C. Cook Nuclear Plant. This is still an open, unresolved item. In addition, the Park Manager has written Region III describing his concerns about the present state of emergency notification to the Warren Dunes State Park. He has also suggested installation of additional sirens plus an additional public address system to be added to one of the existing park vehicles. A copy of his letter is included as an attachment.

NRC Region III believes that this requires prompt resolution. Your representatives should contact the Warren Dunes State Park management and the State of Michigan and work closely with them to coordinate the effort to resolve this problem. An adequate capability must exist to promptly notify the transient population within the Warren Dunes State Park of an emergency condition at the D.C. Cook Nuclear Plant that requires their taking protective actions. These requirements are contained in 10 CFR 50, Appendix E, IV D.

We have written the Federal Emergency Management Agency (FEMA) Region V requesting also, their evaluation of the public warning siren system within the 10 mile Emergency Planning Zone (EPZ) around the D.C. Cook Nuclear Plant and will advise you of their evaluation as soon as it is received.

8301110277 830107
PDR ADOCK 05000315
PDR
Q

DMB
FC 35


JAN 07 1983

Please inform us within 30 days of receipt of this letter what steps you have taken or plan to take to resolve this problem of inadequate notification to the transient population within Warren Dunes State Park.

The responses directed by this letter are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 96-511.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,



J. A. Hind, Director
Division of Emergency Preparedness
and Operational Support

Attachment: As Stated

cc: W. G. Smith, Jr., Plant Manager
DMB/Document Control Desk (RIDS)
Resident Inspector, RIII
Ronald Callen, Michigan
Public Service Commission
EIS Coordinator, USEPA
Region 5 Office

bcc: B. Grimes, DEP/OIE

RIII
JPS
Patterson/jp
12/17/82

RIII
me
Axelson

RIII
me
Papadopoulos

RIII
me
Boyd

RIII
VHK
Lewis
1/6

RIII
me
Hind
1/7/83