

CONTROL BLOCK: [] [] [] [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0] [1] [P] [A] [S] [E] [S] [I] [2] [0] [0] [-] [0] [0] [0] [0] [0] [-] [0] [0] [3] [4] [1] [1] [1] [1] [4] [] [] [5]
7 8 9 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
[0] [1] [R] [E] [P] [O] [R] [T] [S] [O] [U] [R] [C] [E] [L] [6] [0] [5] [0] [0] [0] [3] [8] [7] [7] [1] [1] [2] [7] [8] [2] [8] [1] [2] [2] [8] [8] [2] [9]
7 8 80 DOCKET NUMBER 88 89 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0] [2] | During the Startup Testing Program, while investigating the failure of an
[0] [3] | annunciator to clear, it was determined that 7 instrument valves had
[0] [4] | inadvertently been left closed, isolating the instruments. This is considered
[0] [5] | reportable per T.S. 6.9.1.9.C. These instruments, which measure turbine pressure,
[0] [6] | prevented the EOC/RPT from coming out of bypass and prevented the RSCS from
[0] [7] | going into bypass at the appropriate power levels. The valves were opened,
[0] [8] | returning equipment to operable status.

[0] [9] [I] [F] [11] [D] [12] [Z] [13] [Z] [Z] [Z] [Z] [Z] [Z] [14] [Z] [15] [Z] [16]
7 8 9 10 11 12 13 14 15 16 17 18 19 20
[17] [8] [2] [] [0] [6] [3] [] [0] [3] [L] [] [0]
21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN [X] [18] [G] [19] [Z] [20] [Z] [21] [0] [0] [0] [0] [N] [23] [N] [24] [Z] [25] [Z] [9] [9] [9]
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
LER/RO REPORT NUMBER FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

[1] [0] | These balance-of-plant valves had neither been numbered nor been clearly assigned
[1] [1] | as either Operations or I&C responsibility. Jurisdictional control will be
[1] [2] | established and the appropriate mechanism (check off list and/or procedure) will
[1] [3] | be instituted. A complete review of systems will be performed to identify and
[1] [4] | correct any similarly uncontrolled valves.

[1] [5] [B] [28] [0] [2] [9] [29] [NA] [30] [A] [31] [Operator observation] [32]
7 8 9 9 FACILITY STATUS 10 % POWER 12 OTHER STATUS 13 METHOD OF DISCOVERY 44 45 46 DISCOVERY DESCRIPTION 80

[1] [6] [Z] [33] [Z] [34] [NA] [35] [NA] [36]
7 8 9 9 ACTIVITY CONTENT 10 RELEASER OF RELEASE 11 AMOUNT OF ACTIVITY 44 LOCATION OF RELEASE 80

[1] [7] [0] [0] [0] [37] [Z] [38] [NA] [39]
7 8 9 9 PERSONNEL EXPOSURES 10 NUMBER 11 TYPE 12 DESCRIPTION 44

[1] [8] [0] [0] [0] [40] [NA] [41]
7 8 9 9 PERSONNEL INJURIES 10 NUMBER 11 DESCRIPTION 44

[1] [9] [Z] [42] [NA] [43]
7 8 9 9 LOSS OF OR DAMAGE TO FACILITY 10 TYPE 11 DESCRIPTION 44

[2] [0] [N] [44] [8301110381 821228 PDR ADOCK 05000387 S PDR] [45] [NRC USE ONLY]
7 8 9 9 PUBLICITY ISSUED DESCRIPTION 45

NAME OF PREPARER D. G. Mitchell

PHONE 717-542-2181 Ext. 524