



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 42
License No. DPR-59

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Power Authority of the State of New York (the licensee) dated August 10, 1978, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR- is hereby amended to read as follows:


(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 42, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

7812080170

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 22, 1978

ATTACHMENT TO LICENSE AMENDMENT NO. 42

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

Remove

44
46

Replace

44
46

TABLE 4.1

**REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENT FUNCTIONAL TESTS
MINIMUM FUNCTIONAL TEST FREQUENCIES FOR SAFETY INSTRUMENT AND CONTROL CIRCUITS**

	Group (2)	Functional Test	Minimum Frequency (3)
Mode Switch in Shutdown	A	Place Mode Switch in Shutdown.	Each refueling outage.
Manual Scram	A	Trip Channel and Alarm	Every 3 months.
RPS Channel Test Switch	A	Trip Channel and Alarm	Every refueling outage or after channel maintenance.
IRRI			
High Flux	C	Trip Channel and Alarm (8)	Once per week during refueling or startup and before each startup.
Inoperative	C	Trip Channel and Alarm (8)	Once per week during refueling or startup and before each startup.
APRM			
High Flux	B	Trip Output Relays (8)	Once/week.
Inoperative	B	Trip Output Relays (8)	Once/week.
Downscale	B	Trip Output Relays (8)	Once/week.
Flow Bias	B	Calibrate Flow Bias Signal (8)	Once/month. (1)
High Flux in Startup or Refuel	C	Trip Output Relays (8)	Once per week during refueling or startup and before each startup.
High Reactor Pressure	B	Trip Channel and Alarm (4)	Once/month. (1) (Instrument Check once per day)
High Drywell Pressure	A	Trip Channel and Alarm	Once/month. (1)
Reactor Low Water Level (5)	A	Trip Channel and Alarm	Once/month. (1)
High Water Level in Scram Discharge Tank	A	Trip Channel and Alarm	Every 3 months.
Main Steam Line High Radiation	B	Trip Channel and Alarm (8)	Once/week.
Main Steam Line Isolation Valve Closure	A	Trip Channel and Alarm	Once/month. (1)
Turbine Control Valve EHC Oil Pressure	A	Trip Channel and Alarm	Once/month.
Turbine First Stage Pressure Permissive	A	Trip Channel and Alarm	Every 3 months. (1)
Turbine Stop Valve Closure	A	Trip Channel and Alarm	Once/month. (1)

TABLE 4.1-2

REACTOR PROTECTION SYSTEM (RPS) INSTRUMENT CALIBRATION
 MINIMUM CALIBRATION FREQUENCIES FOR REACTOR PROTECTION INSTRUMENT CHANNELS

Instrument Channel	Group (1)	Calibration (2)	Minimum Frequency (4)
ARM High Flux	C	Comparison to ARM on Controlled Shutdowns	Maximum frequency once/week
ARM High Flux Output Signal	b	Heat balance	Daily
Flow Alarm Signal	B	Internal Power and Flow Test with Standard Pressure Source	Every refueling outage
ARM Signal	B	TR System Traverse	Every 6 weeks
High Reactor Pressure	B	Standard Pressure Source	Once/Operating cycle
High Drywell Pressure	A	Standard Pressure Source	Every 3 months
Reactor Low Water Level	A	Pressure Standard	Every 3 months
High Water Level in Scram Discharge Volume	A	Note (5)	Note (5)
Main Steam Line Isolation Valve Closure	A	Note (5)	Note (5)
Main Steam Line High Radiation	B	Standard Current Source (3)	Every 3 months
Turbine First Stage Pressure Permissive	A	Standard Pressure Source	Every 6 months
Turbine Control Valve Fast Closure Oil Pressure Trip	A	Standard Pressure Source	Once/oper. and cycle
Turbine Stop Valve Closure	A	Note (5)	Note (5)
Reactor Pressure Permissive	A	Standard Pressure Source	Every 6 months

NOTES FOR TABLE 4.1-2

1. A description of three groups is included in the Basis of this Specification.