

ORIGINAL ACRST-1999

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards

Title: Meeting of the Subcommittee on ABP-CE
Standard Plant Designs

Docket No.

LOCATION: Bethesda, Maryland

DATE: Wednesday, March 9, 1994

PAGES: 299 - 543

ACRS Office Copy - Retain
for the Life of the Committee

ANN RILEY & ASSOCIATES, LTD.

1612 K St., N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

9403160007 940309
PDR ACRS
T-1999 PDR

0/11

ORIGINAL

ACRST-1999

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards

Title: Meeting of the Subcommittee on ABB-CE
Standard Plant Designs

Docket No.

LOCATION: Bethesda, Maryland

DATE: Wednesday, March 9, 1994

PAGES: 299 - 543

ACRS Office Copy - Retain
for the Life of the Committee

ANN RILEY & ASSOCIATES, LTD.

1612 K St., N.W., Suite 300

Washington, D.C. 20006

(202) 293-3950

0/1

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DATE: March 9, 1994

The contents of this transcript of the proceedings of the United States Nuclear Regulatory Commission's Advisory Committee on Reactor Safeguards, (date) March 9, 1994, as Reported herein, are a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected or edited, and it may contain inaccuracies.

150080

ANN RILEY & ASSOCIATES, Ltd.
Court Reporters
1612 K. Street, N.W., Suite 300
Washington, D. C. 20006
(202) 293-3950

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 ***

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5
6 Meeting of the Subcommittee on
7 ABB-CE Standard Plant Designs

8
9 U.S. Nuclear Regulatory Commission
10 7920 Norfolk Avenue
11 Conference Room P-110
12 Bethesda, Maryland

13
14 Wednesday, March 9, 1994

15
16 The above-entitled proceedings commenced at 8:30
17 a.m., pursuant to notice, Jay Carroll, chairman of the
18 subcommittee, presiding.

19
20 PRESENT FOR THE ACRS SUBCOMMITTEE:

21 J. Carroll	P. Davis
22 T. Kress	W. Lindblad
23 C. Michelson	R. Seale
24 W. Shack	E. Wilkins
25 C. Wylie	D. Coe

ANN RILEY & ASSOCIATES, LTD.
Court Reporters
1612 K Street, N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

1 PARTICIPANTS:

2 On Behalf of ABB-CE

3	S. Ritterbusch	T. Crom
4	D. Finnicum	C. Brinkman
5	S. Stamm	E. Siegmann
6	L. Gerdes	J. Trotter
7	F. Carpentino	M. Cross
8	R. Schneider	J. Longo
9	T. Oswald	

10 On Behalf of NRC/NRR

11	M. Franovich	R. Li
12	D. Terao	J. Guo
13	B. Palla	R. Architzel
14	J. Lyons	N. Saltos
15	A. El-Bassioni	

16

17

18

19

20

21

22

23

24

25

P R O C E E D I N G S

[8:30 a.m.]

1
2
3 MR. CARROLL: Let's reconvene our subcommittee on
4 ABB-CE standard plant design. The plan today is to begin by
5 picking up the remaining sections of Chapters 2 and 3 that
6 we didn't get to yesterday and then Pete, we're going to
7 talk about PRA. We're the same cast of characters as
8 yesterday except Ivan, of course, is not here and we are
9 joined by Bill Shack.

10 MR. MICHELSON: Good trade.

11 MR. CARROLL: Good trade; yeah. So -- you're
12 going to make the presentation; you're on.

13 MR. CROM: Okay. I'm Tom Crom from Duke
14 Engineering and Services. I am currently the engineering
15 manager for the System 80+ project from Duke Engineering and
16 Services. I have been with Duke Power since 1976 when I
17 started on the design at Catawba Nuclear Station, and stayed
18 on Catawba Nuclear Station until about 1985 when I started
19 on this particular project, and I've been on this project
20 since 1985.

21 This morning I want to start with inservice
22 testing of pumps and valves, then get into flood protection
23 and then, finally, talk about high energy line breaks. And
24 my discussion on high energy line breaks is pretty much
25 going to be where the lines are located, particularly

1 outside a containment, so that we can talk about any
2 interaction that may be with high energy line breaks.

3 As far as what I'm going to talk about on
4 inservice testing, safety-related pumps and valves, I'm
5 going to tell you basically, generally what we did in the
6 program in CESSAR-DC. We have a very extensive table that
7 has all pumps and valves that are in the standard plant,
8 safety-related pumps and valves listed along with the test
9 requirements. I'm going to talk about what we have in that
10 table, the provisions we have for testing pumps and valves,
11 and finally I'm going to go over the numerous COL
12 applicants, because there are a lot of COL applicant-type
13 items that are in this particular chapter.

14 [Slide.]

15 MR. CROM: My first slide here -- and the reason I
16 have it is we spent a lot of time with the staff going over,
17 particularly in valves, what the safety function is. We
18 went through almost every valve that we have on our PNIDs
19 and determined what the safety function was, determined what
20 the design bases were, to first determine if it belonged in
21 the IST program.

22 For example, there are some valves and stuff that
23 are in the CVCS system that are considered in the safety
24 class pressure boundary but have no safety function. And
25 those particular valves are not included in the program and

1 at the same time, there are some valves that may not have a
2 pressure or may not have a leak-type requirement for their
3 safety function but may have a stroke requirement. And we
4 went through the definition of safety-related in each one of
5 these cases, in determining whether the valve belonged in
6 the program or what its safety function and what test did it
7 need to have.

8 The major portion of what we did is in table 3.9-
9 15 where list every safety-related pump and valve in the
10 standard design. We developed this plan utilizing the
11 ASME/ANSI OMa-1988 for Part 1 for Relief Valves, Part 6 for
12 Pumps, and Part 10 for Valves other than relief valves.

13 Of course, also in there, as far as leak rate
14 testing and test requirements also 10 CFR 50 Appendix J,
15 testing for containment isolation valves is also included
16 when we were developing the plan.

17 The types of headings we have in this table, for
18 pumps we have -- for each pump we give the pump name, the
19 ASME safety class, whether safety class 1, 2, or 3, the test
20 parameter that is required to be done, listing those there,
21 differential pressure, static suction pressure, operating
22 suction pressure, flow and speed for a pump, the test
23 frequency, whether it needs to be done quarterly at cold
24 shutdown or refueling. For pumps, we were able to do
25 quarterly testing. We've reviewed all our pumps and we're

1 doing quarterly testing on all pumps.

2 We also provide in that table the test
3 configuration for various test connections and stuff to
4 ensure that the design is such that we can do these tests,
5 and also list where the pump is located on the figure number
6 within CESSAR-DC so it can be found.

7 As far as valves --

8 MR. CARROLL: Do I remember wrong? I thought
9 vibration was also on that list.

10 MR. CROM: Yes, it is. It is. I believe it's --
11 I'm trying to remember if that's included on the table or
12 whether it's just discussed in the SAR. The vibration is
13 included as part of the inservice testing.

14 As far as valves, we list each valve number, valve
15 name, valve type, whether it's a globe, gate, check valve,
16 whether -- what type of actuator, whether it has an
17 actuator, whether it's an EMO, whether it's an air-operated
18 valve, hydraulic and so forth. Of course, the ASME safety
19 class whether it's safety class 1, 2, or 3. The ASME code
20 category, either A, B, C, D; A being that it's late-type
21 requirements, either a pressure isolation valve, containment
22 isolation valve, or a temperature isolation valve; B that it
23 requires a stroke test; C that it's a check valve; and D is
24 an explosive valve, which we have no explosive valves in the
25 plant. There is no D category of valves. And of course

1 there can be a combination of these, depending on what the
2 actual valve function is.

3 We also list the valves that are -- function if
4 they are pressure isolation valves -- in particular we're
5 talking about the RCS pressure isolation valve -- a
6 temperature isolation valve, which is a new requirement the
7 staff asked us to add, with some of the problems of valves
8 where there is a high temperature on one side actually
9 leaking into a system and causing system problems and heat
10 up. We listed those in the appropriate test to ensure that
11 we don't have leakage or are able to detect leakage, and of
12 course the containment isolation valves are listed.

13 We also put the required testing -- you know,
14 whether it requires a stroke test, a leak test, whether it
15 requires valve position verification, reverse flow stroke
16 time, failure position, whether they can do a failure
17 position if it has an air operated valve that fails to open
18 or close or whether it requires a bench test if it's a
19 relief valve.

20 We also have the test frequency which is either
21 quarterly, refueling or cold shutdown and one thing I'm
22 going to talk about a little bit later, the number of valves
23 that we have to test either at refueling or cold shutdown,
24 the number has reduced significantly compared to current
25 plans.

1 MR. DAVIS: Excuse me; is the valves in your
2 reactor cavity flooding system -- are they considered
3 safety-related?

4 MR. CROM: Yes.

5 MR. DAVIS: And what's the testing frequency of
6 those?

7 MR. CROM: I don't recall right offhand, but we
8 can look -- I can look up in the table what it is. Sandy,
9 you know --

10 MR. RITTERBUSCH: Yeah; at refueling outages.

11 MR. DAVIS: You can't test them during operation,
12 I guess, can you?

13 MR. CROM: Yes -- I should -- yeah; the reason for
14 that now, I recall, is you have to go inside down into the
15 hold up volume and you have to shut a manual valve before
16 you can do the stroke test or else you'll be flooding into
17 the hold up volume.

18 MR. LINDBLAD: Mr. Crom, are there requirements to
19 test after maintenance is done?

20 MR. CROM: Yes. There is.

21 MR. LINDBLAD: And does that apply across the
22 board or just on certain valves?

23 MR. CROM: That's across the board.

24 MR. MICHELSON: Now in case of -- a few of the
25 valves, the steam-driven auxiliary feedwater for instance -

1 -

2 MR. CROM: Yes.

3 MR. MICHELSON: -- you have the possibility that
4 if you are experience that type rupture you have to isolate
5 under blowdown conditions. How do you differentiate that
6 from your full differential to open or full differential at
7 closure?

8 MR. CROM: That is --

9 MR. MICHELSON: There is a difference.

10 MR. CROM: Yes. And we got a COL action item.
11 That's one that I have listed, that the COL applicant has to
12 determine the design bases conditions, specify what those
13 differential pressures are. He then has to do a type test
14 on the valves in the shop and do then a --

15 MR. MICHELSON: Where is -- is that in the staff's
16 SER, then?

17 MR. CROM: I don't know whether it's in the staff
18 -- it is in our --

19 MR. MICHELSON: It is in here somewhere?

20 MR. CROM: In our SER.

21 MR. MICHELSON: Maybe if you find the reference
22 I'll read it.

23 MR. CROM: I've got it on my slide. It is in 3.9-
24 6. There's a whole series on -- for pumps, valves --

25 MR. MICHELSON: I did find the blowdown tests in

1 that discussion, though, but maybe I'm --

2 MR. CROM: It asks for a different -- it states
3 the differential pressure, the differential pressure that
4 has to close down.

5 MR. MICHELSON: But that doesn't do it, as you
6 probably well know from the valve testing that was done
7 there. The difference between opening under static, even
8 though it's full differential conditions, and opening under
9 dynamic conditions because of the differences in hydraulics
10 around the disk as it's rising and so forth. The fact is on
11 some tests it took a larger torque after the valve was
12 cracked open, even, than during the full closure portion of
13 the cycle.

14 MR. CROM: Yeah.

15 MR. MICHELSON: So you have to do that type of
16 test, and I couldn't find on the table how you identify it.
17 There are only a handful of valves that need that, but
18 alternatively you could make it a COL action. I don't know
19 -- but you'd probably know today which valves they'd have to
20 be. Obviously auxiliary feedwater is one of them.

21 MR. DAVIS: Emergency.

22 MR. MICHELSON: Pardon me; emergency feedwater in
23 this case.

24 MR. CROM: It's considered under the design basis
25 and the COL applicant would determine the design basis.

1 MR. MICHELSON: Yeah, you can pass the buck on if
2 you wish, although you shouldn't have to because you already
3 know today, in most cases, which valves they are.

4 MR. CARROLL: You are saying you know which valves
5 they are --

6 MR. MICHELSON: Yeah.

7 MR. CROM: That's correct.

8 MR. CARROLL: -- that the testing would be
9 specific to the valve manufacturer.

10 MR. MICHELSON: Yeah; I don't mind that part. At
11 least I thought, though, in this testing table I would have
12 seen identified with a footnote or an asterisk or something
13 that that particular valve will have to have more than just
14 a normal breakopen --

15 MS. LI: This is Renee Li from Mechanical
16 Engineering. The table 3.9-15, the intent is only to
17 address the inservice testing and in the SAR. That's
18 section 3.9 --

19 MR. MICHELSON: That is my point; it's inservice
20 testing. Even for inservice testing now, you obviously
21 can't break the pipe and do the test.

22 MS. LI: Right.

23 MR. MICHELSON: But you have to look at the test
24 results during inservice testing differently than you do for
25 a valve that doesn't have to open or isolate under blowdown

1 conditions. And you somehow should flag in the table that
2 this particular valve has got some unique requirements and
3 you've got to go back to look at the prototypical test that
4 was done back at the laboratory and then try to relate that
5 to the test result you're getting to verify it will still
6 work.

7 MS. LI: I agree with that. I am trying to point
8 out that in the SAR, under the design and the qualification
9 for pumps, MOV check valve, POV, they have detailed
10 description of how a valve or a pump should be qualified.
11 And in there, the manufacturer will perform ranges of
12 different differential pressure and those --

13 MR. MICHELSON: That's the one that I was trying
14 to find. Maybe you could tell me what section to read.

15 MS. LI: Okay.

16 MR. MICHELSON: I've probably just had too much to
17 read.

18 MS. LI: For pumps --

19 MR. CARROLL: No; valves.

20 MR. MICHELSON: No, let's just do valves.

21 MS. LI: Okay; for valves --

22 MR. CROM: It's in several sections. There's one
23 --

24 MS. LI: The format is MOV, check valve, POV. So
25 if you look at --

1 MR. MICHELSON: Well, let's just do the MOV just
2 as an example.

3 MS. LI: Okay. MOV, 3.9-6.2.1.1.

4 MR. MICHELSON: 9-6.2.1.1; okay. Okay. I'll read
5 that and see if that does what I need.

6 MS. LI: Okay. And then there will be similar
7 sections for check valves and other types.

8 MR. MICHELSON: Yeah; right. But this problem is
9 kind of unique to the isolation --

10 MR. CROM: Yeah; okay.

11 MR. MICHELSON: Thank you.

12 MR. CROM: Going on, we also list the -- give the
13 test configuration. Again, all this to ensure that the
14 valves are testable, we can do the test, and also the
15 CESSAR-DC figure the valve is located on.

16 I will note here that through our program and plan
17 that we had -- took no exemptions to the code. We went
18 through -- and that was one of the main reasons to do it,
19 ensure the design did not require any exemptions to the
20 code.

21 Some of the design provisions we include in the
22 design to aid in IST, we include full flow testing for all
23 safety-related pumps, that they can be tested quarterly; we
24 have the capability to measure NPSH throughout the pump
25 operating range. When I talk about redundance and

1 separation of systems, a lot of current plants may have a
2 common test line, recirc line or something, that the way the
3 configuration of the system is, they can't test it quarterly
4 because they put both divisions out simultaneously. We do
5 not have any situations like that in this plant so that we
6 are able to not take any exemptions on testing pumps, that
7 we can't test them all quarterly.

8 MR. MICHELSON: That is under full flow condition?

9 MR. CROM: That's --

10 MR. MICHELSON: Or design flow condition.

11 MR. CROM: That's correct. We have full flow
12 conditions -- have the capability of testing all pumps at
13 full flow; all safety-related pumps.

14 As far as testing safety-related valves, again, we
15 have ensured that we do not have to take any exemptions to
16 the code and we have the capability to test all valves. We
17 also, again, are able to test a large majority of valves
18 quarterly because of our redundancy in separation and the
19 system design, such that we do not have to test as many
20 valves as current plants at cold shutdown and refueling.
21 And there still is valves -- I mean, you can't test your RCS
22 pressure isolation valves quarterly, and there isn't a way
23 that you're going to be able to design that to do that.

24 MR. CARROLL: What progress is being made to
25 update the inservice testing of valves by ASME to reflect

1 89-10 kind of considerations?

2 MR. CROM: I'm not sure I can answer that. Todd,
3 do you know the answer to that?

4 [No response]

5 MR. CARROLL: All right.

6 MR. CROM: I'm now going to go through the various
7 COL applicant items that we do have in CESSAR-DC. First of
8 all, the actual IST -- full IST program is a COL action
9 item. We have provided to him considerably the starting
10 point, what he needs, and the table, based on the frequency
11 and the type of test that had to be done for all safety-
12 related valves and pumps. But he still has to develop, you
13 know, his test procedures, his test schedules. Of course,
14 the test frequencies are pretty well already set for him
15 from what we have done in CESSAR-DC and also has to
16 determine his baseline preservice test program, which we're
17 going to talk a little bit more on some of the other COL
18 action items.

19 This first one is for pumps and this is pretty
20 much, Mr. Michelson, what you were talking about on valves
21 if the COL applicant establishes the baseline pump design
22 qualification. Basically all the flow head NPSH
23 requirements, speed, vibration, that the manufacturer has to
24 qualify the particular pump to, and also then is required to
25 have the manufacturer do the type test on each size, type

1 and model of pump.

2 The COL applicant also has to ensure that the
3 pumps specified is not susceptible to minimum flow or
4 inadequate thrust bearing capacity, ensuring pretty much the
5 min-flow problems we've seen on some of the pumps. He has
6 to ensure that the pump that's actually procured does not
7 have a problem with min-flow, that we have adequate
8 recirculation flow.

9 COL applicant has to develop the pump -- this
10 assembly program for all safety-related pumps based on the
11 historical pump performance, the pump components performance
12 in non-intrusive test results. That is a new item that was
13 in the SECY letters, looking at pump dis-assembly. And that
14 is something that the COL applicant will have to do based on
15 his performance.

16 COL applicant items that we have for MOVs and POVs
17 -- Mr. Michelson, this is the one that I think you were
18 looking for, that the COL applicant establishes, again, the
19 baseline valve design qualification testing, determine the
20 fluid flow, the differential pressure, including pipe break,
21 system pressure, fluid temperature, ambient temperature,
22 minimum voltage/pneumatic or hydraulic pressure and minimum
23 and maximum stroke time requirements. He also would have
24 the action to ensure the manufacturer does the appropriate
25 type test for each size, type, and manufacture, and he also

1 will have to then relate that to his pre-operational testing
2 and what he has to do on each of the MOVs and POVs.

3 MR. MICHELSON: Is it clear to you from the SAR
4 that the COL holder will have to look at even low energy
5 lines from the viewpoint of the ability of valves to
6 isolate? Because low energy lines have valves that, if you
7 should rupture the pipe, it's a much smaller rupture
8 situation of course, but they still have to operate under
9 those conditions. And depending on the valve and the size
10 of the operator, it may or may not. Generally, it's not a
11 problem, but it's been found to be a problem already when
12 people start looking closely.

13 MR. CROM: We have another -- when we get to
14 flood, we have another COL applicant item, you know, that
15 basically, when it comes to moderate energy line breaks or
16 even with high energy line breaks, since we're not fixing
17 the pipe routing, you know, for the certification stage,
18 that the COL applicant has to ensure, you know, from a flood
19 standpoint or an interaction standpoint, that he can isolate
20 those portions of the system that need to be.

21 MR. MICHELSON: When looking at the possible break
22 sizes, of course traditionally we look at the pipes which at
23 low energy end aren't really too much of a problem.
24 However, you have to look at heat exchanges where you can
25 have a serious problem because two ruptures can be far

1 bigger leaks sometimes than a critical crack.

2 MR. CROM: One other thing I want to demonstr --
3 was going to show, I think, in my flood presentation, is
4 there may not be a need to isolate.

5 MR. MICHELSON: Yeah; if you can also show --
6 yeah. It all depends upon whether there's a need or not.

7 MR. CROM: Yes.

8 MR. MICHELSON: Clearly; yes. And the COL holder
9 is going to do that. Now, somewhere there is a prescription
10 that says he's going to do that.

11 MR. CROM: Yes. That's in the flood section.

12 MR. MICHELSON: And that's in the flood section.

13 MR. CROM: Yes.

14 MR. MICHELSON: That's in Chapter 9 or --

15 MR. CROM: That's in Chapter 3.

16 MR. MICHELSON: Chapter 3.

17 MR. CROM: Chapter 3, Section 3.4.

18 MR. MICHELSON: 3.4; okay. That's the one I read.

19 Thank you.

20 MR. CROM: Continuing with MOVs and POVs, the COL
21 applicant ensures that the MOV specified for each applicant
22 is not susceptible to pressure locking and thermal binding,
23 and the COL applicant will --

24 MR. CARROLL: That's easy to say. How does he do
25 that?

1 MR. CROM: That would have to be done during the
2 type test by the manufacturer and the layouts of the piping.
3 You have to ensure that they were not -- based on past
4 problems, ensure that it doesn't have that type of problem.

5 MR. MICHELSON: There was a day that people when
6 people that understood this problem, that was 30 years ago,
7 had bonnet leakoffs. Is the bonnet leakoff still there and
8 they don't use it, or are they now going back and using it?
9 You used to have a little --

10 MR. CROM: Right.

11 MR. MICHELSON: -- on the bonnet, leakoff the
12 pressure to whichever side you wanted it to leak to.

13 MR. CROM: Uh-huh.

14 MR. MICHELSON: But those things people got tired
15 of and they just kind of capped them off and I suspect the
16 manufacturers might even be leaving them off now.

17 MR. CROM: Yeah; most of them are.

18 MR. MICHELSON: Yeah. But that's what solved that
19 problem when they knew about it. It took 30 years to
20 rediscover it.

21 MR. CROM: Okay. Finally we have a COL applicant
22 who will periodically test the MOVs per Generic Letter 89-
23 10 paragraphs D and J and POVs to demonstrate continuing
24 capability for design basic conditions.

25 MR. MICHELSON: When you say the 89-10, are you

1 talking about the latest supplements as well? Does that
2 kind of go without saying, or --

3 MR. CROM: Yes.

4 MR. MICHELSON: Because there have been
5 supplements all the way up until very recently.

6 MR. CROM: That's correct.

7 MR. MICHELSON: Supplement 6 I guess is the last
8 one out right now.

9 MR. CARROLL: Which struck me as a very
10 prescriptive supplement.

11 MR. MICHELSON: Well, you've got to -- eventually
12 you get prescriptive because that's one way people finally
13 understand the message. I think the industry generally
14 agreed with it. It was just -- so everybody agreed, they
15 made it more prescriptive.

16 MR. CROM: Okay. For check valves, we have a COL
17 app can establish again the baseline design qualification
18 testing. Basically here he has to establish the required
19 operating cycles to be experienced by the valve, numbers of
20 operating cycles, duration; the severe transient loadings,
21 again, pipe break and waterhammer; sealing and leakage
22 requirements; operating medium temperature and gradients,
23 and vibratory loadings. Those types of things. And then
24 also ensure that the type test is done with the valve.

25 MR. CARROLL: What's the significance of vibratory

1 loadings? What does that mean?

2 MR. CROM: I think basically vibratory loadings on
3 the pump discharge.

4 MR. CARROLL: We're talking check valves.

5 MR. CROM: Check valves.

6 MR. MICHELSON: It's a flooder.

7 MR. CROM: Yeah.

8 MR. CARROLL: Okay.

9 MR. MICHELSON: One of the problems on high energy
10 lines is if you break a line upstream of a check valve it
11 experiences a sudden and violent reversal of flow. Is there
12 any requirement that the designer now verify that what he
13 bought will stay in place and act as an isolation valve when
14 you experience this sudden violent reversal of flow?

15 MR. CROM: One is in the IST program on check
16 valves. You have to do a reverse flood test.

17 MR. MICHELSON: It won't tell you, I don't think -
18 - no. But you don't do it under break conditions.

19 MR. CROM: Right.

20 MR. MICHELSON: You just do it --

21 MR. CROM: That would only be done --

22 MR. MICHELSON: That's not a laboratory testing of
23 these under break conditions, that I'm aware of, at least.

24 MR. CARROLL: That looks like the second bulletin.

25 MR. CROM: But that would be the type test. That

1 would have to be done in the shop, but then you would do a
2 reverse flow test.

3 MR. MICHELSON: Is there a reverse flow test
4 required for check valves under break conditions?

5 MR. CROM: No. There would be a -- if the check
6 valve is required to withstand a break condition, there
7 would have to be a type test done in the shop.

8 MR. MICHELSON: Is that said somewhere in Chapter
9 3?

10 MR. CROM: Yes. That would be under --

11 MR. CARROLL: Isn't that under the second bullet?

12 MR. CROM: That's the --

13 MR. MICHELSON: Well, no, I don't think -- it
14 depends on how you interpret -- do they have in mind on pipe
15 break the fact that if you've got a high energy pipe and you
16 break upstream of the check valve, there's a sudden violent
17 reversal flow. All you've got to do is stress analysis or a
18 test.

19 MR. CROM: Todd, you want to handle this?

20 MR. OSWALD: This is Todd Oswald, Duke
21 Engineering. In Section 3.9-6.2.3.1 there is a statement
22 about the type testing. These design conditions include all
23 required operating systems experience, environmental
24 conditions, several transient loadings expected during the
25 life of the valve such as waterhammer or pipe break.

1 MR. MICHELSON: But people don't normally think
2 about that check valve under this reverse flow dynamics and
3 -- but I guess we can interpret it to be included there,
4 even though not said. You should have just said flow
5 reversal, and everybody could pick up on it right away then.

6 MR. CARROLL: I think pipe break is the clue
7 there.

8 MR. CROM: Yeah.

9 MR. CARROLL: I think pipe break --

10 MR. CROM: The only way the check valve can hold
11 is on a reverse flow.

12 MR. MICHELSON: Yeah; that's right. Well, no.
13 Check valves also experience violent operating conditions
14 even in the forward direction --

15 MR. CROM: Oh, I agree.

16 MR. MICHELSON: -- and you have the blowdown flow
17 through them and you don't want to tear them up then,
18 either, because -- depending on what their subsequent
19 function might have to be. But the reverse flow would be a
20 nice word to throw in there to make sure there's no
21 misunderstanding. But we'll assume it's understood.

22 MR. CROM: Okay.

23 MR. MICHELSON: 3.9-6 you said?

24 MR. CROM: Todd, can you just repeat that section?

25 MR. OSWALD: That's 3.9-6.2.3.1.

1 MR. MICHELSON: 2.3.1; thank you.

2 MR. CROM: We also have a COL applicant ensures
3 that check valve application is the proper size, type,
4 location, operation, as recommended by the manufacturer,
5 since there has been a series of problems with check valves
6 that are in the wrong orientation as recommended by the
7 manufacturer. We have a COL applicant item to ensure that
8 they are installed and the proper check valve for that
9 particular applicant.

10 MR. MICHELSON: Is there a requirement to put the
11 marker on the valve body yet?

12 MR. CROM: We do not state that in the SAR.

13 MR. MICHELSON: So that's the only -- that's one
14 good way -- fairly good way, at least, of checking.

15 MR. CROM: Yes.

16 MR. MICHELSON: Not all valve bodies have the
17 arrows on them.

18 MR. LINDBLAD: Or steam traps.

19 MR. MICHELSON: Yeah.

20 MR. CROM: We also have a COL applicant ensures
21 the capability of nonintrusive testing, measurable flow
22 through check valve. Again, this is in addition to the
23 code, to the SECY letters that would be able to do
24 nonintrusive testing.

25 MR. CARROLL: You are saying every safety-related

1 check valve --

2 MR. CROM: No. Not every one. The ones that the
3 COL applicant puts in his program as being critical.

4 MR. CARROLL: Okay. I wouldn't infer that from
5 what you have on the slide.

6 MR. CROM: I believe the SAR has further
7 explanation.

8 MR. DAVIS: There was an incident one time where
9 an applicant or a plant operator was testing the two-train
10 containment spray system and discovered that one of the
11 check valves had been installed backwards.

12 MR. CROM: Uh-huh.

13 MR. DAVIS: They were using compressed air, which
14 is the typical way to do it.

15 MR. CROM: Right.

16 MR. DAVIS: So they sent a crew down to turn the
17 valve around, and they turned the wrong valve around. And
18 so they ended up with no operable system.

19 MR. CROM: Yeah.

20 MR. DAVIS: And I frequently use this as an
21 example where redundancy really hurt, because if they'd only
22 had one system, they would have got the right valve.

23 MR. CROM: Right.

24 MR. DAVIS: But the point is that there were no
25 arrows on these valves either, so this was a mistake that

1 was made because they couldn't tell.

2 MR. CROM: Uh-huh.

3 MR. DAVIS: And it seems to me like this
4 illustrates the fact that it would sure be advantageous to
5 indicate on the valve which way the flow is going. I
6 personally would like to see that kind of requirement. It
7 would prevent this kind of a problem.

8 MR. CROM: Todd?

9 MR. OSWALD: This is Todd Oswald, Duke Engineering
10 Services. Just one comment; when you're down there looking
11 at the pipe, you've got to know which direction the flow is
12 coming from. I mean, even if you have an arrow on the valve
13 -- I mean, there's no question about it -- it's a good idea
14 to have that. But you've also got to realize where your
15 flow is coming from and going to when you're down there.

16 MR. DAVIS: We'll put an arrow on the pipe, too.

17 MR. OSWALD: Okay.

18 MR. CROM: By the way, Todd, even though he is our
19 structural expert, he's done inservice testing at McGuire
20 for several years and he's got a lot of good answers on that
21 too.

22 MR. CARROLL: The other thing that needs arrows
23 are flow leveling orifices.

24 MR. CROM: Yes.

25 MR. CARROLL: That has bit people more than once.

1 MR. CROM: I understand.

2 MR. CARROLL: Me too. I've been bit.

3 MR. CROM: And finally, for valves, we have a COL
4 applicant that he develop the disassembly program for all
5 safety-related valves, again based on the historical valve
6 performance, the valve components' performance, and non-
7 intrusive test results. That is everything I have, unless
8 there's any further questions.

9 MR. LINDBLAD: I have a question or two.

10 MR. CROM: Sure.

11 MR. LINDBLAD: Mr. Crom, does the program require
12 that the inservice testing be done before the mechanic
13 touches the valve?

14 MR. CROM: No; I don't believe it does.

15 MR. LINDBLAD: So there isn't a requirement that
16 as-found conditions be used?

17 MR. OSWALD: Can I address that? This is Todd
18 Oswald, Duke Engineering Services. You have to get your as-
19 found condition particularly on Appendix J-type valves.
20 There is a requirement to have the as-found leakage. I
21 don't think that we have specifically required the -- such
22 as MOV that's not an Appendix J valve.

23 MR. LINDBLAD: Yeah. But there is a natural
24 competition between the engineer wanting functionality of
25 the pump and the valve to have a loose gland and the

1 housekeeper who goes around and tightens up the glands.

2 MR. OSWALD: Uh-huh.

3 MR. LINDBLAD: How is that prevented in the IST
4 program?

5 MR. CROM: I'm not sure I've got an answer. Do
6 you know, Todd?

7 MR. OSWALD: I'm not sure I understand the
8 question exactly. You mentioned -- you're talking about
9 someone just arbitrarily going out and touching the valve?

10 MR. LINDBLAD: No. I guess I'm talking about -- I
11 didn't see in the program that there is a requirement to --
12 in the touch program to be satisfied, that the gland does
13 not leak under service conditions. The stem packing of
14 either the pump or the valve. And so if you want to be sure
15 you pass the test, you have a loose packing to get the valve
16 stroking at the best time, and yet you don't want puddles on
17 the floor, and so you want the tight packing then. But --

18 MR. OSWALD: I think that would be more
19 appropriately addressed in the maintenance program on your
20 valves. When you have your work request or whatever
21 maintenance program you use, you have that valve identified
22 and you don't do your inservice testing on it until after
23 all the maintenance is done. Your QA and inservice testing
24 is one of the last steps in your maintenance program.

25 MR. LINDBLAD: Yes. That's what I've seen, too.

1 But then --

2 MR. CARROLL: And then the mechanic comes back --

3 MR. LINDBLAD: -- comes in to service --

4 MR. CARROLL: -- takes another half turn on the
5 packing valve.

6 MR. OSWALD: Well, he's wrong.

7 MR. CARROLL: But he is real.

8 MR. LINDBLAD: Yes.

9 MR. CARROLL: The rule is that anytime you do
10 maintenance, you've got to repeat the testing, Bill I'm
11 not sure that always happens in practice, but that's what
12 you're supposed to do. And a classic example is packing.

13 MR. LINDBLAD: Yeah.

14 MR. MICHELSON: The biggest problem is, though,
15 these valves just aren't that reproducible either. You can
16 cycle them a few times, they'll work one way, if you leave
17 them set for 30 days, they'll work quite differently.
18 There's a range of uncertainty there that kind of
19 overshadows much of this. It just -- I think you just have
20 to put a lot of conservatism into the selection and
21 adjustment of the valves and hope for the best, because you
22 won't get it by precision.

23 MR. OSWALD: This is Todd Oswald, again; Duke
24 Engineering. I guess that's why we have the quarterly
25 testing, is to catch that.

1 MR. LINDBLAD: I was just writing a note to Mr.
2 Coe a minute ago that he distributed an operation occurrence
3 where a steam generator recently went dry because the MSIB
4 had been adjusted cold when -- and tested cold, when it
5 should have been adjusted hot and tested hot.

6 MR. DAVIS: This was McGuire?

7 MR. LINDBLAD: Yeah.

8 MR. CROM: I'm quite familiar with that one.

9 MR. LINDBLAD: These are the same people.

10 MR. MICHELSON: But it also makes a difference in
11 how many cycles and what your history is just before you do
12 your final calibration test on a motor operated valve, too.

13 MR. CROM: But again, that is the type of thing
14 that, you know -- for example, the McGuire instance, it's
15 not something that we can specify in the SAR now because
16 that's a manufacturer's recommendation and it depends on
17 what the manufacturer tells you, whether it should be done
18 cold or whether it should be done high. And that would have
19 to be put in the COL applicant procedures for adjusting that
20 particular valve. McGuire was testing it inappropriately.
21 The manufacturer said it should be tested hot and they were
22 testing it cold, and it did not shut under hot conditions.

23 MR. MICHELSON: If you did all your testing like
24 the manufacturers say you'd be in deep trouble, too, as
25 we've found out.

1 MR. CROM: I agree.

2 MR. MICHELSON: So ultimately the owner has to
3 understand what he's doing and do it right.

4 MR. DAVIS: How many valves are covered by this
5 program?

6 MR. CROM: I don't know if I've done a count,
7 even. It's about -- that table is about that thick and the
8 first page is pumps and the rest is valves. I don't know if
9 I've ever done a count.

10 MR. CARROLL: Carl's got the table if you want to
11 count, Pete.

12 MR. MICHELSON: It's a long table. Would you like
13 to look at it?

14 MR. DAVIS: I'm not sure I can count that far.

15 MR. CARROLL: You can count the number on a page
16 and multiply by the number of pages.

17 MR. MICHELSON: The critical valves are fairly
18 small in number, probably of the order -- less than a
19 hundred, perhaps, depending on --

20 MR. CROM: Yes.

21 MR. DAVIS: Can one crew do all of the valves
22 quarterly?

23 MR. CROM: Todd, can you answer that since you --

24 MR. OSWALD: Yes. Those shouldn't be any problem.
25 Well, when you say one crew, you have a test group normally

1 that does it, which consists of probably about 10
2 technicians or so, and a staff of engineers.

3 One other thing; quick glancing, looks like
4 there's about 80 pages and I counted one page had about 10
5 valves -- of course one page has more than that. So it
6 looks like it would be in the neighborhood of 700, 800
7 valves in the program.

8 MR. MICHELSON: But not all of those gets this
9 awfully detailed kind of examination.

10 MR. CROM: Yes. Some of them are just basic.

11 MR. MICHELSON: Most of them are just push the
12 button and watch it go up and down.

13 MR. CROM: Yes. Some are just the stroke test and
14 some are just checking it's in the proper position.

15 MR. MICHELSON: Yes. But a few of them are very
16 critical.

17 MR. CROM: Okay. Are you ready for me to go on to
18 flood?

19 MR. CARROLL: Are you ready?

20 [Slide.]

21 MR. CROM: Yeah; I'm ready. The first G slides
22 that I have in the package we really covered yesterday.
23 Lyle Girdes covered pretty much on external flood. So I'm
24 going to skip over those and go right into our internal
25 flood slides.

1 MR. MICHELSON: Before you do that, I had a couple
2 of questions. I never manage to get back with the people to
3 show me where these tunnels are. You've got a big tunnel
4 going from the point of cooling water building over to the
5 nuclear island, and you probably have other tunnels.

6 MR. CROM: Todd's going to pull out the --

7 MR. MICHELSON: Including the intake structure.
8 There's -- the RSW has, someday, a tunnel going from there
9 over to the nuclear island. Couldn't find much detail on
10 these, but these are all potentially worrisome sources of
11 water, particularly in the case of the component cooling
12 water or the -- in the case of the service water; you don't
13 want to have a pipebreak start draining the pond back into
14 the --

15 MR. CROM: Well, we're going to cover that --

16 MR. MICHELSON: You're going to cover that now?

17 Okay --

18 MR. CROM: -- and that's going to be a non-problem
19 for this plant.

20 MR. MICHELSON: Okay, now -- but on the site
21 floods, it's the same problem again. You've got to keep the
22 water out of all these buildings and all these tunnels,
23 unless you provide some other means of keeping them from
24 getting burst.

25 MR. CROM: That's correct.

1 MR. MICHELSON: And get you in trouble.

2 MR. CROM: Steve, do you want to --

3 MR. STAMM: Yes. This is Steve Stamm, Stone
4 Webster. As far as component cooling water type tunnel, the
5 elevations are showing that the connections of the tunnel on
6 the building drawings for the nuclear annex and the
7 component cooling water --

8 MR. MICHELSON: For which one? Which one?

9 MR. STAMM: The figures are Figure 1.2-2 shows the
10 connection to the annex, at plus one feet for the top of the
11 tunnel.

12 MR. MICHELSON: Okay.

13 MR. STAMM: Figure 1.2-25 shows the connection to
14 the component cooling water building at 3.5 feet below grade
15 for the top of the tunnel.

16 MR. MICHELSON: What was the elevation then in the
17 nuclear island?

18 MR. STAMM: 91-9. The elevation of the actual --

19 MR. MICHELSON: Part of the tunnel then is a
20 vertical --

21 MR. STAMM: It comes a vertical pipe and then into
22 the tunnel.

23 MR. MICHELSON: -- going downward.

24 MR. CROM: That's correct.

25 MR. MICHELSON: So that if you have a site flood,

1 if it does get into the tunnel, then it goes all the way
2 down and produces hydrostatic pressure at elevation. What
3 was that again?

4 MR. OSWALD: Delta 70.

5 MR. MICHELSON: 70 is about grade, isn't it?

6 MR. OSWALD: No. 91-9.

7 MR. STAMM: 91-9 is the top.

8 MR. MICHELSON: So that's only about 11, 12 feet
9 then?

10 MR. STAMM: Yes. Although not explicitly stated,
11 and we talked about adding some words so that it makes it
12 very clear, the penetration seals and the seals for the
13 tunnels, we considered structural components and are covered
14 by the design criteria in 3.8a, which covers hydrostatic
15 pressure.

16 MR. MICHELSON: Yeah. That's okay. That's an
17 important part of it. Now, the next question is if we were
18 to experience a seal failure and you have no good way of
19 testing these through the life of the plant very easily, you
20 can inspect them; that's about the best you can do; but you
21 have to design some kind of a limited leakage seal such as
22 if you get a catastrophic failure during a flood you don't
23 fill the whole building because there's almost an infinite
24 source of water available to fill the building.

25 MR. CROM: Let me address the station service

1 water before you --

2 MR. MICHELSON: You've got to design it so you can
3 do damage control while you're trying to stop the leak.

4 MR. STAMM: The source of flooding in the
5 component cooling water tunnels is only component cooling
6 water plus ex --

7 MR. MICHELSON: No, no, no. This is site flood I
8 was talking about.

9 MR. STAMM: Oh; from site flood.

10 MR. MICHELSON: If site flood gets into the
11 tunnel.

12 MR. CROM: Okay. Tom is going to --

13 MR. MICHELSON: Now you've got an infinite source
14 of water to flood the building with.

15 MR. STAMM: Tom's going to cover that --

16 MR. MICHELSON: Site floods are pretty large.

17 MR. CROM: Let me understand you. When you say
18 site flood --

19 MR. MICHELSON: Yes; outside.

20 MR. CROM: Okay. From outside.

21 MR. MICHELSON: Yes. The one that comes just one
22 foot below grade.

23 MR. CROM: Right. Now, Steve, isn't there a
24 requirement that the tunnel be watertight?

25 MR. MICHELSON: Has to be; yeah.

1 MR. CROM: Yeah. So that the water is not going
2 to -- if the --

3 MR. MICHELSON: This is where you get into the
4 question of when do you discount the single failure criteria
5 during the --

6 MR. CROM: Well, the other thing -- well --

7 MR. MICHELSON: -- do we have a failure of one of
8 our seals, and if we do, how do we control the damage before
9 we fill the whole building with water?

10 MR. CROM: Let's look at the internal flood and I
11 think that maybe --

12 MR. MICHELSON: This is not an internal flood.
13 This is an external flood that gets in internally.

14 MR. CROM: Well, what I'm saying is, what I think
15 is if you look at our internal flood protection, including
16 the safety-related pumps --

17 MR. MICHELSON: Well, if you look at it internally
18 you don't see it because the water isn't coming from a
19 source internally. You usually have limited sources and you
20 show how you handle all that, and that's good.

21 MR. CROM: Yeah.

22 MR. MICHELSON: But this is an infinite source of
23 water external to the building that comes in through a hole.

24 MR. CROM: Uh-huh.

25 MR. MICHELSON: And now, how do you plug the hole?

1 Well, the best thing to do is make sure you set a limited
2 leakage seal such that you show you can do a damage control
3 and get to the seal and do a damage control on it before it
4 floods the building out.

5 MR. CROM: Right.

6 MR. MICHELSON: And that's --

7 MR. CROM: But that can be addressed -- what I'm
8 saying is, if it is an external flood, and it's going
9 internally into the building --

10 MR. MICHELSON: This is --

11 MR. CROM: -- that safety-related sump pump in
12 level indication is going to detect it.

13 MR. MICHELSON: It depends on the rate of leakage
14 of this seal --

15 MR. GUO: This is Jim Guo of --

16 MR. MICHELSON: -- and that's why they call it a
17 limited leakage seal, so that you can handle it.

18 MR. GUO: I think the external flood has no way to
19 go into the building because all the grade level below one
20 foot from the flood level have no entrance, so there's no
21 way to --

22 MR. MICHELSON: I'm sorry. I was just pointed out
23 this vertical shaft here drops down, what, 10, 11 feet and
24 then goes into the building. So you're 11 feet below the
25 flood.

1 MR. GUO: Even if that's so, they have the seal at
2 the --

3 MR. CROM: Well, that's what he's talking about.
4 The failure of the seal.

5 MR. MICHELSON: That's what I'm talking about.
6 All I'm saying, it has to be a limited leakage seal. Has to
7 be -- and you can design seals so that even when the
8 elastomers fail, the metal portions limit the leakage to a
9 rate that you can handle, either with sump pumps or you can
10 handle with damage control or something. I didn't find that
11 requirement.

12 MR. CROM: Okay. I think we -- I understand what
13 you're saying and Steve, do you think there needs to be --
14 we need to look at it, whether there needs to be any --

15 MR. STAMM: Todd just pointed out, you're
16 absolutely right. The seal is designed so that we wouldn't
17 expect a catastrophic failure. The other point that was
18 just made to me was that the component cooling water seals
19 are designed to prevent leakage in the event of a component
20 cooling water pipe rupture in there, which would be much
21 greater than we would get from an in-leakage, from an
22 external in-leakage during a flood.

23 MR. MICHELSON: No, the source is pretty small.
24 You've only got a few hundred feet of piping at most, and
25 that's all the water --

1 MR. STAMM: Agreed. But the rate --

2 MR. MICHELSON: Sure you dump the infinite source
3 of the site flood. You fill the building. You can't stop.

4 MR. STAMM: I was talking about rate as opposed to
5 the total quantity.

6 MR. MICHELSON: Yeah; the rate would be greater in
7 that case, but the damage control would be easier because of
8 the very limited amount of water that you release. Here
9 it's coming forever.

10 MR. STAMM: The other factor that needs to be
11 considered and Tom probably is going to point this out, is
12 the plant separation shows that small leakage, even
13 significant leakage from external flood, will not affect
14 both trains of the plant.

15 MR. MICHELSON: If seals don't -- if only one seal
16 fails.

17 MR. STAMM: If only one seal fails; that's
18 correct.

19 MR. MICHELSON: Does this tell me you've got
20 limited leakage seals or not? You know, if you don't
21 specify it as being limited leakage and limited to some
22 value or one value is limited to the leak rate of the
23 capability of the sump pumps.

24 MR. GUO: This is Jin Guo again. Even if --

25 MR. MICHELSON: It's not hard to do, by the way.

1 MR. STAMM: I understand.

2 MR. GUO: In case of leakage inside the
3 reactivating subsphere, they have a sump and a pump that
4 monitors 24 hours and they --

5 MR. MICHELSON: We're not even questioning that
6 feature. We're questioning only what happens when the flood
7 water gets into the building through a single failed seal.

8 MR. GUO: In case -- entrance of -- the seal
9 fails, the water goes in the building, then you have a
10 monitoring system and --

11 MR. MICHELSON: Right; right. Now, how fast does
12 the water come into the building? How much is the leakage
13 limited by the seal design?

14 MR. GUO: In any case, the leakage will not -- the
15 leakage is not a big flood goes in.

16 MR. MICHELSON: Well, you better take a look at
17 how people design seals. I've seen some seals that can leak
18 literally hundreds of gallons a minute, and I've seen seals
19 that only leak a few gallons a minute even after the
20 elastomers fail.

21 MR. GUO: This leakage are monitoring 24 hours a
22 day.

23 MR. MICHELSON: To monitor them -- that isn't the
24 question.

25 MR. RITTERBUSCH: This is Stan Ritterbusch. Mr.

1 Michelson, we'll take a look at our statements in the SAR
2 and make sure they say what we want them to say.

3 MR. MICHELSON: The nice thing to say is that the
4 leakage is limited to the capacity of the sump pumps. That
5 would be the nice -- I don't know if you can say that or
6 not. In the case of GE, they couldn't quite say that. But
7 that would be the ideal, is it's limited -- design a seal
8 that limits the leakage upon a failure of the elastomers,
9 limits the leakage to the capacity of the sump pumps; and
10 you've got it made.

11 MR. CROM: Okay.

12 MR. CARROLL: All right. Let's move on.

13 MR. CROM: I'm going to start on the internal
14 flood protection.

15 [Slide.]

16 MR. CROM: The first point I want to make is that
17 station service water is totally located outside of the
18 nuclear annex. The only place that station service water
19 enters it into the component cooling water heat exchanger
20 structure and the component cooling water heat exchanger
21 structure is designed such that if you have a moderate
22 energy line break of service water in that structure, it
23 will not flood through the tunnels back into the nuclear
24 annex. There is flood protection there.

25 MR. MICHELSON: One small question and I couldn't

1 find, again, the answer. That is the piping between the
2 service water pumping station and the component cooling
3 water building.

4 MR. CROM: Yes.

5 MR. MICHELSON: That appears to be underground
6 piping.

7 MR. CROM: That's correct.

8 MR. MICHELSON: Is it in a chase or is it in the
9 ground?

10 MR. CROM: Right now it's buried.

11 MR. MICHELSON: It looked like it was buried. I
12 couldn't verify that.

13 MR. CROM: That's correct. It's buried.

14 MR. MICHELSON: And it's buried, I guess, at least
15 ten feet or so deep. You don't have a turbine missile
16 problem then.

17 MR. CROM: That's correct.

18 MR. MICHELSON: Telephone poles would go pretty
19 deep if you dropped them.

20 MR. CROM: The other point I wanted to make is
21 that component cooling water and emergency feedwater systems
22 are fully separated by division. These are not the only
23 systems. Basically, what I'm saying is there's no cross-
24 connects between the systems.

25 I've pointed these two systems out because current

1 plants, when they look at their moderate energy line break,
2 have found that in component cooling water and emergency,
3 they normally have -- some plants have an open cross-connect
4 and show that they lose both divisions on some of the breaks
5 that they don't want.

6 MR. MICHELSON: You didn't specify, of course,
7 much about the service water pumping station, since that's
8 outside the scope of the certificate.

9 MR. CROM: That's outside the scope.

10 MR. MICHELSON: But I didn't find any interface
11 requirement that says it shall have a divisional wall up to
12 grade. Did I miss it?

13 MR. CROM: That is in the service water section.

14 MR. MICHELSON: It says it shall be separated, but
15 it didn't say there was a divisional wall up to grade that
16 would keep the water out and limit the water to just one
17 side, which is what you have in the service water.

18 MR. CROM: Steve, do you recall what we had?

19 MR. STAMM: No. But in all likelihood, the
20 designs that we were looking at, we actually had separate
21 structures for the two trains.

22 MR. MICHELSON: The present plan here only shows
23 one structure. If there were two structures, I wouldn't
24 have asked the question.

25 MR. STAMM: But, obviously, we need to do that.

1 MR. CROM: I will check, but I think the ITAAC,
2 which has an interface requirement, says that there has to
3 be a divisional wall between the two.

4 MR. MICHELSON: Don't put it in the ITAACs. We've
5 been assured repeatedly by the staff there are no new design
6 requirements in ITAACs. Every design requirement --

7 MR. CARROLL: Put it in both places.

8 MR. MICHELSON: Both places, but don't just put it
9 in ITAACs.

10 MR. CROM: I agree. It is in both. Let me check
11 where it is.

12 MR. MICHELSON: We'll look for it later after you
13 get a chance to look at it. Thank you.

14 MR. CROM: The next one let me go through and then
15 I'm going to show a figure to point them all out. Of
16 course, the divisional wall is our primary means of flood
17 control in the nuclear annex. I'm going to point out that
18 there are no doors provided up to Elevation 70 in the
19 divisional wall. Also, the wall that we have around the two
20 diesel generator rooms, again, there is no door until
21 Elevation 70.

22 We will note there is no pipe or duct penetrations
23 or any penetrations to --

24 MR. MICHELSON: There will be a note that says
25 there are no penetrations of the all. Is that what you're

1 saying?

2 MR. CROM: No. Let me put it this way. Right now
3 we have -- in our design, we have no penetration through the
4 wall. The pipes that we have routed, the duct we have
5 routed, there is no penetration. In the SAR, we say if the
6 COL later design puts a penetration through that wall, it
7 has to be appropriately sealed and, your point, it would
8 have to be qualified for the hydrostatic loading.

9 MR. MICHELSON: And/or pipe break loadings that go
10 higher.

11 MR. CROM: That's correct. The reactor building
12 subsphere is also separated in quadrants and those are also
13 designated as flood barriers. There is a door in those
14 walls, which is a flood door.

15 [Slide.]

16 MR. CROM: I will answer your question you had
17 yesterday. We arbitrarily selected Elevation 70, but I've
18 got a later slide that talks about analysis that
19 demonstrates that that is an acceptable level.

20 MR. MICHELSON: Elevation 70 is what?

21 MR. CROM: Elevation 50 is, of course, the
22 basement level. Elevation 70 is the first level above the -
23 - or is the next level up.

24 MR. MICHELSON: It's 20 feet up from that.

25 MR. CROM: It's 20 feet, yes.

1 MR. MICHELSON: But that's not to grade.

2 MR. CROM: No, it is not to grade.

3 MR. CARROLL: My question was what's magic about
4 Elevation 70.

5 MR. CROM: It was arbitrarily chosen, but we have
6 done analysis which demonstrates that essentially we can
7 take a break in every line, moderate energy line,
8 simultaneously and will not flood above Elevation 70. We
9 have flood barriers to provide separation between the
10 electrical equipment and mechanical systems at the Elevation
11 50, the lowest elevation in the nuclear annex.

12 We also, around each of the emergency feedwater
13 pump rooms, which is on Elevation 50, are compartmentalized
14 and also have flood barriers around those.

15 MR. MICHELSON: Are you going to tell us later how
16 you get the steam line down to the steam-driven feedwater?

17 MR. CROM: Steam line goes through a pipe tunnel
18 from the main steam valve house down into the turbine-driven
19 pump room.

20 MR. MICHELSON: I could find the tunnel on the
21 drawings, but then the tunnel suddenly disappeared and I
22 couldn't tell how you got from quite a ways away yet over to
23 the room. In fact, you had to go somehow across the
24 corridor to do it.

25 MR. CROM: It probably does not show up in detail.

1 Todd, do you want to answer that question?

2 MR. OSWALD: Todd Oswald, Nuclear Engineering. It
3 crosses the corridor up at the main steam valve house at
4 Elevation 106. It goes back down and the straight down into
5 the top of the --

6 MR. MICHELSON: That's not the way I read the
7 drawing. That was a problem, because those auxiliary
8 feedwaters are out near the edge underneath the containment
9 and the chase is quite a bit further in. This is that chase
10 right there.

11 This is the chase that you're referring to, I
12 assume.

13 MR. OSWALD: Yes.

14 MR. MICHELSON: It's not far down. Here's the
15 room.

16 MR. OSWALD: No, that's the tanks.

17 MR. MICHELSON: Yes. That's the tanks, but the
18 room is directly above the tanks.

19 MR. OSWALD: No. The main steam valve house is -
20 -

21 MR. MICHELSON: Let's just get the room.

22 MR. OSWALD: The room is right here.

23 MR. MICHELSON: Here it is.

24 MR. OSWALD: So your tunnel comes down right here.

25 MR. MICHELSON: You're staying there and it's not

1 far to go. So that's also the vent shaft for the pressure.

2 MR. CROM: That's correct.

3 MR. MICHELSON: Have you done the pressure
4 analysis on that room somewhere in the SAR?

5 MR. CROM: The pressure analysis -- Todd, that was
6 done as part of the structural design, was it not? And it
7 was also included in the equipment qualification in 311.

8 MR. MICHELSON: But is it written up somewhere in
9 the codes you're going to use for the pressure analysis and
10 the results?

11 MR. CROM: The person who did that is not here and
12 I don't know the answer. Do you now, Todd?

13 MR. OSWALD: No. I'm not sure what code they
14 used.

15 MR. MICHELSON: Could you get us the answer? If
16 it isn't in the SAR, then can you send us a write-up on how
17 you did your calculations, what code you used and what
18 results you got?

19 MR. CROM: I'll ask CE. They were the ones that
20 did it.

21 MR. OSWALD: I know what the result was. It was
22 ten psi.

23 MR. MICHELSON: It sounds like it could be even
24 higher than that, depending on which code you're using and
25 what assumptions you're making. That's what we want to see.

1 These are very high pressures you get. So we have to ask
2 the design of the doors to make sure that it really does
3 vent the pressure up through the shaft and the whole pathway
4 all the way to atmosphere. That I couldn't find anywhere.
5 It becomes an important calculation and I'd like to see the
6 results. I'm sure Ivan would, also, since he looked at them
7 for ABWR very carefully.

8 After we look at them long enough and carefully
9 enough, we finally realize what really happens.

10 MR. CROM: I think Mr. Mitchell was the one in
11 your shop that performed that.

12 MR. MICHELSON: Is that a six-inch on this turbine
13 or a four?

14 MR. CROM: Six-inch.

15 MR. MICHELSON: Six-inch. That's a substantial
16 line, then.

17 MR. CARROLL: How do we resolve this?

18 MR. RITTERBUSCH: We're going to caucus here and
19 we're going to have an approach to how to fix this before
20 the end of the day.

21 MR. CARROLL: Sounds good.

22 MR. MICHELSON: Sounds good.

23 MR. CROM: Steve, do you have something?

24 MR. STAMM: Yes, if I could go back for a second.

25 Steve Stamm. Section 9.2.1.1.4, Item B, says the "SSWS pump

1 structure shall provide physical barriers to maintain
2 divisional separation of SSWS components."

3 MR. MICHELSON: That I already knew. Was that a
4 question I had?

5 MR. CARROLL: You asked about the separation of
6 the station service water.

7 MR. MICHELSON: I knew about it. It has a
8 divisional wall right down the middle. The fact is it's not
9 even divisional. Oh, the service water. I'm sorry.

10 MR. STAMM: Yes, the service water.

11 MR. MICHELSON: I'm thinking of the -- I'm sorry.
12 The service water, then, does specify a divisional wall to
13 grade.

14 MR. CARROLL: It implies that, I think.

15 MR. STAMM: It definitely implies that.

16 MR. MICHELSON: That was the requirement and I
17 will find that.

18 [Slide.]

19 MR. CROM: I just wanted to throw up a figure
20 here. I've had the word slides. When we talk about the
21 divisional wall on Elevation 50, we're talking about this
22 wall, all the way across. The quadrant wall is here and, as
23 I said, there are two doors here and here which are flood
24 doors. Each of the motor-driven pump rooms and the turbine-
25 driven pump rooms, and, again, there are doors entering each

1 of those rooms which are flood doors.

2 MR. CARROLL: Tell me about a flood door.

3 MR. CROM: I'm not sure I can answer that
4 question. We're talking about what's in typical plants, the
5 submarine type door for flood doors, yes.

6 MR. CARROLL: Are they self-closing?

7 MR. CROM: We do have those all sensed and
8 alarmed in the control room.

9 MR. CARROLL: That was going to be my next
10 question.

11 MR. MICHELSON: They are essentially, though,
12 lugged down, aren't they?

13 MR. CROM: Yes.

14 MR. MICHELSON: You're talking about fairly large
15 hydrostatic pressures.

16 MR. CROM: I don't think you can design a self-
17 closing flood door, but we do have them sensed and alarmed
18 in the control room.

19 MR. MICHELSON: You could, but --

20 MR. GUO: Jin Guo. The flood doors are pressure
21 doors and they have sensors in a central fire station.
22 They're monitored 24 hours a day. So it's guaranteed the
23 doors close.

24 MR. CARROLL: There was a statement in the FSER
25 that made it sound like there's an operator station

1 monitoring this thing 24 hours a day. I don't believe that.
2 I can find it. Did you read the same thing?

3 MR. MICHELSON: I don't recall that one, no.
4 Clarify something for me. What you show here is the
5 vertical divisional wall is under the subsphere.

6 MR. CROM: Yes.

7 MR. MICHELSON: In the subsphere area. It only
8 goes that far, whereas the main divisional wall, the
9 horizontal one, actually goes all the way up through the
10 building to what elevation?

11 MR. CROM: The divisional wall and even the
12 quadrant walls go --

13 MR. MICHELSON: Let's just talk about the
14 divisional wall first.

15 MR. CROM: The divisional wall goes all the way
16 up to the building, yes.

17 MR. MICHELSON: All the way to the topmost floor?

18 MR. CROM: Yes. We don't designate that as a
19 flood barrier.

20 MR. MICHELSON: No, no.

21 MR. CROM: Up above Elevation 50. It goes all the
22 way through.

23 MR. MICHELSON: It's identified as the divisional
24 wall.

25 MR. CROM: That's correct.

1 MR. MICHELSON: Now, the subsphere division into
2 four quadrants is only through the subsphere area.

3 MR. CROM: That's correct, because you have
4 containment above that.

5 MR. MICHELSON: And above that you've got nothing.

6 MR. CROM: That's correct.

7 MR. MICHELSON: That's right.

8 MR. GUO: There is a statement in the ITAAC Table
9 2.1.1-1 that says the flood door shown in Figure 2.1.1-1
10 through 2.1.1-12 has a sensor with open and closed status at
11 the central fire station.

12 MR. CROM: The central fire station, by the way,
13 is in the control room.

14 MR. CARROLL: That's not what my point was. I'll
15 find it.

16 MR. CROM: Okay.

17 MR. CARROLL: Move on.

18 MR. CROM: The only other one I had, of course, is
19 the flood walls around each of the diesel generator rooms,
20 which have no doors in this particular elevation. They
21 enter actually in Elevation 70 with stairs going down.

22 MR. MICHELSON: In the drawings at Elevation 70,
23 it just shows an open doorway into that compartment. There
24 really must be doors on it or something, aren't there? I'm
25 looking at, in particular, 1.2-5A.

1 MR. CROM: At Elevation 70?

2 MR. MICHELSON: At Elevation 70, yes.

3 MR. CROM: Are you talking about into the diesel
4 generator rooms?

5 MR. MICHELSON: Yes.

6 MR. CROM: Yes. There are two doors on either
7 end, required for life safety.

8 MR. MICHELSON: They're not shown on the drawing,
9 is that the idea, or am I -- you do show doors on this
10 drawing, but not in this case.

11 MR. CROM: There are doors shown on that.

12 MR. MICHELSON: I'm looking at it right there.
13 That's a door, sure, but how about that? What's that?

14 MR. CROM: There's a door on each side. You have
15 to have two doors for --

16 MR. MICHELSON: You're actually showing a door on
17 each side and then kind of a door about a third of the way
18 across the wall.

19 MR. CROM: There is an equipment door also on that
20 elevation.

21 MR. MICHELSON: Yes, but it doesn't show a door
22 there. That's all I was asking. Is that an open doorway or
23 has it --

24 MR. CROM: No.

25 MR. MICHELSON: -- got doors on it? You couldn't

1 tell from the drawing, that's for sure.

2 MR. LINDBLAD: Mr. Crom, could you put up the
3 slide of Level 2?

4 MR. CROM: Level 2?

5 MR. LINDBLAD: The 70-foot elevation.

6 MR. CROM: The 70-foot elevation, sure.

7 [Slide.]

8 MR. LINDBLAD: It shows the remote shutdown room
9 being directly below the control room.

10 MR. CROM: That's right here.

11 MR. LINDBLAD: Adjacent to a stairwell.

12 MR. CROM: Yes.

13 MR. LINDBLAD: Have you looked at that for firemen
14 trying to put out a fire in the control room with water
15 coming out of the control room? Will it cascade down the
16 stairs into the shutdown room?

17 MR. DAVIS: The PRA says you can't have a fire in
18 the control room.

19 MR. LINDBLAD: But you can still have firemen in
20 the control room, can't you?

21 MR. DAVIS: Well, I'm not sure what they'd be
22 doing there if there was not a fire.

23 MR. CROM: Fires in the control room are going to
24 be put out with extinguishers in the control room. Control
25 room fires are -- the fire suppression is manual

1 extinguishers. The other thing is we do have three-hour
2 barriers, which we'll talk about when we get to fire
3 protection, around that stairwell.

4 MR. LINDBLAD: I guess I was talking about
5 internal flooding rather than the fire, but I was concerned
6 about whether the remote shutdown room is occupied -- can be
7 occupied under all conditions when the control room maybe
8 challenged.

9 MR. CROM: Yes.

10 MR. LINDBLAD: You say there's no way for water to
11 come down the stairwell.

12 MR. CROM: We do not have any automatic
13 suppression for the control room. It is only done by manual
14 fire suppression with manual extinguishers. So I don't see
15 that there's a water source that could flood it. I've got
16 other slides to talk about control room and the flood
17 provisions we have on that.

18 MR. LINDBLAD: Could you answer my question? Is
19 there an interconnecting stairway from --

20 MR. CROM: There is an interconnecting stairway.
21 You do exit the control room and you go down that stairway.

22 MR. LINDBLAD: And while the remote shutdown room
23 is not in the very lowest level of the building, it's --

24 MR. CROM: It's in Elevation 70.

25 MR. LINDBLAD: -- adjacent to the stairwell.

1 MR. CROM: That's correct.

2 MR. LINDBLAD: Thank you.

3 MR. CARROLL: I found the statement that I think
4 needs clarifying in the staff FSER. I am on Page 19-220.
5 It's talking about the flood doors and the alarms on them.
6 It says that they're provided at a central fire alarm
7 station, and that should go on and say which is located in
8 the control room.

9 MR. FRANOVICH: This is Mike Franovich. If that's
10 the case, we'll go ahead and clarify the FSER.

11 MR. CARROLL: And it also goes on and says "CA
12 stated that the flood door open/closed status will be
13 continuously monitored and manned 24 hours a day." That
14 implies that it's manned, that there's some guy sitting here
15 looking at these indicator lights, and that's not the case.

16 MR. GUO: The flood door is monitored in the
17 central fire alarms, not the control room.

18 MR. CARROLL: Didn't I just hear that that is in
19 the control room?

20 MR. GUO: No.

21 MR. MICHELSON: That's what I heard.

22 MR. FRANOVICH: This is not to be confused with
23 the central alarm station for security.

24 MR. CARROLL: No.

25 MR. CROM: That's correct. The central fire alarm

1 station is a panel that is located in the control room. It
2 is not on the main control room console, but it is in the
3 control room.

4 MR. CARROLL: And is there an operator sitting in
5 front of it?

6 MR. CROM: No. There are operators in the control
7 room that would be alerted.

8 MR. CARROLL: I think the wording needs a little
9 cleaning.

10 MR. FRANOVICH: We'll go ahead and clarify that.

11 MR. SEALE: Is the panel alarmed or are there
12 annunciators on the panel to call attention to a change in
13 status?

14 MR. CROM: Yes.

15 [Slide.]

16 MR. CROM: I'm going to continue. We've already
17 talked about the sensors. Again, at higher elevations,
18 electrical equipment is elevated above the floor such that
19 flooding events will not affect components.

20 MR. MICHELSON: That's always assuming that water
21 comes from the bottom up from the floor and then it won't
22 affect the component, it's on a pedestal. But how about
23 water coming from the top down to the floor and the
24 equipment is in the way?

25 MR. CROM: Of course, when we talk about fire, of

1 course, we talk about the electrical equipment, that being
2 NEMA-qualified for water sprays and interaction. The other
3 thing is, of course, we --

4 MR. MICHELSON: Be careful, now. You're going to
5 qualify it for water spray or you're going to qualify it
6 just for --

7 MR. CROM: For drip-proof.

8 MR. MICHELSON: Drip-proof. That's not a water
9 spray, of course.

10 MR. CROM: The other thing, of course, with the
11 complete divisional separation, we still have the other
12 division.

13 MR. MICHELSON: That does help, yes.

14 [Slide.]

15 MR. CROM: As far as the floor drainage system,
16 they're separated by divisions in quadrants. What I'm
17 saying is that the drain lines are physically not connected
18 to each other going to the sumps. In the quadrants, each
19 quadrant has a separate sump with two safety-related sump
20 pumps.

21 MR. MICHELSON: When you get the water out of the
22 sump, where does it go to?

23 MR. CROM: It goes into the rad waste building.

24 MR. MICHELSON: Does it go in as separate pipes
25 into the rad waste building from each of the two divisions

1 or is it headered?

2 MR. CROM: Of course, once it reaches into the rad
3 waste building, it would be into a common header and back-
4 flow devices are in that particular line.

5 MR. MICHELSON: You've provided how many back-
6 flow devices? How many devices have to fail in order for
7 back-flow to get both sides?

8 MR. CROM: I'd have to look at the diagram. I
9 know what you're saying.

10 MR. MICHELSON: Gravity is what is driving it,
11 unless these lines are high enough in the building, of
12 course, where they're headered so they can't get a back-
13 flow from one side to the other. If it's at a lower
14 elevation, the water just goes through the header and right
15 on into the sumps of the other division.

16 I guess there will be some words that cautions the
17 owner and requires some amount of surveillance of check
18 valves or whatever you're using. Design is the best way to
19 solve the problem, of course, but you could solve it with
20 valves, if you had to.

21 MR. CROM: Yes.

22 MR. MICHELSON: But I just didn't find any of
23 this, but I probably didn't know where to look.

24 MR. CROM: We'll look at that and address that.

25 MR. MICHELSON: That is an open question.

1 MR. CARROLL: Are those check valves part of your
2 check valve testing program?

3 MR. CROM: Only the safety-related ones. We have
4 safety-related check valves in each of the sumps, which is
5 my next bullet there. Those are included in there. The
6 reverse flow test.

7 MR. MICHELSON: So the check valves on the sumps,
8 even though they're non-safety sumps, are going to be
9 safety-related.

10 MR. CROM: They are safety-related sumps.

11 MR. MICHELSON: They are?

12 MR. CROM: In each of the quadrants in the
13 subsphere, they have two safety-related sump pumps powered
14 from the diesel generators.

15 MR. MICHELSON: Safety-related means the QA on the
16 piping, the whole thing.

17 MR. CROM: Yes.

18 MR. MICHELSON: All the way back to rad waste?

19 MR. CROM: No.

20 MR. MICHELSON: How far?

21 MR. CROM: Only to -- it's the pressure boundary
22 that --

23 MR. MICHELSON: Like the check valve or somewhere.

24 MR. CROM: Yes.

25 MR. MICHELSON: And from there on, is it

1 seismically qualified?

2 MR. CROM: No. My next bullet was that the safety
3 Class 3 check valves were provided to prevent back-flow, and
4 that is when the drain lines actually enter into the sump.
5 Of course, we've already talked about each subsphere
6 quadrant has a sump and there's two safety-related sump
7 pumps that are powered from the diesel generators in each of
8 those.

9 Relating to some of the interaction problems that
10 plants have seen in the control room, no water lines are
11 routed above or through the control room or the computer
12 room. We have that requirement.

13 MR. DAVIS: Excuse me. Let me ask you, if I
14 could, about the diesel generator rooms.

15 MR. CARROLL: No drinking fountain?

16 MR. CROM: In our design, we have all the break
17 rooms, kitchens and everything outside of the main control
18 room. We intentionally did that, even though we violated an
19 EPRI requirement.

20 MR. CARROLL: I know you did.

21 MR. CROM: That was the reason for it.

22 MR. CARROLL: Pete, I'm sorry I interrupted.

23 MR. DAVIS: The diesel generators are protected by
24 a pre-action water spray system.

25 MR. CROM: That's correct.

1 MR. DAVIS: And the pre-action valve is
2 automatically opened on detection of smoke.

3 MR. CROM: That's correct. Then the nozzle itself
4 has to open on the heat sensitive.

5 MR. DAVIS: Now, this system is not Seismic 1.
6 That's right?

7 MR. CROM: The standpipes are seismic, the Seismic
8 1. The piping, from an interactions standpoint, are Seismic
9 Category 2. There's a shutoff valve on the standpipe and
10 it's Seismic Category 1 all through there. Then we have a
11 requirement that all suppression lines, from an interaction
12 standpoint, be Seismic Category 2.

13 MR. MICHELSON: That means they don't fall down on
14 vital equipment, but they can dump their contents.

15 MR. CROM: That's correct.

16 MR. DAVIS: Let me lead you through a scenario
17 here and see what's wrong with it. If you have a seismic
18 event, frequently there's a lot of dust generated. I'm
19 postulating that that would cause this pre-action valve to
20 open.

21 MR. CROM: Yes.

22 MR. DAVIS: Based on the detection of aerosols.

23 MR. CROM: Yes.

24 MR. DAVIS: And then the piping fails because it's
25 not Seismic Category 1. It can be stranded pipe, which

1 doesn't --

2 MR. CROM: No. We require it all to be welded
3 pipe. We addressed that in that one question and we
4 consider that to be seismically rugged. That's the way it's
5 addressed in the PRA.

6 MR. MICHELSON: Seismic Category 2 isn't rugged
7 from the viewpoint of contents.

8 MR. CROM: In the PRAs and all of the IPES, it's
9 considered if it's welded to be seismically rugged.

10 MR. MICHELSON: You mean the PRA people think pipe
11 is seismically qualified even when it isn't.

12 MR. CROM: That's correct.

13 MR. MICHELSON: I didn't realize that.

14 MR. CROM: That's the way current IPES are being
15 done in current plants.

16 MR. LINDBLAD: If you're in the diesel room,
17 wouldn't it be two over one?

18 MR. MICHELSON: Only from the viewpoint of the
19 pipe falling down.

20 MR. LINDBLAD: Yes.

21 MR. MICHELSON: But not from the viewpoint of
22 dumping contents.

23 MR. DAVIS: I'm concerned about spray from this
24 system.

25 MR. LINDBLAD: I understand that, but I --

1 MR. MICHELSON: The pre-action valve is already
2 open and now you've got a crack in the pipe where a joint
3 broke or whatever and he's dumping the contents and it
4 continues to dump it until you perform some kind of an
5 isolation, which takes a while.

6 MR. CROM: Dave, do you want to address that?

7 MR. FINNICUM: The piping, as Tom said, is all
8 welded piping and it's supported. We spoke with Dr. Kennedy
9 about this and he says that that is seismically rugged. His
10 first estimate is that if you support it laterally, also,
11 that it should have a HCLPF value in the .9g range.

12 Within the nuclear annex, we have a limited water
13 source for the automatic sprinkler systems. The major water
14 sources are outside the annex in separate buildings and are
15 non-seismic and do not have the welded piping. So they
16 would probably not be available for a spurious actuation of
17 a fire system in a seismic event.

18 So in looking at the available inventory for the
19 spray-down, from a flooding standpoint, we only get a depth
20 of about four inches, I believe it was.

21 MR. MICHELSON: But where is the water coming
22 from? It's coming from the ceiling, not from the floor.
23 It's coming down on the equipment before it ever gets to the
24 floor and that's the concern, what it's doing to the
25 equipment in the process of coming down to the floor. So I

1 don't think pedestal heights are meaningful at all.

2 The ability of the equipment to resist the spray
3 is meaningful, but not the elevation of the equipment.

4 MR. CROM: Again, it's a limited source, as Dave
5 said.

6 MR. MICHELSON: It's speculative as to how limited
7 it is. That depends on what's happened to the rest of the
8 fire protection system during the earthquake.

9 MR. CROM: I agree.

10 MR. MICHELSON: We just don't know. On the other
11 hand, you can eventually understand that this is happening
12 and get it isolated, but that takes time. First of all, in
13 an earthquake, things are exciting, I'm sure, and maybe this
14 is not high on their list of things to think about. I don't
15 even know if you have a detection -- I guess you've got an
16 alarm that says your pre-action valve opened, but you have
17 nothing that says that --

18 MR. CROM: You also have a safety-related sump and
19 sump pumps in that particular detection.

20 MR. MICHELSON: Then the water finally gets to the
21 floor and gets into the sump. Is it alarmed or is it only
22 monitoring how often --

23 MR. CROM: It would be alarmed on high level.

24 MR. MICHELSON: No, but it doesn't get to high
25 level when it starts pumping. It just pumps the water

1 that's coming in.

2 MR. CROM: I understand.

3 MR. MICHELSON: So you may not even know it's
4 spraying in there until somebody walks in or whatever.

5 MR. CROM: The alarm would be on your pre-action
6 valve.

7 MR. MICHELSON: Only on the pre-action.

8 MR. CROM: That's correct.

9 MR. LINDBLAD: Mr. Crom, when he says welded
10 piping, was he talking about butt welding or socket welding?

11 MR. CROM: Socket welding. It could be either,
12 depending on the pipe size.

13 MR. LINDBLAD: I am almost sure that the nozzles
14 in the fire system would be socket welded.

15 MR. MICHELSON: Yes.

16 MR. CROM: Yes.

17 MR. MICHELSON: They'd have to be.

18 MR. LINDBLAD: Which isn't quite as rugged as butt
19 welding systems.

20 MR. CARROLL: Why does every earthquake, I heard
21 it yesterday again, result in fire systems letting go? Loma
22 Prieta wiped out the whole United Airlines wing of San
23 Francisco Airport because of fire systems letting to and I
24 think Kennedy or Idriss yesterday mentioned --

25 MR. LINDBLAD: In the North Ridge recently, all

1 large commercial buildings have provisions to evacuate the
2 building on earthquake and nobody goes back in until a
3 building inspector says it's safe. So as a result, a
4 substantial amount of the damage in North Ridge is based on
5 flooding of contents because a mechanic wouldn't go in and
6 turn off the water.

7 MR. SEALE: And they had inadequate water to fight
8 fires because of the bleed-down of the system.

9 MR. LINDBLAD: Yes.

10 MR. CARROLL: Real fires.

11 MR. MICHELSON: The real question here, I think,
12 is simply why aren't we seismically qualifying at least
13 within the diesel compartment and get rid of all this Mickey
14 Mouse -- I think I almost heard it was, but not quite.
15 What's wrong with just going the rest of the way? It's no
16 big deal.

17 MR. LINDBLAD: I'm sure it is on the basis of two
18 over one. I'm sure that the supports --

19 MR. MICHELSON: That keeps the big pieces from
20 coming down.

21 MR. LINDBLAD: Yes.

22 MR. MICHELSON: I think there's hardly anything
23 left but making it a seismically qualified system inside of
24 the diesel compartment.

25 MR. CROM: Let us take that under advisement and

1 get back to you with a response to that question.

2 MR. MICHELSON: And then I think you've got to
3 begin to get --

4 MR. DAVIS: In this scenario, of course, the
5 diesel generators would be trying to start because you would
6 lose off-site power.

7 MR. CROM: Correct.

8 MR. DAVIS: So they would be trying to start at
9 the same time they're being sprayed. I don't know how
10 fragile the nozzles are on the fire protection system
11 either.

12 MR. CROM: If your piping withstood the seismic
13 event, not only would you have to have the pre-action valve
14 opening -- and that would be the most likely, not only from
15 the signal that you're talking about. The pre-action valves
16 are only a flapper that's held in place and the seismic
17 event could actually cause it to open. We have looked at
18 that and agree that during a seismic event, they could open,
19 even if we seismically qualified the lines.

20 MR. CARROLL: Could open, but would they stay
21 open?

22 MR. CROM: They would stay open, because when --
23 all it is is a flapper held with a solenoid and if that
24 flapper opens, it stays open.

25 MR. MICHELSON: It stays.

1 MR. CROM: But you still have to have the heat-
2 sensitive spray nozzle to actuate, as well, because you've
3 got redundancy there. I think the real question --

4 MR. CARROLL: And diversity.

5 MR. CROM: Yes.

6 MR. CARROLL: Right, Pete?

7 MR. MICHELSON: What do you mean diversity?

8 MR. DAVIS: I don't think diversity.

9 MR. CROM: The real question is whether the pipe
10 ruptures and you're spraying it down. We've said it's
11 seismically rugged and there's a question as to why not go
12 further and make it all Seismic Category 1. We will take
13 that under advisement and respond to it.

14 MR. DAVIS: The scenario is you get both diesels
15 this way, because if one fails -- they're highly correlated
16 because they're at the same elevation.

17 MR. CROM: I understand.

18 MR. DAVIS: Then your combustion turbine is not
19 seismic, either.

20 MR. CROM: That is not. It is not seismic.
21 However, we have a requirement, which Dave, I think, will
22 talk about. There's a HCLPF requirement, even though it's
23 not Seismic Category 1.

24 MR. DAVIS: To me, that's just as good.

25 MR. CROM: It must withstand a certain HCLPF as

1 far as the seismic PRA is concerned.

2 MR. MICHELSON: You're talking about the
3 combustion turbine.

4 MR. CROM: Yes.

5 MR. MICHELSON: How about all the wiring coming
6 into the building and everything?

7 MR. CROM: I'll have to ask Dave to address that.
8 Are you going to address that, Dave, in your PRA?

9 MR. CARROLL: Pete, you're cheating. You're
10 moving into PRA space and we're trying to get rid of floods.

11 MR. DAVIS: I'm trying to move it into the
12 important areas here.

13 MR. CARROLL: We'll get there.

14 MR. MICHELSON: I think you had an answer back
15 here.

16 MR. FINNICUM: Would you like me to provide an
17 answer?

18 MR. CARROLL: Sure, do it.

19 MR. FINNICUM: This is Dave Finnicum from ABB. In
20 the PRA, based on information provided by EPRI in the URD,
21 the seismic fragility of the combustion turbine was assumed
22 to be about .36g, which is above the fragility of the off-
23 site power source, which is about .12g. It's underground
24 cabling from the alternate AC source into the building and
25 this is assumed to be seismically rugged.

1 MR. MICHELSON: It is required to be or just
2 assumed to be?

3 MR. FINNICUM: It was assumed to be.

4 MR. MICHELSON: Are you going to have a
5 requirement, an interface requirement for the COL holder
6 that they make it seismically rugged?

7 MR. FINNICUM: That has not been specified at this
8 point.

9 MR. MICHELSON: Then I can't assume it is unless
10 it's specified.

11 MR. CARROLL: We also discussed the fuel supply to
12 the gas turbine yesterday and I don't think I got a complete
13 answer on how good it is seismically.

14 MR. CROM: Again, the fuel supply is not a Seismic
15 Category 1.

16 MR. CARROLL: I understand.

17 MR. CROM: Dave, can you address the fragilities
18 and things like that of it?

19 MR. FINNICUM: That was included within the EPRI
20 discussion on the seismic ruggedness of the AC source.

21 MR. MICHELSON: How did EPRI know that? Because
22 that tank arrangement is a site-specific situation, too.
23 The COL holder is going to design that fuel storage, I
24 think. So how would you know ahead of time what the seismic
25 ruggedness is unless you specify it?

1 MR. LINDBLAD: Are we talking about deterministic
2 design basis accidents or the PRA now?

3 MR. MICHELSON: We're talking about the earthquake
4 in the PRA.

5 MR. LINDBLAD: PRA.

6 MR. MICHELSON: Yes.

7 MR. LINDBLAD: So it seems to me that the PRA
8 examiner inspects what the conditions are.

9 MR. MICHELSON: But what is he inspecting? We
10 don't have any design or anything to inspect.

11 MR. LINDBLAD: The concept, then.

12 MR. MICHELSON: So you look at the -- you look at
13 the requirements is what you look at, and I'm asking where
14 are the requirements that say that it's going to be
15 seismically rugged and whatever. I didn't find them, but
16 you can point out where I should read and I'll read it.

17 MR. DAVIS: The COL will verify, after the plant
18 is built, the seismic capacity.

19 MR. LINDBLAD: The assumptions of the PRA, yes.

20 MR. DAVIS: The seismic capacity of all this
21 equipment. If there's a problem at that point --

22 MR. LINDBLAD: Whether it's specified or not.

23 MR. MICHELSON: If they have to meet the PRA
24 requirements, then that's great. I didn't find that either.
25 Is there something that says that they must verify and meet

1 the PRA assumptions?

2 MR. CARROLL: That's the D-RAP and U-RAP.

3 MR. FINNICUM: This is Dave Finnicum, again. Yes.
4 What it is is in Section 19.7.5.3, there is an area that
5 specifically talks about the assumed fragility for the
6 alternate AC source and it references the EPRI URD report
7 that talked about the considerations on which they based
8 their evaluation of the fragility of the AC source. That is
9 there.

10 I believe based on discussion with the NRC, we
11 have also added into the -- I believe it's 19.7.5.3 -- a
12 discussion that talks about that the COL must perform a
13 seismic walkdown for the plant to confirm the assumptions
14 made in the seismic PRA.

15 MR. DAVIS: Right.

16 MR. MICHELSON: The assumption includes all the
17 electrical breakers and controls and whatever it takes to
18 make that gas turbine work.

19 MR. FINNICUM: This is correct.

20 MR. MICHELSON: So if there's a walkdown
21 requirement and a verification of the PRA, that should take
22 care of it.

23 MR. EL-BASSIONI: I'm El-Bassioni. I'm in the PRA
24 Branch of NRR. Dr. Michelson, usually, in conventional
25 PRAs, we do not consider cables in seismic PRAs, because we

1 assume that they are flexible enough to take seismic events.

2 MR. MICHELSON: But structures are important, too,
3 to house them.

4 MR. EL-BASSIONI: What?

5 MR. MICHELSON: The structures that house the
6 cables are just as important and they are not necessarily
7 flexible.

8 MR. EL-BASSIONI: Yes. For this reason, as you're
9 saying, this is a basic assumption in PRA and we are
10 highlighting key assumptions and the most significant
11 insights to be included in the design control document and
12 as Tier 1 or Tier 2. We are going to see to that. This
13 assumption is highlighted.

14 MR. MICHELSON: At the time of COL licensing.

15 MR. CARROLL: Moving on.

16 [Slide.]

17 MR. CROM: Water lines to HVAC air conditioning
18 units around the control room, and we're talking about the
19 air conditioning for the control room itself, are contained
20 in rooms and we have curbs around those particular rooms so
21 that if there would be a moderate energy break, and these
22 are small lines, that the flood would not go into the
23 control room or the computer rooms, but be directed down
24 around those into the lower elevations.

25 MR. MICHELSON: Now, none of those lines are in

1 the control room, though.

2 MR. CROM: That's correct.

3 MR. MICHELSON: Or in the computer room.

4 MR. CROM: That's correct.

5 MR. MICHELSON: From your earlier statement.

6 MR. CROM: Yes.

7 MR. MICHELSON: And it can't get in there. Now,
8 the rooms that they are located in are just for the air
9 handling units.

10 MR. CROM: That's correct. The component cooling
11 water heat exchanger structure, and there's one structure
12 for each division, is -- I say it's divisionally separated,
13 but there actually is -- it's divisionally separated because
14 there are two structures.

15 It also is, I believe, separated -- each heat
16 exchanger is separated within a division, such that they --
17 since we have two buildings, you can't -- a flood or break
18 from service water or component cooling water in those
19 particular buildings cannot effect both divisions.

20 Also, from a turbine building standpoint, we have
21 one door that leads from the turbine building to the nuclear
22 annex. This door is located at Elevation 130 plus six and
23 that is at an elevation such that any flood that may occur
24 in the turbine building, the turbine building flood will
25 flood out, since we've got an aluminum-sided turbine

1 building, onto the grade elevation at 91.9 before it ever
2 reaches this door.

3 MR. MICHELSON: There must be some lines from the
4 turbine building over to rad waste, aren't there?

5 MR. CROM: Yes. They're all located out of the
6 building. They do not --

7 MR. MICHELSON: They apparently don't have to be
8 processed.

9 MR. CROM: They do not run through the nuclear
10 annex.

11 MR. MICHELSON: How do they get over to the rad
12 waste building?

13 MR. CROM: Through pipe tunnels in the ground.

14 MR. MICHELSON: And they don't in any way connect
15 to anything but the rad waste portion of --

16 MR. CROM: That's correct.

17 MR. MICHELSON: -- nuclear island.

18 MR. CROM: That's correct.

19 MR. MICHELSON: Looking backwards, how do you --
20 or are you going to get to how you -- floods in the rad
21 waste building, how can they get into the nuclear island?

22 MR. CROM: There is a flood barrier in the pipe
23 chase between the two.

24 MR. MICHELSON: Are you going to talk about it in
25 a little bit?

1 MR. CROM: I don't have a slide, but the answer is
2 that the pipe chase leading between --

3 MR. MICHELSON: How about doorways from the rad
4 waste building, are they all above elevation, whatever it
5 is, 91 or whatever?

6 MR. CROM: Do you recall, Todd?

7 MR. OSWALD: No. They are the -- one door we have
8 I think is right at grade.

9 MR. MICHELSON: But there are no doors below
10 grade.

11 MR. OSWALD: That's right. There are no doors
12 below grade. They're one foot above grade, as we've
13 committed to all the doors.

14 MR. MICHELSON: There are probably, undoubtedly,
15 in fact, pipe penetrations below grade from rad waste over
16 into the nuclear island.

17 MR. CROM: Yes.

18 MR. MICHELSON: Where will I read how those are
19 going to be sealed for a flood now in the rad waste
20 building, which can get there a number of different ways.

21 MR. CROM: You mean have we got a statement
22 anywhere, and I'm not sure we do. I know the answer, but
23 I'm not sure there's anything in the SAR. We'll have to
24 look and make sure there is. The answer is there is a flood
25 barrier in that penetration.

1 MR. MICHELSON: Any time you connect buildings
2 together with umbilical cords, I think it behooves the
3 safety analysts at least to look carefully at the umbilical
4 cords to make sure they aren't common connectors to all
5 buildings. I didn't find that kind of a connection
6 anywhere.

7 MR. CROM: We will look for it and if it's not
8 there, we'll add the words.

9 MR. MICHELSON: It's easy enough to -- I'm sure
10 you're taking care of it all, but this makes it --

11 MR. CARROLL: I was surprised to hear one door.
12 It wouldn't meet standards in California, at least. You
13 have to have two ways out of any building.

14 MR. CROM: Todd?

15 MR. OSWALD: That's the one door into the rad
16 waste building, but there's also doors -- the rad waste
17 building doesn't cover that whole length of wall along the -
18 -

19 MR. CROM: We're talking the door from the nuclear
20 annex to the rad waste building. We're not talking about
21 doors in and out of the rad waste building.

22 MR. MICHELSON: Only above grade we were asking.
23 There may be several doors further up, I don't know, but
24 none below grade was the answer.

25 MR. OSWALD: No doors are below grade. The other

1 egress doors, there are other egress doors, but not into the
2 rad waste building.

3 MR. CARROLL: Fine.

4 [Slide.]

5 MR. CROM: We did perform an analysis. What we
6 did -- and this is all in Chapter 19 under the flood PRA.
7 We looked at the volumes of various large volume sources
8 that were contained in one division or each division of the
9 nuclear annex. We included one component cooling water
10 division, including the external piping, the piping leading
11 to the component cooling water heat exchanger structure, and
12 the surge tank, the in-containment refueling water storage
13 tank, one emergency feedwater system division, including the
14 emergency feedwater storage tank, which is 350,000 gallons.

15 MR. MICHELSON: Is that a tank within that
16 compartment?

17 MR. CROM: Yes.

18 MR. MICHELSON: It didn't show a tank in the
19 compartment.

20 MR. CROM: The compartment itself is the tank.

21 MR. MICHELSON: That was my question. Is this a
22 box, in other words?

23 MR. CROM: Yes.

24 MR. MICHELSON: And it fills the entire volume
25 shown on the drawing.

1 MR. CROM: That's correct.

2 MR. MICHELSON: That must have pipes going off
3 here and there, for nothing more than to keep the water
4 clean.

5 MR. CROM: Yes. You have pipes coming from the
6 condensate system.

7 MR. MICHELSON: And there's a fairly large volume,
8 350,000, I think you said.

9 MR. CROM: Yes. We also included the entire fire
10 protection system, including the two external water supply
11 tanks. I think each one of those tanks are 300,000 gallons.
12 The chemical volume control system, including the external
13 hold-up tank, the boric acid tank and the reactor makeup
14 water tank.

15 If you look at the total water volumes of all
16 those, even if they all simultaneously failed in one
17 division, we have demonstrated through this analysis that
18 that comes up to an equivalent volume of 385,521 cubic feet.
19 Division 1 is 477,000 cubic feet up to Elevation 70 and
20 Division 2 is 525,000 cubic feet, and that includes a very
21 conservative analysis assuming that 50 percent of that space
22 is occupied by equipment.

23 So what we have demonstrated there is that this
24 Elevation 70, and you had asked a question about that
25 Elevation 70, that we can take a flood of one division

1 without going through a doorway or something up on Elevation
2 70.

3 MR. CARROLL: Now, if you put appropriate
4 conservatism into the analysis, what's the answer?

5 MR. CROM: Can I get more conservative?

6 MR. MICHELSON: It has to be the same. You've
7 already named the maximum possible water sources, but you
8 haven't named all the ways water could get in. You just
9 named the sources, the storage tanks, and I'm not sure that
10 that's the only way water can get in and flood the building.

11 MR. CROM: You're talking about the external
12 floods.

13 MR. MICHELSON: Yes. What's happening out in the
14 yard or what's flowing back from the cooling pond or
15 however, depending on how this whole thing is arranged. It
16 depends on the event you want to name and your ability to
17 prevent siphoning or back-flowing and things of that sort.
18 Generally, that's not a problem --

19 MR. CROM: Traditionally it's always been the
20 service water system and the make of that. We have that
21 contained in the outside nuclear annex.

22 MR. MICHELSON: You've got a heat exchanger in
23 between and you put it out in a separate building, and
24 that's a big step in the right direction.

25 [Slide.]

1 MR. CROM: We do have a COL applicant item that he
2 shall perform a flooding analysis associated with high and
3 moderate energy line rupture analysis outside containment.
4 I think that from what I've told you here, it's easily
5 demonstratable that we can shut this plant down considering
6 a single failure, particularly since they allow you to take
7 credit for non-safety equipment in moderate energy line
8 break analysis.

9 And with the combustion turbine, we could flood
10 the whole division and be able to shut the plant down
11 considering a single failure since we have redundancy in all
12 our safety systems in the opposite division. Plus, with the
13 combustion turbine, we would have redundancy on the off-
14 site power.

15 MR. CARROLL: And you're saying with a single
16 failure, meaning the 1E EDG and the --

17 MR. CROM: And the combustion turbine would be
18 able to meet that particular single failure. However, he
19 could --

20 MR. MICHELSON: How is the combustion turbine
21 power brought into the two divisions?

22 MR. CROM: The actual power itself, the actual
23 switchgear is located in the turbine building. We have a
24 requirement that the -- and that's discussed in the fire
25 protection section.

1 MR. MICHELSON: So the power is in a non-seismic
2 building, then, which we talked a little more about, asked
3 him about the duct work and everything, yeah, that's all
4 seismic. You're coming into a non-seismic building with
5 your power distribution.

6 MR. CROM: Let me answer this question, because we
7 don't have to consider a seismic event here.

8 MR. MICHELSON: Okay.

9 MR. CROM: The X and Y buses, the cables are
10 separated by the divisional wall, X being in Division 1 and
11 Y being in Division 2.

12 MR. MICHELSON: Wait a minute. The turbine
13 building doesn't have a divisional wall.

14 MR. CROM: No. I'm talking about once it enters
15 the nuclear annex.

16 MR. MICHELSON: Okay. I was worried about
17 outside.

18 MR. CROM: Now, what I'm saying is the flood in a
19 nuclear annex, if it floods one division, will not flood
20 into the turbine building.

21 MR. MICHELSON: Yes.

22 MR. CROM: So that the combustion turbine and the
23 switchgear are protected, but also the power cables going to
24 the two Class 1E buses are also separated, so that you would
25 have power to those.

1 MR. MICHELSON: Is the power distribution drawing
2 in the SSAR somewhere?

3 MR. CROM: Yes.

4 MR. MICHELSON: Because there you do worry about
5 the effects of flooding the switchgear in one division.
6 There are going to be some power cables flooded in one
7 division.

8 MR. CROM: The Class 1E switchgear are located on
9 Elevation 70 and they're quadratized.

10 MR. MICHELSON: And you're going to make sure that
11 that doesn't interact back to the panel that you've put in
12 the turbine building and cause you to lose both sides
13 because you've got a fault that you can't clear.

14 MR. CROM: Yes. The location of all the
15 switchgear is shown on the general arrangement drawings.

16 MR. MICHELSON: Okay. I'll look at it. Thank
17 you. You do have to go back and think about that seismicity
18 some more because I thought you were bringing it straight
19 into the seismically qualified building and not into the
20 turbine building from the combustion turbine.

21 MR. CROM: Remember that the turbine building is a
22 somewhat Seismic Category 2 structure.

23 MR. MICHELSON: Somewhat, yes, and that's what
24 they're going to verify in this whole explanation when it
25 comes out. Not quite as good, I think, as the --

1 MR. CROM: To conclude the flood section, as far
2 as ITAAC, the things that we have addressed to ensure that
3 they are met in the final design as far as flood. We have
4 provided those flood barriers, the ones I showed you on
5 Elevation 50, they're in the ITAAC.

6 Structural load from flooding is an ITAAC item.
7 It is considered that you have to consider the hydraulic
8 forces due to flooding.

9 MR. LINDBLAD: Mr. Crom, are we talking internal
10 and external now?

11 MR. CROM: That's correct.

12 MR. LINDBLAD: When we're talking flood
13 protection.

14 MR. CROM: That's correct.

15 MR. LINDBLAD: Thank you.

16 MR. CROM: The sensors on the flood doors are also
17 an ITAAC item in the structural -- nuclear annex structural
18 ITAAC. The divisional and quadra separation of the floor
19 drains are an ITAAC item in the equipment floor drain system
20 ITAAC. Station service water located outside of the nuclear
21 annex is essentially covered in the station service water
22 ITAAC and the location of it.

23 The divisional separation of the systems is in
24 every system ITAAC. You have to ensure that it is
25 divisionally separated by the divisional wall. Safety Class

1 3 check valves to prevent the back-flow that I talked about
2 in each of the sumps is also in the equipment and floor
3 drain ITAAC. The reactor building subsphere and diesel
4 generator rooms provide redundant safety Class 3 sump pumps
5 which are powered from the diesel generators is also in the
6 equipment and floor drain ITAAC.

7 MR. LINDBLAD: Most of this has been directed to
8 the nuclear island requirements. Are there any yard
9 requirements on flood protection? Are buried tanks
10 permitted?

11 MR. CROM: I'm not following your question. Are
12 buried tanks permitted, the answer is --

13 MR. LINDBLAD: In balance of plant, can one --

14 MR. CROM: Yes.

15 MR. LINDBLAD: -- bury a tank that would pop up
16 with an external flood if it were empty?

17 MR. CROM: I don't know if any safety-related
18 tanks, because the only safety-related tanks that would be
19 in the yard is the diesel generator fuel oil, and that is in
20 a structure.

21 MR. LINDBLAD: But there is no limitation on that.

22 MR. CROM: No.

23 MR. MICHELSON: It's a waterproof structure up to
24 grade.

25 MR. CROM: That's correct.

1 MR. LINDBLAD: How is the hydrogen stored and the
2 chlorine stored?

3 MR. CROM: The hydrogen and all those gases are a
4 COL item. It's not part of the standard design. However,
5 there are interface requirements that they be stored --
6 protected and stored a certain distance from safety-
7 related structures, and the protection, I think, is what
8 you're referring to.

9 Unless there are more questions on flood, I'm
10 going to go into the high energy lines.

11 MR. CARROLL: Shall we take a break?

12 MR. MICHELSON: Before we do that, let me ask you
13 one question. I was looking in the order in which these
14 were and you've got a drawing back here which I asked a
15 question on yesterday. I don't know how to identify the
16 drawing, except that it says "Nuclear Island Structure
17 Section AA."

18 MR. CROM: Yes. I know which one you're talking
19 about.

20 MR. MICHELSON: It's the first one of those
21 series.

22 MR. CROM: This one here.

23 MR. MICHELSON: Yes. Could you clarify for me
24 this flood wall that keeps the electrical stuff out of the
25 balance of the building flood or are you conceding that the

1 water goes into the electrical area, but on only one side?
2 Is that -- because there's no flood wall between the
3 electrical and the mechanical area there.

4 MR. CARROLL: You're talking about which room?

5 MR. CROM: Let me make sure I understand you.

6 MR. CARROLL: Far right?

7 MR. MICHELSON: Far righthand corner.

8 MR. CARROLL: The vital instrument and equipment
9 room.

10 MR. MICHELSON: Right.

11 MR. CROM: Yes. We showed that on the Level 1.

12 MR. MICHELSON: Is the idea that you left that
13 flood, along with the flood that occurs in that side of the
14 divisional wall?

15 MR. CROM: Let me pull up another slide here a
16 minute.

17 MR. MICHELSON: If you do, then I guess you -- I
18 see doorways --

19 MR. CROM: No. The answer is no and I'm looking
20 for that particular slide, because we have a flood wall on
21 Elevation 50.

22 [Slide.]

23 MR. CROM: Look at the plan view. This is the
24 flood barrier I'm talking about right here all the way
25 through around here. This is where your electrical is, your

1 --

2 MR. MICHELSON: That just happens to be on top of
3 the pedestal on your drawings, so you can't see it.

4 MR. CROM: It does not show up in that view.

5 MR. MICHELSON: That's the one that keeps it out.

6 MR. CROM: Yes.

7 MR. MICHELSON: And that goes up to grade.

8 MR. CROM: This one goes up to -- this flood
9 barrier goes up to Elevation 70. Now, these walls for
10 external floods go all the way up to grade.

11 MR. MICHELSON: Yes. And the divisional wall goes
12 all the way up to the building, all the way to the top.

13 MR. CROM: Correct.

14 MR. MICHELSON: But without any doors, it's -- I
15 thought below grade had no doors on the divisional wall.

16 MR. CROM: Below grade?

17 MR. MICHELSON: Yes.

18 MR. CROM: No. We have doors at Elevation 70.

19 MR. MICHELSON: You do, okay.]

20 MR. CROM: And a divisional wall. This wall here.

21 MR. MICHELSON: But you have no sources that can
22 get --

23 MR. CROM: That's correct.

24 MR. MICHELSON: -- above 70.

25 MR. CROM: That's correct.

1 MR. MICHELSON: Okay. So all of these have doors
2 above 70, because I see some --

3 MR. CROM: That's correct.

4 MR. MICHELSON: I thought I saw some.

5 MR. CARROLL: Okay, Carl?

6 MR. MICHELSON: Yes.

7 MR. CROM: My high energy line is not going to
8 take long, if you want to finish that. Then we can take a
9 break and go on to PRA.

10 MR. MICHELSON: It may take a little while.

11 MR. CARROLL: Yes. I'm afraid it may take a
12 little while.

13 MR. CROM: I'll let you decide.

14 MR. CARROLL: Let's recess and return at 10:30.

15 [Recess.]

16 MR. CARROLL: Let's reconvene.

17 Tom, do you want to continue?

18 MR. CROM: Yes. I was going to go on to high
19 energy lines.

20 [Slide.]

21 MR. CROM: The first slide here is just to
22 identify, when we talk about high energy lines, what systems
23 we're talking about inside containment, and these are all
24 listed in the SAR -- I don't recall exactly the table number
25 -- in Chapter 3, and of course, we're talking about the main

1 steam system, main feedwater system, steam generator
2 blowdown, steam generator wetlayup and recirculation,
3 reactor coolant system, safety depressurization system, the
4 chemical volume control system, safety injection and
5 emergency feedwater, and there's only portions of safety
6 injection and emergency feedwater, and those are meshed to
7 the pressure isolation valves. They are considered moderate
8 energy lines from that based on usage factors.

9 MR. CARROLL: When are we going to talk about the
10 safety depressurization system with respect to the steam
11 condensation?

12 MR. CROM: That will be in Chapter 6, which is
13 schedule on April 5th and 6th.

14 MR. CARROLL: So, you're going to be ready to tell
15 us why -- some of them hopefully will be.

16 MR. CARROLL: Why steam condenses in water, cold
17 water.

18 MR. CROM: That is in Chapter 6 and discussed in
19 Chapter 6.

20 MR. CARROLL: And the sparger design?

21 MR. CROM: Yes.

22 MR. CARROLL: And the testing you've done in
23 support of it?

24 MR. CROM: That's correct.

25 MR. CARROLL: Okay.

1 [Slide.]

2 MR. CROM: Now, my next slide is the listing of
3 the systems located -- with high energy lines -- located
4 outside of containment within the nuclear annex, and then
5 I'm going to have slides that tell you where the locations
6 of these lines are.

7 Of course, the systems we have listed are the main
8 steam system, the main feedwater system, steam generator
9 blowdown, emergency feedwater steam line to the turbine-
10 driven pump, and the chemical volume control system. I will
11 note those are small lines. They're two-inch lines in
12 letdown and also on the pumps, the charging pumps going in
13 there.

14 MR. CARROLL: Refresh our memory, Tom. What is
15 the definition of a high energy system?

16 MR. CROM: A high energy system is any system that
17 has a temperature over 200 degrees and --

18 MR. GUS: 275 psi.

19 MR. CROM: -- 275 psi. Also, you have a usage
20 factor, and I'm trying to remember what that is, you know,
21 how often it's used, and most of the safety systems, like
22 safety injection, shutdown cooling, and emergency feedwater
23 fall within the usage factor and considered moderate energy
24 lines.

25 MR. MICHELSON: In looking at your SSAR, on page

1 3.6-3, you've got an additional wrinkle on the definition
2 which maybe I just didn't remember has ever been there, and
3 the staff can comment if they wish. In addition to the
4 criteria of temperature and pressure, you've got a further
5 criterion, and that is that it's pressurized above
6 atmospheric pressure during normal plant operation. I never
7 heard of that one, but that's a part of your criteria. It
8 must also be pressurized during normal operation to be high
9 energy, and I can't believe that. It's high energy when
10 it's in operation and it's pressurized.

11 MR. CROM: Is that in the high energy section or
12 is that in the moderate energy section? I know that's a
13 true statement for moderate. It's really the usage factor
14 on high energy lines.

15 MR. MICHELSON: I think you just got carried away
16 or something.

17 MR. CROM: I don't recall that as being a
18 definition in high energy. I know it is in moderate.

19 MR. MICHELSON: I had not heard of it before, but
20 I thought maybe the staff had heard of it before, and
21 something may have been added as a wrinkle. I don't know.

22 MR. RITTERBUSCH: This is Stan Ritterbusch. Tom
23 Crom and I will take a look at those words and get it
24 straightened out.

25 MR. MICHELSON: I think it's probably just an

1 error.

2 [Slide.]

3 MR. CROM: I'm going to talk about the location of
4 these lines.

5 The main steam, main feedwater steam generator
6 blowdown, as you've probably seen -- we've shown previous
7 slides, and I'll show another one here -- penetrate on each
8 side of the containment or on each side of the divisional
9 wall. They exit from the containment through the annulus
10 through the shield wall, in-yard pipes, and then enter
11 through the main steam valve house and then exit the main
12 steam valve house through the yard, along piers, into the
13 turbine building.

14 Just a quick refresher. Unfortunately, this slide
15 does not show the lines, but we're talking, on each side,
16 this being the main steam valve houses, the penetrations
17 through the containment into the main steam valve house, and
18 the main steam lines cross the yard into the turbine
19 building.

20 MR. MICHELSON: Have you done the pressure
21 calculations for the pipe break in the valve room?

22 MR. CROM: Yes, we have.

23 MR. MICHELSON: And what pressures are we dealing
24 with?

25 MR. CROM: Todd, do you want to address that?

1 MR. OSWALD: This is Todd Oswald, Duke Engineering
2 Services. We are looking at 10 psi on that one.

3 MR. MICHELSON: Now, again, I suspect there are
4 various penetrations of that wall back into the nuclear
5 island, probably, at least for conduits and control cables
6 and I don't know what else, but I couldn't find any detail
7 that says that the penetrations can take the 10 pounds, just
8 like the wall, I'm sure, must handle it all right, but how
9 about the penetrations of the wall? I couldn't find any
10 doors, but somehow you've got to get in that area.

11 MR. CROM: There is a door.

12 MR. MICHELSON: There must be doors, and where is
13 the pressure rating on the door, or where is it dealt with?

14 MR. CROM: Todd, do you have an answer to that?

15 MR. OSWALD: It's not specifically stated.

16 MR. CROM: The answer is that they will be
17 qualified for the 10 psi.

18 MR. CARROLL: That's some kind of a door.

19 MR. MICHELSON: It will have be a big heavy steel
20 submarine-type door. For 10 pounds pressure, you're going
21 to have a real door, and 10 pounds sounds not unreasonable.
22 It's even a fairly good wall.

23 MR. OSWALD: They're four-foot-thick walls, and
24 actually, where the main steam line penetrates the walls, we
25 had to go up to five-foot.

1 MR. MICHELSON: My one concern was the
2 penetrations and what kind of sealant you have there and
3 will it take the pressure? If not, where does the steam go
4 back into? One concern is the diesel compartment is right
5 next to the -- has a common wall, in part, I think.

6 MR. OSWALD: The diesel compartment is located
7 down below grade, although it goes from elevation 50 up
8 through elevation 70. So, the roof of the diesel is
9 elevation 90, and you have the emergency feedwater tank
10 directly below the main steam valve house. About elevation
11 104 is the top of -- the bottom of the main steam valve
12 house. So, it wouldn't interfere with the diesel.

13 MR. MICHELSON: It shouldn't if there aren't any
14 penetrations. If there are, then I don't know that -- I
15 couldn't see enough of the detail to tell for sure. I
16 assume not, but it's right in that neighborhood, at least.
17 But I would expect, before we're done, to see some kind of
18 design requirements on sealing up that room against these
19 kinds of pressures, unless you can show you don't need the
20 sealant.

21 MR. CARROLL: Where does the room vent to?

22 MR. CROM: The room vents out of louvers on each
23 side of the valve house --

24 MR. CARROLL: To the outside.

25 MR. CROM: -- to the outside.

1 MR. MICHELSON: That's accounted for in the 10-
2 pound calculation.

3 MR. CROM: That's correct.

4 MR. MICHELSON: It's just a small detail, but
5 again, we would like to get an answer to it.

6 MR. CROM: Okay.

7 MR. CARROLL: Is the 10 pounds quasi-steady-state
8 pressure, or is it the peak pressure you reach until the
9 louvers open, and then does it drop to something much less
10 than that?

11 MR. CROM: Fred Carpentino, can you answer that?

12 MR. CARPENTINO: That is a peak pressure, and the
13 pressure would come down after it reached that peak, through
14 the louvers.

15 MR. CARROLL: At what sort of a level?

16 MR. CARPENTINO: I don't remember how quickly or
17 how low it dropped.

18 MR. MICHELSON: I suspect your louvers are opening
19 --

20 MR. CARPENTINO: They are very large louvers.

21 MR. MICHELSON: -- not at 10 pounds. Are they a
22 10-pound-rated louver? They open at 10 pounds?

23 MR. CARPENTINO: The louvers are always
24 pressurized.

25 MR. MICHELSON: Does it even have louvers on it?

1 MR. CARPENTINO: It's basically bird screens and
2 things like that.

3 MR. MICHELSON: Okay. That's different.

4 MR. CARPENTINO: Yes.

5 MR. MICHELSON: There's nothing dynamic about
6 that. It's always open.

7 MR. CARPENTINO: Yes.

8 MR. MICHELSON: Yes.

9 MR. CROM: Fred, before you sit down, you told me
10 that you had an answer for the question on the break
11 analysis.

12 MR. MICHELSON: Before we finish this one, though,
13 I don't know if Ivan would want to see the calculations on
14 the valve room as well as the emergency feedwater, but he
15 was very much interested in that.

16 MR. CROM: Fred, you said you could answer that
17 now.

18 MR. CARPENTINO: Yes.

19 You had asked earlier, Mr. Michelson, about the
20 pressure in the emergency feed pump room and how that was
21 calculated.

22 After thinking about it, our memory banks got back
23 into sync, and the calculation for the pump room, per se,
24 was done in a rather simple manner, by hand calculations,
25 assuming the inflow to the room was from the six-inch steam

1 line to drive the pump at critical flow conditions, at full
2 pressure, and that the venting from the room was
3 countercurrent to the inflow from the pipe, inside the pipe,
4 on the outside of the pipe, within the pipe chase itself,
5 back up to the main steam valve room.

6 So, that was done in a steady-state manner by hand
7 calculations.

8 MR. MICHELSON: Can you send us a xerox copy of
9 the hand calculation?

10 MR. CARPENTINO: We could do that.

11 MR. MICHELSON: I don't think we have to have
12 anything fancy.

13 Now, you did calculations for the valve room, as
14 well, for the case of the steam or feedwater line breaks.

15 MR. CARPENTINO: Right. That was done with a
16 computer code.

17 MR. MICHELSON: Okay. Which code did you use for
18 it?

19 MR. CARPENTINO: I believe we used our DDIF
20 computer model, which is used for the subcompartment-type
21 pressurization.

22 MR. MICHELSON: Is it written up anywhere in the
23 SAR?

24 MR. CARPENTINO: It's referenced -- I think it's
25 documented in a topical report, the number of which fails me

1 right now.

2 MR. MICHELSON: We can get the topical report.

3 MR. CARPENTINO: I believe that's a matter of
4 public record. It was reviewed the staff.

5 MR. MICHELSON: We can see it if it's referenced
6 in the SSAR. I don't think there's any question of public
7 record or not.

8 MR. CARPENTINO: Yes.

9 MR. MICHELSON: But the reference will be in
10 there. In what chapter will I look for that?

11 MR. CARPENTINO: That will be in Chapter 6,
12 referenced within 6.2, I believe.

13 MR. MICHELSON: Okay. That will do it. We'll ask
14 for the reference.

15 MR. CARPENTINO: Okay.

16 MR. MICHELSON: Thank you.

17 MR. CROM: My next bullet I think we've already
18 covered. The emergency feedwater steam line to the turbine
19 driven pump is located in the main steam valve house, in the
20 turbine driven pump rooms, and then is located -- routed
21 through the vented chase between the two rooms.

22 Finally, the two lines on the chemical volume
23 control system are located in a pipe chase after they
24 penetrate the containment and then are routed through the
25 pipe chase into the chemical volume control system area,

1 which is a non-safety area.

2 I don't have much of a slide, but the pipe chase
3 we're talking about, on the Division 2 side, is the one
4 through here, CVCS area being in this area, and then on the
5 upper elevations and then also in this elevation here.

6 MR. MICHELSON: What's the largest pipe size?

7 MR. CROM: Two inches.

8 MR. MICHELSON: Two-inch?

9 MR. CROM: Two inches.

10 MR. MICHELSON: What pressures did you get in that
11 compartment when you broke the pipe?

12 MR. CROM: That line was not analyzed.

13 MR. MICHELSON: How well vented is the room?

14 MR. CROM: That's something which is very
15 difficult. The reason it was not analyzed is you cannot do
16 an analysis until you know what all your vent spaces are.

17 MR. MICHELSON: Is it a COL action item, then, to
18 do the analysis?

19 MR. CROM: I'm not sure. Do you know, Todd, if
20 that was a COL?

21 MR. OSWALD: This is Todd Oswald, Duke
22 Engineering. Yes, there is a requirement to determine that
23 pressure once the final duct-work and all of the
24 penetrations into the room are determined.

25 MR. MICHELSON: That's a COL action item? It

1 ought to be if it's not. It's something you can't do today,
2 clearly.

3 MR. GERDES: Lyle Gerdes of ABB-CE.

4 I'm not sure, right now, in the SAR, if we've
5 identified it as a COL action item. We have defined that
6 that pipe chase will be designed for the pressures and
7 temperatures for a pipe break. That would be done in the
8 detailed design. Primarily, what that would define, then,
9 is how much rebar, how much steel you need in those walls.

10 So, again, all of the detailed design has not been
11 done. So, that would automatically become a COL action item
12 when he does the detailed design.

13 MR. CROM: I believe there is a COL action item
14 for all high energy line and moderate energy line breaks. I
15 know there is one in flood, that the COL has to consider the
16 effects of the flood and analyze all those, and also, in the
17 EQ, there's also any effects from that, too.

18 MR. MICHELSON: A further extension of the
19 question, then. Is there an ITAAC item that requires an
20 inspection, you know, walk-down and so forth, to verify that
21 these final calculations are realistic and that sort of
22 thing?

23 MR. CROM: Can you answer that, Lyle?

24 MR. GERDES: Specifically for what you questioned,
25 I don't believe the ITAAC identifies that. The ITAAC does

1 identify that all the high energy line pipe breaks and
2 protection from those pipe breaks, including pipe whip
3 sprays, jet impingement, there will be analyses and a report
4 relating to that.

5 MR. MICHELSON: But does the ITAAC require
6 verification and examination of the report in a walk-down of
7 the areas?

8 MR. GERDES: I do not believe it requires a walk-
9 down. It does require a report.

10 MR. MICHELSON: What's the staff's position going
11 to be in the case of this plant?

12 MR. TERAQ: This is David Terao. There is no
13 ITAAC that requires the walk-down, but that is specified in
14 the SSAR.

15 MR. MICHELSON: Now, in the ABWR, there is an
16 ITAAC requirement to do it.

17 MR. TERAQ: Well, the details also in the ABWR
18 were in the SAR. So, that's what we have also done on
19 System 80+.

20 MR. MICHELSON: I was only making a statement.
21 The ITAAC does require that it be verified and that a walk-
22 down be performed.

23 MR. TERAQ: That's correct. The ITAAC requires a
24 general requirement to verify it, and the details are in the
25 SAR.

1 MR. MICHELSON: Will this ITAAC have the same
2 requirement?

3 MR. TERAQ: Yes. Yes, it does.

4 MR. MICHELSON: Okay. Then we'll look for it when
5 we review the ITAAC.

6 MR. TERAQ: And the details are in the SAR.

7 MR. MICHELSON: Okay. I didn't find the details
8 in the SAR. What details are you referring to?

9 MR. TERAQ: The details as far as what would be
10 included in the walk-down and what is included in the pipe
11 break analysis report.

12 MR. MICHELSON: That's in the SAR?

13 MR. TERAQ: That's in the SAR.

14 MR. MICHELSON: I found what's in the pipe break
15 analysis report. I didn't find the walk-down part.

16 MR. TERAQ: It was added in Amendment U or V. It
17 was one of the later amendments.

18 MR. MICHELSON: I don't have those yet.

19 MR. CARROLL: Yes, you do.

20 MR. MICHELSON: Amendment T is the last one I got.

21 MR. CARROLL: Oh, no.

22 MR. COE: I had sent a large box.

23 MR. MICHELSON: I never got that box. You said
24 you were going to send it me. It was about two weeks ago we
25 chatted. I never got it, not before I left, at least, but I

1 didn't leave until just a couple of days ago.

2 MR. CROM: That's all right. I didn't get my
3 Amendment U until I just left.

4 MR. MICHELSON: Maybe that will clear it up, then.
5 All right. We'll leave it for later.

6 MR. CROM: Okay.

7 MR. MICHELSON: All right. Thank you.

8 MR. CROM: That's all I have in my presentation.
9 Any questions?

10 [No response.]

11 MR. CARROLL: We thank you.

12 Let's see. What's next, Pete? I guess we're
13 going to move on into the PRA area. Are there some remarks
14 you would like to make before we start here, Pete, since
15 you've done a fairly detailed review?

16 MR. DAVIS: Yes, a couple of things.

17 I found this one to be the most comprehensively
18 documented PRA that I've seen. When the UPS man delivered
19 this to my door, I thought it was the entire SAR, and then I
20 discovered it was only Chapter 19, all nine volumes of it.

21 MR. FINNICUM: And I was told to be terse.

22 MR. DAVIS: Let me just say a couple of things.

23 I thought it was a good PRA. I found a couple of
24 things that I like very much.

25 One of them was a comparison of the as-built or, I

1 should say, as-currently-designed plant versus the PRA-
2 assumed design, because there have been some changes made
3 since the PRA was finished, and that was very helpful, and
4 this may have been because of the staff's requirements, I
5 don't know.

6 You also had at least one operator-active
7 commission, which is not commonly found in PRAs. This is
8 the inadvertent entry into the feed-and-bleed mode by the
9 operator. I don't know if there are any other acts of
10 commission in there, but that one was certainly prominent.

11 One thing that troubled me a little bit -- I had
12 trouble finding the results. I'm used to seeing those up
13 front, but that wasn't the case in this PRA, and I had to
14 dig around to find the results. It's always useful for a
15 reviewer to know the results first, I think, so he can
16 determine what's important and what isn't as he goes through
17 the review. That's just an editorial comment.

18 One of the things that bothered me a little bit is
19 that there are a number of assumptions made in the PRA that
20 don't have any basis attached to them, and it's not clear
21 that those assumptions are tied back into a design
22 requirement anywhere.

23 I suspect a lot of the assumptions did come from
24 the design requirements, but it's not so stated in many
25 cases. I can give you a few examples as we move along.

1 It would have been helpful, I think, to show or at
2 least refer to where this assumption can be validated.

3 One of them you make is there aren't any
4 combustible materials in the electrical cabinets in the
5 control room, and that's just an assumption that's stated,
6 and that's used as part of your argument that you can't get
7 a fire in the control room and that's not a contributing
8 factor to the fire Core Damage Frequency.

9 In all other PRAs that look at fires that I'm
10 aware of, the control room fire is usually the dominant
11 contributor. So, it was a little bit unusual to see, in
12 this case, that it was screened out, and I think you had
13 some pretty good arguments for that, but that has to be
14 reflected back into the design requirement.

15 [Slide.]

16 MR. FINNICUM: Let me just sign in, and then I'll
17 tell you.

18 As I mentioned yesterday, my name is David
19 Finnicum, with ABB, and I am the Task Manager for the System
20 80+ PRA.

21 One question I have -- have you received Amendment
22 U and looked at that?

23 MR. COE: Yes.

24 MR. FINNICUM: That would be the large box.

25 MR. DAVIS: Yes, I think so. I couldn't read all

1 nine volumes, I must confess.

2 MR. FINNICUM: Okay.

3 In Amendment U, in section 19.15.1, there is a new
4 table that was added in Amendment U that was specifically
5 added late to cover ongoing analyses.

6 What that table describes are the -- it's called
7 the "Important Insights and Assumptions," and ABB-CE and the
8 NRC staff had gone through the PRA and identified the
9 important PRA insights in that and tied it back either to
10 what we call Certified Design Material, which is ITAAC
11 information, or Tier 2 information, which is information to
12 be found in the SAR, or to COL action items.

13 The combustible material assumption that you
14 specifically referenced that is specifically addressed in
15 that table. It is tied back to design statement: in -- I
16 believe it's Chapter 7 of CESSAR-DC. We understand there
17 were a number of assumptions.

18 MR. CARROLL: It seems to me that one of the
19 points that was made during the discussion of Chapter 7 was
20 that, given the kind of control room you have -- you don't
21 have high voltages, you've got fiber -- that you just don't
22 have the combustible loading that traditional control rooms
23 have had. Is that not the case?

24 MR. FINNICUM: This is true, yes.

25 MR. MICHELSON: They certainly can still burn.

1 You've got a lot of wiring in the control room. You've got
2 at least 110-volt equipment, probably, may even have some
3 220 in certain power supplies and so forth, I don't know, I
4 haven't seen that level of detail, but you're not claiming
5 it's all 24-volt inside the control room.

6 MR. FINNICUM: No, we're not. What we are
7 claiming, as in the design, is that the materials used
8 within that, other than the metal, would not sustain
9 combustion.

10 MR. MICHELSON: What kind of wiring are you using
11 for all your instrument wiring in the cabinets and whatever?
12 What kind of insulation are you using on the wiring?

13 MR. RITTERBUSCH: We can't answer the details
14 today. I do know that there was quite an extensive review,
15 and the conclusion was that there was a very significantly
16 reduced risk of fire in the control room.

17 MR. MICHELSON: I don't doubt there's a
18 significantly reduced loading of combustibles, there's no
19 doubt of that, but it's still combustible, and you still
20 have to treat it accordingly.

21 MR. DAVIS: Well, the staff points out in the FSER
22 that there are a lot of documents, of course, that are
23 combustible and procedures and so forth.

24 MR. MICHELSON: Unless they've got some exotic
25 insulation now, the wiring is, too. In fact, some of the

1 instrument wiring is worse than the big power wiring.

2 MR. CARROLL: Some operators I've known have been
3 known to burn procedures, too.

4 MR. FINNICUM: That was generally in the manager's
5 office.

6 MR. MICHELSON: That's a good regulation to think
7 about, isn't it?

8 MR. RITTERBUSCH: This is Stan Ritterbusch.

9 Mr. Michelson, I know you have a question. I'm
10 not sure what the action is to resolve it. Do we owe you
11 something on that issue?

12 MR. MICHELSON: I was only commenting on what Pete
13 had read, I think, to the effect there wasn't any
14 combustible, and apparently, there is combustibles in the
15 control room, I think a significant amount, but it's nowhere
16 near what it used to be.

17 MR. LINDBLAD: I think there's one issue about
18 what is the definition of support combustion. Does it flame
19 or does it smoke or does it smolder? I think that we've
20 kind of identified that it probably won't ignite from --

21 MR. MICHELSON: This low-voltage stuff, unless
22 they've gone to some of the -- there are some that won't
23 ignite, but unless they've spent the money to get that for
24 their low-voltage stuff, that's good stuff to burn. Wiring
25 doesn't have to have much insulation, and it burns nicely

1 unless you buy the --

2 MR. CARROLL: Yes, but in a manned area, you're
3 talking about a local situation if you have some kind of a
4 fault. I believe that people are going to be put that kind
5 of fire out in a big hurry.

6 MR. WYLIE: There are insulations that, I'll say,
7 won't burn.

8 MR. MICHELSON: There are, yes. That's why I
9 asked which ones they're using for this plant.

10 MR. WYLIE: If they're using those, then they
11 don't have a problem as a source from their wiring itself.

12 MR. MICHELSON: Precisely.

13 MR. WYLIE: Now, is that the case?

14 MR. MICHELSON: They didn't know yet.

15 MR. RITTERBUSCH: We can find some additional
16 detail and provide it when we hit Chapter 9 in early April.
17 I don't think we contend that fires are so small -- the
18 likelihood of fire is so small that we won't have to ever
19 evacuate the control room. We realize that we may. What we
20 demonstrated is that there was adequate time so that
21 transfer could be -- control could be transferred, and then
22 they would exit and go down to the remote shutdown panel
23 room.

24 MR. MICHELSON: Yes. I think all that is supposed
25 to be factored into the PRA, including the probability of

1 the failure, you know, the fire and so forth, and you've got
2 to do it right. I don't know -- they may be using
3 polyethylenes for all this 24-volt stuff. It's real good
4 insulation. It just kind of burns a little bit.

5 MR. WYLIE: Well, there is the Raychem insulation
6 systems that were developed for aircraft --

7 MR. MICHELSON: Yes, and they're good

8 MR. WYLIE: -- and they are very good. don't
9 really burn.

10 MR. MICHELSON: But I didn't find anywhere --

11 MR. WYLIE: The wires will fuse before the
12 insulation will burn.

13 MR. MICHELSON: But I didn't find any commitment
14 to that kind of insulation in the control room.

15 MR. RITTERBUSCH: We will describe our commitments
16 at our next meeting.

17 MR. MICHELSON: And then you can judge fire
18 accordingly.

19 MR. SALTOS: This is Nick Saltos from the NRC.

20 We looked at -- we did a scoping study, a risk
21 study, considering a fire in the control room and how the
22 functions would be transmitted to the remote shutdown panel
23 and what functions would be accessed from the remote
24 shutdown panel, and we found that there is enough hard-wire
25 for those functions that the risk is --

1 MR. MICHELSON: I don't think anyone is
2 questioning the design of the remote shutdown arrangement at
3 all. That wasn't the point. The point was what the PRA is
4 doing, and if they assume no combustibles in the control
5 room, I think they've missed a point somewhere.

6 MR. SALTOS: But we assume that it can happen with
7 a certain frequency, and we're trying to see how they can
8 take care of it from the shutdown -- how the plant can be
9 shut down from the remote shutdown panel.

10 [Slide.]

11 MR. FINNICUM: Briefly, what I want to talk about
12 today is briefly to identify the objectives of the PRA,
13 provide a brief description of the approach we used
14 throughout the entire PRA and a brief description of the
15 methodology, primarily discuss the results we have, and
16 there are a couple of specific ACRS questions, issues that
17 have been brought up in other areas that were pertinent to
18 the PRA that I'm providing information on.

19 [Slide.]

20 MR. FINNICUM: Specifically, the objectives of the
21 PRA performed for the System 80+ plant are we had to comply
22 with the Severe Accident Policy Statement for providing a
23 Level III PRA for an ALWR design; we have to demonstrate
24 compliance with the EPRI ALWR Mean Core Damage Frequency
25 Goal of 1 times 10 to the minus 5th events per year;

1 demonstrate compliance with a large release goal of 10 to
2 the minus 6th events per year; and to demonstrate our
3 containment performance and reliability. In addition, our
4 internal objective was to use the PRA to support the design
5 of the plant.

6 [Slide.]

7 MR. FINNICUM: The basic approach we used was to
8 establish a baseline PRA for System 80+ using our currently
9 certified design of the System 80. This is an NSSS design.
10 We do have an operating plant, the Palo Verde plant, in
11 operation, but the PRA was based on the certified NSSS
12 design in CESSAR-F.

13 We used a balance of plant which was basically an
14 amalgam of balance of plant for recent vintage CE plants. It
15 was not strictly representative of any given CE plant.
16 Basically, it was a BLP that would meet the interface
17 requirements.

18 We then used the PRA as an evaluation tool for
19 assessment of certain design changes, and through the
20 process, the PRA that started out as a System 80 PRA evolved
21 to the System 80+ PRA.

22 We prepared, then, the Level III PRA for the
23 System 80+, and this included an evaluation of the external
24 events.

25 [Slide.]

1 MR. FINNICUM: With the Level I portion of the
2 analyses, the determination of Core Damage Frequency, we
3 used pretty much standard methodology. We used the small
4 event tree/large fault tree approach, which is used by most
5 of the current PRA practitioners, with the exception,
6 primarily, of Pickard, Lowe & Garrick.

7 Our front line system models address both the
8 system component failures, we look at common cause faults,
9 maintenance unavailability, operator actions, and we
10 included a full support system model, including electrical
11 power and component cooling.

12 The support system models were modeled to the same
13 level of detail as the front line system models, and we
14 solved this using the CAFTA code and performed full fault
15 tree linking for the analysis.

16 MR. CARROLL: How would you characterize the
17 approach that Pickles, Lox & Bagels uses on --

18 MR. FINNICUM: It is typically characterized as a
19 large event tree/small fault tree.

20 MR. CARROLL: Okay.

21 [Slide.]

22 MR. FINNICUM: For the external events, the first
23 step in the evaluation was basically a qualitative screening
24 of external events. There is a very large listing that has
25 been prepared by EPRI identifying many things.

1 We went through, grouped like events, things that
2 had like effects, and looked at elements that could be
3 grouped together as covered by existing events or things
4 that could be covered as one event or things that, based on
5 the standard site requirements, could be excluded. Such
6 things as landslides, volcanoes were basically excluded from
7 further quantitative analysis.

8 What we then did is identified events that were to
9 be evaluated in more detail, either quantitatively or in
10 more detail qualitatively.

11 The events we looked at were the tornado strikes,
12 seismic events, which we used the seismic margin assessment
13 for, and a scoping evaluation for internal fires and floods.

14 MR. SEALE: Could I confirm that you did verify
15 that the hurricane problem was subsumed with the range of
16 external assaults, if you will, that you had in this
17 assessment?

18 MR. FINNICUM: Yes. It was subsumed within the
19 tornado. The main impact was the wind velocity, and the
20 tornadoes have larger wind velocities.

21 MR. SEALE: And some flooding.

22 MR. FINNICUM: Yes, some flooding. With the
23 layout of our site, it should not produce significant
24 external flood threat. So, the main threat was the wind
25 loads.

1 MR. CARROLL: But for some sites, hurricanes could
2 be different than tornadoes in that they do produce
3 flooding, whereas a tornado typically doesn't.

4 MR. FINNICUM: Correct.

5 MR. CARROLL: Okay.

6 MR. EL-BASSIONI: This is El-Bassioni, the PRA
7 branch of NRR.

8 Part of the post-certification tasks for the COL
9 holder will be integrating site specifics. So, this would
10 be addressed by the COL holder.

11 MR. CARROLL: We were just talking generally.

12 MR. LINDBLAD: Did I understand, then, on external
13 floods, there is no PRA for external floods?

14 MR. FINNICUM: There is no PRA for external
15 floods, based on the design we have of site requirements,
16 where it's sloped away from it, and that the maximum flood
17 level is one foot below grade.

18 MR. LINDBLAD: Mr. Michelson has this concern
19 about umbilicals and penetrations that are supposedly
20 sealed, but the seal, over a period of years, might fail,
21 and one doesn't identify the seal to fail until there is
22 water in the sump. That was not considered a major issue?

23 MR. FINNICUM: No, that was not considered.

24 MR. MICHELSON: They don't know where the seal is,
25 and until you know that, you don't know whether it's a major

1 issue or not.

2 [Slide.]

3 MR. FINNICUM: Shutdown risk was also identified
4 in the PRA. The basic Level I analyses were performed for
5 at-power --

6 MR. CARROLL: You deliberately skipped a slide, or
7 we're out of order?

8 MR. FINNICUM: Oh, I'm sorry. I did not
9 deliberately skip a slide. Yesterday I had pulled the
10 seismic margin slides. If you'd like me to go back over
11 those again --

12 MR. CARROLL: Are we all happy? Okay. Moving on.

13 MR. FINNICUM: Okay.

14 As I said, the main Level I PRA covered at-power
15 events, which were considered to cover Modes 1, 2, and 3.

16 We also performed a shutdown risk analysis. In
17 this case, basically had developed an outage profile, or
18 Duke Engineering had developed an outage profile. This
19 outage was divided into four plant operating states.

20 The first one was a Mode 4 or Mode 5 with normal
21 inventory and Mode 6 with the IRWST full and refueling
22 cavity empty. For these different conditions, it was all
23 assumed to be at the equivalent in plant configuration.

24 The second operating state was what is called Mode
25 5R. In other words, it was in Mode 5, it was reduced

1 inventory, and this includes the mid-loop operation.

2 The third plant operating state was Mode 6E. This
3 is the case when we're in a refueling outage, with the IRWST
4 empty, with the refueling cavity full, and the upper
5 internals removed. In other words, the inventory from the
6 IRWST has been transferred into the refueling cavity.

7 And finally, the fourth mode was Mode 6I. Again,
8 the refueling cavity is full, with the IRWST empty but with
9 the upper internals in place.

10 For each of these plant operating states, event
11 trees were developed for four types of events. The first
12 one was a loss of decay heat removal or DHR, the second was
13 a small LOCA on drain-down events, third is fire, and fourth
14 was the loss of offsite power.

15 MR. CARROLL: So, you're not considering in these
16 event trees certain things. One that comes to mind are
17 dropping of a heavy load damaging fuel.

18 MR. FINNICUM: We did not include an event tree
19 for that event.

20 Eric, do you want to address more on that?

21 MR. SIEGMANN: My name is Eric Siegmann.

22 We did, as part of the review of shutdown risk, a
23 look at dropping heavy items and considered, because of
24 either procedures -- that is, paths of moving heavy items
25 and such -- or because of the robustness of the piping, that

1 dropping of heavy items was not risk significant, and that's
2 discussed in Appendix 19.8A, which is a mechanistic risk
3 assessment.

4 MR. CARROLL: Okay. What other kinds of things
5 did you look at that aren't covered by event trees? That's
6 one.

7 MR. FINNICUM: We have some back-up slides on the
8 mechanistic analyses that were done. If you would like us
9 to present that at this time, we could, or if you would
10 like, we could hold it till later.

11 MR. CARROLL: Let's hold it till we get into
12 shutdown risk.

13 MR. FINNICUM: Okay.

14 MR. RITTERBUSCH: We can certainly summarize by
15 saying we looked at all of the issues identified by the
16 staff and also documented in NUREG-1449. It was quite a
17 thorough review.

18 MR. DAVIS: Did you look at seismic events during
19 shutdown?

20 MR. FINNICUM: No, we did not.

21 [Slide.]

22 MR. FINNICUM: Within the shutdown risk, the
23 initiating event frequencies that were used were taken from
24 the Brookhaven National Lab 1991 study. We developed fault
25 trees for each of the branch points in the event trees, and

1 these were based on modifications of the Level I fault
2 trees.

3 Within this, shutdown risk is heavily dependent
4 upon operator actions. The human error probability that we
5 used within the analysis were really developed for two basic
6 response times. One was a 40-minute response time for
7 reduced inventory conditions and, secondly, a two-hour
8 response time for all other events.

9 MR. CARROLL: What does the 40 minutes mean? What
10 happens in that time period?

11 MR. FINNICUM: Eric Siegmann will address that
12 specifically.

13 MR. SIEGMANN: The 40 minutes represents the time
14 to boil off the reactor coolant from the bottom of the hot
15 leg to the active core and then heating up the active core
16 until the onset of clad damage.

17 MR. DAVIS: This would be a mid-loop operation
18 condition?

19 MR. SIEGMANN: Yes.

20 MR. CARROLL: Okay. And you're saying that the
21 operators are capable of responding to this within 40
22 minutes?

23 MR. SIEGMANN: Yes, we are, because of the
24 instrumentation available to the operator and alarms and
25 such.

1 MR. CARROLL: How much margin is there?

2 MR. SIEGMANN: By the way, we calculated an error
3 rate for the operator.

4 MR. DAVIS: Yes. There still is an error
5 probability that he won't do it.

6 MR. SIEGMANN: Right.

7 MR. CARROLL: But assuming he does do it, does he
8 just make it, or is there some margin here? You tell me
9 it's 40 minutes until the bad things happen.

10 MR. SIEGMANN: It isn't a case that he does or
11 doesn't make it. Well, actually, on each branch point,
12 there is a case he does or doesn't make it. If he doesn't
13 make it, that's basically failure just like failure of a
14 mechanical thing. He doesn't half make it. But there's
15 basically a probability that he does or doesn't make it.

16 MR. CARROLL: But a success path would be
17 completed how much sooner than --

18 MR. FINNICUM: I think the timing was developed
19 such that, if the operator was capable of performing the
20 action, either start an injection or restore heat removal,
21 within the 40 minutes, that he would make it. If it was
22 longer than 40 minutes, then we would have seen onset of
23 core damage, and at this point, one of the assumptions we
24 made throughout the PRA is, once we had the onset of core
25 damage, that was called core damage.

1 MR. CARROLL: Okay. I'm happy.

2 MR. DAVIS: I may be getting ahead of you here,
3 but in your shutdown risk analysis, typically the
4 containment will be open for part of that, if not most of
5 it, and are you able to close the containment up if loss of
6 offsite power occurs?

7 MR. CARROLL: Yes.

8 MR. FINNICUM: Eric Siegmann can address that.

9 MR. SIEGMANN: Yes, we are.

10 MR. DAVIS: How long does that take?

11 MR. SIEGMANN: We will be able to close the
12 containment in one hour.

13 MR. DAVIS: One hour. Okay. Thank you.

14 MR. CARROLL: And you have considered all the
15 things that might be -- all the cables and steam -- maybe
16 not a steam generator but a coolant pump motor in the
17 process of going through the equipment hatch. In one hour,
18 you can clear all that out of the way and get the hatch
19 closed.

20 MR. FINNICUM: Again, Eric.

21 MR. DAVIS: With the lights out.

22 MR. CARROLL: With the lights out.

23 MR. SIEGMANN: We do not plan to have any cabling
24 run through the equipment hatch during shutdown modes, and
25 as far as probabilistically, I haven't addressed, you know,

1 the probability of having an RCP pump motor in the hatch at
2 the time of the blackout or whatever, but when you're
3 getting into multiple events of RCP replacement followed by
4 station blackout, you're going to be well beyond design
5 basis accidents.

6 MR. CARROLL: So, in other words, the hour assumes
7 that there is nothing blocking the hatch at time zero.

8 MR. SIEGMANN: That's correct.

9 MR. CARROLL: What occupies the hour? What has to
10 happen at time zero plus?

11 MR. SIEGMANN: By the way, at mid-loop, the
12 containment will be closed.

13 MR. CARROLL: Always?

14 MR. DAVIS: That's required?

15 MR. SIEGMANN: Yes.

16 MR. CARROLL: Okay. So, at time zero, something
17 has happened to suggest that we ought to get the equipment
18 hatch closed. Some time is devoted to getting some people
19 up there, and the rest is just operations that are required
20 to swing the thing back in place and get four bolts in it?

21 MR. CROM: This is Tom Crom from Duke Engineering.

22 I wanted to mention that we have considered in the
23 design, you know, a lot of the questions you've asked, that
24 we do not have to run cables particularly for steam
25 generator eddy current testing, the known types of tests

1 that have to currently be done on plants, that we provide
2 provisions that you can hook that type of equipment up
3 inside containment rather than run the cables right through
4 the equipment hatch.

5 We also have a design that says you can do most of
6 your pre-staging of all your equipment, you know, moving of
7 equipment in and that type of thing, before you would go to
8 mid-loop operation, such that the equipment hatch can be in
9 place, so it can be closed quickly.

10 We also have the motors on the trolleys powered
11 off of the battery such that they will close, you know,
12 during the station blackout event.

13 MR. FINNICUM: Does that answer your question?

14 MR. CARROLL: I guess so.

15 [Slide.]

16 MR. FINNICUM: For the Level II analyses, the
17 process we followed was to define a set of plant damage
18 states by defining plant damage state parameters and then
19 grouping them to develop individual plant damage states
20 based on parameter values, and we quantified the probability
21 of getting a given plant damage state using the Level I
22 information. We then developed our containment event tree
23 and supporting logic models.

24 Like in the Level I analyses, we used what could
25 be referred to as a small event tree/large fault tree

1 approach. In NUREG-1150, they use rather large
2 decomposition trees. I personally have always had trouble
3 trying to follow them, so I moved to a methodology that I
4 could follow a little easier, where we had a containment
5 event tree that looked at the high level -- the containment
6 failure -- the high level failures, early containment
7 failure, late containment failure, major phenomena that
8 affect the source term, and address the details of the
9 phenomenology in supporting logic models, and then we were
10 able to solve the CET or to quantify the CET for each of our
11 plant damage states.

12 From that, we were able to define a release class
13 where each end point on the CET was considered to be a
14 unique release class based on how it was defined originally.
15 We could assign a probability to that end point based on the
16 quantification process.

17 We did not do a full uncertainty analysis on this
18 equivalent to that that was done for NUREG-1150. We
19 basically propagated it through what would be considered
20 mean probabilities. We did perform sensitivity analyses for
21 selected parameters.

22 [Slide.]

23 MR. FINNICUM: For the Level III analyses, the
24 risk measure that we were using is basically a dose at a
25 half-mile from the reactor. This is based on the EPRI goal,

1 which is that the probability of exceeding a release of 25
2 rem at a half-mile from the reactor would be less than 10 to
3 the minus 6th.

4 We used the MACCS code for determining the dose at
5 the distance. This basically used meteorological data for a
6 bounding site, and this information was provided by EPRI via
7 the URD.

8 We did not use demographic or population data for
9 calculating the dose at distance, although it was input into
10 the code.

11 Within the calculation, we assumed that there was
12 no evacuation, and we calculated the cumulative --
13 complementary cumulative distribution function for the whole
14 body dose at .5 miles and also at 300 meters from the
15 reactor, and again, we performed a set of sensitivity
16 analyses for selected issues.

17 MR. DAVIS: Let me ask you a couple of questions,
18 if I may.

19 I couldn't tell for sure if your fire results had
20 been used in the Level III analysis.

21 MR. FINNICUM: The fire and flood -- the fire,
22 flood, and seismic margin analyses were not propagated into
23 the Level II and III.

24 MR. DAVIS: Okay. So, these risk results don't
25 include those contributions.

1 MR. FINNICUM: No, they do not.

2 MR. DAVIS: Secondly, I couldn't find anywhere a
3 comparison of your results with the NRC safety goals. Is
4 that something you did, or did the staff try to do that?

5 MR. FINNICUM: We did not specifically do that.
6 The rationale was that the other safety goals are primarily
7 risk to a population. The population risk requires
8 inputting the population data, and what we really had was
9 generic, for no specific site.

10 MR. DAVIS: Right.

11 MR. FINNICUM: That's why we did look only at dose
12 at distance and figured that would give an indication.

13 There are several areas where there might be no
14 change in risk from dose at distance but might have an
15 impact on risk if you looked at some of the other measures,
16 but in looking at what our probability of exceeding the dose
17 at 25 rem at half-mile was, it was very low. We did not
18 feel that we would see any significant change in the other
19 risks.

20 MR. KRESS: Pete, if you look at their Core Damage
21 Frequency and their Conditional Containment Failure
22 Probabilities, then you can infer that they meet the safety
23 goals.

24 MR. DAVIS: There is no question in my mind that
25 it meets it. I was just surprised you didn't make the

1 comparison, because that is one of the primary indices of
2 the risk comparison.

3 MR. EL-BASSIONI: This is El-Bassioni, PRA branch
4 in NRR.

5 We didn't press for that comparison, because we do
6 not have a full scope PRA including -- as you know, we have
7 done margins analysis, for example, for seismic, and most of
8 the external events were not explicitly calculating Core
9 Damage Frequency, for example, and they have mentioned, many
10 of the analyses and external events were not propagated to
11 Levels II and III. This is why we didn't press very hard
12 for that. But eventually, if we are going to have a living
13 PRA, this comparison will be done.

14 MR. DAVIS: Thank you.

15 MR. CARROLL: You said "if." What is the status
16 of the living PRA with respect to the Advanced Light Water
17 Reactors?

18 MR. EL-BASSIONI: The staff is still working about
19 what's meant by a living PRA, and we hope that there will be
20 a Commission paper within a few months.

21 MR. DAVIS: But on page 19-25 of the FSER, it
22 states that the PRA is to be revised by the COL to account
23 for site-specific information.

24 MR. CARROLL: But that doesn't make it living.

25 MR. DAVIS: As-built info, tech specs, operating

1 procedures, design changes, failure rates, and human errors
2 are to be updated.

3 MR. CARROLL: That's just an update. That's not a
4 living PRA.

5 MR. DAVIS: I don't know what your definition of
6 living is.

7 MR. CARROLL: Through the life of the plant.

8 MR. EL-BASSIONI: The PRA will evolved till the
9 plant is operational. Then it will be a living PRA, but the
10 staff did not define under what conditions this PRA will be
11 updated. Are we going to have triggers for updating the
12 PRA, or we're going to have periodic, and if it is periodic,
13 what is the span of this period?

14 MR. CARROLL: Okay. And you're still working on
15 that.

16 MR. EL-BASSIONI: Yes.

17 MR. CARROLL: Okay.

18 [Slide.]

19 MR. FINNICUM: The next area I want to talk about
20 are the PRA results. The next two slides really go much
21 together. I will talk about them together, but I will
22 present them individually.

23 [Slide.]

24 MR. FINNICUM: What I am showing is the Core
25 Damage Frequency contributions by initiating event for our

1 PRA.

2 What I show is the original PRA we did, the
3 baseline, the Core Damage Frequency contributions. These
4 were performed to a set of ground rules in effect
5 essentially in 1986.

6 MR. CARROLL: Whose ground rules?

7 MR. FINNICUM: These are basically the EPRI ground
8 rules.

9 MR. CARROLL: Okay.

10 MR. FINNICUM: And I will address that in
11 conjunction with the slides.

12 We then upgraded that to a System 80+
13 configuration based on the design features using the same
14 ground rules. This was performed shortly thereafter, and we
15 have a comparison, and the bottom total for the original
16 System 80 baseline -- we have a Core Damage Frequency of 8
17 times 10 to the minus 5th per year, and for the System 80+
18 PRA, performed to the same ground rules, we have a Core
19 Damage Frequency of 6.7 times 10 to the minus 7th. This
20 represents an improvement of about two orders of magnitude,
21 and what we've looked at is how did we get there?

22 MR. CARROLL: Okay.

23 Now, going back to the original ground rules,
24 what's Palo Verde's CDF?

25 MR. FINNICUM: I did not have that. We did not

1 calculate a Palo Verde CDF.

2 MR. CARROLL: I would guess, if it's like the PRAs
3 on a lot of PWRs, it's another order of magnitude -- well,
4 maybe not. Yes, maybe another order of magnitude higher.

5 MR. DAVIS: Than what?

6 MR. CARROLL: Than the 8 times 10 to the minus
7 5th.

8 MR. DAVIS: I'd be surprised if it was that high.

9 MR. CARROLL: It would be higher, though, wouldn't
10 it, Pete?

11 MR. DAVIS: No, I don't think so. Most of them
12 are coming in around 10 to the minus 4.

13 MR. CARROLL: Okay.

14 MR. DAVIS: I don't think one has been done on
15 Palo Verde except for the IPE submittal. I don't whether
16 that's come in or not.

17 MR. FINNICUM: I'm not sure whether they finally
18 submitted that.

19 MR. EL-BASSIONI: I don't have any number for Palo
20 Verde.

21 MR. FINNICUM: They have submitted their IPE. I
22 saw it recently. I don't recall the exact number, but I can
23 get that for you.

24 MR. CARROLL: Okay. Go ahead.

25 MR. FINNICUM: There are, across the board,

1 reductions in Core Damage Frequency, and we looked at what
2 are the major design contributors. If you look, we have a
3 fairly substantial reduction in large LOCA.

4 The things that really contribute to this -- we
5 have the in-containment refueling water storage tank, which
6 eliminates the need for the RAS, the changeover for
7 recirculation. That has always been a problem in existing
8 plants.

9 The other big item was the four-train ECCS, which
10 provides a high level of redundancy.

11 Other major contributors also include the reliable
12 power source, the two diesel generators, the stand-by
13 combustion turbine, the grid connections, and the -- that's
14 primarily the impact.

15 Likewise, for a medium LOCA, we again have a
16 substantial reduction, and it's basically the same thing as
17 the IRWST and the four-train ECCS.

18 For small-break LOCA, again a substantial
19 reduction. In this case, the four-train ECCS is an
20 important feature, also the four-train EFWS. We do need
21 secondary side heat removal for small LOCA, and we have a
22 very reliable emergency feedwater system.

23 For the other item, for secondary side break,
24 again a substantial reduction, and again, it's the reliable
25 ECCS, the reliable emergency feedwater system, and also the

1 reliable power systems and the change in that, and likewise
2 for the tube ruptures, and basically, the transients-related
3 items, again it's the -- the impact is the four-train
4 emergency feedwater system and the reliable power system,
5 and for transients, the capability of a diverse means of
6 cooling, the feed-and-bleed cooling capability provided by
7 use of the depressurization valves, helps to make a
8 substantial reduction in the transient.

9 Loss of offsite power -- again, a substantial
10 reduction. This impact is primarily with the two diesel
11 generators and the alternate AC source, highly reliable
12 feedwater system. We do have six batteries, primarily the
13 four division -- or the four channel batteries and two
14 division batteries, and plus, with the turbine run-back
15 feature and the two switchyards, make an impact on reducing
16 the frequency for a loss of offsite power.

17 MR. CARROLL: Now, when you make these CDF
18 numbers, do you consider the fact that, during the life of
19 the plant, there are going to be periods of time when, say,
20 one diesel generator is out of service?

21 MR. FINNICUM: We did include diesel generator
22 maintenance elements in the fault tree models.

23 MR. CARROLL: And what did you assume for the
24 frequency and duration of maintenance during operation?

25 MR. FINNICUM: During operation, what we assumed

1 for maintenance unavailability is we looked at the test
2 frequency for the diesels and the assumed failure rate for
3 the diesels and calculated a probability of the diesel
4 having failed a test, and we then assumed the full allowed
5 outage time.

6 MR. CARROLL: Seventy-two hours or something like
7 that?

8 MR. FINNICUM: Correct.

9 MR. CARROLL: Okay. All right. I see what you're
10 doing.

11 MR. FINNICUM: Again, for ATWS, not quite as
12 substantial reduction but still good reduction.

13 Inter-system LOCA, we did see a substantial
14 reduction. This reduction is primarily due to a dedicated
15 effort to eliminate interfacing system LOCAs. Primarily, we
16 have high-pressure piping in areas that were subject to the
17 inter-system LOCA problem seen on current plants.

18 Finally, we have vessel rupture. This is a WASH-
19 1400 carryover. We include it because it was in WASH-1400,
20 and I really can find no valid basis for excluding it at
21 this time.

22 MR. FRANOVICH: You've probably got a better
23 vessel, though.

24 MR. FINNICUM: I do have a better vessel, but I
25 cannot statistically justify eliminating it.

1 MR. KRESS: On your interfacing systems LOCA, the
2 original number comes out that low because of some assumed
3 probability that your isolation valves will work. What did
4 you use for that probability?

5 MR. FINNICUM: It was based on a calculation using
6 a valve failure rate per hour.

7 MR. KRESS: That comes out of the standard valve
8 failure rate.

9 MR. FINNICUM: Yes.

10 MR. KRESS: That's one of our sore points, using
11 that particular value for interfacing system LOCAs, because
12 those failure rates don't include the blowdown loads.

13 MR. FINNICUM: These are static valves, and we
14 assume they failed open. Either you blew the disk out or
15 you had a disk failure and did not --

16 MR. KRESS: Those are the static valves.

17 MR. FINNICUM: Yes. The primary risk areas are
18 the --

19 MR. DAVIS: They're normally closed?

20 MR. FINNICUM: Yes.

21 MR. WYLIE: On your loss of offsite power numbers,
22 if you assumed that your combustion turbine is not
23 available, would the numbers come out the same?

24 MR. FINNICUM: No.

25 MR. WYLIE: What would they come out at?

1 MR. FINNICUM: I don't know whether I have that.

2 MR. CARROLL: You have a big section in the back
3 here on --

4 MR. FINNICUM: Yes.

5 MR. CARROLL: -- on this issue, Charlie.

6 MR. WYLIE: Oh, okay.

7 MR. CARROLL: He's going to get to it, I think.

8 MR. WYLIE: All right.

9 MR. FINNICUM: It's in the slide package. I'm
10 going to get to it.

11 MR. CARROLL: Let me ask about seal LOCA.

12 MR. FINNICUM: Okay.

13 MR. CARROLL: You have a dedicated seal injection
14 pump that does not require cooling water or a positive
15 displacement pump.

16 MR. FINNICUM: Correct.

17 MR. CARROLL: How long does it take -- now, is
18 that manually placed in service under station blackout
19 conditions?

20 MR. FINNICUM: It would be manually started from
21 the control room.

22 MR. CARROLL: And is there valving to be done with
23 it, too? My question is how long does it take to --

24 MR. FINNICUM: I cannot remember the details of
25 valving, whether they have to open some specific valves or

1 not. We can get back to you on that.

2 MR. CARROLL: Okay.

3 MR. FINNICUM: Just one second. Mike? Mike
4 Cross?

5 MR. CROSS: Mike Cross from ABB.

6 There would be no valves that would have to be
7 opened. It would be in parallel with the current charging
8 valves that -- charging pumps -- excuse me -- that are with
9 the chemical volume control system. So, you would have two
10 centrifugal pumps, and in parallel with them would be a
11 positive displacement pump.

12 MR. CARROLL: And all I've got to do is turn it
13 on.

14 MR. CROSS: That is correct.

15 MR. CARROLL: So that looks like it's something
16 you could do within 10 minutes. Is that correct?

17 MR. FINNICUM: Yes.

18 MR. CARROLL: Okay.

19 MR. DAVIS: I think, originally, that CE's
20 contention was that those seals wouldn't fail anyway, and
21 this was added, I think, mostly because of the staff's
22 concern over this seal LOCA. Isn't that true?

23 MR. FINNICUM: This is true. It's still CE's
24 contention that the seals would not fail under those
25 conditions, but we do have the back-up pump.

1 MR. CARROLL: And it can be powered by either the
2 diesels or the AAC.

3 MR. FINNICUM: Correct.

4 MR. CARROLL: Okay. Our interest in this is that
5 GI-23 is still kicking around out there, and the last time
6 the issues resolution guys from RES came down, they were
7 arguing that, at least on a Westinghouse plant, unless you
8 got the back-up system in service within -- I think it was
9 10 minutes, the front of hot water would reach the seals,
10 and the ball-game was over, mechanistically, at least. You
11 had a 440-gallon-a-minute leak on each pump that you
12 couldn't recover from.

13 MR. FINNICUM: I understand.

14 MR. CARROLL: We sort of said, you know, tell us
15 about this probabilistically, and well, no, that's the way
16 it is. So, it sounds like you've come up with a solution to
17 this.

18 When we met with the Germans and French last year,
19 their solution is basically a little different. They don't
20 -- the French have tried a pump, a turbine-driven pump, and
21 found that it had some problems, because the steam generator
22 pressure keeps changing, and it affects the performance of
23 the pump.

24 I guess their approach now is a mechanical design
25 to their reactor coolant pumps, so that, on loss of power

1 and the pump stops, it comes down and back-seats so that you
2 can't have seal leakage.

3 MR. RITTERBUSCH: This is Stan Ritterbusch. We
4 were aware of that design option. We maintained that our
5 original seal design was adequate and didn't need extra
6 protection, and there was quite some debate about that. We
7 have a different seal design than Westinghouse plants --

8 MR. CARROLL: I know.

9 MR. RITTERBUSCH: -- and the charging pump was
10 simply an added margin of security.

11 MR. CARROLL: Well, you were getting bagged in
12 with Westinghouse the last time they resolved GI-23, because
13 you had not presented convincing information on that.

14 MR. RITTERBUSCH: We have always been in that bag.
15 We have tried to get out, and unfortunately, we haven't
16 succeeded yet.

17 MR. CARROLL: Okay.

18 [Slide.]

19 MR. FINNICUM: The second slide that I talked
20 about -- what I present here is now, again, the Core Damage
21 Frequency contribution by initiating event, comparing the
22 System 80+ Core Damage Frequency as we performed the
23 analysis under the original ground rules and the System 80+
24 Core Damage Frequency as performed under the current ground
25 rules.

1 The bottom line is, in changing the ground rules,
2 our Core Damage Frequency went from 6.7E to the minus 7th up
3 to 1.7E to the minus 6th, and what were the ground rule
4 changes? In the original analyses, check valve common cause
5 failure was excluded, was assumed to be not credible.
6 Additional thought and some additional information indicated
7 that it may be a credible failure and should be included.
8 So, we did include common cause failure for the check
9 valves.

10 MR. CARROLL: Which check valves are important in
11 this regard?

12 MR. FINNICUM: I included all check valves, the
13 EFW, the safety injection, the containment spray, the RHR.

14 MR. CARROLL: So, you just waved a magic wand and
15 --

16 MR. FINNICUM: That's it. If I've got to include
17 them, I might as well include them all.

18 MR. CARROLL: -- and made them not function.

19 MR. FINNICUM: Yes.

20 MR. CARROLL: Okay.

21 MR. FINNICUM: The second major item is, in the
22 original --

23 MR. CARROLL: Is that not function in the sense of
24 not opening?

25 MR. FINNICUM: Not opening.

1 MR. CARROLL: Okay.

2 MR. FINNICUM: The second major item was, in the
3 original analyses, a number of the operator error rates were
4 calculated using the original EPRI human cognitive
5 reliability model.

6 That model has fallen into disfavor, primarily
7 because when you look at short action time or the short
8 amount of time needed to perform an action and a relatively
9 long period of time in which to perform the action, it
10 produces some patently absurd results.

11 The decision made was to go back to the primary
12 methodology using the Swain & Guttman handbook, the '84
13 version, and it produced -- it did increase a number of our
14 operator error rates.

15 In addition, another change was made. This did
16 not have a significant impact, but it was a change made.

17 For the valves inside containment, such as the
18 safety depressurization valve, they are tested at an 18-
19 month interval. We had been using the generic failure rate,
20 and there was a concern that there may be a time-dependent
21 element for the failure rate.

22 So, for the valves inside containment, they were
23 tested at 18-month intervals. We back-calculated an hourly
24 failure rate and recalculated a new demand failure rate
25 based on the test envelope.

1 MR. DAVIS: On your loss of offsite power
2 contribution, you used a number of 3.5E to the minus 2 as
3 the initiating event, and I was wondering where that came
4 from.

5 MR. FINNICUM: That number was provided by EPRI.

6 MR. DAVIS: Okay.

7 MR. FINNICUM: They had a calculation for the loss
8 of offsite power, which really was defined to be a loss of
9 offsite power such that actuation of the emergency diesels
10 was required. It required loss of the main switchyard, loss
11 of the secondary switchyard, and failure of the turbine
12 generator to run back and pick up the hotel loads.

13 MR. DAVIS: That's not what your event tree says.
14 Your event tree has this as the lead-in, and then you
15 consider the switchyards and the turbine generator run-
16 back.

17 MR. FINNICUM: That's included in the calculation
18 of the initiating event frequency for loss of offsite power.

19 MR. DAVIS: If that's the case, it looks like
20 you've taken credit for it twice. I'll have to check that
21 again.

22 MR. FINNICUM: Let me see if I have a copy of my
23 event trees here with me then.

24 MR. DAVIS: Let me see if I can help you find it.

25 MR. FINNICUM: I have a copy of the loss of

1 offsite event tree. I do not have a slide for this. The
2 events I show across the top are called loss of offsite
3 power --

4 MR. DAVIS: Right.

5 MR. FINNICUM: -- then failure to deliver
6 emergency feedwater, then failure of long-term decay heat
7 removal, failure of safety depressurization for bleed,
8 failure of safety injection for feed, and then failure of
9 long-term containment heat removal.

10 MR. DAVIS: Are you looking at Figure 19.4.8-1?

11 MR. FINNICUM: I believe that's what it would be.
12 Mine is not labeled as a figure. Let me come over there.
13 Yes, that's the equivalent.

14 The calculation of this frequency for the loss of
15 offsite power includes the element of loss of the site
16 power, the original grid loss, the conditional probability
17 that we would lose the second switchyard given the first one
18 was gone, and then a conditional probability that we would
19 fail to run back and pick up hotel load.

20 MR. DAVIS: If you go through that, you get a
21 number of 5E to the minus 3. I'm still saying that your
22 original loss of offsite power number is 3.5E to the minus
23 2. Why don't you go ahead, and I'll find where that is?

24 MR. FINNICUM: Okay. The calculation of the
25 frequency for loss of offsite power is in Section 19.3, and

1 there is a summary table right towards the end of the
2 chapter, and that shows the input.

3 MR. DAVIS: My point was that number looks awful
4 low, and I was wondering what kind of assumptions went with
5 it, whether this is a sustained loss of offsite power,
6 because you don't have a recovery factor in the event tree,
7 and I couldn't find a definition.

8 MR. FINNICUM: The recovery factors -- the
9 recovery of power are included as recovery actions against
10 the individual cut sets. The 3.5E to the minus 2 was an
11 EPRI number that they calculated a probability of losing
12 offsite power, and I think it's for greater than 60 seconds
13 or something like that, based on operating experience data.

14 MR. CARROLL: They have accumulated a huge
15 database --

16 MR. FINNICUM: Yes.

17 MR. CARROLL: -- from the industry.

18 MR. DAVIS: We did not do any additional
19 evaluation of those numbers. We just used the EPRI
20 calculation.

21 MR. DAVIS: Okay. Thank you.

22 MR. SIEGMANN: Eric Siegmann.

23 I'd like to point out, a single loss of the
24 switchyard today, of a single switchyard, is considered like
25 8E to the minus 2 for a single switchyard based on EPRI

1 data. So, it doesn't look particular low to me.

2 MR. DAVIS: Well, again, the 3.5E to the minus 2
3 was used as the entry event. Then you considered the loss
4 of the other switchyard, and you gave that a .36 probability
5 of failure.

6 MR. FINNICUM: Correct.

7 MR. DAVIS: That was considered later, not as part
8 of the initiating event, and then your run-back
9 unavailability was a 3-to-2 split, and you went on through
10 the event tree.

11 MR. FINNICUM: Yes.

12 MR. DAVIS: I haven't looked at that EPRI
13 database, but this number is considerably lower than most
14 PRAs use. As you may recall, WASH-1400 used one loss of
15 offsite power every five years, .2 instead of .035, and then
16 that number gradually dropped down to about .1, and that
17 seemed to be where most people were coming out.

18 MR. FINNICUM: The NRC had performed some
19 evaluations several years ago, and their evaluation also
20 came out with, I believe, a .07 value --

21 MR. DAVIS: Right.

22 MR. FINNICUM: -- in the calculation, and the EPRI
23 value is --

24 MR. DAVIS: Above that.

25 MR. FINNICUM: Yes. We do have a sensitivity

1 study talking about the sensitivity to the loss of offsite
2 power frequency in there, and I believe we used a value of
3 .15. Matter of fact, I'm getting to these, the sensitivity
4 studies.

5 [Slide.]

6 MR. FINNICUM: For Level 1, we also did a number
7 of sensitivity studies, and the base case that we're talking
8 about was the 1.7E to the minus 6 as our Core Damage
9 Frequency.

10 The first sensitivity study we did is we basically
11 increased all of our operator error rates by a factor of 10.
12 That's one order of magnitude. With that change, the Core
13 Damage Frequency increased to 9E to the minus 6, an increase
14 of about 5.

15 MR. CARROLL: So that says we don't have to spend
16 all this money training operators or paying them as much as
17 we do. They can screw up and it's no problem.

18 MR. FINNICUM: Probabilistically or realistically?

19 MR. DAVIS: They're one and the same.

20 MR. CARROLL: Catton should have been here to hear
21 that.

22 MR. FINNICUM: The second sensitivity study we
23 evaluated --

24 MR. CARROLL: These aren't cumulative. They are -

25 -

1 MR. FINNICUM: No. They're individual sensitivity
2 studies.

3 MR. CARROLL: Yes.

4 MR. FINNICUM: Okay.

5 We basically increased all of the motor operator
6 valve failure rates and the common cause -- associated
7 common cause failure rates by a factor of 10, and in this
8 case -- I missed one. I'll go back to this. For the change
9 in the MOV failure rates, the Core Damage Frequency
10 increased to 8.5E to the minus 6.

11 Back to the second one, we did a second operator
12 action study where we set the human error probability or the
13 operator failure rate for actions performed outside the
14 control room -- these were set to 1.0. In other words, he
15 could perform no action outside the control room. That did
16 not have a significant impact. It's basically up to 2E to
17 the minus 6th.

18 The primary reason is we do not have many actions
19 in the PRA that need to have action taken outside the
20 control room. Most of the actions we credited were things
21 that would be taken inside the control room.

22 MR. CARROLL: Okay. Now, all of this that you're
23 describing is exclusive of shutdown risk.

24 MR. FINNICUM: This is exclusive of shutdown risk.

25 MR. CARROLL: This is another category. Okay.

1 MR. FINNICUM: Correct. These are the basic at-
2 power Level I sensitivity analyses.

3 MR. CARROLL: Got you.

4 MR. FINNICUM: Another issue where we looked at
5 the modeling issue -- in this case, we used the large LOCA
6 as the safety injection tank injection requirements for a
7 medium LOCA, did not have a significant impact at all.

8 MR. CARROLL: What's significant about that?
9 What's the issue here?

10 MR. FINNICUM: The number of tanks required.

11 MR. CARROLL: Okay.

12 MR. FINNICUM: Secondly, for small LOCA and steam
13 generator tube rupture, if we have these events which are
14 small loss-of-coolant-type events and if we fail the
15 injection system, the high-pressure injection system, if the
16 operator reacts within sufficient time, we can cool the
17 plant down and depressurize it to a pressure where we can
18 align and use the shutdown cooling pumps for injection, and
19 this was credited in the model.

20 This sensitivity analysis basically said assume
21 that we cannot do that, that that is not a feasible
22 operation. What would be the impact on the Core Damage
23 Frequency? And the Core Damage Frequency increased to about
24 7 times 10 to the minus 6th. So, it's a factor of about 3
25 or about 4.

1 We did specifically do a sensitivity study for the
2 reactor coolant pump seal LOCA, assuming that it could
3 occur, as a sensitivity study, and the probabilities were
4 low enough that they did not have a significant impact on
5 the Core Damage Frequency. They were in the 10 to the minus
6 8th range.

7 We did another one -- this is an unusual one, and
8 what we wanted to see is, if we assume we did no test or
9 maintenance in-power and if we had no maintenance
10 unavailability, what would be the impact, and we would
11 expect to see some decrease in the Core Damage Frequency.
12 We really did not see any significant decrease.

13 MR. CARROLL: What kinds of maintenance and
14 testing were you --

15 MR. FINNICUM: We looked at all of the safety
16 system tests and maintenance.

17 MR. CARROLL: That are in the standard tech specs?

18 MR. FINNICUM: The ones that were specifically
19 modeled in the fault tree, the diesel generator test and
20 maintenance unavailability, maintenance unavailability on
21 like the safety injection pumps and the shutdown cooling
22 pumps or the containment spray pumps. Anything where a pump
23 would fail during a surveillance test and have to be
24 maintained, we set those to zero. We did not see a
25 decrease.

1 MR. CARROLL: Got you. I understand. Thank you.

2 MR. FINNICUM: Another issue we looked at is, for
3 ATWS, if the moderator temperature coefficient is
4 sufficiently positive when the ATWS occurs, the peak
5 pressure will exceed the Level III values, and we will have
6 what is assumed to be an unmitigatable LOCA.

7 For our plant, we calculated a value such that the
8 probability of having an adverse MTC was about .01 or 1
9 percent of core life.

10 The sensitivity study we performed was -- assumed
11 that, in fact, we had -- 10 percent of the time the MTC was
12 adverse, that we would have an unmitigatable LOCA during
13 that timeframe, and the Core Damage Frequency increased to
14 2.2E to the minus 6th.

15 MR. CARROLL: Didn't we learn last month, though,
16 that the fuel design basis is to have no period of time when
17 the MTC is positive?

18 MR. SEALE: Yes.

19 MR. FINNICUM: Yes. These original analyses were
20 performed a number of years ago, and we maintained them as
21 probabilistic.

22 MR. DAVIS: Mr. Chairman, while he's getting the
23 next slide, I was provided some information on Palo Verde's
24 Core Damage Frequency by Dean Houston from the IPE. Their
25 result is 9E to the minus 5 for internal events.

1 MR. CARROLL: Which doesn't look too out of line
2 with 8.1.

3 MR. DAVIS: No. It's about a factor of 50 higher
4 than the internal events from System 80+ results of 1.7E to
5 the minus --

6 MR. CARROLL: 8.1 is the original ground rules for
7 80.

8 MR. DAVIS: But the current number now is 1.7E to
9 the minus 6th. I'm reading from --

10 MR. CARROLL: For Palo Verde?

11 MR. DAVIS: No, no. For System 80+.

12 MR. CARROLL: Well, I'm looking at the --

13 MR. FINNICUM: Let me go back to that slide.

14 MR. CARROLL: -- original ground rules, System 80,
15 Pete.

16 MR. DAVIS: I'm talking about the current ground
17 rules.

18 MR. CARROLL: Oh, okay.

19 MR. DAVIS: That's the current number, is the
20 current ground rule.

21 MR. CARROLL: Yes, you're right.

22 MR. DAVIS: It's 1.7.

23 MR. SEALE: That's for System 80+.

24 MR. DAVIS: That's right.

25 MR. CARROLL: I just wanted to get calibrated on

1 how the -- the starting point, the System 80 original ground
2 rules, compared.

3 MR. DAVIS: Oh, okay.

4 MR. CARROLL: Okay.

5 [Slide.]

6 MR. FINNICUM: Again, on this slide, I repeated
7 the base frequency, so we could refer to it. The LOOP
8 frequency -- again, we increased that by a factor of 10, and
9 we did not really see a large increase in overall Core
10 Damage Frequency.

11 We set the loss of grid frequency -- that would be
12 that basic input value, the 3.5E to the minus 2 value -- I
13 jacked that up to .15 per year, and the overall Core Damage
14 Frequency increased to 1.8E to the minus 6th.

15 Another sensitivity study I did is let's assume
16 vesse_ rupture was not a credible event. What would the
17 impact be? And it dropped our Core Damage Frequency to 1.5.
18 Basically, we took one sequence out.

19 MR. SEALE: Fifty percent faster.

20 MR. FINNICUM: Yes.

21 MR. CARROLL: Well, I think, in all cases, though,
22 you have to make the point that the 1.7E minus 6th is a very
23 low absolute number.

24 MR. FINNICUM: Yes.

25 A couple of other ones we did were looking at what

1 was the impact of the various common cause failure rates.
2 We did one where we set all the common cause failure rates
3 to zero, in other words assumed there was no such thing as
4 common cause except for diesels and for the batteries, and
5 in this case, the Core Damage Frequency had a significant
6 drop. It dropped from 1.7E to the minus 6th to 2.4E to the
7 minus 7th. Basically, it shows that common cause failures
8 are important to the risk for the plant.

9 MR. CARROLL: As modeled.

10 MR. FINNICUM: As modeled, yes, and as the data is
11 used for calculating them.

12 Finally, just combining the two above, we said
13 let's assume that, except for batteries and diesels, we have
14 no common cause failure and assume vessel rupture is not
15 credible. What would be the bottom line? And as expected,
16 it's 1.4E to the minus 7th.

17 MR. CARROLL: What were you thinking when you
18 decided to exclude diesels and batteries?

19 MR. FINNICUM: There is a large body of
20 information on testing and operation of the diesels, and you
21 have pretty good evidence of common cause failure there.
22 So, there's no reason to even think about excluding that.

23 MR. CARROLL: Again, mentioning our meeting with -
24 - our quadripartite meeting which included the French and
25 Germans, they are, on the European pressurized water

1 reactor, going to four diesels diverse.

2 MR. FINNICUM: Yes.

3 MR. DAVIS: Wait a minute. That sounds like an
4 oxymoron. Four diesels -- you mean four different kinds of
5 diesels?

6 MR. CARROLL: No. Two of one kind and two of
7 another.

8 MR. DAVIS: Oh, okay. Two-by-two diverse.

9 MR. CARROLL: Two-by-two diverse.

10 MR. FINNICUM: By diesels diverse, two of one kind
11 and two of another kind, do you mean they are two different
12 types of diesels or just two different manufacturers?

13 MR. CARROLL: Different manufacturers.

14 MR. FINNICUM: Okay. Well, I do have slides on
15 the particular issue of two diesels versus four diesels at
16 the end of the slide package.

17 MR. CARROLL: Looking forward to it.

18 Let's see. We now move into shutdown?

19 MR. FINNICUM: Yes.

20 MR. CARROLL: Shall we eat lunch and come back for
21 shutdown?

22 MR. FINNICUM: That's acceptable to me.

23 MR. CARROLL: All right. Why don't we reconvene
24 at 1:05?

25 [Whereupon, at 12:06 p.m., the meeting recessed

1 for lunch, to reconvene this same day, at 1:05 p.m.]

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

ANN RILEY & ASSOCIATES, LTD.
Court Reporters
1612 K Street, N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

AFTERNOON SESSION

[1:05 p.m.]

1
2
3 MR. CARROLL: Let's reconvene. We're on shutdown
4 risk.

5 [Slide.]

6 MR. FINNICUM: The next slide here presents the
7 results of our shutdown risk evaluation and presents a
8 comparison to the three other existing shutdown risk PRAs.

9 The bottom line -- we have a Core Damage Frequency
10 for shutdown of 8E to the minus 7th, and it's pretty well
11 balanced across the four areas we looked at. Loss of DHR
12 contributes about a quarter of it, LOCA is 16 percent, loss
13 of offsite power contribution is about a quarter, and fire
14 is about a quarter. It is about an order of magnitude less
15 than the comparable studies.

16 MR. CARROLL: Why do you think that's true?

17 MR. FINNICUM: Again, we have a large degree of
18 separation, a lot of redundancy, and based on the
19 mechanistic evaluation we had, we actually put in some
20 features and procedures, and those will come out in the next
21 slides.

22 MR. CARROLL: And what the others with respect to
23 NSAC-84 and Seabrook?

24 MR. FINNICUM: Eric, could you address what the
25 other elements are?

1 MR. SIEGMANN: I'm Eric Siegmann. I don't recall
2 what the others were.

3 MR. SEALE: That's bad.

4 MR. LINDBLAD: You just eliminated 15 minutes of
5 presentation time.

6 MR. CARROLL: I guess I would like to know what
7 they are. Can we get a response to that?

8 MR. FINNICUM: Yes.

9 Eric, we'll need to get a response on that.

10 [Slide.]

11 MR. FINNICUM: Specifically, some of the design
12 features that help contribute to reducing the shutdown risk
13 is we will have two safety injection pumps operable. We do
14 have the capability to inject to the RCS via the shutdown
15 cooling system.

16 We have a safety depressurization system that we
17 can use for feed-and-bleed cooling even in the shutdown
18 mode. Our containment spray pumps can back up our shutdown
19 cooling pumps. They can be used interchangeably. The IRWST
20 does act as a sump for a LOCA.

21 Again, we have the alternate AC source to back up
22 the diesels. We have a dedicated shutdown cooling system,
23 as opposed to the old LPSI system that doubled as a shutdown
24 cooling system, and we have put in place technical
25 specifications for shutdown cooling or for shutdown modes.

1 MR. CARROLL: Do those include a requirement that
2 two of the three diesel generators plus the alternate AC --
3 two of those three have to be available --

4 MR. FINNICUM: Correct.

5 MR. CARROLL: -- at all times during shutdown or
6 when you're in mid-loop?

7 MR. FINNICUM: Eric, can you address that
8 specifically?

9 MR. SIEGMANN: At all times in shutdown.

10 MR. FINNICUM: At all times in shutdown.

11 MR. SIEGMANN: Eric Siegmann. All times in
12 shutdown, two of the three.

13 [Slide.]

14 MR. FINNICUM: As a direct result of the
15 mechanistic evaluation that was performed for shutdown risk,
16 we did add additional instrumentation.

17 We added two additional Delta P based narrow range
18 RCS water level indicators, and we added two heated junction
19 thermocouple based RCS water level and temperature
20 indicators.

21 In other words, the same instrument performs both
22 a level and a temperature function, but this instrumentation
23 was added specifically based on the mechanistic evaluations.

24 MR. CARROLL: And the heated junction thermocouple
25 instrument that you're talking about here is different than

1 the one that's part of LOCA protection?

2 MR. FINNICUM: Fred Carpentino can address that
3 specifically.

4 MR. CARPENTINO: There are two types of heated
5 junction thermocouple strings in the upper head region.

6 One is the one we had for LOCA and other design
7 basis events, and what we've added is two more strings that
8 have higher resolution for level measurement in the mid-
9 loop regime.

10 I have an overhead that shows the locations of the
11 indications of the heated junction thermocouples if you'd
12 like to see that.

13 MR. CARROLL: Not so much the locations but --

14 MR. CARPENTINO: There are two different types.

15 MR. CARROLL: Okay. And are these operable for
16 LOCA conditions, for example? Do they add to what you
17 already had?

18 MR. CARPENTINO: Yes, they do. They're pedigreed
19 to the same degree as the original two strings.

20 MR. CARROLL: Okay. Thank you.

21 [Slide.]

22 MR. FINNICUM: Also as a direct result of the
23 shutdown risk evaluations, we've made changes to more than
24 20 of our technical specifications to address our shutdown
25 modes, and some examples of these changes -- one, we require

1 two shutdown cooling divisions to be operable and at least
2 one of the divisions is in operation in Mode 6.

3 We have two safety injection trains with one pump
4 in each division is required to be operable in Modes 4, 5,
5 and 6, and during reduced inventory operation, the
6 containment is required to be closed, and there are a number
7 of other changes, including the two of three that you
8 mentioned earlier.

9 MR. CARROLL: I would have thought that would have
10 been one of your more important examples.

11 MR. FINNICUM: It's one I overlooked on the
12 slide.

13 [Slide.]

14 MR. FINNICUM: Procedural guidance was also
15 developed for our shutdown operations based on our
16 evaluations, and these fall into the areas of reduced
17 inventory operations, we have guidance for coping with the
18 loss of DHR, how to detect and mitigate RCS drain down
19 events, outage maintenance during shutdown.

20 MR. CARROLL: You mean management.

21 MR. FINNICUM: No, it's outage maintenance
22 management.

23 MR. CARROLL: Okay.

24 MR. FINNICUM: Fire protection, the use of feed-
25 and-bleed for RCS cooling during shutdown operations. These

1 procedures are discussed in the report that's in Appendix
2 19.8A. They are also captured in Appendix B of our System
3 80+ emergency operating guidelines. They were extracted
4 from the PRA area and put in the operations guidelines.

5 [Slide.]

6 MR. FINNICUM: For external events -- the tornado
7 strike Core Damage Frequency contribution is 2 times 10 to
8 the minus 7th. This number was calculated the same way that
9 we calculate Core Damage Frequency for internal events, with
10 full fault tree linking.

11 MR. DAVIS: Excuse me. Let me ask you a couple of
12 things about that.

13 I noticed in the tornado CDF estimate, you assumed
14 that you could not run the turbine back to pick up house
15 loads. Why was that assumption made?

16 MR. CARROLL: Yes, I saw that, too.

17 MR. FINNICUM: I don't remember what the basis was
18 on that.

19 MR. DAVIS: It wouldn't make a big change, but I
20 was just wondering why you made that assumption.

21 MR. CARROLL: Probably sucked all the water out of
22 the condenser.

23 MR. FINNICUM: Eric?

24 MR. SIEGMANN: Your turbine building is not -- the
25 turbine building, the qualifications of the turbine building

1 might be the reason.

2 MR. FINNICUM: Yes, I think what we're looking at
3 is there was a potential for loss of condenser vacuum.

4 MR. MICHELSON: Yes, but how do you run back the
5 turbine if you lose offsite power and you don't have on-
6 site power yet? It takes a while to get it -- 10, 15, 20
7 seconds, whatever. How do you run back and keep control and
8 bring the turbine up at the lower --

9 MR. DAVIS: They assumed they couldn't do it.

10 MR. MICHELSON: Yes, I assume that that's probably
11 right.

12 MR. LINDBLAD: The turbine is running.

13 MR. MICHELSON: The turbine was running, but it's
14 now tripped.

15 MR. CARROLL: No, no, no, no, no.

16 MR. MICHELSON: I thought the tornado --

17 MR. FINNICUM: On the tornado, we just assumed it
18 could not be done.

19 MR. MICHELSON: This is the non-tornado case.

20 MR. WYLIE: If you assume the building destroys,
21 it takes out your generator breaker and everything else.

22 MR. MICHELSON: Well, yes, if that happens, then
23 you don't have it either, but I wasn't even going to
24 speculate that. I just thought the tornado was the case.

25 MR. CARROLL: They're designed to go back and

1 carry house load.

2 MR. MICHELSON: You mean they can go power-off,
3 total blackout for 20 seconds and bring the turbine back up.

4 MR. CARROLL: There's no blackout, because the
5 turbine is supplying the house loads.

6 MR. MICHELSON: But when you lose the offsite
7 power, that thing is going to trip off.

8 MR. DAVIS: They run it back.

9 MR. MICHELSON: I don't think you can run it back.
10 As soon as that thing starts winding down, those breakers
11 are going to open.

12 MR. CARROLL: When the breakers open, it's going
13 to go on the governor.

14 MR. WYLIE: Which breaker?

15 MR. CARROLL: The offsite breaker.

16 MR. WYLIE: You're getting a tornado strike --

17 MR. CARROLL: Yes.

18 MR. WYLIE: -- in the building.

19 MR. CARROLL: No, no, no, no, no. It has wiped
20 out offsite power.

21 MR. WYLIE: Oh, okay.

22 MR. CARROLL: Then the unit just runs back and
23 picks up house load.

24 MR. WYLIE: What's it hit, the switchyard?

25 MR. CARROLL: Probably.

1 MR. WYLIE: Your breaker is out in the switchyard.

2 MR. CARROLL: Yes.

3 MR. MICHELSON: I think it's gone.

4 MR. CARROLL: The breaker is open.

5 MR. WYLIE: And the unit is gone, too.

6 MR. CARROLL: Why?

7 MR. WYLIE: Because it shorts. If it hits the
8 switchyard, it's going to short out the switchyard and your
9 breaker and everything else.

10 MR. CARROLL: No, the breaker is going to trip.

11 MR. WYLIE: If a tornado hit a switchyard, there's
12 nothing going to be intact.

13 MR. FINNICUM: We did not credit turbine run-back
14 for a tornado.

15 MR. DAVIS: That was the original question, right?

16 MR. FINNICUM: Yes.

17 MR. DAVIS: And I think I know why now.

18 MR. FINNICUM: There are a number of issues.

19 MR. CARROLL: But a more general tornado case is
20 that it takes out offsite transmission.

21 MR. WYLIE: If it is outside the switchyard.

22 MR. CARROLL: Then the breaker opens. It will
23 back down and carry house load.

24 MR. WYLIE: If it rings the plant and it doesn't
25 get your switchyard, then that's true.

1 MR. CARROLL: Has that ever happened, Charlie?

2 MR. WYLIE: Oh, yes, at Dresden.

3 MR. CARROLL: I know. I was just kidding.

4 MR. FINNICUM: For fire and flood, we made a
5 scoping estimate calculation. We did a qualitative
6 evaluation both in Chapter 19 and also in Chapter 9 looking
7 at the separation, and the basic conclusion of the
8 qualitative evaluation is, because of the high degree of
9 separation, fires and floods should not pose a significant
10 risk.

11 We did a scoping evaluation --

12 MR. MICHELSON: Now, let me understand why tornado
13 is an order of magnitude higher than the fire. What's the
14 tornado probability to begin with?

15 MR. FINNICUM: I cannot remember the specific --

16 MR. MICHELSON: What's the fire probability to
17 begin with? We've got to start somewhere and kind of get a
18 feel for where we lost a few factors.

19 MR. FINNICUM: The fire probability is higher than
20 the tornado.

21 MR. MICHELSON: I would hope so.

22 MR. FINNICUM: It is. The big difference on the
23 tornado strike is, one, we cannot recover offsite power for
24 a period of 24 hours.

25 MR. MICHELSON: Okay.

1 MR. FINNICUM: Two, we don't have the alternate AC
2 source. It was assumed that that would be gone. And three,
3 it was also assumed that there was a potential for a
4 vulnerability in the service water intake structure that
5 might potentially take out both divisions.

6 MR. MICHELSON: What probability is that that's
7 related to a tornado?

8 MR. FINNICUM: We used a value of .01.

9 MR. MICHELSON: It's a tornado-qualified building
10 and all that good stuff. It's all designed for a tornado.

11 MR. FINNICUM: What we looked at is the
12 vulnerability was a potential for trash getting thrown into
13 the intake structure and clogging it up.

14 MR. MICHELSON: It's designed for that, isn't it?

15 MR. FINNICUM: It should be, and it's a caveat
16 there, but in the analysis, we assumed a .01 probability
17 that we would -- that we could fail that.

18 MR. MICHELSON: Okay. In spite of the design, it
19 still failed.

20 MR. FINNICUM: Correct.

21 MR. MICHELSON: You could pick up a little that
22 way.

23 MR. DAVIS: Which is true for everything.

24 MR. MICHELSON: I can go back in fire and start
25 playing those games, too, and I'll get you way on up there.

1 It escapes me why those two are inverted.

2 MR. FINNICUM: As I said, the basic conclusion
3 from the qualitative analysis is that, because of the high
4 degree of separation, it should not be a risk.

5 We did a scoping analysis. Basically, we
6 calculated from generic sources a fire initiation frequency
7 and assumed that the fire took out one entire division and
8 then quantified the loss of CCW models to estimate a Core
9 Damage Frequency.

10 MR. DAVIS: I had a little trouble with the way
11 you did that. In your analysis, it looked like you assumed
12 that a fire occurred, then you had a factor that the fire
13 went through some fire barriers in the same division, before
14 you got the total division wiped out.

15 MR. FINNICUM: That was one specific type of fire.
16 A fire in the diesel room would not cause a transient.

17 MR. DAVIS: Well, go ahead. I'll find what I'm
18 talking about.

19 MR. FINNICUM: There was two types of fires, a
20 fire that would occur in a room that could disable safety
21 equipment and potentially cause a transient and one that
22 would occur in a room that would disable safety equipment
23 but probably would not initiate a trip, specifically the
24 diesel generator room, and we assumed that we had a 10 to
25 the minus 3rd probability of going through the barrier and

1 getting to some vital equipment that would cause a
2 transient.

3 MR. DAVIS: This occurs on page 19.7-31 and 32,
4 and you may want to go back and take a look at that. It
5 looked like you used this fire barrier for all fires, both
6 type A and type B, which include switchgear, as well as
7 diesel generator, battery room, and so forth, and this
8 failure probability of the barrier is quite low, $1.2E$ to the
9 minus 3, but go ahead. You may want to take another look at
10 that.

11 MR. FINNICUM: Okay. We will take a look at it.
12 That was our basic event where we took out one division.

13 We also looked at what would happen if we assumed
14 there was a potential for a fire-induced seal LOCA, what the
15 impact would be.

16 MR. CARROLL: What does that mean?

17 MR. FINNICUM: The fire took out all seal cooling
18 and seal injection on one division and we had a subsequent
19 failure. We then would assume that, given those conditions,
20 that we could have a seal LOCA.

21 Again, remember, the design -- CE's design
22 contention is that the seals would not fail. In this case,
23 we assumed that they could fail under these conditions.
24 What would be the contribution?

25 MR. MICHELSON: The seal cooling system is

1 divisionalized?

2 MR. FINNICUM: Yes. The cooling is provided by
3 the CCW pumps. Each division of cooling water cools two RCP
4 seals.

5 MR. MICHELSON: Two seals meaning two of the four
6 pumps.

7 MR. FINNICUM: Two of the four pumps. So, if we
8 lose CCW in one room, we will lose seal cooling to those two
9 pumps. We still have seal injection from the charging
10 system. The fire is assumed to take out one of the charging
11 pumps. We also have the conservative assumption that the
12 seal injection pump would be in the division that was
13 affected by the fire and it would be gone.

14 MR. MICHELSON: Isn't the CCW required for the
15 safety injection or CVCS or the equivalent of it?

16 MR. FINNICUM: It's required for the charging
17 pumps --

18 MR. MICHELSON: Yes.

19 MR. FINNICUM: -- but not for the seal injection
20 pump.

21 MR. MICHELSON: There are no coolers or anything
22 related to it and no cooling of the motors or the pumps.

23 MR. FINNICUM: Correct.

24 MR. MICHELSON: Okay.

25 MR. FINNICUM: But we still have the other

1 charging pump.

2 MR. MICHELSON: It's apparently all air-cooled.

3 MR. CARROLL: Yes.

4 MR. FINNICUM: The dedicated seal injection pump
5 is an air-cooled pump.

6 MR. MICHELSON: And no coolers in the fluid system
7 of it. Okay.

8 MR. FINNICUM: Correct.

9 MR. CARROLL: Except*it's just one pump.

10 MR. FINNICUM: But we assumed that was failed
11 anyway.

12 MR. MICHELSON: They assumed it was failed anyway.
13 It was just trying to figure out what the arrangement was.
14 I thought he would have had two, not just one.

15 MR. FINNICUM: We also did a similar analysis for
16 the -- the total fire scoping analysis was about 6E to the
17 minus 8th. We did a similar type analysis for the flooding,
18 the basic cases where we assumed a flood would take out one
19 entire division, and modeled the other one.

20 MR. MICHELSON: Excuse me. Now, on fire, since
21 you're coming up with definitive numbers, I guess you didn't
22 use the FIVE methodology, you used a true PRA, a true fire
23 PRA.

24 MR. FINNICUM: No.

25 MR. MICHELSON: Well, how did you get numbers?

1 MR. FINNICUM: That was the methodology I was
2 explaining. We calculated a fire initiation frequency based
3 on generic data.

4 MR. MICHELSON: Yes. That doesn't tell you how
5 you respond. That just tells you how often you get the
6 fire.

7 MR. FINNICUM: We then assumed that we lost one
8 entire division.

9 MR. MICHELSON: That's okay, but that may not be a
10 good assumption, depending on where the fire is and so
11 forth.

12 MR. FINNICUM: It's a reasonably conservative
13 assumption, though.

14 MR. MICHELSON: It depends on where the fire is,
15 whether it's in the control complex end of the business or
16 back in the other end. Of course, you're also assuming no
17 interactions, and if you do a fire PRA, you're supposed to
18 pick up the interaction effects.

19 MR. FINNICUM: The qualitative analysis showed we
20 did not have the interactions because of the divisional
21 separation.

22 MR. MICHELSON: What does this number mean, then?
23 You relate it, so far, quantitatively, only to the fire
24 frequency.

25 MR. FINNICUM: Yes, it's a scoping estimate of

1 where will we be. If we did a FIVE methodology, what we
2 would do is we go into our individual fire rooms --

3 MR. MICHELSON: I think that we all understand the
4 way it works, and you don't get numbers from it, but you do
5 get a number here, and it's related to fire frequency.

6 MR. FINNICUM: In the full FIVE, FIVE goes into
7 the quantitative valuation.

8 MR. MICHELSON: I won't get into that now.

9 MR. FINNICUM: Okay. There is accepted
10 methodology.

11 MR. MICHELSON: You're just claiming you have an
12 extremely low fire frequency and therefore you have a low
13 risk from fire.

14 MR. SALTOS: Excuse me. This is Nick Saltos from
15 NRC again.

16 I don't think that the frequency is low, and I
17 don't think the result depends on the frequency of the fires
18 that is assumed.

19 The assumption is that the integrity of the
20 divisional separation will be maintained during a severe
21 fire. That is a major assumption. The next step was to
22 look how this integrity could be defeated.

23 MR. MICHELSON: But there are areas of the plant
24 where you do not have divisional separation in the
25 electrical area. Obviously, when you get to the control

1 room itself, you really don't have true divisional
2 separation, unless you want to talk about an inch being
3 divisional separation. It's certainly not a concrete wall.

4 Now, you can buy some of these arguments out where
5 you've got big heavy concrete walls, and I think they are
6 valid. They become much less valid when you get into the -

7 -

8 MR. SALTOS: It does not assume a fire in the
9 control room.

10 MR. MICHELSON: That's a zero probability.

11 MR. SALTOS: No.

12 MR. MICHELSON: If it's an assumption there are
13 none, that means there is no probability of fire.

14 MR. CARROLL: I think they're saying there is no
15 probability of a fire in the control room that would cause
16 core damage.

17 MR. MICHELSON: Yes, but that's only an
18 assumption.

19 MR. DAVIS: That's right.

20 MR. MICHELSON: They haven't done a PRA.

21 MR. SALTOS: For a fire in the control room, you
22 would have to use the remote shutdown panel, and if you
23 assume a set of probabilities, say 10 to the minus 2 or 10
24 to the minus 3 per year, then you have to see what is your
25 probability of transfer to the remote shutdown panel, and

1 then you have a plant trip and then you have a transient,
2 and you look what are your safety functions and how you can
3 access those safety functions so you can shut the plant
4 down.

5 MR. MICHELSON: Which division is the back-up
6 panel in?

7 MR. FINNICUM: It's in Division 1 or 2.

8 MR. CROM: This is Tom Crom. The remote shutdown
9 panel is located in Division 1, but you can operate both
10 divisions.

11 MR. MICHELSON: You mean they both come together
12 at that point, electrically? You can't control them unless
13 you bring wires and whatever in.

14 MR. CROM: It's all fiber optic into that
15 particular area.

16 MR. MICHELSON: Pure fiber optic only.

17 MR. CROM: Yes.

18 MR. MICHELSON: That's interesting. How do you
19 power this division, this backup panel? Only one division
20 of power?

21 MR. CROM: I'm definitely not the person to answer
22 that. We need to ask --

23 MR. MICHELSON: We'll get into it later on when we
24 get to back-up control.

25 MR. DAVIS: Before we leave the fire, I think it's

1 important to qualify these results.

2 In Volume 20, in section 19.7.3, on page 31, the
3 statement is made that "A quantitative assessment of the
4 risk of internal fire cannot be made at this time, because
5 detailed design information for cable routing and fire
6 detection and fire suppression systems is not presently
7 available," but they go ahead and attempt to produce this
8 number, and they call it a conservative scoping estimate.

9 Now, the staff, in their FSER, says -- and if I'm
10 characterizing it incorrectly, please correct me -- that
11 they are not convinced it's conservative because of the
12 things that were left out and the unknown information.

13 I happen to agree with that. I do not think you
14 can demonstrate that this number is conservative. It may,
15 in fact, go up, because some non-conservative assumptions
16 were made, and one of them was that you don't have any
17 contribution from control room fires. You also assumed that
18 this divisional separation was 100-percent in place and
19 worked always, there was no probability of failure for that,
20 and I don't personally think that your fire initiating
21 frequencies are conservative. I'm not sure where they came
22 from, but they don't look conservative to me.

23 So, I think what it really says is that the COL
24 has to redo this fire part when this information becomes
25 available. So, I don't think it's worth worrying about the

1 numbers at this point.

2 Now, have I said anything you disagree with?

3 MR. FINNICUM: No.

4 MR. DAVIS: Okay.

5 MR. MICHELSON: I think there's another thing you
6 need to account for. If you're going to put the back-up
7 control controlling both divisions from one location and the
8 fire is near the back-up center, then you have to worry
9 about spurious actuations in both divisions caused by
10 heating up this room, because you probably aren't going to
11 be able to condition the air in it anymore and so forth, and
12 it's going to get hot.

13 MR. CARROLL: But in that case, the control room
14 is still available.

15 MR. MICHELSON: Well, I don't know what the
16 scenario is. I didn't put the fire in the back-up control.
17 I said nearby somewhere such as to elevate the temperature.
18 It's only one of the two divisions, and the fire will be in
19 that division.

20 Now, you have to start chasing heating and
21 ventilating and a lot of other things before you can fully
22 understand what a fire might do. That's what a PRA,
23 hopefully, does. It models the whole thing correctly. Only
24 a good PRA would do that, of course, but if you model it
25 correctly and you model environmental interactions

1 correctly, then you'll pick the whole thing up out of a PRA
2 and you've got believable numbers. Otherwise, I'm not sure
3 what you believe out of all this subjective argument.

4 MR. SALTOS: This is Nick Saltos again from NRC.

5 We don't take these numbers to be accurate. I
6 think what we got out of that is that the integrity of the
7 divisional wall is very important, and the objective was to
8 see what has to come through, what kind of requirements has
9 to be served.

10 MR. MICHELSON: Remember, in the case of ABWR, we
11 actually have two back-up control rooms, one for each
12 division. Now, they're side by side and there is a divider
13 wall between them, but you don't try to bring all the wiring
14 and all the control and everything into one location in one
15 division and claim that you're okay for controlling both
16 divisions from it. It gets pretty argumentative after a
17 while.

18 MR. CROM: Mr. Michelson, this is Tom Crom again.
19 You know, you mentioned the possibility of fire near the
20 area of the remote shutdown panel. In that particular fire,
21 the remote shutdown panel is not energized. It's
22 disconnected.

23 MR. MICHELSON: You have to look at the scenario
24 to see whether there was any connection between that and the
25 viability of what was coming from the main control room to

1 begin with.

2 Now you've got to look at the routing of all the
3 fiber optic cables going up to the main control room to find
4 out whether you might have had to abandon the main control
5 room because of the fire, not because it was chasing you
6 out, because you lost control.

7 So, you've got to look to see where the fire is,
8 and then you look to see if the back-up panel is
9 sufficiently divorced from the fire to carry you on through,
10 and that's the name of the game.

11 MR. CARROLL: Well, assuming that you can make the
12 argument that the main control room is not affected by a
13 fire in one or the other divisions, then I guess I think I
14 agree with Tom that you're home free.

15 MR. CROM: The only time the remote shutdown panel
16 will be energized is if there is a fire in the control room,
17 and they are physically and electrically isolated from each
18 other.

19 MR. MICHELSON: Well, if you go back and look at
20 the history of fires, you'll find that has not been the
21 history either. They have had to use back-up control panels
22 for a couple of big fires that we have had, partly because a
23 portion of the main control room capability was lost and
24 they had to go to the back-up control panel to regain that
25 capability, and that's exactly what they did. They didn't

1 abandon the main control room, but they used both, in
2 essence. I didn't realize this was a common, shared back-
3 up control room.

4 MR. CARROLL: Okay. Moving on.

5 [Slide.]

6 MR. FINNICUM: This slide --

7 MR. CARROLL: Let's see. You passed over the
8 seismic margin one, because you covered it yesterday.

9 MR. FINNICUM: Yes.

10 MR. CARROLL: Okay.

11 MR. FINNICUM: I don't even recognize it, because
12 they're out of my package. I apologize.

13 This slide -- we had a comparison of the average
14 of some IPE results. It basically shows what the average
15 IPE Core Damage Frequency is as compared to the current
16 System 80+ value and a relative breakdown of where the risk
17 contributions are.

18 For System 80+, our big contributions are in the
19 LOCA area, and this includes both the large and medium
20 LOCAs, and in the transients area where, as you see, for a
21 IPE, you see a large contribution from loss of site power,
22 loss of coolant, and transients, and a lot of that shift is
23 due to the design activities for System 80+.

24 MR. MICHELSON: What is a loss of site power?

25 MR. FINNICUM: It's, in actuality, a loss of

1 offsite power. In the IPEs, it was called loss of site
2 power.

3 MR. MICHELSON: Oh, I hadn't heard that one. I'm
4 way behind, I guess. I didn't associate that with loss of
5 offsite. I thought this was some new kind of a speculation
6 about on-site.

7 MR. FINNICUM: The reason I kept that acronym is
8 that was what was used in the report that we had.

9 MR. MICHELSON: I understand what it is now.

10 MR. FINNICUM: Okay.

11 [Slide.]

12 MR. FINNICUM: The Level II results that we looked
13 at -- the primary area we were looking for from here was our
14 containment performance, and there was no real clear
15 definition of what constitutes containment performance. So,
16 we looked at the various elements of 90-016 and came up with
17 three different potential definitions and basically what
18 we're looking at here.

19 What we're saying is, if we define containment
20 failure as above-normal releases within the first 24 hours,
21 then our containment reliability is .098 or the
22 unreliability is .02.

23 If we look and say containment failure is defined
24 as having a large release or a release greater than 25 rem
25 at a half-mile, then our containment reliability is .097 or

1 the unreliability is .027. That's fairly close.

2 And if we say that the containment failure is
3 defined as any breach whatsoever of the containment, then
4 the containment reliability is --

5 MR. CARROLL: At any time --

6 MR. FINNICUM: -- at any time --

7 MR. CARROLL: -- after the accident.

8 MR. FINNICUM: -- then it's .886, and this is, in
9 general, .9, and it's consistent with the goal of .1 that
10 was stated in 90-016.

11 MR. CARROLL: That last number is dominated by
12 basemat melt-through.

13 MR. FINNICUM: Correct.

14 MR. BRINKMAN: This is Charlie Brinkman. Just for
15 the record, since this is on the transcript, you misspoke
16 some of those numbers, Dave, and I'd appreciate it if you'd
17 go back over them again. You had some decimal places off.
18 Simply for the transcript.

19 MR. FINNICUM: Okay.

20 The first item is, if containment failure is
21 defined as failure with above-normal releases within the
22 first 24 hours, containment reliability is .98, containment
23 unreliability would be .02.

24 MR. CARROLL: Actually, the slides are part of the
25 record, if I'm not mistaken. So, I don't know that you

1 really need to do this. Do they get in if you buy a
2 transcript?

3 MR. DAVIS: Besides that, I think he's corrected
4 the only mistake he made. He said .098 before.

5 MR. CARROLL: All right.

6 [Slide.]

7 MR. FINNICUM: A little more detail on that. In
8 looking at what we call an intact containment for 24 hours
9 is 96.5 percent, this consists of a containment intact
10 indefinitely. That's our 88.6 percent value. Late
11 containment failure due to overpressure is .4 percent of
12 containment failure probability.

13 MR. CARROLL: Now, included in that is preventing
14 overpressure by opening the vents?

15 MR. FINNICUM: No. I did not credit opening those
16 vents.

17 MR. CARROLL: Okay.

18 MR. FINNICUM: I also did not credit use of the
19 reactor fan coolers.

20 MR. CARROLL: Okay.

21 MR. FINNICUM: Late containment failure due to
22 basemat melt-through is 7.5 percent.

23 Our containment isolation failures are 2.4
24 percent, and early containment failure constitutes 1.1
25 percent with -- the dominant portion of that is the ex-

1 vessel steam explosion, which contributes .95 percent or,
2 essentially, about 80 or 85 percent of the early containment
3 failure probability.

4 The alpha mode failures is about .12 percent. The
5 hydrogen burn or detonation constitutes about .03 percent,
6 with a subtotal of 1.1 percent. DCH had a very small
7 contribution and did not show up, and this is our total of
8 100 percent.

9 [Slide.]

10 MR. FINNICUM: Again, we performed a set of
11 sensitivity analyses for the Level II analyses, and I
12 present the -- the base case, I show the containment intact
13 indefinitely value, then late containment failures
14 aggregate, early containment failure aggregate, and
15 isolation failure aggregate. These are in percent.

16 We looked at if we assume the hydrogen igniters
17 are not available, the containment intact probability goes
18 down slightly, late containment failure comes up slightly,
19 early containment comes up, almost doubles because of the
20 increased probability of hydrogen burn.

21 The second sensitivity study we looked at,
22 assuming that the deflagration to detonation transition was
23 more likely, that we were more likely to have a hydrogen
24 detonation as opposed to a burn, the underlying assumption
25 is, given a hydrogen detonation, the probably of containment

1 failure is 1.

2 So, by increasing the deflagration detonation
3 would increase containment failure probability, it really
4 did not have a significant impact in the round-off error.

5 MR. CARROLL: Is that third number supposed to be
6 1.1 or .1?

7 MR. FINNICUM: Yes, it should be 1.1 instead of
8 .11.

9 The next sensitivity study we looked at is
10 assuming a lower heat transfer rate from the corium to the
11 coolant. The impact of this is that you will ablate through
12 the -- the concrete will be ablated sooner even in the
13 presence of cooling. The intact containment probability
14 went down, late containment failure probability went up, and
15 again, the early containment failure was not affected,
16 because this is primarily a late containment failure
17 phenomena.

18 We looked at reducing the probability of
19 containment spray recovery in the late case. What we looked
20 at is, for the cases where sprays were unavailable
21 initially, as part of this analysis we had credited recovery
22 of containment spray late, after 24 hours.

23 We reduced the probability of doing that recovery
24 and looked at the impact. The containment intact
25 indefinitely went down, late containment failure again came

1 up on overpressure. The early failure was not impacted,
2 because the sprays were unavailable in the first 24 hours.
3 Isolation toggle effects were based on how we structured the
4 event tree.

5 A second item we looked at is no possibility of
6 recovering any of the heat removal of the containment. The
7 difference between this is we looked at recovery of the
8 spray system, mechanically. Here we looked at -- there was
9 three different factors -- recovery of offsite power late or
10 use of the back-up spray system or recovery of the spray
11 system itself, and we basically just turned that off and
12 took a look at what would happen to containment. Again,
13 this had a large increase on the late containment failure.
14 This is all overpressure, steam overpressures.

15 We also looked at some of the things that impacted
16 DCH. This is primarily thermally induced failure of the RCS
17 piping during a high pressure sequence, and we've assumed
18 either they always occurred or that it never occurred, and
19 because of the very low impact of DCH on our containment
20 failure probability, it really had no impact on the
21 sensitivity studies.

22 [Slide.]

23 MR. FINNICUM: The next case we looked at is, for
24 high-pressure sequences, we assumed that we could not
25 depressurize with -- the RCS with the safety

1 depressurization system, and again, we see no impact,
2 primarily because DCH did not have a big contribution.

3 We also looked at assuming that the safety
4 depressurization valves were 100-percent reliable and would
5 depressurize all the sequences. Likewise, again, no
6 significant impact, because it's primarily DCH-related.

7 We also looked at a sequence where we would
8 increase the containment isolation failure rate for the
9 general sequences to a 10 to the minus 2, and again, that
10 did not affect the early and late primarily. It did have
11 the impact on our isolation failure rate.

12 We also looked at -- terrible spelling here -- we
13 also looked at depressurization of the RCS using the
14 depressurization valves for medium and high pressure
15 sequences.

16 The sequences we looked at with respect to RCS
17 pressure are the 2,500-pound sequences, which are cycling
18 relief valve, and the high-pressure sequences are those that
19 are in the 1,000- to 2,000-pound range, medium pressure are
20 in the 400- to 1,000-, 1,200-pound range, and there was
21 originally assumed to be some potential for DCH in those
22 sequences if we did not depressurize.

23 So, we looked at assuming that we could not
24 depressurize further and see what the impact was. Again, no
25 significant impact, because DCH was not a significant

1 contributor.

2 The final one we looked at was failure of the
3 operator to turn on the hydrogen igniters. We increased the
4 failure rate by an order of magnitude.

5 There was a slight increase in the early
6 containment failure probability due to an increase in the
7 containment failure due to hydrogen burn.

8 [Slide.]

9 MR. FINNICUM: For the Level III PRA, as I
10 mentioned earlier, the risk measure we looked at was the
11 probability of exceeding a whole body dose of 25 rem at a
12 half-mile, and the value we came up with is 5.3E to the
13 minus 8th as the probability of exceeding 25 rem whole body
14 dose at a half-mile. The goal was 1 times 10 to the minus
15 6th. So, we're well within the goal.

16 We also looked at -- we considered a small site, a
17 300-meter reactor boundary, and we got a 6.2E to the minus
18 8th probability exceedance for that.

19 MR. DAVIS: If you went past a half-mile, would
20 that number go up or down?

21 MR. FINNICUM: I believe it goes down. I can't
22 remember the exact curve.

23 MR. DAVIS: Well, the thing I'm concerned about
24 is, if you have an energetic release, you can jump over the
25 near-site people, and I don't know whether you have any

1 contributing sequences that have an energetic release when
2 the containment fails.

3 MR. CARROLL: A la Chernobyl.

4 MR. DAVIS: Well, it's a plume rise phenomena.
5 You know, WASH-1400 showed that, that you can jump over the
6 people within a mile or two miles, and then the plume comes
7 down beyond that.

8 MR. FINNICUM: Stanley, do you have a comment?

9 MR. RITTERBUSCH: We understand that phenomenon.
10 It turned out to be not dominant. At one point, we thought
11 we were concluding that the people ought to run into the
12 plant, but on an overall basis, that turned out not to be
13 the case.

14 MR. MICHELSON: Well, if you fail the containment,
15 you end up venting into the annulus, and the annulus is
16 directed upward to the top of the containment and then out
17 through some process. Doesn't this give you a higher level
18 release and a somewhat energetic ejection out the top of
19 this -- from the annulus?

20 MR. DAVIS: It's usually the thermal energy that
21 causes the lofting.

22 MR. MICHELSON: Yes, but it's all hot gases, and
23 it's all being vented up to the top of the containment, and
24 I'm not sure what the routing is from there to the normal
25 vent point.

1 MR. PALLA: This is Bob Palla with the staff.

2 I just wanted to mention that the bulk of the risk
3 for this design is dominated by steam generator tube
4 ruptures, and these would not have the kind of energies
5 released that you're thinking of.

6 There is still a contribution from early failures
7 from events like DCH, small probabilities, but I believe the
8 bulk of the risk and frequency, as well, will not. I'd have
9 to think about that further, but these should be dominated
10 by the events such as steam generator tube rupture with
11 lower energies released.

12 MR. DAVIS: Loss of feedwater is a big
13 contributor, almost 30 percent to the core damage frequency,
14 and steam generators is also a large one.

15 MR. FINNICUM: The tube ruptures -- when you look
16 at the risk, the probability of exceeding 10 to the minus
17 6th --

18 MR. DAVIS: Is from tube ruptures because you
19 bypass -- yes.

20 MR. FINNICUM: You bypass. You have no scrubbing.

21 MR. DAVIS: Right. Thank you.

22 [Slide.]

23 MR. FINNICUM: We also had looked at several
24 different sensitivity studies.

25 One of the things we did is we looked at assuming

1 all releases occur at the top of containment, where you'd
2 get -- we looked at taking the releases all at the top of
3 containment and seeing what would happen, and at the half-
4 mile, the doses -- the probability of exceeding 10 to the
5 minus -- or 25 rem went down, and that's probably due to the
6 effect of the plume being distributed over a wider area.

7 We also looked at the releases occurring all at
8 grade level, and the dose at a half-mile -- the probability
9 of getting 25 rem at a half-mile increased slightly to 5.4E
10 to the minus 8th, and this is the effect of the ground
11 hugging plume there and the shadowing of the reactor
12 building.

13 MR. MICHELSON: What is the release from the
14 relief valves, then? What do you consider that? It's
15 certainly not ground level, and it's certainly energetically
16 directed upward, generally, but I suspect the plume is well
17 beyond the top of the containment, even, because when those
18 valves go off, they shoot a plume way up. That would be the
19 steam generator tube rupture case.

20 MR. DAVIS: The core melt occurs after that.

21 MR. MICHELSON: That's true, yes.

22 MR. FINNICUM: Those valves are also in the valve
23 house.

24 MR. MICHELSON: Yes, but they're directed upward
25 and outward, I hope. You're relieving into the room?

1 MR. FINNICUM: Tom, can you address that?

2 MR. CROM: The main steam safety valve -- when
3 they relieve in the valve house, they direct it outside or
4 they relieve inside and then exit.

5 MR. CROM: The main steam valve house or the
6 safety valve is directed outside the main steam valve house,
7 yes.

8 MR. MICHELSON: You can blow the house apart if
9 you aren't careful.

10 MR. CARROLL: It might be a little tough on people
11 setting valves.

12 MR. MICHELSON: I don't think you'd want to work
13 around them either. That all has to be outside and upward.

14 MR. SEALE: But as I understand it, the release
15 height is an input into the meteorology part of the
16 calculation, and what he's done here is just say it's all
17 released on the ground, let's see what the meteorology does
18 from there.

19 MR. FINNICUM: That's what I did in this
20 sensitivity study.

21 MR. SEALE: You neglected all of that, for
22 whatever reason.

23 MR. PALLA: Just a point of clarification not on
24 the sensitivity but on the baseline calculations. I believe
25 a number of 19.7, approximately 20 meters elevation was the

1 release for steam generator tube ruptures.

2 MR. MICHELSON: That's the elevation. Isn't that
3 about the elevation of the valve. That's not necessarily
4 the elevation of the plume it creates. Those things are
5 normally directed upward.

6 MR. FINNICUM: The calculation was based on the
7 elevation of the valve.

8 MR. PALLA: The roof of the main steam line, main
9 steam valve room.

10 MR. MICHELSON: Yes, that's the correct number for
11 that.

12 MR. CARROLL: That's where it's released, but it
13 jets up beyond that.

14 MR. FINNICUM: The third sensitivity study we
15 looked at, we just basically increased the release fractions
16 for iodine and cesium by one order of magnitude. What we
17 say is the release -- or the probability of exceeding 25 rem
18 went from 5.3E to the minus 8th to 6.4E to the minus 8th,
19 which is not unexpected.

20 The next item we looked at is assuming that all of
21 our containment bypass releases were unscrubbed. The basic
22 -- no change in the probability of exceeding 25 rem, in part
23 because most of the releases were already unscrubbed.

24 Next we looked at increasing our containment
25 isolation failure rate by one order of magnitude. In other

1 words, we had more likely a direct release, and as expected,
2 we saw a large jump in the probability of exceeding 25 rem.

3 We looked at doubling the basemat melt-through
4 failure frequency to see what the impact was. The releases
5 are not large releases on this. So, the probability of
6 exceeding 25 rem did increase but not by a large amount.

7 We also looked at the concrete ablation failure,
8 i.e. the basemat melt-through. Our calculations show that
9 the time of failure, of a release would be at about 65
10 hours. We cut that in slightly less than half to see what
11 the potential impact would be. Not a significant increase
12 in the probability of exceeding 25 rem.

13 Likewise, we increased our ISLOCA frequency by two
14 orders of magnitude, and that is a bypass release, and we
15 went from 5E to the minus 8th to 1E to the minus 7th for
16 probability of exceeding 25 rem.

17 MR. CARROLL: Now, you are going to move into the
18 ACRS questions?

19 MR. FINNICUM: Correct.

20 MR. CARROLL: Can we do them in reverse order,
21 since we're going to lose two members, and I think they're
22 more interested in issue two than in issue one.

23 MR. FINNICUM: Okay.

24 MR. CARROLL: And then we'll pick up issue one.

25 MR. DAVIS: Is this the four diesels?

1 MR. CARROLL: Yes.

2 While you're getting ready, one question on the
3 total PRA picture. Did Combustion consider going out and
4 getting an independent review of their total PRA work, other
5 than the review the staff provides?

6 MR. FINNICUM: We did not do that. During the
7 first System 80+ -- using the original ground rules, the
8 Level I analysis was reviewed, not in a great deal of
9 detail, but was reviewed by Tenera Corporation.

10 MR. CARROLL: Okay.

11 [Slide.]

12 MR. FINNICUM: The issue here was asked about --
13 it's the two diesel generators plus the alternate AC source
14 versus four diesel generators issue and what impact does
15 that have on core damage?

16 MR. CARROLL: It's a two-by-two four diesel
17 generator. So, you don't have to consider common mode
18 failure.

19 MR. FINNICUM: We looked at this issue back in
20 1991. We did a sensitivity study. We looked primarily at
21 unavailability of the diesel generator configuration. We
22 did not include the support systems in the model. We were
23 looking purely at the diesel generators, combustion turbine,
24 and the busing availability, and we looked at two
25 configurations.

1 For LOCA, we need to have two HPSI pumps. For
2 transients, we would need to have only one HPSI pump.

3 Now, that has the most impact on the four-diesel
4 configuration, and what we looked at is, for the
5 configuration we had with two diesel generators with a gas
6 turbine, that the unavailability for the transients was 1.4E
7 to the minus 4th per demand, for LOCAs it was 2.7E to the
8 minus 3 per demand, and if we looked at the unavailability
9 of the diesel generators, for transient, the unavailability
10 was about 1.3E to the minus 4th demand, which is a lower
11 unavailability than for the two-diesel and the gas turbine.

12 For the LOCA, again, it was 1.9E to the minus 3,
13 which is, again, a lower unavailability than we showed for
14 the two-diesel with a gas turbine, but they were not
15 significant differences, and to put in four diesel
16 generators would have a significant effect on the design of
17 the plant.

18 We would have had to have added two additional
19 component cooling water systems and service water systems,
20 and it would have had a significant impact on the footprint
21 of the plant.

22 MR. CARROLL: Why?

23 MR. DAVIS: I thought these were air-cooled
24 diesels.

25 MR. CARROLL: No, they're not.

1 MR. DAVIS: They aren't?
2 MR. FINNICUM: These are water-cooled diesels.
3 MR. DAVIS: But they could be air-cooled.
4 MR. FINNICUM: That I cannot address. Tom?
5 MR. CARROLL: They could be air-cooled.
6 MR. DAVIS: There are diesels this big that are
7 air-cooled.
8 MR. CARROLL: Yes.
9 MR. WYLIE: What size diesels are we talking about
10 here?
11 MR. FINNICUM: Tom?
12 MR. CROM: As I recall, the diesel size is 6.4
13 megawatts.
14 MR. WYLIE: This is per division?
15 MR. CROM: Per division.
16 MR. WYLIE: For two divisions.
17 MR. CROM: For two divisions. That's correct.
18 MR. WYLIE: So, what is it for four? Half of
19 that?
20 MR. CROM: It should be essentially half, that's
21 correct.
22 MR. FINNICUM: It would be slightly more than
23 half.
24 MR. WYLIE: They could be easily air-cooled.
25 MR. CARROLL: Yes. Diablo is air-cooled, and

1 they're bigger than that.

2 MR. DAVIS: In fact, it would be, I think,
3 advantageous, because you would remove this dependency, and
4 also, it would be cheaper, I think.

5 MR. FINNICUM: That was our 1991 study, and we
6 looked at some potential costs, but the main shot was,
7 looking at water-cooled diesels, that the impact would have
8 been major on the design under that consideration.

9 MR. WYLIE: The size of the diesel that you say is
10 \$25 million there, is that a half-size or a full-size?

11 MR. FINNICUM: Eric?

12 MR. SIEGMANN: That's full-size.

13 MR. WYLIE: That's full-size. All right. Are we
14 comparing apples and apples or apples and oranges? I'm not
15 sure about your numbers.

16 MR. CARROLL: Now, what happens if you do go
17 diverse, two of one kind and two of another, and let's just,
18 for the sake of argument, say that common cause failure has
19 been eliminated.

20 MR. FINNICUM: If you say, for the sake of
21 argument, that common cause failure is eliminated by
22 selecting different manufacturers, you will see the benefit
23 of this increase. How much I don't know, but it will
24 increase, because this addresses the common cause with four
25 diesels.

1 In the past, we have not considered different
2 manufacturers as being diverse. Part of that is based on
3 the assumption --

4 MR. CARROLL: The staff has told us they would
5 consider that diverse.

6 MR. FINNICUM: In years past, in other arenas --
7 for example, the reactor trip switchgear -- we were told
8 that different manufacturers of switchgear did not
9 constitute diverse.

10 MR. LINDBLAD: Of course, the gas turbine, while
11 it's not safety-grade, is a diverse power supply.

12 MR. CARROLL: Okay.

13 Now, this assumes -- or does this assume that, if
14 I have one diesel out of service for more than 72 hours, I'm
15 going to have to shut the plant down, because I don't meet
16 GDC-4, I'm vulnerable to a common cause failure, unless the
17 staff has, since we last talked to them, decided to give you
18 credit for --

19 MR. CROM: This is Tom Crom. The answer is the
20 tech specs still requires the plant to be shut down if a
21 diesel is out for more than 72 hours.

22 MR. CARROLL: Okay.

23 MR. SEALE: Even if there are four of them?

24 MR. WYLIE: No, no, no. He's talking about two.

25 MR. ARCHITZEL: This is Ralph Architzel from the

1 staff. We're responding to your letter on that point at the
2 moment right now.

3 MR. CARROLL: Do you know what the response is
4 going to say?

5 MR. ARCHITZEL: Basically, I believe the applicant
6 hasn't requested any relief from the standard tech spec, and
7 we're not going to pursue it independently.

8 MR. CARROLL: Okay.

9 Does the applicant intend to --

10 MR. ARCHITZEL: That's prejudging. It's with the
11 technical staff. It's got management review, but that's
12 where we're heading right now.

13 MR. CARROLL: Okay.

14 Do you plan to ask for such relief?

15 MR. RITTERBUSCH: This is Stan Ritterbusch. Yes,
16 we are going to have a discussion. I can't predict where
17 it's going to end up, but as a result of the comments and
18 interest expressed here, we are going to go back and ask
19 that question as we go through the final stages of the
20 technical specification confirmatory effort.

21 MR. CARROLL: Okay. I would say to you that the
22 \$43 million, or whatever it is, isn't very much money. If I
23 were the guy buying this power plant for Podunk Light and
24 Power, I could use up \$43 million in 60 years in down time
25 costs in a big hurry.

1 MR. MICHELSON: Is it \$57 million for the two
2 diesel plus -- is that plus gas turbine, the \$57 million?

3 MR. FINNICUM: I believe so.

4 Eric, could you answer that?

5 MR. SIEGMANN: Yes.

6 MR. MICHELSON: It is the combined cost and all
7 the insulation of them and so forth.

8 MR. SEALE: According to that, then, I assume,
9 when I buy four diesels, I get four seismically-qualified
10 diesels, but when I buy two diesels plus a gas turbine, I
11 get two seismically-qualified diesels plus a non-qualified
12 gas turbine.

13 MR. CARROLL: Well, I'd say it another way. I'd
14 say plus a gas turbine that has a HCLPF of .36 g.

15 MR. SEALE: Okay.

16 MR. CARROLL: I was wondering about that number.
17 What happens if the gas turbine is running when the
18 earthquake happens?

19 MR. FINNICUM: If it is running when it happens,
20 I'd have to think about that a minute.

21 MR. DAVIS: You mean in a test mode?

22 MR. CARROLL: For whatever reason.

23 MR. DAVIS: Or is the plant down?

24 MR. CARROLL: No. Maybe you're running it for
25 peaking.

1 MR. FINNICUM: We would not be running it for
2 peaking.

3 MR. CARROLL: Why not?

4 MR. FINNICUM: Because it's not hooked to the
5 switchyard.

6 MR. CARROLL: Yes, but I can displace loads in the
7 plant.

8 MR. FINNICUM: Oh, okay. I understand.

9 MR. SIEGMANN: This is Eric Siegmann with
10 Combustion Engineering.

11 I'd like to point out -- we discussed four trains
12 with two diverse with another utility. I'd like to point
13 out that, when you go to two different vendors on diesels or
14 on any part, whether it be HPSI pumps or what, you're
15 doubling your spare parts, you're doubling your procedures,
16 and your training, and my personal opinion is you're going
17 to be doubling your maintenance errors, okay?

18 It is not clear to me that manufacturing defects
19 and common cause failures associated with the manufacturing
20 or installation of a single vendor is going to be overcome
21 by the increase in maintenance errors associated with having
22 two different vendors on the site.

23 Your pre-existing maintenance errors tend to
24 dominate your failure rates, and I suggest you had better
25 look carefully before you suggest that you double your

1 inventory of component on a site, as the British have done
2 at a cost of 50 percent more for the BNFL plant, and it's a
3 questionable decision.

4 MR. CARROLL: One of your problems, though, is
5 although, practically, you know, I believe a lot of what you
6 say, these PRA rascals keep hitting me with this stupid beta
7 factor that I can't overcome. They say just trust me, this
8 is the right number, and the only way to defeat them is to
9 say I don't have to use your dumb number, I'm going to have
10 diverse equipment.

11 MR. CROM: This is Tom Crom from Duke Engineering,
12 and I guess I'm trying to put my two cents in, too, on what,
13 really, common mode failure is, because what I've seen, at
14 least at Duke plants, common mode failure does not really
15 occur just because of different manufacturers.

16 Unless you would go all the way to having
17 different fuel sources, different governors -- I mean it
18 would have to be strictly more than just different
19 manufacturers to be totally diverse.

20 MR. CARROLL: Oh, I agree, but I don't think it's
21 that hard, if you really wanted to, to make it that way.

22 MR. CROM: We'll include even probably different
23 maintenance crews into that.

24 MR. CARROLL: I have yet to confirm it, but I now
25 understand that the major airlines flying 767s across the

1 drink are using different maintenance crews on the two
2 engines. They must know something.

3 MR. DAVIS: I had a question on the previous
4 slide. Why are the unavailabilities different for
5 transients and LOCAs?

6 MR. FINNICUM: For LOCAs, we need to -- for a
7 large LOCA, we need to have two HPSI pumps, and that impacts
8 the number of buses and support systems within that arena.
9 It has the same impact on the four diesels.

10 In this case, we'd need to have -- two of the four
11 diesels would have been operating for a LOCA. Here we'd
12 need one of the two diesels, but more buses would have to be
13 available.

14 MR. DAVIS: Okay. For the transient, you just
15 need one of four diesels?

16 MR. FINNICUM: Yes.

17 MR. DAVIS: That failure rate looks awful
18 optimistic if you consider common cause failures.

19 Go ahead.

20 MR. CARROLL: Well, what I really want to see is
21 some realistic credit given for the AAC. I think you and
22 the staff have got to work out something so you get some
23 realistic credit for it.

24 MR. DAVIS: Aren't you seeing it here in this
25 slide? Showing the fourth diesel doesn't improve things

1 over the two diesels with the combustion turbine.

2 MR. CARROLL: If you believe it, but the staff is
3 saying, until Combustion comes to them and says I want
4 credit beyond 72 hours, they are going to have to shut down
5 --

6 MR. DAVIS: Okay.

7 MR. CARROLL: -- and I think you need credit for
8 the gas turbine, because I think it's going to do its job.
9 You may want to put some restrictions on how many diesel
10 generators you can have out of service when the tornado
11 warnings are up or something like that.

12 MR. ARCHITZEL: This is Ralph Architzel again from
13 the staff. We did credit the gas turbine in the tech specs
14 for the reduced inventory mode. So, it is in there at that
15 point.

16 MR. CARROLL: That's correct.

17 MR. ARCHITZEL: And there is also a difficulty
18 with CE's design in that they only have the two divisions,
19 as opposed to GE that had the three. So, there is some more
20 difficulty with CE's design.

21 [Slide.]

22 MR. FINNICUM: The benefits -- I've really covered
23 the benefits and the detractions.

24 MR. CARROLL: The first bullet under the first
25 bullet, did we learn that you were saying that two

1 additional full-size diesels far exceed the cost of one gas
2 turbine?

3 MR. WYLIE: That's what they're saying.

4 MR. FINNICUM: That's apparently what the costs
5 are.

6 MR. CARROLL: What's the cost of four half-size
7 diesels versus two full-size plus a gas turbine? That's the
8 comparison I would make.

9 MR. SEALE: You could buy the same number of
10 megawatts in a diesel.

11 MR. FINNICUM: I cannot answer that question.

12 MR. CARROLL: Okay. So, the costs on the
13 preceding slide are for the case I just talked about, not
14 for the case I'm interested in. Okay.

15 [Slide.]

16 MR. FINNICUM: In 1992, an additional sensitivity
17 study was done. This one was performed by Duke Engineering
18 Services for the British Nuclear Fuels, and it looked at --
19 essentially at risk or Core Damage Frequency with a smaller
20 model.

21 They looked at loss of offsite power, small LOCA,
22 large LOCA, and general plant trip as initiators within a
23 smaller model, and their conclusion is that the two diesel
24 with the alternate AC source had a lower CDF than four
25 diesels without the AAC. Let me show you the number.

1 [Slide.]

2 MR. FINNICUM: The number here -- they show that,
3 for their model, that the Core Damage Frequency was 1.7E to
4 the minus 6th per year with two diesels and an alternate AC
5 source. For the four diesels without the alternate AC
6 source, it went up to 2.4E to the minus 4th, which
7 probabilistically speaking is essentially the same number.

8 The diesel generators again were dominated by the
9 common cause failure both of the diesels and of the support
10 system. These models did include support systems. For the
11 base case, the two diesels with the AAC, it looked at our
12 current support system design, in general. For the four
13 diesels, they looked at having two more with component
14 cooling water systems. It did not look at air-cooled
15 diesels.

16 The real conclusion is, in looking at the numbers,
17 I would say that there is not a big difference, there is
18 just essentially no difference between the two, and that
19 there is some cost differential in going to the four
20 diesels.

21 MR. CROM: This is Tom Crom again. I want to
22 touch a little bit on that cost number.

23 One, I want to point out, one, that the combustion
24 turbine is twice as large as the diesel generator. We're
25 talking about a 15-megawatt combustion turbine.

1 MR. CARROLL: That's correct.

2 MR. CROM: The other thing, those numbers -- you
3 know, you're talking about, essentially, you could have
4 half-size diesels, but if you look at the cost, where that
5 number is really driven is more in building costs and
6 concrete. You don't get that much reduction going to a
7 smaller diesel. So, even if you have a half-size diesel,
8 the number is not going to be that much different.

9 MR. CARROLL: Plus more switchgear.

10 MR. CROM: That's correct.

11 MR. SEALE: Unless you're able to go to air-
12 cooled, which cuts down on the peripherals, I would think.

13 MR. CROM: That would come down even on the two
14 diesel generator case, but still, those cost numbers are
15 going to be based on concrete and your building costs more
16 than it is on your diesel generator and your support
17 systems.

18 MR. CARROLL: Your two diesels are just getting up
19 in the size range where I'm not sure it is practical to have
20 air-cooled.

21 MR. SEALE: But four --

22 MR. CARROLL: Definitely you can air-cool.

23 MR. WYLIE: That's right.

24 MR. CARROLL: Okay. We know what the issue is.

25 MR. WYLIE: Just one other thing, though. Will

1 these numbers change if this plant were sitting at Turkey
2 Point and you had Andrew hit it?

3 MR. DAVIS: Which numbers?

4 MR. WYLIE: Well, I don't know. I'm talking about
5 the overall numbers here.

6 MR. CARROLL: You mean the risk numbers.

7 MR. WYLIE: The risk numbers, yes.

8 MR. DAVIS: Because of the combustion turbine not
9 being hardened?

10 MR. WYLIE: Well, they had combustion turbines down
11 at Turkey Point that were wiped out. They had all their
12 lines wiped out for a week. They were down to two diesels,
13 and they labored on that. They lost one of those during
14 that time and they relied on one. I think that a plant
15 sitting in that particular location, to get hit by a
16 hurricane, is very vulnerable.

17 [Slide.]

18 MR. FINNICUM: To pick up the last set of slides,
19 the last issue, it was the issue on the failure rate used
20 for failure of the MOVs to close, especially close in the
21 EFWS system. I understand this was Mr. Catton's question,
22 and he's concerned that the failure rate we used, the base
23 failure rate, was too optimistic.

24 MR. CARROLL: Do we know where Carl is?

25 MR. SEALE: He got pulled out by Med for some

1 reason.

2 MR. FINNICUM: The failure rate we used was 4E to
3 the minus 3. It was based on generic data from the key
4 assumption ground rules, and it was basically for valves
5 tested on a quarterly basis.

6 We understand Mr. Catton's contention is that, for
7 failure of the MOVs to close -- and I understand, it's
8 probably in the blowdown situation -- they really should be
9 much higher, 8E to the minus 2.

10 MR. CARROLL: At least for some valves.

11 MR. FINNICUM: At least for some valves.

12 [Slide.]

13 MR. FINNICUM: What I basically did is -- we
14 wanted to take a look at a sensitivity study of what would
15 be the impact on Core Damage Frequency. We looked at really
16 two cases.

17 The first case, we increased the failure rate for
18 all MOVs for fail to close failure mode from 4.0E to the
19 minus 3 to 8E to the minus 2 to take a look at the impact,
20 and our Core Damage Frequency went from 1E to the minus 6
21 per year up to 3E to the minus 6 per year, a factor of about
22 2.

23 For the second case, we increased the failure rate
24 for all EPW valves for all modes, both failed open and fail
25 to close, up to 4.0E to the minus 3 to 8E to the minus 2.

1 The base Core Damage Frequency went from 1.7E to the minus 2
2 up to 4E to the minus 6 -- 1.7E to the minus 6 per year to
3 4E to the minus 6 per year, which is an increase of about 2
4 1/2. So, it would have some impact on Core Damage Frequency
5 but not a large impact.

6 [Slide.]

7 MR. FINNICUM: Some of these other things that
8 I've prepared a slide is based on the operating conditions.
9 I now have a fuller understanding of what his concern was,
10 and it was the blowdown loads, and at this point in time,
11 this really does not address that issue.

12 [Slide.]

13 MR. FINNICUM: Now, what we did is we had looked-
14 - we used a generic Core Damage Frequency or generic valve
15 failure rate. We had looked at other available industry
16 sources in selecting that, and the value we selected was
17 within range of what we see in current PRAs and other
18 sources. We did not have access to the 8E to the minus 2
19 number, and that's why we used the 4E to the minus 3.

20 MR. DAVIS: I think that number is based on some
21 German data that --

22 MR. SEALE: Yes, that's right.

23 MR. DAVIS: -- Dr. Catton had obtained.

24 MR. FINNICUM: I could not find that in the
25 sources, and we looked at U.S. -- we had some access to

1 Swedish data, and their generic data -- and this is for
2 valve fails to change position, and it's in the same realm
3 as what U.S. and generic --

4 MR. MICHELSON: That's the numbers you're using
5 for valves that have to operate under blowdown kind of
6 conditions?

7 MR. CARROLL: Yes.

8 MR. FINNICUM: Yes. We used the 4E to the minus
9 3.

10 MR. MICHELSON: You have no database for that
11 except the few tests that have been run.

12 MR. FINNICUM: Yes.

13 MR. MICHELSON: Is this reflecting those few
14 tests?

15 MR. FINNICUM: Not that I know of. We used
16 generic data, and what I've shown is --

17 MR. MICHELSON: My question was did you use
18 generic data for blowdown conditions? The answer has to be
19 no, because there isn't any.

20 MR. CARROLL: No. They used the EPRI data.

21 MR. MICHELSON: They used the generic, no loaded -
22 -

23 MR. CARROLL: 4E to the minus 3.

24 MR. MICHELSON: -- and that's in the right
25 ballpark for that, but it's clearly not right for valves

1 under duress.

2 MR. DAVIS: You'd better go back to the other
3 slide. They raised it considerably to see what the effect
4 was.

5 MR. MICHELSON: You mean they raised it and it
6 showed no effect?

7 MR. DAVIS: A minor effect.

8 MR. CARROLL: Look at the Case 1/Case 2 slide.

9 MR. MICHELSON: Which parts of the PRA? You know,
10 like auxiliary feedwater would be one case.

11 MR. FINNICUM: We did two things.

12 MR. MICHELSON: Your plan is probably in fair
13 shape from this viewpoint, because you don't have many
14 energetic lines to begin with outside of containment, and
15 furthermore, they have a limited impact when they do fail.
16 You may not have a problem with it, but that doesn't make
17 your numbers right. It just means that --

18 MR. FINNICUM: I can't say that. I used the
19 generic number consistent with the data sources I had
20 available, and if we changed it, I can see what the impact
21 is.

22 MR. MICHELSON: I'm not even sure anymore how good
23 these generic numbers are.

24 When people start -- and I'm sure Duke will
25 confirm all of this. When they started looking at their

1 valves closely, they realized that there were many, many
2 valves that were way out of adjustment, and as a
3 consequence, the failure rate was -- in the generic data --
4 was not reflective of what was really there.

5 When they went back and fixed it up, I'm sure, if
6 anything, the generic numbers are now conservative, after
7 the readjustment and so forth had taken place, but that's
8 the uncertainty in these cases of isolating breaks. We
9 don't have enough data to know what the impact is, but the
10 generic numbers probably aren't too bad now, once they got
11 all the valves tuned up, but they weren't too good before.
12 They were way off before.

13 MR. CARROLL: How about the fail to open case for
14 the depressurization valves? How bad would that hurt you?

15 MR. FINNICUM: For the depressurization valves, I
16 believe we already addressed that in --

17 MR. CARROLL: The MOVs are open already.

18 MR. MICHELSON: It depends on which ones you're
19 talking about.

20 MR. FINNICUM: For the safety depressurization
21 valves in the RCS?

22 MR. CARROLL: Yes.

23 MR. FINNICUM: Those are -- inside containment,
24 both the block valves and the isolation valves have to open.
25 The failure rate we used there is based on an 18-month test

1 interval. So, it is higher than the 4E to the minus 3.
2 It's somewhere in the 10 to the minus 2 range.

3 MR. MICHELSON: With a testing interval of whose
4 valves? Testing interval means nothing.

5 MR. CARROLL: He's put in a cheat factor for the
6 fact that the valves are only tested every 18 months.

7 MR. MICHELSON: That's okay.

8 MR. CARROLL: That's for aging effects.

9 MR. MICHELSON: That doesn't help the orders of
10 magnitude that your reliability numbers may be off to begin
11 with. It just makes a small correction in a big error.

12 The valves that have to open under full
13 differential pressure have been just about as bad as those
14 that have to open under blowdown or close under blowdown
15 conditions, and again, they found that, in many cases, they
16 just would not have hacked it if they'd had to, but they
17 fixed it and now they should. So, the problem went away
18 only because it was -- I think because the valves have been
19 properly adjusted now.

20 MR. CARROLL: Well, I believe there are some
21 valves out there that are just mis-designed that are going
22 to have to be replaced. They don't have a big enough
23 operator on them.

24 MR. FINNICUM: There are some very glaring cases
25 of that. In the early days, San Onofre I found out that

1 their -- one of their injection valves -- the motors
2 couldn't open the valve at all, and they had to go back in
3 and replace them with a bigger motor.

4 MR. MICHELSON: I think the generic database --
5 maybe we're beginning to get to the point where maybe it's
6 not so bad now for these cases, but it certainly was way off
7 in the past, and we just didn't realize it.

8 MR. CARROLL: We're in the category of things that
9 Combustion perceived ACRS had some questions about, Carl.
10 We've dealt with the MOV issue, and while you were out, we
11 discussed the two EDGs with AAC.

12 MR. MICHELSON: I heard some of that.

13 MR. CARROLL: Have we got any other issues?

14 MR. FINNICUM: That concludes the slide show I
15 have.

16 MR. CARROLL: I know. I know. This jogs me to
17 say is there anything else we want Combustion to do some
18 analysis?

19 MR. MICHELSON: Other than the things we've asked
20 for during the meeting?

21 MR. CARROLL: Yes.

22 MR. MICHELSON: Namely the pressurization
23 analysis, for instance, on the auxiliary feedwater. They
24 were going to supply that.

25 One thing I have kind of an uneasy feeling about -

1 - I think they've got to go back and sharpen pencils a whole
2 lot on their flood analysis to make it believable. I'm not
3 sure that there's really a problem, per se. It's just not
4 yet believable, because they haven't done it in sufficient
5 detail. I think, once they do and catch all the little
6 things, you know, things like the leaking seals where you're
7 going out into an area exposed to a site flood, things like
8 that, once they get those things taken care of, I think
9 they're okay. They've promised to fix all those that we
10 talked about.

11 MR. FINNICUM: Mr. Michelson, we do have in the
12 PRA, in 19.15 now -- one of the insights is that, on the
13 final design, the COL will go back in and factor in the
14 site-specific and final design information, and it
15 specifically calls out look at the external events.

16 So, I agree. These were scoping estimates only.
17 We wanted to look at a number, and that's why I don't call
18 them the Core Damage Frequency.

19 MR. DAVIS: I think your main purpose was to see
20 if you had any obvious vulnerability that you'd overlooked,
21 and for that purpose, I think it was probably adequate, and
22 the question is now is it really worth doing anymore till
23 you have the plant, and I guess I don't think it is.

24 MR. CARROLL: Okay. I guess what we have left are
25 some remaining questions from yesterday. Let's see. Who

1 had questions?

2 MR. COE: I think one question that was left over
3 from December was the question that appears on page 69 of
4 your handout. This was Mr. Wylie's question. Maybe we've
5 already addressed it.

6 MR. SEALE: Over-voltage protection?

7 MR. COE: Yes, over-voltage protection, and I
8 don't think we have discussed that yet. I know we've looked
9 at it, you've looked at it, but we haven't discussed it in
10 committee yet.

11 MR. MICHELSON: What page is it on?

12 MR. COE: Page 69 of the handout that I provided
13 to you, not the staff handout.

14 MR. WYLIE: It looked all right. They provided
15 volts per hertz relay, and it looks fine to me.

16 MR. CARROLL: Is Duke Engineering doing this
17 stuff?

18 MR. WYLIE: I do not know.

19 MR. MICHELSON: Was that done on your earlier
20 plants?

21 MR. WYLIE: Yes.

22 MR. MICHELSON: Not done for everybody.

23 MR. RITTERBUSCH: Could you repeat the question,
24 please?

25 MR. CARROLL: I just wondered whether Duke

1 Engineering was doing this electrical stuff.

2 MR. CROM: Yes, we are.

3 MR. CARROLL: That makes me suspicious given your
4 heritage.

5 [Laughter.]

6 MR. SEALE: No comment.

7 MR. MICHELSON: For the type of breakers that you
8 now have in mind for this plant, are you going to go to
9 solid state controlled over voltage and under voltage and so
10 forth, or is it going to be the old relay type?

11 MR. CROM: I am not sure I can answer that right
12 off hand.

13 MR. MICHELSON: It could be either.

14 MR. CROM: It could be either right now. It is
15 not specified.

16 MR. MICHELSON: It did not seem to be specified.
17 The solid state devices have got some unique
18 characteristics.

19 MR. CARROLL: Duke found out about some of them
20 once not too long ago.

21 MR. MICHELSON: Yes. And they are programmable
22 too, and you can program them wrong. You get 100 breakers
23 in the plant all programmed wrong, and you get the right
24 event, and they all cascade in the wrong way.

25 MR. WYLIE: I guess I can ask this other question

1 too about the basis of the test, the ITAAC Test Number 9 in
2 the table. You provided me an answer to that.

3 MR. CROM: Yes, that's correct.

4 MR. CARROLL: That is page 70.

5 MR. COE: It has not been formally submitted yet.

6 MR. CARROLL: Okay. What's next.

7 MR. COE: The next one was --

8 MR. SEALE: You had a question for Bill Shack.

9 MR. COE: That's correct. That was on page 47 and
10 48 of your hand-out. That was the question regarding copper
11 content that Dr. Catton referred to Dr. Shack.

12 MR. CARROLL: Dr. Shack does not have to answer it
13 until next month. Are you prepared to?

14 MR. SHACK: I am prepared to, yes. In this one,
15 you know, your mother was right: cleanliness is next to
16 godliness; a cleaner steel is a better steel. Cleaning up
17 things like phosphorous and sulfur are going to give you a
18 higher upper shelf energy to begin with. You are just going
19 to have more toughness.

20 Reducing the cooper, again, there is obviously
21 some limit to where the cooper clusters become so far apart
22 that their embrittlement effect is minimal, but it seems to
23 me a sort of an ALARA process toward the cooper content is a
24 good thing.

25 Just how much benefit you can go by going very low

1 I do not think is clear. There is no reason not to go low.

2 MR. CARROLL: If you can do it.

3 MR. SHACK: If you can do, do it.

4 MR. DAVIS: Bill, I am not a metallurgist, but
5 when Ivan came back from Europe he wrote a trip report. One
6 of the inclusions of that was that some of the Europeans are
7 convinced that copper doesn't have anything to do with
8 embrittlement. Did you see that, by the way, his trip
9 report? This came as a real surprise to me, and I do not
10 know what the basis was, but I guess it does not have
11 anything to do with the question.

12 MR. SHACK: Yes. That sounds like an awfully
13 sweeping statement.

14 MR. DAVIS: Well, I am paraphrasing.

15 MR. SHACK: I would like to know what context they
16 think that in.

17 MR. DAVIS: You may want to ask him about that
18 when you see him, because I found it surprising too.

19 MR. CARROLL: Yes. That was the report on the
20 trip he made.

21 MR. DAVIS: Way back.

22 MR. CARROLL: That we finally got just before last
23 meeting.

24 MR. DAVIS: Right.

25 MR. CARROLL: Do you remember me commenting why it

1 took him so long to get it?

2 MR. SEALE: September or something like that.
3 August or September.

4 MR. SHACK: I have seen arguments like that in
5 terms of low temperature embrittlement. You know, when you
6 are talking about support structures, it is not so clear
7 that copper has an effect on embrittlement at those low
8 temperatures.

9 To say that copper has no effect on embrittlement
10 at reactor operating temperatures, I would like to see the
11 context that statement was made in.

12 MR. CARROLL: Okay. So we will tentatively -- or
13 say this one is tentatively scratched off the list subject
14 to Bill --

15 MR. SHACK: Clarifying with Ivan just what that
16 was about.

17 MR. CARROLL: All right.

18 MR. COE: The next one was on page 54, the hand-
19 out. I do not know whether we covered this. This is the
20 post accident radiation monitor basis for the temperature
21 qualification requirement.

22 MR. CARROLL: Yes, we did.

23 MR. COE: Okay. That one is finished.

24 MR. CARROLL: Who have you got down?

25 MR. COE: Well, talk to Catton.

1 MR. CARROLL: I think I asked the question,
2 actually. Maybe Catton did, or maybe both of us did. I
3 think we have dealt with it.

4 MR. COE: Okay. The next one was page 41 of the
5 hand-out. This was the discrepancy in the CESSAR regarding
6 use of cobalt-based materials. That was your question, Mr.
7 Chairman.

8 MR. CARROLL: Sounds like they resolved it. That
9 they've fixed the problem that I identified. Now the Staff
10 has got to fix the problem, the rad protection section. It
11 looks like they understand that.

12 MR. COE: Okay. The next one was on page 46 of
13 the hand-out, and that was --

14 MR. CARROLL: Just on the subject of cobalt, what
15 do you know about that, Bill? How close are we to having
16 some decent replacements for Stellite?

17 MR. SHACK: When I read the EPRI reports, it looks
18 pretty good.

19 MR. CARROLL: That is what I was going to say.

20 MR. SHACK: But if I was buying a plant --

21 MR. CARROLL: You would still want the option of
22 being able to use Stellite.

23 MR. MICHELSON: EPRI doesn't make valves.

24 MR. SHACK: Yes. It is a big investment here. I
25 would like to see a little more field stuff. The research

1 reports look very good for some of these replacements. They
2 have, I guess, some field experience is now being
3 accumulated, but if I was investing my billion dollars, I
4 still would be specifying Stellite at this moment.

5 MR. SEALE: Could I ask in that regard from the
6 ABB people, this represents a considerable or serious
7 attempt to reduce the amount of cobalt relative to what was
8 in the System 80. Is that correct?

9 MR. RITTERBUSCH: Yes.

10 MR. SEALE: I know at Palo Verde they've indicated
11 some problems with cobalt.

12 MR. CROM: Yes. This is Tom Crom. Yes, most of
13 the current plants have anywhere from .1 to .2 in weight
14 percent cobalt and a lot of the materials where we are
15 talking about .05.

16 A little bit of a discussion on Stellite
17 replacement, it is not only a factor of the material itself,
18 but the design of the valve. There is currently replacing
19 in plants all globe valves and check valves that have
20 Stellite in them, and they are doing that regularly during
21 maintenance.

22 The real concern yet is on gate valves where there
23 is a high torque and thrust and the galling. The problem is
24 that the test results that were done were based on the
25 thrust settings that may be calculated, but typically when

1 you do the tests on the thrusts it is a lot higher.

2 Now, that is a little bit dependent on the design
3 of the valve. You can design the valve appropriately that
4 does not require that high thrust, then you may be able to
5 get away with the replacements.

6 MR. MICHELSON: We just don't have much
7 experience. The only experience we have is with stellite,
8 and we'd have to have a whole new test program, because that
9 would have a definite effect on the thrust requirements.

10 MR. CROM: I understand.

11 MR. CARROLL: GE got rid of the stellite rollers
12 on their control blades.

13 MR. MICHELSON: But they didn't get it on their
14 valves.

15 MR. CARROLL: Well, except the control blades are
16 in the core, which is not --

17 MR. MICHELSON: That is not nice either.

18 MR. CARROLL: And I guess combustion has some
19 stellite in the control rod drive mechanism.

20 MR. SHACK: It is interesting that they have
21 committed to lower the cobalt in the stainless steel more
22 than GE has in the ABWR.

23 MR. CARROLL: Is that correct?

24 MR. SHACK: Yes. GE is sticking with the 0.1
25 percent rather than the 0.05 percent. Obviously, somebody

1 has different perceptions of what is commercially
2 achievable.

3 MR. CARROLL: Do you want to change your mind?

4 MR. RITTERBUSCH: We checked before we wrote down
5 0.05.

6 MR. CARROLL: Good.

7 MR. COE: The next one was on page 46, is question
8 number 7 regarding the capability for System 80+ to handle
9 frequency degradation without tripping the reactor. This is
10 Mr. Carroll's question.

11 MR. CARROLL: It was my question and I got the
12 answer and then I heard Lindbald say he had a question about
13 this, so we haven't put that one to rest. I don't know what
14 his question is.

15 MR. COE: Then the next one is on page 53,
16 question number 12. This had to do with the extent to which
17 tech specs allow alternate AC to be used as a backup for the
18 diesel generators.

19 MR. MICHELSON: Is that question 11 or 12?

20 MR. COE: It was question -- excuse me, 11. Page
21 53.

22 MR. CARROLL: We know a bit more from what we
23 heard earlier this afternoon. I think you can scratch that
24 guy off.

25 MR. DAVIS: This provision has been accepted by

1 the Staff; is that correct?

2 MR. CARROLL: What is that?

3 MR. DAVIS: That the AC can be used to replace one
4 diesel generator?

5 MR. CARROLL: The tech specs will require the two-
6 of-three concept during shutdown.

7 MR. DAVIS: Oh, okay. I'm sorry.

8 MR. CARROLL: But the issue of what credit you get
9 for the AAC during mode 1 is still up in the air. That was
10 what we commented on in our letter last month and what we
11 hear Combustion and the Staff are going to be discussing in
12 the near future.

13 MR. SIEGMANN: I would like to correct something
14 there. This is Eric Siegmann.

15 Our tech specs require two of the three during
16 shutdown. I am not too sure what the NRC requires. But
17 they might require two of the three during mid loop or
18 reduced inventory.

19 MR. CARROLL: The tech specs you have voluntarily
20 submitted require two of three at all times in mode 6?

21 MR. SIEGMANN: No, in shutdown. That's modes 4, 5
22 and 6, basically.

23 MR. CARROLL: Four, 5 and 6. Okay.

24 MR. ARCHITZEL: Ralph Architzel from Staff.

25 I believe we are going to require, in mid-loop,

1 two power sources on site. And we are allowing the use of
2 the combustion turbine. They could have just proposed their
3 two safety diesels as opposed to the combustion turbine. So
4 we allowed them to use the combustion turbine.

5 I don't believe that we require two in all
6 shutdown modes because -- well, in mode 6 when you're fueled
7 up, you'll require more than one.

8 MR. CARROLL: But if they're willing to commit to
9 that, you're not going to disagree with it?

10 MR. ARCHITZEL: To two at all times? We didn't
11 disagree, no. I'm not aware on that particular point.

12 MR. CARROLL: I saw it someplace in here. Okay.

13 MR. COE: The next question was one for the Staff.
14 Question number 14, this was responded to on the Staff's
15 handout about six pages on the back.

16 MR. MICHELSON: Are we done with CE's handout yet?

17 MR. COE: No, you have a couple questions
18 remaining.

19 MR. MICHELSON: I have a couple others I want
20 clarification on.

21 MR. COE: Right.

22 It's about six pages from the back of the Staff's
23 handout. The pages are not numbered. But about six from
24 the back, it's question number 14. This is Mr. Carroll's
25 question regarding the use of the term "vital areas"

1 commonly for both security and RP purposes.

2 And the Staff has responded with a copy of a
3 letter the ACRS wrote in February.

4 MR. CARROLL: All right, a copy of the response we
5 got.

6 MR. COE: A copy of the response, yes. The
7 response to that letter.

8 MR. CARROLL: I'm not giving up. But scratch it
9 off the list.

10 MR. COE: Okay.

11 And the next question is responded to immediately
12 after that by the staff, question number 15, also
13 Mr. Carroll's question regarding the -- an apparent
14 discrepancy in the FSER on the requirements for the OSC
15 being in the ITAAC.

16 MR. CARROLL: I thought they answered that during
17 the meeting, that that was an oversight and they were going
18 to fix it.

19 MR. COE: And they have indicated that's a
20 confirmatory item.

21 And the last question then on Staff responses is
22 the following question after that. Number 16, regarding the
23 exception that was taken on the topical report that was
24 referenced in this -- in the draft FSER, also Mr. Carroll's
25 question .

1 MR. CARROLL: What was the answer?

2 MR. COE: See attached page.

3 MR. CARROLL: We didn't look at that. Why don't
4 you move on while we're looking.

5 MR. COE: The next one is on the handout that I
6 have distributed on page 49 through 51, Mr. Michelson's
7 question -- oh, excuse me. We have already discussed that
8 one.

9 MR. MICHELSON: Well, yes. But as long as you've
10 got it open now, though, it wasn't -- it is not entirely
11 clear to me how we finally ended up as to how it is going to
12 be resolved.

13 MR. COE: I have two notes. One is that we will
14 treat a portion of it at the subcommittee meeting in May,
15 the Auxiliary and Secondary Systems --

16 MR. MICHELSON: It's now going to be June.

17 MR. COE: Which is now going to be June.

18 MR. MICHELSON: June 8th, I guess it is, something
19 like that.

20 MR. COE: Also a portion of it will be treated at
21 the April subcommittee meeting of this subcommittee.

22 MR. MICHELSON: I didn't understand that. Is that
23 going to be because we pick up chapter whatever it is where
24 it appears?

25 MR. COE: Yes.

1 MR. MICHELSON: Much of the argument in here is
2 going to have to be getting all these cats together that
3 have different stories and get the story to come together.

4 MR. COE: That's correct. I was anticipating that
5 in Chapter 9 of the CESSAR that we would be discussing, the
6 fire protection issues.

7 MR. MICHELSON: Okay. So that will be in April,
8 then?

9 MR. COE: In April.

10 MR. MICHELSON: But we will won't hear from the
11 University of Maryland and so forth until later, June. I
12 don't know why we couldn't get that meeting earlier except
13 that nobody could come.

14 MR. DUDLEY: This is Noel Dudley. The report from
15 Maryland will be issued in the next couple of weeks.

16 MR. MICHELSON: Okay. But, of course, what we
17 wanted to do is discuss it with the department head and so
18 forth to understand it and then act accordingly on System
19 80. That doesn't fit too well, a subcommittee that doesn't
20 meet until June.

21 MR. COE: Not very well, no.

22 MR. MICHELSON: When are you going to write a
23 final letter?

24 MR. COE: It will be out the door in June.

25 MR. MICHELSON: Well, that doesn't fit at all,

1 then. We had it in May, but I understood there was somebody
2 who couldn't come. Why didn't we move it further up? If
3 the report is going to be in, in two weeks, why isn't it
4 going to be in April, the meeting?

5 MR. DUDLEY: I could work on that.

6 MR. MICHELSON: Why don't you get with Ivan again
7 and find out because really that needs to come before we
8 talk about the diesels, the fire protection, with CE.

9 MR. COE: I think we will have to look into that.

10 MR. MICHELSON: I didn't think well enough. But
11 clearly June is just too late to fit much of anything.

12 MR. CARROLL: Backing up one, I am happy with the
13 staff response.

14 MR. COE: On question 16.

15 MR. MICHELSON: That took care of 9, then.

16 MR. COE: All right. Well, then, there was one
17 final question. Mr. Michelson had asked Number 10 on page
18 52 regarding the design capability of the doors between the
19 turbine building and the nuclear annex.

20 MR. MICHELSON: There the claim is that they will
21 be designed for the tornado case, which is a differential
22 pressure of 2.4. Those are going to be pretty good doors.
23 People have started looking at doors very closely and have
24 found that that is a tough requirement.

25 MR. CARROLL: How do you open it?

1 MR. MICHELSON: How do you do other things? If it
2 is a big double swinging door, it gets tough to latch. But
3 at any rate, the only question I had was: Has somebody done
4 the calculations of the postulated brakes that might occur
5 in the neighborhood of those doors to see if the 2.4 bounds
6 those calculations or not?

7 MR. STAMM: The answer is we have done enough to
8 know that we can make a commitment to make it work at 2.4.

9 MR. MICHELSON: A lot of big vent areas available
10 and so forth?

11 MR. STAMM: Yes, in the turbine building typically
12 you have a lot of spaces for venting.

13 MR. MICHELSON: No jet impingements on the door or
14 anything like that?

15 MR. STAMM: No, if you wanted to, I could show you
16 a sketch.

17 MR. MICHELSON: Not really. I will just take your
18 word for it. You looked at all the hazards of a pipe break
19 in the vicinity. The doors are protected against that?

20 MR. STAMM: Yes, the doors are actually --

21 MR. MICHELSON: They are pressurized and it is
22 less than the tornado design requirements?

23 MR. STAMM: That's right. The doors actually are
24 on the annex side of an enclosed stairwell. The piping is
25 run on the floor below, about 20 or 30 feet below the

1 elevation of the doors.

2 MR. MICHELSON: So it already shielded well from
3 the direct impingement effects?

4 MR. STAMM: Correct.

5 MR. MICHELSON: That should take care of the
6 answer. 2.4 is the key. That is a good door.

7 MR. CARROLL: Those are our follow-up questions.

8 MR. COE: I have just one reminder for CE. We are
9 still waiting for additional information on the two follow-
10 up questions we discussed the last meeting -- questions 3
11 and 8 from the December meeting. There were some
12 commitments made to add some language to the answers.

13 Also from this meeting, we had earlier discussed
14 their commitment to try to get additional information.

15 MR. RITTENBUSCH: We agree.

16 MR. COE: Okay.

17 MR. MICHELSON: One clarification on this door
18 business since we have now identified the turbine door. Are
19 all doors to the nuclear island qualified then, all doors to
20 the outside, for tornado depressurization effect? They
21 would all be qualified for the 2.4; is that correct?

22 MR. OSWALD: Todd Oswald. Yes, all exterior doors
23 are.

24 MR. MICHELSON: Okay. Thank you.

25 MR. CARROLL: Okay. Those are the questions.

1 All right. I guess we have one other item on the
2 agenda that Stan tells me he can deal with in exactly 60
3 seconds. The challenge is on ITAAC.

4 [Laughter.]

5 MR. CARROLL: Now I have already told him that we
6 have been Tony James'd to death on ABWR, so we really didn't
7 need any more of that.

8 [Slide.]

9 MR. RITTENBUSCH: You may know that I have been
10 with Combustion Engineering for 24 years now. I hope that
11 qualifies me to summarize in 60 seconds what it took us
12 three or four years to produce.

13 I am not going to read to you the details of our
14 approach to CDM and what it is. What I would like to say is
15 that we have participated with the NRC staff, meetings with
16 General Electric and the industry ever since the beginning
17 of the ITAAC and the CDM saga several years ago. We have
18 adopted all of their lessons learned.

19 This means that the process that we used for
20 developing our CDM is nearly identical to that used by
21 General Electric. Our designs, however, are different.
22 Therefore, obviously, we have a different ITAAC, and in a
23 few cases, a few different approaches, which I will state in
24 a second.

25 [Slide.]

1 MR. RITTENBUSCH: I am now going to go to the next
2 slide. You are probably all familiar with the basic
3 segments of certified design material. I am simply going to
4 point to Section 3, which is the non-system specific design
5 descriptions. This is one area where we had a difference
6 from ABWR. ABWR proposed four non-system specific ITAACs.
7 We have two.

8 MR. CARROLL: Sometimes referred to as DACs.

9 MR. RITTENBUSCH: That is correct. You said it
10 first.

11 MR. CARROLL: Okay.

12 MR. RITTENBUSCH: That finishes my presentation.

13 MR. MICHELSON: Tell us what the two are.

14 MR. RITTENBUSCH: Piping and shielding.

15 MR. MICHELSON: You don't need any DAC, then, for
16 your instrumentation and control arrangements?

17 MR. RITTENBUSCH: Well, that is covered in our
18 sections on ITAAC.

19 MR. MICHELSON: That means there are no additional
20 things to be confirmed in future dates?

21 MR. CARROLL: Oh, yes, both for that and for --

22 MR. MICHELSON: Well, that is what a DAC is about.

23 MR. CARROLL: Yes, except they put them into
24 Section 2 kind of stuff.

25 MR. MICHELSON: Well, what you are saying is that

1 two of the four DACs you put in a different section in a
2 different way and you don't call them DACs anymore?

3 MR. RITTENBUSCH: I will be a little more
4 explicit. On the other two DACs we have done sufficient
5 additional design work such that we thought it was more
6 appropriate to put them into the context of ITAAC rather
7 than DAC.

8 MR. MICHELSON: Sure.

9 MR. RITTENBUSCH: I believe the staff concurred.

10 MR. MICHELSON: Okay. I understand now. I was
11 just wondered how you were doing it.

12 MR. ARCHITZEL: This is Ralph Architzel from the
13 staff. I don't think staff quite characterized it that way.
14 We are probably pretty much in disagreement that they don't
15 have four DACs right now. We are going to be working that
16 out. That is one of the confirmatory items.

17 MR. MICHELSON: Is it a question of which section
18 they go into?

19 MR. ARCHITZEL: It is not the difference in what
20 they are going to do, but a difference in how we
21 characterize them. We believe there are four DACs. We are
22 going to get together with them.

23 MR. MICHELSON: I thought it a little skimpy for a
24 final design.

25 MR. FRANOVICH: Yes. It's true. When you take the

1 example of the control room design, that is certainly not a
2 final design. That's still a DAC and so fundamentally we
3 don't agree that it is analogous to a system ITAAC.

4 MR. RITTERBUSCH: I want to apologize to Staff. I
5 didn't mean to say we agreed on DAC. I knew we did not
6 agree on the terminology on what we call these. What I
7 wanted to say is that the Staff has looked at the manner of
8 incorporating our control room and I&C into the CDM and I
9 believe we do have agreement on that.

10 MR. FRANOVICH: Yes, we do have agreement on the
11 process, on the design process, no doubt.

12 MR. MICHELSON: Let me ask the subcommittee
13 chairman then how are we going to treat -- are we going to
14 look at the same four areas as we did or are we not going to
15 look at I&C at all?

16 MR. CARROLL: We did. We looked at I&C in
17 December in the context of Chapter 7.

18 MR. MICHELSON: Yes.

19 MR. CARROLL: And the certified design mechanism.

20 MR. MICHELSON: I didn't realize we were covering
21 all the certified design material at the same time.

22 MR. CARROLL: Yes.

23 MR. MICHELSON: Okay.

24 MR. CARROLL: Similarly, we looked at the human
25 factors area in terms of --

1 MR. MICHELSON: That was our review of the CDM as
2 well, okay.

3 MR. CARROLL: Because that is really the best
4 place to look for an overview of it.

5 MR. MICHELSON: For an overview, that's true.

6 MR. CARROLL: Okay. I would point out that I went
7 through the Staff FSAR on 14.3 and it goes on for quite a
8 number of pages and it does describe the Staff's process by
9 which they set up multidisciplinary task forces, if you
10 will, I to look at whether this certified design material was
11 really what ought to be in there and I was fairly impressed
12 with what was described there.

13 Did I say that well?

14 MR. ARCHITZEL: One point I would like to make, to
15 make sure that the ACRS is familiar -- we are currently
16 doing an independent or quality verification, if you will,
17 of the ITAAC, the CDM. I am not talking about the trip that
18 went up there with the multidiscipline team. We also had a
19 multidiscipline team doing a quality verification of the
20 ITAAC and we have got back right now a stack of comments on
21 the ITAAC that we are going to work out first internally and
22 then the remainder of those comments we'll be interacting
23 with CE to resolve problems, so it's not totally finished
24 yet but that process is ongoing right now.

25 MR. FRANOVICH: I would like to add to that, that

1 is a confirmatory item in the FSAR and it is a QA check
2 between Tier 1 and the SSAR material.

3 MR. CARROLL: I did note on page 14-3 something
4 Earl always is asking about. There is no design information
5 presented in the CDM or Section 14.3 that is not also
6 contained in the various sections of the CESSAR-DC.

7 Staff did not base its safety evaluation for the
8 design on the information in the CDM and therefore this
9 section of the report contains no safety evaluation of the
10 design.

11 MR. MICHELSON: Therefore we don't need to look at
12 it.

13 MR. CARROLL: But the point is they are saying in
14 very clear terms that what they are basing their safety
15 determination on is the SSER and not the CDM.

16 MR. MICHELSON: Yes, we don't need to review the
17 CDM at all to determine safety of the plant.

18 MR. CARROLL: Okay. Your one minute is up,
19 Ritterbusch.

20 MR. RITTERBUSCH: Okay, thank you.

21 MR. CARROLL: Is there any more that should come
22 before this august body? We're adjourned -- I just want to
23 mention to Bill that you understand what you are on the hook
24 for next month?

25 MR. SHACK: Yes.

1 MR. RITTERBUSCH: May I ask a question?

2 MR. CARROLL: Yes.

3 MR. RITTERBUSCH: Can you give us an assessment of
4 the schedule? I heard you mention something about meetings
5 in June. It is my understanding that --

6 MR. CARROLL: I said the report will be out the
7 door in June.

8 MR. RITTERBUSCH: Okay. Well, I will state my
9 understanding and if you agree, I would appreciate it. It's
10 my understanding that we will have two days of meetings on
11 April 5th and 6th.

12 MR. CARROLL: Correct.

13 MR. RITTERBUSCH: And at that time we will assess
14 the need for an additional half-day, approximately, clean-
15 up meeting at some point in late April or early May.

16 MR. CARROLL: That is probably --

17 MR. DAVIS: Early May probably.

18 MR. CARROLL: Yes, probably early May, yes.

19 MR. RITTERBUSCH: Thank you.

20 MR. CARROLL: We do have the question of whether
21 we need to have a presentation to the full committee in
22 April. We are still discussing that and hopefully we'll get
23 some resolution to that during our full committee meeting
24 over the next two days.

25 MR. RITTERBUSCH: We will support that.

1 MR. CARROLL: I don't know that you need to.

2 MR. RITTERBUSCH: If asked.

3 MR. CARROLL: Okay. I am arguing that the
4 subcommittee is virtually the full committee and --

5 MR. MICHELSON: It is not the full committee
6 though. The members of the full committee have to make the
7 same decision we have to make and they have to hear enough
8 of a presentation so they feel comfortable.

9 MR. CARROLL: The members of the full committee
10 that have not participated in these meetings are Ernest, who
11 won't be here in June --

12 MR. MICHELSON: That's a plus, I guess, in a way.

13 MR. CARROLL: And Hal, who has participated in
14 what I think the areas of his interest are.

15 MR. MICHELSON: If you feels that he has
16 participated, then that's fine --

17 MR. CARROLL: Well, that's what I want to debate,
18 and Bill, who has beer participating, and Ivan is a member,
19 so --

20 MR. MICHELSON: So you probably are okay.

21 MR. CARROLL: Well, I don't know. Doug raises the
22 question of whether we have to --

23 MR. MICHELSON: But the public needs to -- you
24 know, they can come to these meetings, too, but somehow they
25 generally come just to the full committee's final

1 discussion.

2 MR. SEALE: Check with the lawyers.

3 MR. CARROLL: So we are going to have to check
4 that one out.

5 MR. MICHELSON: You could make it an hour.

6 MR. CARROLL: We could have an hour of overview.

7 MR. MICHELSON: No one says how long it has to be,
8 only that I think it's probably good politics to do it.

9 MR. CARROLL: I think it is, too.

10 MR. MICHELSON: If somebody says they have got to
11 hear six hours, then I guess you have got to arrange for six
12 hours.

13 MR. CARROLL: Then I'm going to argue with them.

14 Okay, we stand adjourned.

15 [Whereupon, at 3:04 p.m., the meeting was
16 adjourned.]

17

18

19

20

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings
before the United States Nuclear Regulatory
Commission
in the matter of:

NAME OF PROCEEDING: ACRS ABB CE Plant Design

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, MD

were held as herein appears, and that this is the
original transcript thereof for the file of the
United States Nuclear Regulatory Commission taken
by me and thereafter reduced to typewriting by me
or under the direction of the court reporting
company, and that the transcript is a true and
accurate record of the foregoing proceedings.

Maulana Estep

Official Reporter
Ann Riley & Associates, Ltd.

ABB Combustion Engineering

System 80+™ Standard Plant
CESSAR - DC Section 3.9.6
Testing of Pumps and Valves

Thomas D. Crom
Duke Engineering & Services, Inc.

ACRS ABB-CE Standard Plant Designs Subcommittee
March 8 & 9, 1994

System 80+™ Standard Plant

Testing of Safety-Related Pumps and Valves

- Section 3.9.6 General
- Table 3.9-15 Inservice testing plan for pumps and valves
- Pump and valve testing provisions
- COL Applicant responsibilities

System 80+™ Standard Plant

Section 3.9.6 General

- Definition of “Safety-related” for IST applicability
 - Safety-related pumps and valves include those necessary to ensure:
 - The integrity of the reactor coolant pressure boundary.
 - The capability to achieve safe shutdown of the reactor and keep it in a safe shutdown condition.
 - The capability to prevent or mitigate the consequences of accidents that could result in potential offsite exposures in excess of 10 CFR 100 Guidelines.

System 80+™ Standard Plant

Table 3.9-15 Inservice Testing Safety-Related Pumps and Valves

- IST Plan (Table 3.9-15) developed to identify safety-related components tested in accordance with:
 - ASME/ANSI OMa-1988 of Addenda to ASME/ANSI OM-1987;
 - Part 1 - Relief Valves
 - Part 6 - Pumps
 - Part 10 - Valves (other than relief valves)
 - 10 CFR 50 Appendix J Testing

Table 3.9-15 Inservice Testing Safety-Related Pumps and Valves (continued)

- Plan format for pumps

- Pump name
- ASME Safety Class
- Test parameter
 - DP - Differential pressure
 - SPs - Static suction pressure
 - SPo - Operating suction pressure
 - Q - Flow
 - V - Speed
- Test frequency
- Test configuration
- CESSAR-DC figure number

- Plan format for valves

- Valve number
- Valve name
- Valve type
- Valve actuator
- ASME Safety Class
- ASME Code Category
- Valve function (cont. isol., TIV, PIV)
- Required testing (stroke, leak test, etc.)
- Test frequency
- Test configuration
- CESSAR-DC figure number

System 80+™ Standard Plant

Testing of Safety-Related Pumps

- System 80+ Design includes provisions for:
 - Full flow pump testing during plant operations (quarterly)
 - Capability to measure NPSH throughout pump operating range
 - Redundancy and separation of systems and components to allow complete pump testing with minimal impact to plant operability.

System 80+™ Standard Plant

Testing of Safety-Related Valves

- System 80+ Design includes provisions for:
 - Capability to perform required testing
 - Redundancy and separation of systems and components to allow maximum valve testing with minimal impact to plant operation

System 80+™ Standard Plant

COL Applicant Responsibilities - General

- COL Applicant provides details of IST:
 - Test procedures
 - Test schedules
 - Test frequencies
 - Baseline preservice test program

System 80+™ Standard Plant

COL Applicant Responsibilities - Pumps

- COL applicant establishes baseline pump design qualification testing encompassing design conditions which demonstrate acceptable pump performance
- COL applicant ensures pump specified is not susceptible to inadequate minimum flow and inadequate thrust bearing capacity
- COL applicant develops pump disassembly program for all safety-related pumps; program based on:
 - Historical pump performance
 - Pump components' performance
 - Non-intrusive test results

System 80+™ Standard Plant

COL Applicant Responsibilities - MOVs and POVs

- COL applicant establishes baseline valve design qualification testing encompassing design conditions which demonstrate acceptable valve performance (i.e., torque, thrust, force); conditions vary based on valve type (MOV, POV) but generally are:
 - Fluid flow
 - Differential pressure (including pipe break)
 - System pressure
 - Fluid temperature
 - Ambient temperature
 - Minimum voltage/pneumatic or hydraulic pressure
 - Minimum and maximum stroke time requirements

COL Applicant Responsibilities -
MOV's and POV's (continued)

- COL Applicant ensures that MOV specified for each application is not susceptible to pressure locking and thermal binding
- COL Applicant will periodically test MOVs (per Generic Letter 89-10 paragraphs D and J) and POVs to demonstrate continuing capability for design basic conditions

System 80+™ Standard Plant

COL Applicant Responsibilities - Check Valves

- COL Applicant establishes baseline valve design qualification testing encompassing design conditions which demonstrate acceptable valve performance (i.e., stroke and sealing) for check valves; check valves are tested for design conditions of:
 - Required operating cycles to be experienced by the valve - numbers of operating cycles and duration
 - Severe transient loadings (pipe break/waterhammer)
 - Sealing and leakage requirements
 - Operating medium temperature and gradients
 - Vibratory loading

System 80+™ Standard Plant

COL Applicant Responsibilities - Check Valves (con't)

- COL Applicant ensures that check valve application is proper (size, type, Location, orientation) as recommended by manufacturer.
- COL Applicant ensures capability of nonintrusive testing, measurable flow through check valve

System 80+™ Standard Plant

COL Responsibilities - Valve Disassembly Programs

- COL Applicant develops valve disassembly program for all safety-related valves; program based on:
 - Historical valve performance
 - Valve constituent components' performance
 - Non-intrusive test results

ABB Combustion Engineering

System 80+™ Standard Plant Flood Protection

Thomas D. Crom
Duke Engineering & Services, Inc.

ACRS ABB-CE Standard Plant Designs Subcommittee
March 8 & 9, 1994

System 80+™ Standard Plant

External Flood Protection

Site Parameters:

- Grade elevation - 90+9 (reference)
- Maximum groundwater level - two feet below grade (elevation 88+9)
- Probable maximum flood (PFM) level for site - one foot below grade (elevation 89+9) (PMF defined in ANSI/ANS-2.8)

System 80+™ Standard Plant

External Flood Protection

Design Features:

- Concrete construction joints sealed with waterstops
- External penetrations below grade sealed
- Doors/accesses at least one foot above grade (elevation 91+9)
- Seepage will end up in sumps in basement through floor drains

System 80+™ Standard Plant

Internal Flood Protection

Features:

- Station Service Water is located outside the Nuclear Annex
- Component Cooling Water and Emergency Feedwater Systems are fully separated by division
- Divisional wall is primary means of flood control in the Nuclear Annex
- No doors are provided up to EL. 70+0 in the divisional wall and diesel generator rooms
- Reactor Building Subsphere separated into quadrants

System 80+™ Standard Plant

Internal Flood Protection

Features (continued):

- Flood barriers provide separation between electrical equipment and mechanical systems at the lowest elevation within the Nuclear Annex
- Emergency Feedwater pump is located in separate compartment within each quadrant with each compartment protected by flood barriers
- Flood doors are provided with open and close sensors and are alarmed in the control room
- At higher elevations electrical equipment is elevated above the floor so that flooding events will not affect components

System 80+™ Standard Plant

Internal Flood Protection

Features (continued):

- Floor drainage systems are separated by division and by quadrant in subsphere
- Safety Class 3 check valves are provided to prevent backflow of water to areas containing safety related equipment within a division
- Each subsphere quadrant and each diesel generator room is provided with redundant Safety Class 3 sump pumps and associated instrumentation, which are powered from the diesel generators
- No water lines are routed above or through the control room or computer room

System 80+™ Standard Plant

Internal Flood Protection

Features (continued):

- Water lines to HVAC air conditioning units around the control room are contained in rooms with curbs
- Component Cooling Water Heat Exchanger Structure is divisionally separated such that a flood in one division cannot flood the other division
- Door leading from the Turbine Building to the Nuclear Annex is located above the maximum Turbine Building flood elevation

System 80+™ Standard Plant

Internal Flood Protection

Analysis:

- An analysis was performed which demonstrated that the following system volumes can only flood one division of the Nuclear Annex assuming no operator action to terminate the flood
 - One Component Cooling Water System division including external piping and surge tank
 - Incontainment Refueling Water Storage Tank
 - One Emergency Feedwater System division including Emergency Feedwater Storage Tank
 - Fire Protection System including two external water supply tanks
 - Chemical Volume Control System including external Holdup Tank, Boric Acid Tank and Reactor Makeup Tank

System 80+™ Standard Plant

Internal Flood Protection

Analysis (continued):

- The COL applicant shall perform the flooding analysis associated with high and moderate energy line pipe rupture analysis outside of containment
- The divisional and interdivisional flood barriers ensure that a high or moderate energy line break outside of containment can be mitigated assuming loss of offsite power and single failure (normal operating systems such as the Component Cooling Water System are excluded from the single failure criteria)

System 80+™ Standard Plant

High Energy Lines

High Energy Systems within Containment:

- Main Steam System
- Main Feedwater System
- Steam Generator Blowdown System
- Steam Generator Wetlayup and Recirculation System
- Reactor Coolant System
- Safety Depressurization System
- Chemical Volume and Control System
- Safety Injection System
- Emergency Feedwater System

System 80+™ Standard Plant

High Energy Lines

High Energy Systems outside Containment:

- Main Steam System
- Main Feedwater System
- Steam Generator Blowdown System
- Emergency Feedwater System (steam line to turbine driven pump)
- Chemical Volume Control and System (two inch line)

System 80+™ Standard Plant

High Energy Lines

Location of high energy lines outside Containment:

- Main Steam, Main Feedwater and Steam Generator Blowdown Systems penetrate containment annulus area through guard pipes and are located in main steam valve houses, yard, and turbine building
- Emergency Feedwater System steam line to turbine driven pump located in main steam valve houses, turbine driven pump rooms, and vented pipe chase between turbine driven pump rooms and main steam valve house
- Chemical Volume and Control System located in pipe chase from containment penetration to Chemical Volume Control System area

System 80+™ Standard Plant

Flood Protection


ITAAC Scope:

- Flood barriers
- Structural load from flooding
- Sensors on flood doors
- Divisional and quadrant separation of floor drains
- Station Service Water located outside the Nuclear Annex
- Divisional separation of systems
- Safety Class 3 check valves to prevent backflow
- Reactor Building Subsphere and Diesel Generator rooms provided with redundant Safety Class 3 sump pumps powered from the diesel generators

SYSTEM 80+™

434'-0"

260'-0"



LEGEND

FLOOD BARRIER

NUCLEAR ISLAND STRUCTURES
SECTION A-A

ELEV. 12+8 LEVEL 8

ELEV. 15+0 LEVEL 7

ELEV. 18+0 LEVEL 6

ELEV. 11+4 LEVEL 5

ELEV. 20+7 LEVEL 4


ELEV. 8+0 LEVEL 3

ELEV. 7+0 LEVEL 2

ELEV. 20+6 LEVEL 1

SYSTEM 1001
 AS SHOWN
 PLANT ORIENTATION

434'-0"



226'-0"



LEGEND




NUCLEAR ISLAND STRUCTURES
 PLAN AT LEVEL 1

SYSTEM BOX 1"



434'-0"



DIVISIONAL WALL



LEGEND



FLOOD BARRIER

36-22

NUCLEAR ISLAND STRUCTURES
PLAN AT LEVEL 2

ABB Combustion Engineering System 80+™ Standard Plant

Chapter 19 - Probabilistic Risk Assessment

David J Finnicum

ACRS ABB-CE Standard Plant Designs
Subcommittee

March 8 & 9, 1994

ABB

System 80+ Standard Plant Probabilistic Risk Assessment

- Objectives
- Approach
- Methodology
- Results
- ACRS Issues

System 80+ Standard Plant Probabilistic Risk Assessment

● Objectives:

- Comply with Severe Accident Policy Statement providing a Level III PRA for the System 80+ Design
- Demonstrate compliance with EPRI ALWR Mean Core Damage Frequency Goal of $1.0E-5$ events/year
- Demonstrate compliance with large release goal of $1.0E-6$ events/year
- Demonstrate containment performance/reliability
- Support evaluation of design changes and demonstration that System 80+ provides an increased level of safety.

System 80+ Standard Plant Probabilistic Risk Assessment

- *Approach:*

- Establish baseline PRA for System 80+ (i.e., System 80)
- Use PRA as evaluation tool for assessment of design changes
- Prepare Level III PRA for System 80+
- Include Evaluation of External Events

System 80+ Standard Plant PRA Methodology

- Level I
 - Small Event Tree/Large Fault Tree Approach
 - Front Line System Fault Trees Include:
 - System Component Failures
 - Common Cause Faults
 - Maintenance Unavailability
 - Operator Actions
 - Full Support System Models

System 80+ Standard Plant PRA Methodology (Cont.)

- External Events
 - Qualitative Screening of External Events
 - Quantitative Analysis of Tornado Strikes
 - Quantitative Scoping Analyses
 - Internal Fire
 - Internal Flood
 - Seismic Margins Assessment for Earthquake

System 80+ Standard Plant PRA Methodology (Cont.)

- PRA Based Seismic Margins Assessment
 - Modify Level 1 Fault Tree Models to Include Seismic Failure of Structures and Components
 - Construct Seismic Event Trees
 - Solve Seismic Core Damage Sequences Using Fault Tree Linking to Obtain Cutsets for Each Seismic Core Damage Sequence
 - Calculate High Confidence of Low Probability of Failure (HCLPF) Values For Components and Structures
 - HCLPF values calculated using EPRI CDFM Approach
 - HCLPF calculations used a Review Level Earthquake of 0.6g with a modified NUREG/CR-0098 Spectral Shape
 - System 80+ specific response spectra curves for 0.3g design basis earthquake reviewed against RLE spectra

System 80+ Standard Plant PRA Methodology (Cont.)

- Shutdown Risk

- Outage Divided Into 4 Plant Operating States (POS)
 - Mode 4, 5 (Normal Inventory), Mode 6F (IRWST Full, Refueling Cavity Empty)
 - Mode 5R (Reduced Inventory, Including Mid-Loop)
 - Mode 6E (IRWST Empty, Refueling Cavity Full, Upper Internals Removed)
 - Mode 6I (Refueling Cavity Full, Upper Internals in Place)
- For Each POS, Event Trees Developed for 4 Event Types
 - Loss of DHR
 - Small LOCA
 - Fire
 - Loss of Offsite Power

System 80+ Standard Plant PRA Methodology (Cont.)

- Shutdown Risk (Cont.)
 - Initiating Event Frequencies Taken From BNL 1991 Study
 - Fault Trees Were Developed For Each Branch Point
 - Trees Modified From Level 1 Fault trees
 - Human Error Probabilities Developed for Two Response Times
 - 40 Minute Response for Reduced Inventory
 - Two Hour Response For All Other Events

System 80+ Standard Plant PRA Methodology (Cont.)

- Level II

- Define and Quantify Plant Damage States
- Develop Containment Event Tree and Supporting Logic Models
- Quantify CET
- Define Release Classes
- Perform Sensitivity Analyses for Selected Parameters

System 80+ Standard Plant PRA Methodology (Cont.)

- Level III
 - Risk Measure Selected - Dose at 0.5 Miles
 - Use MACCS to Determine Dose at Distance
 - Meteorological Data for Bounding Site Provided by EPRI
 - Demographic/Population Data not used
 - Assumed No Evacuation
 - Calculated Complementary Cumulative Distribution Function (CCDF) for Whole Body Dose at 0.5 Miles and at 300 Meters from Reactor
 - Sensitivity Analyses for Selected Issues

System 80+ Standard Plant
PRA Results

ABB

System 80+ Standard Plant Core Damage Frequency Contributions

Initiating Event	System 80 CDF (Original Groundrules)	System 80+ CDF (Original Groundrules)	Major Design Contributor
Large LOCA	1.8E-06	5.0E-08	IRWST, 4T ECCS
Medium LOCA	3.6E-06	9.1E-08	IRWST, 4T ECCS
Small LOCA	9.4E-06	4.4E-08	4T ECCS, EFWS
Secondary Side Break	9.0E-07	2.0E-10	4T ECCS, EFWS
SGTR	1.1E-05	8.0E-08	4T ECCS, EFWS
Transients	1.2E-05	3.3E-08	4T EFWS, F&B
Loss of Offsite Power (Including SBO)	3.8E-05	1.0E-07	2 DG + AAC, EFWS, 6 BAT.
ATWS	4.8E-06	1.7E-07	4T EFWS
Interfacing System LOCA	4.5E-09	5.2E-10	High Pres. Pipe
Vessel Rupture	1.0E-07	1.0E-07	
Total	8.1E-05	6.7E-07	

ABB

System 80+ Standard Plant Core Damage Frequency Contributions

Initiating Event	System 80+ CDF (Original Groundrules)	System 30+ CDF (Current Groundrules)	Changed Methods & Assumptions
Large LOCA	5.0E-08	1.1E-07	Include Check Valve CCF, Change HRA Calc. Methods, MOV Failure Rates
Medium LOCA	9.1E-08	3.1E-07	
Small LOCA	4.4E-08	2.1E-07	
Secondary Side Break	2.0E-10	2.1E-09	
SGTR	8.0E-08	3.0E-07	
Transients	3.3E-08	5.7E-07	
Loss of Offsite Power (Including SBO)	1.0E-07	2.8E-07	
ATWS	1.7E-07	4.9E-08	
Interfacing System LOCA	5.2E-10	5.2E-10	
Vessel Rupture	1.0E-07	1.0E-07	
Total	6.7E-07	1.7E-06	

ABB

System 80+ Standard Plant Level I Model Sensitivity Analyses

Sensitivity Case	Core Damage Frequency-
Base	1.7E-06
Increase all operator error rates by factor of 10	9.4E-06
Set HEP for all operator actions outside control room to 1.0	1.9E-06
Increase all MOV failure rates and CCF rates by factor of 10	8.5E-06
Use large LOCA SIT model for Medium LOCA	1.7E-06
Aggressive secondary cooldown not feasible for Small LOCA or SGTR	6.7E-06
RCP Seal LOCA for station blackout	1.7E-06
Set test and maintenance unavailability to 0.0	1.7E-06
Increase probability of adverse MTC for ATWS to 0.1	2.2E-06

ABB

System 80+ Standard Plant Level I Model Sensitivity Analyses (Cont.)

Sensitivity Case	Core Damage Frequency
Base	1.7E-06
Increase LOOP frequency by factor of 10	2.0E-06
Loss of Grid frequency set to 0.15 per year	1.8E-06
Vessel Rupture not credible	1.5E-06
Set all CCF rates to 0.0 except for diesels and batteries	2.4E-07
Set all CCF to 0.0 except for diesels and batteries and set vessel rupture to 0.0	1.4E-07

System 80+ Standard Plant Comparison of Shutdown PRAs

Event	System 80+	NSAC-84	NUREG/CR-5015	Seabrook
Total CDF	8.4E-07	1.8E-05	5.2E-05	4.5E-05
Loss of DHR	23%	71%	82%	61%
LOCA	16%	10%	8%	18%
LOOP	25%	0.7%	10%	6%
Fire	36%			4%
Other		18%		11%

System 80+ Standard Plant Shutdown Risk Evaluation

- Design Features Contributing to A Reduced Shutdown Risk
 - Two Safety Injection Pumps Operable
 - Capability to Inject to the RCS Via the SCS
 - Safety Depressurization System
 - Containment Spray Pump Doubles as a Shutdown Cooling Pump
 - IRWST Acts as a Sump in a LOCA
 - Alternate AC Source
 - Dedicated SCS Train Independent of LPSI
 - Technical Specifications for Shutdown Modes

System 80+ Standard Plant Shutdown Risk Evaluation (Cont.)

- Instrumentation Added as Result of Shutdown Risk Evaluation
 - Delta P Based Narrow Range RCS Water Level (2)
 - HJTC Based RCS Water Level and Temperature (2)

System 80+ Standard Plant Shutdown Risk Evaluation (Cont.)

- More Than Twenty Technical Specifications Modified to Address Shutdown Modes
- Examples of Changes:
 - Two SCS Divisions to Be Operable And At Least One Division in Operation In Mode 6
 - Two SIS Trains, With one Pump in Each Division Required to Be Operable in Modes 4, 5, and 6
 - Containment to be Closed during Reduced Inventory Operation

System 80+ Standard Plant Shutdown Risk Evaluation (Cont.)

- Procedural Guidance Developed For Shutdown Operations
 - Reduced Inventory Operations
 - Coping With Loss of DHR
 - Detecting and Mitigating RCS Drain Down Events
 - Outage Maintenance
 - Fire Protection
 - RCS Cooling Using Feed and Bleed

- Shutdown Operations Procedural Guidance Included in Appendix B of System 80+ EOGs

System 80+ Standard Plant External Events Analysis Results

	Core Damage Frequency
Tornado strike - Total	2.5E-07
Internal Fires (Basic)	6.1E-08
Fire-Induced RCP Seal LOCA	5.2E-10
Fire Inside Containment	1.34E-09
Fire - TOTAL (scoping estimate)	6.3E-08
Internal Flood (Basic)	1.3E-08
Flood-Induced RCP Seal LOCA	1.2E-10
Flood - TOTAL (scoping estimate)	1.3E-08

ABB

System 80+ Standard Plant Seismic Margins Assessment Results

- Plant HCLPF is 0.73 g (Goal > 0.50g)
- Dominant Contributor is Seismically Induced Sliding/Overturning of Containment Shell
- Second Dominant Seismic Sequence is LOCA in Excess of ECCS Capacity with HCLPF of 0.86 g. This Event Includes Seismically Induced Failure of RCP Supports

System 80+ Standard Plant Comparison of PRA Results With IPEs

	IPE Average	System 80+
Core Damage Frequency (Internal Events + Flood)	7.8E-5/yr	1.7E-6/yr
LOSP	26%	1.7%
LOCA	24%	43.1%
ATWS	3%	2.9%
Flood	10%	0.8%
ISLOCA	1%	0.03%
SGTR	5%	17.7%
Other Transients	31%	33.7%

ABB

System 80+ Standard Plant Containment Performance

- If Containment Failure Defined as Failure With Above Normal Releases Within First 24 Hours:
 - Containment Reliability = 0.98
- If Containment Failure Defined as Having A Release Greater Than 25 Rem at 1/2 Mile From Reactor:
 - Containment Reliability = 0.973
- If Containment Failure Defined as Any Containment Failure:
 - Containment Reliability = .886

System 80+ Standard Plant Level II PRA Results

	Conditional Probability
Intact Containment for 24 hours	96.5%
Containment Intact Indefinitely	88.6%
Late Cntm. Failure, Overpressure	0.4%
Late Cntm. Failure, Basemat Meltthrough	7.5%
Subtotal	96.5%
Containment Isolation Failure	2.4%
Early Containment Failure	1.1%
Steam Explosion	0.95%
Alpha Mode	0.12%
H2 Burn/Explosion	0.03%
Subtotal	1.1%
TOTAL	100%

System 80+Standard Plant Level II Model Sensitivity Analyses

	Cnt Intact Indefinitely	Late Cnt. Failure	Early Cnt Failure	Isolation Failure
BASE	88.6	7.9	1.1	2.4
H2 Ignitors Not Available	87.5	8.0	2.1	2.4
Deflagration to Detonation Transition Likely	88.6	7.9	.11	2.4
Low Heat Transfer from Corium to Coolant	87.8	8.8	1.1	2.3
Reduced Probability of Cont. Spray Recovery	88.4	8.2	1.1	2.3
Containment Heat Removal Not Recovered	74.8	21.8	1.1	2.4
Thermally Induced Failure of RCS Piping Always Occur	88.6	7.9	1.1	2.4
Thermally Induced Failure of RCS Piping Never Occurs	88.6	7.9	1.1	2.4

ABB

System 80+ Standard Plant Level II Model Sensitivity Analyses (Cont.)

	Cnt Intact Indefinitely	Late Cnt. Failure	Early Cnt Failure	Isolation Failure
BASE	88.6	7.9	1.1	2.4
RCS N Not Depressurized by SDS for Sequences with Cycling Relief Valves	88.6	7.9	1.1	2.4
RCS Always Depressurized by SDS for Sequences with Cycling Relief Valves	88.6	7.9	.11	2.4
Increase Containment Isolation Failure Rate to 1.0E-02	88.1	7.8	1.1	3.0
RCS not Depressurized by SDS for Medium and High Pressure Sequences	88.6	7.9	1.1	2.4
Increase Probability that Operator Fails to Turn on H2 Igniters from 3E-02 to 3E-01	88.3	7.9	1.4	2.4

System 80+ Standard Plant Level III PRA Results

- Frequency of exceeding Whole Body (WB) Dose of 25 Rem at:
 - 1/2 mile from reactor = $5.3E-08$ /year
 - at 300 meters from reactor = $6.2E-08$

System 80+ Standard Plant Level III Model Sensitivity Analyses

	Probability of Exceeding 25 Rem at 1/2 Mile
BASE	5.3E-08
Releases occur at Top of Containment	5.0E-08
Releases Occur at Grade Level	5.4E-08
Increase Iodine and Cesium Release Fractions by One Order of Magnitude	6.4E-08
Containment Bypass Releases Unscrubbed	5.3E-08
Increase Containment Isolation Failure Rate by One Order of Magnitude	4.4E-07
Double Basemat Melt-Through Failure Frequency	5.5E-08
Concrete Ablation Failure Occurs at 30 Hours Instead of 65 Hours	5.4E-08
Increase ISLOCA Frequency by Two Orders of Magnitude	1.0E-07

ABB

System 80+ Standard Plant
Previously Identified ACRS Issues

ABB

System 80+ Standard Plant MOV Fail to Close Issue

- ISSUE: Failure Rate Used For Failure of MOV to Close, Especially For EFW System MOVs, May be too Low.
 - ABB-CE Used Failure Rate of $4.0E-03$ /Demand for Failure of MOVs to Operate
 - Based on generic data
 - For valves tested on quarterly basis
 - Contention is That Failure Rate for Failure of MOVs to Close Should be $8.0E-02$ /Demand
 - Failure rate higher due to accident conditions

System 80+ Standard Plant MOV Fail to Close Sensitivity Studies

- Case 1: Increase failure rate for ALL MOVs, "Fails to Close" Failure Mode only, from 4.0E-03 to 8.0E-02
 - Base Core Damage Frequency = 1.67E-06/yr
 - Resulting Core Damage Frequency = 3.01E-06/yr
 - CDF Increases by Factor of 1.8

- Case 2: Increase failure rate for ALL EFW MOVs, BOTH "Fails to Close" and "Fails to Open" Failure Modes, from 4.0E-03 to 8.0E-02
 - Base Core Damage Frequency = 1.67E-06/yr
 - Resulting Core Damage Frequency = 4.14E-06/yr
 - CDF Increases by Factor of 2.5

System 80+ Standard Plant MOV's Designed For Environment

- MOV's Are Designed To Operate Per Their Specific Location In The Plant
- MOV's Are Purchased And Qualified And Previously Tested For Accident Exposure And Physical Location
- Each Motor Operator Is Designed For Unique Accident Exposure & Physical Location (i.e., inside or outside containment)

ABB

System 80+ Standard Plant

Publically Available MOV Failure Rates

Source	Fail to Open	Fail To Close	Fail to Operate
EPRI ALWR KAG	-	-	4.0E-03/D
NUREG/CR-4639	6.1E-03/D	4.4E-03/D	2.8E-03/D
NUREG/CR-4550	-	-	3.0E-03/D
PVNGS IPE	3.2E-03/D	3.2E-03/D	-
MP2 IPE	2.1E-03/D	2.1E-03/D	-
SONGS IPE	3.0E-03/D	3.0E-03/D	-
IP2 IPE	-	-	1.6E-03/D
ANO2 IPE	-	-	5.8E-03/D
NREP	2.7E-03/D	2.7E-03/D	-
WASH1400	-	-	2.7E-03/D
PSL IPE	6.2E-03/D	2.4E-03/D	-

ABB

System 80+ Standard Plant MOV Failure Rates - Swedish NPRs

MOV Fails to Change Position

PIPE DIMENSION	BWRs	PWRs
DN < or = 100 mm	7.9E-03/D	5.3E-03/D
100 mm < DN < 200 mm	6.3E-03/D	1.7E-03/D
DN > 200 mm	7.2E-03/D	3.3E-03/D

System 80+ Standard Plant
2 DGs with AAC vs. 4 DGs Issue

Why does SYSTEM 80+ DESIGN
have 2 DGs/Gas Turbine rather than 4
DGs when 4 DGs results in a lower
CDF?

ABB

System 80+ Standard Plant 1991 EDS Sensitivity Study

CASE	UNAVAILABILITY 2 DGs with GAS TURBINE	UNAVAILABILITY 4 DGs	BENEFIT FACTOR
Transient	1.42E-04/D	1.29E-04/D	1.1
LOCA	2.70E-03/D	1.93E-03/D	1.4
COST \$	\$57M	\$100M	- \$43M

- STUDY DID NOT INCLUDE SUPPORT SYSTEMS, ONLY EDS & BUSES
 - STUDY COMPARES RELIABILITY ONLY - DOES NOT TAKE INTO ACCOUNT RISK IMPACT OF SEQUENCES
 - COST OF 1 DG CONSERVATIVELY ESTIMATED AT \$25M
 - COST OF GAS TURBINE ESTIMATED AT \$6.5M
- (from United Engineers & Contractors)

ABB

System 80+ Standard Plant Advantages Of 2 DG + AAC System

- Benefit Does Not Justify Cost
 - Cost Of 2 DGs Far Exceeds Cost Of 1 Gas Turbine For Slightly Better CDF
 - Benefit Of 4 DGs Is Most Realized For Large LOCAs, Which Only Make Up A Small Percentage Of Total CDF
- Additional Drawbacks With 4 DGs:
 - Larger Plant "Footprint" - Other Costs Imbedded In This
 - More Equipment Means More Complicated Operating Procedures And Operator Actions Which Negatively Impact Safety

ABB

System 80+ Standard Plant 1992 EDS Sensitivity Study

- New sensitivity study was done by DE&S to extend earlier results into an examination of risk impact
- Four separate initiators were examined
 - Loss-of-Offsite Power
 - Small LOCA
 - Large LOCA
 - General Plant Trip
- RESULTS: 2 EDGs with AAC had lower CDF than 4 EDGs without AAC

ABB

System 80+ Standard Plant 1992 EDS Sensitivity Study (Cont'd)

● RESULTS

	CDF
2 EDSs with an AAC Source	1.71E-06/year
4 EDGs without an AAC Source	2.40E-06/year

- EDG Failures dominated by CCFs (based on industry data)
- Diverse AAC more than offsets benefits of 4 Redundant EDGs

ABB

ABB Combustion Engineering

System 80+™ Standard Plant

Section 14.3 - Certified Design Material

S. E. Ritterbusch

**ACRS ABB-CE Standard Plant Designs Subcommittee
March 8-9, 1994**

ABB

System 80+™ Standard Plant Certified Design Material

- The Certified Design Material (CDM) is that information that is necessary and sufficient to provide reasonable assurance that, if the inspections, tests, and analyses are performed, and the acceptance criteria met, a facility referencing the certified design will be constructed and will operate in conformity with the design certification, the provisions of the Atomic Energy Act, and the Commission's rules and regulations.
- CESSAR-DC, Section 14.3 summarizes the criteria used by ABB-CE to develop the CDM.
- FSER Section 14.3 provides NRC staff approval of CDM with respect to "necessary and sufficient".



System 80+™ Standard Plant Certified Design Material

- **Tier 1 Certified Design Material**
 - Section 1: Introduction and General Provisions
 - Section 2: System Design Descriptions, Figures, and ITAAC
 - Section 3: Non-System Specific Design Descriptions and ITAAC
 - Section 4: Interface Requirements
 - Section 5: Site Parameters
- Development methods and selection criteria for each CDM section in CESSAR-DC Section 14.3
- Selected summaries of CESSAR-DC material incorporated into the CDM



System 80+™ Standard Plant Certified Design Material

- Requirement for ITAAC in 10CFR52.47 & 52.97
- SRM on 90-377, "Rqmts for Design Certification Under 10CFR52" - 2/15/91
 - Graded approach for application based on safety significance
 - ITAAC confirm design, and are not basis for safety decision
- Multiple iterations & senior management meetings 1991-1993
- Industry reviews

ABB