BIG ROCK POINT PLANT

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M I B R P 1 (2) | 0 0 - 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 - 0 1 5 5 (7) | 1 2 0 8 8 2 (8) | 0 1 0 5 8 3 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During an inspection, the audible alarm unit for the fire detection equip-
03 ment in zone 1 and zone 2 of the electrical equipment room was found to be
04 inoperative. The alarm was restored to operable status within two hours.
05 No hazard to the public occurred. A prior failure was reported on LER 82-030.
06 Reportability based on Technical Specification 6.9.2.b.(2).
07
08

09 SYSTEM CODE A B (11) | CAUSE CODE B (12) | CAUSE SUBCODE B (13) | COMPONENT CODE A N N U N C (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 3 2 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN F (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER P 4 3 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Flexing of stiff wiring on the door panel of Pyrotronics Model FIU-6, super-
11 visory unit caused failure at a socket connection. The unit was modified
12 using more flexible wire for the circuit involved and improvements to other
13 circuits in the unit are planned to prevent similar failures.
14

15 FACILITY STATUS G (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY C (31) | DISCOVERY DESCRIPTION (32) Observation during test

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8301110434 830105
PDR ADOCK 05000155
S PDR