

January 6, 1983

Docket No. 50-409

Dairyland Power Cooperative
ATTN: Mr. F. W. Linder
General Manager
2615 East Avenue - South
LaCrosse, WI 54601

Gentlemen:

This is to confirm the telephone conversation between Mr. J. A. Pagliaro and Mr. J. Parkyn on December 9, 1982. As a result of the telephone conversation, we understand the LaCrosse Boiling Water Reactor Emergency Plan and Implementing Procedures will be revised so that Dairyland Power Cooperative will notify both the Houston County Sheriff's Office and the State of Minnesota directly of any declaration of an emergency at the LaCrosse Boiling Water Reactor. This matter was discussed with Mr. Parkyn as a result of an exchange of letters (enclosed) with the State of Minnesota in which they requested the change.

Also, step 4.5.10 of EPP-2 should be expanded to include instructions that, if possible, all known factual information available should be transmitted in the initial message via the Emergency Broadcasting System to the population in the affected area within the required 15 minutes.

Should you have any questions regarding our response, please contact Mr. J. Pagliaro of my staff, at 312/932-2538.

Sincerely,

J. A. Hind
J. A. Hind, Director
Division of Emergency Preparedness
and Operational Support

Attachment: As Stated

cc w/encl:
D. Bement, FEMA Region V
J. La Fleur, State of Wisconsin
K. Parsch, State of Minnesota
F. Pagano, OIE/NRC

RIII

JAP
Pagliaro/jp
1/3/83

RIII

WA
Axelson

RIII

JP
Pappertello
1/4/83

RIII

MB
Menczer
1/4/83

RIII

R
Reyes
1/4/83

RIII

JH
Hind
1/5/83

*DMB
IE35*