



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 30, 1978

NRC PDR
50-219
P

Docket No. 50-219

Jersey Central Power & Light Company
ATTN: Mr. I. R. Finfrock, Jr.
Vice President - Generation
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Gentlemen:

We have reviewed your response dated May 10, 1978 to our letter dated February 1, 1978 regarding the need for a feedwater pump trip on reactor high water level. Based upon our review of your submittal we have determined that a feedwater trip on high reactor level is not necessary to assure safe operation of the Oyster Creek Nuclear Generating Station.

Our Safety Evaluation containing the details of the Regulatory Staff's review is enclosed.

Sincerely,

Dennis L. Ziemann
Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
As stated

cc:
See next page

7812110326

P

cc
G. F. Trowbridge, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

GPU Service Corporation
ATTN: Mr. E. G. Wallace
Licensing Manager
260 Cherry Hill Road
Parsippany, New Jersey 07054

Anthony Z. Roisman
Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20005

Steven P. Russo, Esquire
248 Washington Street
P. O. Box 1060
Toms River, New Jersey 08753

Joseph W. Ferraro, Jr., Esquire
Deputy Attorney General
State of New Jersey
Department of Law and Public Safety
1100 Raymond Boulevard
Newark, New Jersey 07012

Ocean County Library
Brick Township Branch
401 Chambers Bridge Road
Brick Town, New Jersey 08723